

01

Head Detail Thro' SG C/Walling.

Scale: 1:5@A3

TOS +56.970

UNITISED TYPE 1 FRAMING PANEL.

SYSTEM JOINT EPDM GLAZED INTO UNITISED SECTION WITH GASKET 931028, TO BE LEFT LONG TO ALLOW IT TO BE GLAZED & FULLY SEALED INTO C/WALLING SYSTEM.

System Joint
+56.680
TRAN' CTR' +56.641

C/WALLING EXTENDED FACE CAP.
FINISH EV1 SILVER ANODISED 25mic'.
C/WALLING SYSTEM INTERNAL FINISH
RAL 9003 INTERPOD D1036 SA803G 60mic'.

C/WALLING HEAD BRACKET.
BRACKETS FINISHED RAL 9003 INTERPON D1036 SA803G 60mic'.
BRACKET FABRICATED FROM MILD STEEL (GRADE S275)

FWS 60 SG SYSTEM INFORMATION

SEALANT:	DOW 791
BACKING GASKET:	242 526
GLASS CARRIER:	242 302
TRAN GASKET:	244 945
ISOLATOR:	244 808
CLIPS:	242 363/242 362
SCREW:	225 082

C/WALLING FIXING BRACKET TO BE FABRICATED FROM 8mm & 6mm THK MILD STEEL PLATE (GRADE S275)
2No. COATS OF GALVFROID SHOP APPLIED PRIMER

C/WALLING FIXED TO BRACKET WITH:
1No 16mm Ø SOLID ALUM PIN, LOCKED
IN POSITION WITH 2No M16 S/S STARLOCKS.
DOME STARLOCK TO BE USED WHERE VISIBLE.
(DOOR JAMBS)

EPDM INSTALLATION NOTE:
ALL JOINT/OVERLAPS TO BE A MIN. 150mm & BONDED WITH APOLLO CONTACT ADHESIVE TO MANUFACTURES RECOMMENDATIONS

3mm ALUM' FLASHING - EV1 SILVER ANODISED 25mic'.
FLASHING INSULATED WITH SEMI RIGID ROCKWOOL INSULATION.

0.7mm EPDM MEMBRANE GLAZED INTO BTM TRANSOM & DRESSED & BONDED OVER UPSTAND MEMBRANE

BUILDING WORKS BY MAIN CONTRACTOR
WATER PROOFING MEMBRANE, INSULATION TO TOP OF RC SLAB.
M.C TO LEAVE MEMBRANE LONG ENOUGH TO BE OVERLAPPED & BONDED WITH THE SYSTEMS EPDM (min 150mm OVERLAP).


02

Cill Detail Thro' SG C/Walling.

Scale: 1:5@A3

CDM Regulations

Hazards	Date Added	Date Mitigated	Risk Assessment Date
HEAVY GLASS - LOADS INDICATED	05/02/15		



KEY PLAN

DO NOT SCALE : IF IN DOUBT ASK!

THIS DRAWING REMAINS THE PROPERTY OF McMULLEN FACADES LTD AND SHOULD NOT BE COPIED NOR ITS CONTENTS DIVULGED WITHOUT PRIOR CONSENT

Signed:	GB-JW	Internal Quality Check
Date:	22.02.19	

001	JW	GB	22.02.19	SECOND ISSUE - REVISIONS CLOUDED. ISSUE FOR CONSTRUCTION.	22.02.19
000	SP	SP	28-05-18	FIRST ISSUE	28-05-18
No.	Intd	Intd	Date		
Revision	Check	Description	Date		

Contract: KINGSCROSS S1

Architect: MOSSESIAN

Main Contractor: BAM

Drawing: LVL 07 WEST ELEV. TERRACE
BAY STUDY TYPICAL DETAILS

Drawn By: SP-JW Date: 17-06-2018

Scale: 1:5 @ A3 MFL No.: 3135-770

DMS Code: KXC-S1-001-Y-3135-21-770 Revision: 001

DRAWING ISSUED FOR: STATUS OF PREVIOUS RETURN

CONSTRUCTION A B C -

McMullen Facades Limited
66 Lurgan Road, Moira,
Craigavon, Co. Armagh BT67 0LX
Tel: +44 (0) 28 9261 9688
Fax: +44 (0) 28 9261 9711
Email: design@mcmullenfacades.com