


- This drawing package is to Developed Design stage as defined in BSRIA BG/6 2018.
- 2. This drawing package is intended to indicate: 2.1. Approximate locations of horizontal & vertical service
- 2.2. Sizes and locations of main plant and distribution
- Key principles of systems serving the building through typical room/area details.
- Sizes, duties and quantities indicated are provisional only and subject to development during Technical Design stage.
- The proposed MEPH works to these areas are considered to be fit-out installations and are not considered to impact on
- the Heritage aspects of the work areas of the building. 5. Power and data cabling will be run in the floor void or ceiling

void terminating in flush wall outlets or flush floor outlet


- 6. Power will be provided to mechanical plant and other ancillary equipment.
- 7. Ancillary IT equipment such as Wi-Fi outlets will be provided,
- fixed to the ceiling. 8. Other ancillary electrical equipment may be required. Details
- to be confirmed.
- 9. All services installations will need to be supported from the existing structure and fixings will need to be made to the existing slab or steelwork to support interim support systems to support the services installation. This is as per the pre-existing installation.


Legend


Switched fused connection unit: FCU - fan coil unit DTA - disabled toilet alarm DX - comms room air conditioning (direct expansion unit)



Disabled alarm pull cord Disabled alarm reset unit







P1 06/03/2020 Listed Building Application Rev Date Description

HUTCHINSON & PARTNERS

Victoria House Phase 2

Drawing Title

Electrical Services Small Power & Ancillaries Layout High Level Ninth Floor



Building Services Engineering | Sustainability | Acoustics Scriptor Court 157 Farringdon Road London EC1R 3AD

Copyright reserved. Work to figured dimensions only. Discrepancies to be reported before proceeding.

Scale @ A1 1:200

020 3544 5400 www.scotchpartners.com

5228-SP-P2-09-DR-E-410