

**From:** Celia Hodgson

**Sent:** 20 January 2020 10:07

**To:** Young, Tony

**Subject:** RE: Planning application - 2019/6036/P - 10 Lymington Road

Hi Tony,

Re Sedum Roof

The standard roofing system used on our garden buildings at Green Retreats is not indicative to the use of a sedum roof, the roof is flat and the roof panels are self-supporting and are part of the design of our buildings, The exterior has a ridge and farrow overlapping system, and due to this any vegetation in large quantity could grow under the overlap causing detrimental damage to the roof.

My client has asked do you do a fast track system for applications for an additional cost.

Email or call me if additional information is required

Kind regards

Celia