

Application ref: 2020/0506/P  
Contact: Laura Hazelton  
Tel: 020 7974 1017  
Date: 8 April 2020

**Development Management**  
Regeneration and Planning  
London Borough of Camden  
Town Hall  
Judd Street  
London  
WC1H 9JE

Phone: 020 7974 4444

[planning@camden.gov.uk](mailto:planning@camden.gov.uk)  
[www.camden.gov.uk/planning](http://www.camden.gov.uk/planning)

Gerald Eve LLP  
72 Welbeck Street  
London  
W1G 0AY

Dear Sir/Madam

## **DECISION**

Town and Country Planning Act 1990 (as amended)

### **Full Planning Permission Granted**

Address:

**184-192 Drummond Street  
London  
NW1 3HP**

Proposal:

Installation of two metal louvres at 4th floor level of rear elevation  
Drawing Nos: 2020/0275/051, 2020/0275/052, 2020/0275/055, 2020/0275/056,  
Supplementary information document and external louvres manufacturer's  
specifications received 03/02/2020.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policies D1 and D2 of the London Borough of Camden Local Plan 2017.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans: 2020/0275/051, 2020/0275/052, 2020/0275/055, 2020/0275/056, Supplementary information document and external louvres manufacturer's specifications received 03/02/2020.

Reason: For the avoidance of doubt and in the interest of proper planning.

- 4 Noise levels at a point 1 metre external to sensitive facades shall be at least 10dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 15dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

#### Informative(s):

- 1 Reasons for granting permission.

The proposals involve the installation of new high level louvres in place of the existing glazing to two rear windows at level 4. The new louvres would be relatively small, matching the appearance of existing louvres to the lower levels. The louvres would be black powder coated grilles and are required to allow air supply to and from the internal ventilation systems. Due to the size and location of the louvres to the rear elevation, they would be subject to very limited views and would preserve the character and appearance of this locally listed building.

The proposals do not include any new or replacement plant, but, as there may be limited increase in noise escape from the louvres, it is recommended that a condition be imposed to ensure that noise levels do not exceed the Council's noise standards. The proposals would not impact neighbouring amenity in terms of loss of privacy, outlook or daylight.

No objections were received prior to the determination of this application. The planning history of the site has been taken into account when coming to this decision.

As such, the proposed development is in general accordance with policies D1, D2, A1 and A4 of the Camden Local Plan 2017 and the Euston Area Plan 2015. The proposed development also accords with the London Plan 2016 and

the National Planning Policy Framework 2019.

- 2 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).
- 3 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant licence from the Council's Streetworks Authorisations & Compliance Team London Borough of Camden 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444) . Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106 agreement), no licence or authorisation will be granted until the Construction Management Plan is approved by the Council.
- 4 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website at <https://beta.camden.gov.uk/documents/20142/1269042/Camden+Minimum+Requirements+%281%29.pdf/bb2cd0a2-88b1-aa6d-61f9-525ca0f71319> or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these hours.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2019.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully

A handwritten signature in black ink, appearing to be 'DRP', is written over a light grey rectangular background.

Daniel Pope  
Chief Planning Officer