

Application No:	Consultees Name:	Received:	Comment:	Response:
2020/0776/P	Hampstead CAAC	14/04/2020 13:04:04	OBJ	Please have the applicant submit drawings all at same larger scale to clarify top and proposed floors relations etc. Side dormer should not be permitted as drawn - can only be half the width of the dormer below it to be accommodated within the roof area clear of ridges/hips. Proposed new top rear dormer is aimed at normal ceiling height which is not the normal permitted relation to the roof. We will comment further when revised submission available.
