


FIRST FLOOR PLAN




FIRST FLOOR UNDERFLOOR HEATING SCHEDULE								
MANIFOLD REF	ROOM	ZONE REF	DESIGN TEMP (°C)	FLOOR FINISH	MAX FLR TEMP (°C)	HEAT OUTPUT (W/m ²)	HEATED AREA (m ²)	HEAT OUTPUT (kW)
1/A	11-04: MASTER BATHROOM	0/W1	23	TILE	29	64	14.8	-
1/B	11-03: MASTER BEDROOM	0/W2	21	TBC	27	64	28.8	-
	13-11: 1ST FLR LANDING	0/W3	21	TBC	27	64	7.8	-
	11-02: DRESSING	0/W4	21	TBC	27	64	19.2	-

1. ALL MAXIMUM FLOOR TEMPERATURES ARE TO BE CONFIRMED BY THE ARCHITECT BASED ON THE SPECIFIED FLOOR FINISHES.
2. MANIFOLD LOCATIONS REQUIRED ARE TO BE CONFIRMED BY THE UFH SYSTEM MANUFACTURER AS PART OF THEIR DESIGN DRAWINGS.
3. ALL HEAT OUTPUT FIGURES FOR UNDERFLOOR HEATING ARE APPROXIMATE AND ARE TO BE CONFIRMED BY THE UNDERFLOOR HEATING MANUFACTURER AS PART OF THEIR DESIGN PACKAGE.
4. ALL HEATING CONTROLS ARE TO BE FROM THE HEATMISER NEO RANGE, TO BE COMPLETE WITH NEO ULTRA CENTRAL CONTROLLER AND NEOHUB FOR APP CONTROL.



LPHW UNDERFLOOR HEATING ZONE



ELECTRIC UNDERFLOOR HEATING ZONE

□ FP REMOTE FLOOR PROBE

□ WP REMOTE WALL MOUNTED AIR PROBE

**PRELIMINARY
ISSUE**

P3	25/09/19	REVISED AS CLOUDED AS PER RGA COMMENTS.
P2	24/05/19	CONTROLLER DETAILS ADDED.
REV	DATE	COMMENT

**FAIRFIELD
PLUMBING**

TELEPHONE: 020 8446 0591 22 RAVENSDALE AVENUE
E-MAIL: enquiries@fairfieldplumbing.co.uk LONDON, N12 9HS

MARCUS PIGGOT

4 KEATS GROVE

FIRST FLOOR
PROPOSED UNDERFLOOR HEATING
LAYOUT

1:50 @ A1	MAY '19	JL	TA
-----------	---------	----	----

4351/M/003

P3