

PLANNING TECHNICAL SAMPLE / SUBMITTAL FORM

Project Name	Project Number	Submittal Number
73- 75 Avenue Road	3680	EXT-05

Application:

To external facades

Technical Sample Submittal

1. Window frame

Technical / Sample Submittal Reference Image



Picture of mock up sample



Colour sample



Manufacturers details

Further Description	
<ul style="list-style-type: none"> • Internal/external Teknos RAL 9010 30% sheen • cills to be manufactured from iroko • all other materials for frames & sashes to be sapele • finished using tekno paint system ral tbc • double glazed units • 6mm low e climaguard 1.1 toughened glass • 10mm argon filled cavity • 8.8mm clear laminated glass outer pane no visible kite marks. • glazing to achieve 1.4u value • 8.8mm laminated glass to be used for p2a security rating 	
Submitted by	Date
Studio Indigo	24.04.2020