

SHARPS REDMORE

ACOUSTIC CONSULTANTS ▪ Established 1990



Report

262-267 High Holborn
Assessment of fixed plant
noise

Planning application
2013/3983/P Condition
8 & 9

Prepared by
Mark Taylor MIOA

Date 14th April 2020
Project No: 2019518

Head Office

Sharps Redmore

The White House, London Road,
Copdock, Ipswich, IP8 3JH

T 01473 730073

E contact@sharpsredmore.co.uk

W sharpsredmore.co.uk

Regional Locations

South England (Head Office),
North England, Wales, Scotland

Sharps Redmore Partnership Limited

Registered in England No. 2593855

Directors

RD Sullivan BA(Hons), PhD, CEng, MIOA, MAAS, MASA;

DE Barke MSc, MIOA;

KJ Metcalfe BSc(Hons), MIOA

Company Consultant

TL Redmore BEng, MSc, PhD, MIOA



sponsoring
organisation



Contents

- 1.0 Introduction
- 2.0 Assessment methodology and criteria
- 3.0 The fixed plant noise control scheme – conclusions and recommendations
- 4.0 The noise model and prediction methodology
- 5.0 Assessment conclusions

Appendices

- A. Noise source data
- B. Noise model input data
- C. Insertion loss requirements
- D. Calculations – summary (0700-2000 hours)
- E. Calculations – summary (2000-2200 hours)
- F. Calculations – summary (2200 – midnight)
- G. Site layout drawing
- H. Environmental survey data

This report has been prepared with all reasonable skill, care and diligence commensurate with an acoustic consultancy practice under the terms and brief agreed with our client at that time. Sharps Redmore provides no duty or responsibility whatsoever to any third party who relies upon its content, recommendations or conclusions.

1.0 Introduction

- 1.1 Sharps Redmore (SR) has been instructed to undertake a noise assessment of proposed fixed plant equipment, at part of the re-development of 262-267 High Holborn, London. See site layout drawing in Appendix G.
- 1.2 Consent for the development (2013/3983/P) has been granted, subject to a number of planning conditions.

Condition 8 states:

"Noise levels at a point 1 metre external to sensitive facades shall be at least 5 dBA less than the existing background measurement (LA90), expressed in dBA when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous noise (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10 dBA below the LA90 expressed in dBA."

Condition 9 states:

"Before the use commences, the extract/ventilating system/plant shall be provided with acoustic isolation, sound attenuation and anti-vibration measures in accordance with the scheme approved in writing by the local planning authority. All such measures shall thereafter be retained and maintained in accordance with the manufacturers recommendations."

- 1.3 The proposal is to install the air conditioning chiller in a plant area on the 7th floor roof, with the main ventilation plant (Air Handling Units and Extract Fans) located in a basement plantroom with fresh air inlets and exhausts ducted to louvres at ground floor level. Toilet extract fans are located on each floor of the development.
- 1.4 The surrounding area is a combination of other commercial / retail outlets. The nearest noise sensitive premises are The Chancery Court Hotel adjacent to the development, and 268-270 High Holborn (understood to be offices) which is adjacent to the development, and extends to the rear of the development.
- 1.5 The objective of the assessment is to determine how noise that may be generated as a result of the proposed fixed plant equipment would compare against the criteria specified in Condition 8 of the planning consent.
- 1.6 Section 2 of this report contains a discussion of the available methods of assessment and assessment criteria.
- 1.7 Section 3 of this report sets out the findings of an environmental noise survey, section 4 presents an assessment of noise from fixed plant equipment.
- 1.8 The assessment conclusions are contained in section 6 of this report.

2.0 Assessment methodology and criteria


- 2.1 It is usual in dealing with fixed sources of ventilation and refrigeration noise to use BS 4142:2014 “Method for rating and assessing industrial and commercial noise” as a means of establishing the potential impact from the new sources to the nearest residential properties.
- 2.2 However, at the time the original application was submitted / approved, the previous 1997 version of the standard, was in use.
- 2.3 A survey of existing noise levels was carried out between 20th March and 21st March 2013 at a monitoring location shown in Fig 1 below. The monitoring position was chosen to be representative of the nearest noise sensitive properties to the proposed plant area, namely the Chancery Court Hotel.

Fig 1: Monitoring location



- 2.4 The weather during the survey was cold and overcast with a slight ($>5\text{m/s}^{-1}$), easterly wind. Weather conditions were suitable for carrying out sound level measurements.
- 2.5 The measurements were taken using a Norsonic 140 type 1 precision sound level meter. The sound level meter was calibrated at the start and end of the survey and no variation in level noted. Sound level measurements were regularly at 5-minute samples over the duration of the survey. All measurements were taken in free field conditions.
- 2.6 The steady noise level dB $L_{Aeq(5min)}$, non-steady noise level dB L_{Amax} and background noise levels dB, $L_{A90(5min)}$ were recorded during the survey. Fig 2 below is a summary of the noise results recorded. Full details of the survey are included in Appendix H.

Fig 2: Survey Results



- 2.7 Whilst Condition 7 of the original planning application restricted the use of the plant to between 0700 and 1900 hours, this condition was amended under a Section 73 application (2014/2703/P) to permit the use of plant to between 0700 hours and midnight.
- 2.8 In our experience, the type of plant proposed is not considered tonal or impulsive, therefore based on the environmental noise survey undertaken the following criteria has been adopted :

Table 1: Adopted criteria

Time	Adopted criteria L_{Aeq}
0700 to 2000 hours	55 dBA (L_{A90} 60 dB -5)
2000 to 2200 hours	52 dBA (L_{A90} 57 dB – 5)
2200 hours to Midnight	49 dBA (L_{A90} 54dB – 5)

3.0 The fixed plant noise control scheme – conclusions and recommendations

- 3.1 Based on the environmental noise model (see Section 5.0), the predicted noise levels without any additional mitigation are as follows:

Table 2 – Predicted noise levels


Chancery Court Hotel

Time period	Predicted L _{Aeq} (dB)	Criteria L _{Aeq} (dB)
0700 – 2000 hours	55 dBA	55 dBA
2000 – 2200 hours	52 dBA	52 dBA
2200 - midnight	49 dBA	49 dBA

268-270 High Holborn (rear)

Time period	Predicted L _{Aeq} (dB)	Criteria L _{Aeq} (dB)
0700 – 2000 hours	37 dBA	55 dBA
2000 – 2200 hours	36 dBA	52 dBA
2200 - midnight	35 dBA	49 dBA

- 3.2 A schedule of manufacturers noise data used for the proposed plant is shown in Appendix A
- 3.3 The noise control system is based on the selection of intrinsically quiet equipment, distance from the plant to the receptors, load control of the chiller, add-on attenuation, and screening from the building itself / parapet around the roof plant.
- 3.4 The chiller is capable of operating to achieve various cooling loads, generally dependent on ambient temperature, and the cooling demands within the office space, but this can also be controlled via the BMS system, limiting the load capacity at specific times. Based on the information provided by the chiller manufacturer, the chiller will be controlled to not exceed 56 dBA at 10m between 0700 and 2000 hours, 52 dBA at 10m between 2000 and 2200 hours, and 45 dBA at 10m between 2200 and midnight. The calculations for these time periods are presented in summary form in appendices D, E and F.
- 3.5 A schedule of the insertion loss requirements is presented in Appendix C.
- 3.6 The comparison presented in Table 2 indicates compliance with the criteria specified in Condition 8 of the planning consent, based on the mitigation referred to in this report.
- 3.7 Whilst the development building is stand alone, ie no party walls to adjacent properties, it is suggested that all mechanical services plant, extract fans, AHU's and chillers are mounted on suitably selected anti-vibration mounts, and all extract fans and AHU's are isolated from the associated ductwork with flexible connectors.
- 3.8 Detailed below is a sketch from the noise model detailing the location of the development, the plant, the parapet and the nearest noise sensitive premises:



4.0 The noise model and prediction methodology

4.1 The noise model employed has been written in-house to provide an accurate prediction method for assessing environmental noise from, in particular, plant and equipment items which can be perceived as being point sources. It has been mainly used for the prediction of noise emanating from superstores.

4.2 There are three input spreadsheets containing:

- noise sources data
- receiver data
- acoustic screening data

These are included in Appendix B.

4.3 The noise sources data include one of the following forms for each item of plant:

- either, octave band sound power levels in the range of 63 to 8000Hz – this being available from manufacturer of many of the supply and extract fans.
- or, octave band sound pressure levels in the range of 63 to 8000Hz – this is available usually for the small, externally mounted split units' condenser fans from the manufacturer's product catalogue when measured at one metre in anechoic conditions, thus allowing straight forward calculation of the equivalent sound power levels.
- or, single value sound pressure levels at a stated distance

4.4 The relative location of the plant using X and Y co-ordinates with an arbitrary datum point and a Z (height) co-ordinate based on supporting steel and screening heights from the main contractor and then the equipment heights based, in this case, on the mechanical services contractor drawings.

4.5 Where known, the area and orientation of the noise outlet is entered together with its location adjacent to either one, two or three reflective surfaces so that the calculation can establish the directivity pattern and outlet reflection losses.

4.6 The receiver data needed are the X, Y and Z co-ordinates so that the relative distance and angle can be calculated between the source and the receiver.

4.7 Finally, several types of acoustic screening may be entered. In this case, this is designated "R" meaning a ring barrier, in this case indicating the locations of the building itself.

4.8 The noise model carries out "text book" atmospheric side calculations at each receiver position from each source allowing for the attenuation from such as the calculated distance and screening. The calculations are performed in eight Octave bands from 63 to 8000Hz but can then be summarised as dBA, NR or NC for convenience. In this case, the overall summary levels are in dBA. Calculations for the plant are included in Appendix D, E and F. The computer maintains a logarithmic total of the noise levels in Octave bands.

- 4.9 At the end of each program “run”, the overall day or night time noise level at each receiver position are calculated and ranked in descending order of noise level. Where this ranking shows that the receiver position’s noise level exceeds the noise criterion, each calculation can be interrogated to determine the plant items needing more detailed inspection to establish the attenuation needed. The process is repeated until either the noise level meets the noise criterion or the program demonstrates that other noise control methods are needed. This may take the form of restricting the offending plant’s period of operation or improving the screening or re-selection to give quieter plant.
- 4.10 Plant noise predictions are shown in summary form; full calculations of noise from each source to each receptor are available on request

5.0 Assessment conclusions

- 5.1 This assessment of fixed plant indicates compliance with the criteria specified in Condition 8 of the planning consent.
- 5.2 This assessment objectively demonstrates that noise arising from the fixed plant, complies with the requirement of paragraph 180 of the NPPF to avoid significant adverse impact.

APPENDIX A

NOISE SOURCE DATA

Client: Mala				A Page: 1 of 1							
Project: High Holborn				Project no: 2019518							
Consultant: MT				Date: 14 April 2020							
Sound power levels (Lw) & sound pressure levels (Lp) for fans & other equipment											
Equipment name/reference	Lw/ Lp	Dist. (m)	On time D/N/A	Mid-frequency Octave Bands (Hz)							
				63	125	250	500	1k	2k	4k	8k
Roof mounted chiller	Lp	10	D	56	56	59	52	50	47	44	37
Roof mounted chiller	Lp	10	N	44	44	47	41	39	36	33	26
Roof mounted pumps	Lp	1	A	65	dBA						
AHU1 fresh air inlet	Lw		A	61	75	72	67	65	56	50	42
AHU2 fresh air inlet	Lw		A	65	63	70	69	63	59	53	48
AHU1 exhaust	Lw		A	61	71	68	68	65	59	53	50
EFX-B1-05 Exhaust	Lw		A	78	71	69	65	62	61	55	53
EFX-B1-04 Exhaust	Lw		D	92	92	93	92	89	85	81	76
EFX-B1-03 Exhaust	Lw		A	74	80	71	71	71	72	63	55
EFX-B1-02 Exhaust	Lw		A	77	80	65	67	59	59	53	46
EFX-B1-01 Exhaust	Lw		A	79	73	80	73	65	67	58	54
EXF-00-01 Exhaust	Lw		A	82	71	73	75	66	65	62	58
EXF-01-01 Exhaust	Lw		A	82	71	73	75	66	65	62	58
EXF-02-01 Exhaust	Lw		A	82	71	73	75	66	65	62	58
EXF-03-01 Exhaust	Lw		A	82	71	73	75	66	65	62	58
EXF-04-01 Exhaust	Lw		A	82	71	73	75	66	65	62	58
EXF-05-01 Exhaust	Lw		A	82	71	73	75	66	65	62	58
EXF-06-01 Exhaust	Lw		A	82	71	73	75	66	65	62	58
EXF-07-01 Exhaust	Lw		A	82	71	73	75	66	65	62	58
EXF-08-01 Exhaust	Lw		A	82	71	73	75	66	65	62	58
Notes:											
1. Lw/Lp Lw means sound power level (dB) Lp means sound pressure level at the stated distance (dB@m)											
2. On times (On.time D/N/A): D (Day) means that the fan/equipment could operate at any time between 0700 and 2300 hours N (Night) means that the fan/equipment could operate at any time between 2300 and 0700 hours A (All) means that the fan/equipment could operate at any time during the day and night											

APPENDIX B

NOISE MODEL INPUT DATA

Source description	Co-ordinates			Outlet details					Run dna	Lp/Lw	dBA Y/N	Dist (m)	Mid frequency octave bands (Hz)							
	Xm	Ym	Zm	Amm	Bmm	Ang.	%	Q					63	125	250	500	1k	2k	4k	8k
Roof mounted chiller	190.0	195.0	50.1	0	0	0	100	2	D	P	N	10.0	56	56	59	52	50	47	44	37
Roof mounted chiller	190.0	195.0	50.1	0	0	0	100	2	N	P	N	10.0	44	44	47	41	39	36	33	26
Roof mounted pumps	187.0	195.0	50.1	0	0	0	100	2	A	P	Y	1.0	65							
AHU1 fresh air inlet	189.0	190.0	23.0	1600	1600	180	100	1	A	W	N	0.0	61	75	72	67	65	56	50	42
AHU2 fresh air inlet	189.0	190.0	23.0	800	300	180	100	1	A	W	N	0.0	65	63	70	69	63	59	53	48
AHU1 exhaust	184.5	197.0	23.0	1900	600	270	100	1	A	W	N	0.0	61	71	68	68	65	59	53	50
EFX-B1-05 Exhaust	184.5	197.0	23.0	600	600	270	100	1	A	W	N	0.0	78	71	69	65	62	61	55	53
EFX-B1-04 Exhaust	184.5	197.0	23.0	1000	1000	270	100	1	D	W	N	0.0	92	92	93	92	89	85	81	76
EFX-B1-03 Exhaust	184.5	197.0	23.0	600	600	270	100	1	A	W	N	0.0	74	80	71	71	71	72	63	55
EFX-B1-02 Exhaust	184.5	197.0	23.0	600	600	270	100	1	A	W	N	0.0	77	80	65	67	59	59	53	46
EFX-B1-01 Exhaust	184.5	197.0	23.0	600	600	270	100	1	A	W	N	0.0	79	73	80	73	65	67	58	54
EXF-00-01 Exhaust	183.5	207.0	27.3	600	600	270	100	1	A	W	N	0.0	82	71	73	75	66	65	62	58
EXF-01-01 Exhaust	183.5	207.0	31.3	600	600	270	100	1	A	W	N	0.0	82	71	73	75	66	65	62	58
EXF-02-01 Exhaust	183.5	207.0	34.5	600	600	270	100	1	A	W	N	0.0	82	71	73	75	66	65	62	58
EXF-03-01 Exhaust	183.5	207.0	37.7	600	600	270	100	1	A	W	N	0.0	82	71	73	75	66	65	62	58
EXF-04-01 Exhaust	183.5	207.0	40.9	600	600	270	100	1	A	W	N	0.0	82	71	73	75	66	65	62	58
EXF-05-01 Exhaust	183.5	207.0	44.1	600	600	270	100	1	A	W	N	0.0	82	71	73	75	66	65	62	58
EXF-06-01 Exhaust	183.5	207.0	47.3	600	600	270	100	1	A	W	N	0.0	82	71	73	75	66	65	62	58
EXF-07-01 Exhaust	183.5	207.0	50.5	600	600	270	100	1	A	W	N	0.0	82	71	73	75	66	65	62	58
EXF-08-01 Exhaust	183.5	207.0	53.7	600	600	270	100	1	A	W	N	0.0	82	71	73	75	66	65	62	58

Sharps Redmore Partnership						
The White House, London Road, Copdock, Ipswich, IP8 3JH						
Receptor data - description and co-ordinates						
Filename:	C:\High Holborn\270320_1A					
Receptor description	Co-ordinates					
	X m	Y m	Z m	DNA		
Top floor Chancery Court Hotel F	175.0	200.0	52.2	A		
Top floor Chancery Court Hotel E	175.0	195.0	52.2	A		
Top floor Chancery Court Hotel D	175.0	190.0	52.2	A		
Top floor Chancery Court Hotel C	175.0	185.0	52.2	A		
Top floor Chancery Court Hotel B	175.0	180.0	52.2	A		
Top floor Chancery Court Hotel A	175.0	175.0	52.2	A		
1st floor Chancery Court Hotel F	175.0	200.0	29.8	A		
1st floor Chancery Court Hotel E	175.0	195.0	29.8	A		
1st floor Chancery Court Hotel C	175.0	185.0	29.8	A		
1st floor Chancery Court Hotel A	175.0	175.0	29.8	A		
1st floor Chancery Court Hotel	175.0	190.0	29.8	A		
1st floor Chancery Court Hotel	175.0	180.0	29.8	A		
268-270 High Holborn to rear grd floor	189.0	184.0	22.8	A		
268-270 High Holborn to rear 4th floor	189.0	184.0	39.4	A		
268-270 High Holborn to rear 5th floor	189.0	180.0	42.6	A		
1st floor Chancery Court Hotel G	175.0	207.0	29.8	A		
2nd floor Chancery Court Hotel G	175.0	207.0	33.0	A		
3rd floor Chancery Court Hotel G	175.0	207.0	36.2	A		
4th floor Chancery Court Hotel G	175.0	207.0	39.4	A		
5th floor Chancery Court Hotel G	175.0	207.0	42.6	A		
6th floor Chancery Court Hotel G	175.0	207.0	45.8	A		
7th floor Chancery Court Hotel G	175.0	207.0	49.0	A		
8th floor Chancery Court Hotel G	175.0	207.0	53.2	A		
Sharps Redmore Partnership						
The White House, London Road, Copdock, Ipswich, IP8 3JH						
Barrier data - description and co-ordinates						
Filename:	C:\High Holborn\270320_1A					
Barrier description	Co-ordinates					
	Start			End		
	X m	Y m	Z m	X m	Y m	Z m
R	200.0	200.0	54.0	212.0	200.0	54.0
R	212.0	200.0	54.0	212.0	215.0	54.0
R	212.0	215.0	54.0	183.0	215.0	54.0
R	183.0	215.0	54.0	185.0	200.0	54.0
R	185.0	200.0	54.0	200.0	200.0	54.0
R	185.0	200.0	52.0	200.0	200.0	52.0
R	200.0	200.0	52.0	200.0	192.0	52.0
R	200.0	192.0	52.0	193.0	191.0	52.0
R	193.0	191.0	52.0	193.0	198.0	52.0
R	193.0	198.0	52.0	185.0	198.0	52.0
R	185.0	198.0	52.0	185.0	200.0	52.0
F	185.0	198.0	51.7	193.0	198.0	51.7
F	193.0	198.0	51.7	193.0	191.0	51.7
F	193.0	191.0	51.7	185.5	190.0	51.7
F	185.5	190.0	51.7	185.0	195.5	51.7
F	185.0	195.5	48.0	185.0	198.0	48.0

APPENDIX C

INSERTION LOSS REQUIREMENTS

Client: Mala	C Page: 1 of 1							
Project: High Holborn	Project no: 2019518							
Consultant: MT	Date: 14 April 2020							
Atmospheric side dynamic insertion losses for noise control equipment								
Equipment name/reference	Mid-frequency Octave Bands (Hz)							
	63	125	250	500	1k	2k	4k	8k
AHU1 fresh air inlet	7	11	18	24	27	21	17	14
AHU2 fresh air inlet	7	9	14	19	22	18	15	13
AHU1 exhaust	7	10	16	22	24	19	16	13
EFX-B1-05 Exhaust	4	7	11	21	25	25	18	12
EFX-B1-04 Exhaust	5	9	16	30	39	39	31	26
EFX-B1-03 Exhaust	4	7	11	21	25	25	18	12
EFX-B1-02 Exhaust	4	7	11	21	25	25	18	12
EFX-B1-01 Exhaust	4	7	11	21	25	25	18	12
EXF-00-01 Exhaust	1	3	7	16	21	20	13	10
EXF-01-01 Exhaust	1	3	7	16	21	20	13	10
EXF-02-01 Exhaust	1	3	7	16	21	20	13	10
EXF-03-01 Exhaust	1	3	7	16	21	20	13	10
EXF-04-01 Exhaust	1	3	7	16	21	20	13	10
EXF-05-01 Exhaust	1	3	7	16	21	20	13	10
EXF-06-01 Exhaust	1	3	7	16	21	20	13	10
EXF-07-01 Exhaust	1	3	7	16	21	20	13	10
EXF-08-01 Exhaust	1	3	7	16	21	20	13	10

Notes:

- Dynamic insertion loss is the logarithmic summation of the air regenerated sound power level and the residual fan sound power level after subtracting the proposed static insertion loss.
If this concept is unclear or if you have other queries, contact Sharps Redmore Partnership.
- After tendering, please send a copy of your proposed insertion losses, air regenerated L_w , passage velocities, pressure losses, air volumes & dimensions to Sharps Redmore Partnership

APPENDIX D

CALCULATIONS –SUMMARY (0700-2000 HOURS)

Overall receptor listings														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Top floor Chancery Court Hotel F					64	58	58	52	49	46	44	40	55	
Top floor Chancery Court Hotel E					61	54	55	47	42	37	32	26	50	
8th floor Chancery Court Hotel G					61	53	51	44	37	35	36	36	47	
6th floor Chancery Court Hotel G					61	53	51	43	36	35	36	37	47	
7th floor Chancery Court Hotel G					61	53	51	43	36	35	36	37	47	
1st floor Chancery Court Hotel F					60	56	52	42	35	33	33	34	47	
5th floor Chancery Court Hotel G					59	52	51	43	36	35	37	37	47	
4th floor Chancery Court Hotel G					60	53	51	43	35	34	36	36	47	
3rd floor Chancery Court Hotel G					60	53	51	43	34	34	36	36	47	
Top floor Chancery Court Hotel D					59	52	52	43	38	32	27	22	47	
2nd floor Chancery Court Hotel G					60	53	51	43	34	33	35	35	47	
1st floor Chancery Court Hotel G					60	53	50	42	33	33	35	35	46	
1st floor Chancery Court Hotel E					57	56	52	39	30	28	29	29	46	
Top floor Chancery Court Hotel C					58	51	51	41	36	31	26	19	45	
Top floor Chancery Court Hotel B					56	49	49	40	35	29	24	17	44	
1st floor Chancery Court Hotel					55	53	49	36	28	25	25	25	43	
Top floor Chancery Court Hotel A					55	48	47	38	33	27	21	16	42	
1st floor Chancery Court Hotel C					54	51	47	34	26	23	22	21	41	
1st floor Chancery Court Hotel					52	49	44	32	25	22	20	17	38	
268-270 High Holborn to rear 5th floor					52	44	42	31	28	25	23	18	37	
268-270 High Holborn to rear 4th floor					51	44	41	31	29	26	24	19	37	
268-270 High Holborn to rear grd floor					49	46	40	32	27	26	23	19	37	
1st floor Chancery Court Hotel A					50	47	42	30	23	21	18	14	36	

Source noise levels at receiver: Top floor Chancery Court Hotel F										
Period:	Day time					Mid frequency octave bands (Hz)				
						63	125	250	500	1k 2k 4k 8k dBA
Roof mounted chiller						55	55	58	51	49 46 43 36 55
Roof mounted pumps						63	53	46	40	37 36 36 38 46
EXF-08-01 Exhaust						45	37	38	31	17 18 22 21 33
EXF-07-01 Exhaust						45	37	38	31	17 18 22 21 33
EXF-06-01 Exhaust						44	36	37	30	16 17 21 20 32
EXF-05-01 Exhaust						43	35	36	29	15 16 20 19 31
EFX-B1-04 Exhaust						44	44	36	17	1 0 1 1 31
EXF-04-01 Exhaust						42	33	34	27	13 12 16 15 29
EXF-03-01 Exhaust						41	32	33	26	12 11 15 14 28
EXF-02-01 Exhaust						40	31	31	24	8 6 10 9 26
EXF-01-01 Exhaust						39	30	30	23	7 5 9 8 25
EXF-00-01 Exhaust						37	27	26	19	1 0 1 0 21
EFX-B1-01 Exhaust						30	24	28	11	0 0 0 0 20
EFX-B1-03 Exhaust						25	31	19	9	1 0 0 0 17
EFX-B1-02 Exhaust						28	31	13	5	0 0 0 0 16
EFX-B1-05 Exhaust						29	22	17	3	0 0 0 0 11
AHU1 exhaust						11	22	11	1	0 0 0 0 8
AHU1 fresh air inlet						1	8	0	0	0 0 0 0 0
AHU2 fresh air inlet						3	0	0	0	0 0 0 0 0
Total Free field Lp and dBA						64	58	58	52	49 46 44 40 55
Source noise levels at receiver: Top floor Chancery Court Hotel E										
Period:	Day time					Mid frequency octave bands (Hz)				
						63	125	250	500	1k 2k 4k 8k dBA
Roof mounted chiller						53	52	54	46	42 37 31 21 49
Roof mounted pumps						60	49	40	32	27 24 21 20 39
EFX-B1-04 Exhaust						44	44	36	17	1 0 1 1 31
EXF-07-01 Exhaust						43	34	35	28	14 13 17 16 30
EXF-08-01 Exhaust						43	34	35	28	14 13 17 16 30
EXF-06-01 Exhaust						42	33	34	27	13 12 16 15 29
EXF-05-01 Exhaust						41	32	33	26	12 11 15 14 28
EXF-04-01 Exhaust						41	32	33	26	12 11 15 14 28
EXF-03-01 Exhaust						40	31	32	25	11 10 14 13 27
EXF-02-01 Exhaust						39	30	31	24	10 9 13 12 26
EXF-01-01 Exhaust						38	29	30	23	9 8 12 11 25
EXF-00-01 Exhaust						37	28	28	21	5 3 7 6 23
EFX-B1-01 Exhaust						30	24	28	11	0 0 0 0 20
EFX-B1-03 Exhaust						25	31	19	9	1 0 0 0 17
EFX-B1-02 Exhaust						28	31	13	5	0 0 0 0 16
EFX-B1-05 Exhaust						29	22	17	3	0 0 0 0 11
AHU1 exhaust						11	22	11	1	0 0 0 0 8
AHU1 fresh air inlet						5	12	0	0	0 0 0 0 0
AHU2 fresh air inlet						7	2	4	0	0 0 0 0 0
Total Free field Lp and dBA						61	54	55	47	42 37 32 26 50
Source noise levels at receiver: Top floor Chancery Court Hotel D										
Period:	Day time					Mid frequency octave bands (Hz)				
						63	125	250	500	1k 2k 4k 8k dBA
Roof mounted chiller						51	50	51	42	38 32 26 16 45
Roof mounted pumps						58	46	37	29	23 19 16 18 36
EFX-B1-04 Exhaust						44	44	36	17	1 0 1 1 31
EXF-07-01 Exhaust						40	31	31	24	8 6 10 9 26
EXF-08-01 Exhaust						40	31	31	24	8 6 10 9 26
EXF-06-01 Exhaust						40	31	31	24	8 6 10 9 26
EXF-05-01 Exhaust						40	31	31	24	8 6 10 9 26
EXF-04-01 Exhaust						39	30	30	23	7 5 9 8 25
EXF-03-01 Exhaust						38	29	29	22	6 4 8 7 24
EXF-02-01 Exhaust						38	29	29	22	6 4 8 7 24
EXF-01-01 Exhaust						37	28	28	21	5 3 7 6 23
EXF-00-01 Exhaust						36	27	27	20	4 2 6 5 22
EFX-B1-01 Exhaust						30	24	28	11	0 0 0 0 20
EFX-B1-03 Exhaust						25	31	19	9	1 0 0 0 17
EFX-B1-02 Exhaust						28	31	13	5	0 0 0 0 16
EFX-B1-05 Exhaust						29	22	17	3	0 0 0 0 11
AHU1 exhaust						11	22	11	1	0 0 0 0 8
AHU1 fresh air inlet						6	15	2	0	0 0 0 0 0
AHU2 fresh air inlet						8	5	9	1	0 0 0 0 0
Total Free field Lp and dBA						59	52	52	43	38 32 27 22 47

Source noise levels at receiver: Top floor Chancery Court Hotel C														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted chiller					49	48	50	41	36	31	25	15	44	
Roof mounted pumps					56	44	35	26	20	16	14	16	34	
EFX-B1-04 Exhaust					45	43	38	21	7	3	7	7	32	
EXF-07-01 Exhaust					39	29	28	21	3	0	3	2	23	
EXF-08-01 Exhaust					39	29	28	21	3	0	3	2	23	
EXF-06-01 Exhaust					38	28	27	20	2	0	2	1	22	
EXF-05-01 Exhaust					38	28	27	20	2	0	2	1	22	
EXF-04-01 Exhaust					38	28	27	20	2	0	2	1	22	
EFX-B1-01 Exhaust					30	25	30	13	0	0	0	0	22	
EXF-02-01 Exhaust					37	27	26	19	1	0	1	0	21	
EXF-03-01 Exhausr					37	27	26	19	1	0	1	0	21	
EXF-01-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-00-01 Exhaust					35	25	24	17	0	0	0	0	19	
EFX-B1-03 Exhaust					25	32	21	11	5	4	2	0	19	
EFX-B1-02 Exhaust					28	32	15	7	0	0	0	0	17	
EFX-B1-05 Exhaust					29	23	19	5	0	0	0	0	13	
AHU2 fresh air inlet					11	10	17	9	0	0	0	0	11	
AHU1 exhaust					12	21	13	5	0	0	0	0	9	
AHU1 fresh air inlet					14	23	9	0	0	0	0	0	8	
Total Free field Lp and dBA					58	51	51	41	36	31	26	19	45	
Source noise levels at receiver: Top floor Chancery Court Hotel B														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted chiller					47	46	48	39	35	29	23	13	42	
Roof mounted pumps					54	42	32	24	18	14	12	14	32	
EFX-B1-04 Exhaust					44	42	37	20	6	2	6	6	31	
EXF-07-01 Exhaust					37	27	26	19	1	0	1	0	21	
EXF-08-01 Exhaust					37	27	26	19	1	0	1	0	21	
EXF-06-01 Exhaust					37	27	26	19	1	0	1	0	21	
EXF-05-01 Exhaust					37	27	26	19	1	0	1	0	21	
EFX-B1-01 Exhaust					29	24	29	12	0	0	0	0	21	
EXF-04-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-02-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-03-01 Exhausr					36	26	25	18	0	0	0	0	20	
EXF-01-01 Exhaust					35	25	24	17	0	0	0	0	19	
EXF-00-01 Exhaust					34	24	23	16	0	0	0	0	18	
EFX-B1-03 Exhaust					24	31	20	10	4	3	1	0	18	
EFX-B1-02 Exhaust					27	31	14	6	0	0	0	0	16	
EFX-B1-05 Exhaust					28	22	18	4	0	0	0	0	12	
AHU2 fresh air inlet					10	10	15	10	0	0	0	0	10	
AHU1 fresh air inlet					12	24	12	0	0	0	0	0	10	
AHU1 exhaust					11	20	12	4	0	0	0	0	8	
Total Free field Lp and dBA					56	49	49	40	35	29	24	17	44	
Source noise levels at receiver: Top floor Chancery Court Hotel A														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted chiller					46	45	46	37	33	27	21	12	40	
Roof mounted pumps					53	41	32	23	17	14	11	13	31	
EFX-B1-04 Exhaust					42	42	34	15	0	0	0	0	29	
EXF-07-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-08-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-06-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-05-01 Exhaust					35	25	24	17	0	0	0	0	19	
EXF-02-01 Exhaust					35	25	24	17	0	0	0	0	19	
EXF-04-01 Exhaust					35	25	24	17	0	0	0	0	19	
EXF-03-01 Exhausr					35	25	24	17	0	0	0	0	19	
EFX-B1-01 Exhaust					28	22	26	9	0	0	0	0	18	
EXF-01-01 Exhaust					34	24	23	16	0	0	0	0	18	
EXF-00-01 Exhaust					34	24	23	16	0	0	0	0	18	
EFX-B1-03 Exhaust					23	29	17	7	0	0	0	0	15	
EFX-B1-02 Exhaust					26	29	11	3	0	0	0	0	14	
AHU2 fresh air inlet					10	10	16	11	2	1	0	0	12	
AHU1 fresh air inlet					13	25	15	3	0	0	0	0	11	
EFX-B1-05 Exhaust					27	20	15	1	0	0	0	0	9	
AHU1 exhaust					9	20	9	0	0	0	0	0	5	
Total Free field Lp and dBA					55	48	47	38	33	27	21	16	42	

Source noise levels at receiver: 1st floor Chancery Court Hotel F														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBa	
EFX-B1-04 Exhaust					54	54	49	35	24	20	24	24	43	
Roof mounted pumps					57	47	40	34	31	30	30	32	40	
Roof mounted chiller					45	44	45	36	31	25	19	12	39	
EXF-01-01 Exhaust					45	37	38	31	17	18	22	21	33	
EXF-00-01 Exhaust					45	37	38	31	17	18	22	21	33	
EFX-B1-01 Exhaust					39	34	41	24	13	16	14	16	33	
EXF-02-01 Exhaust					44	36	37	30	16	17	21	20	32	
EXF-03-01 Exhaust					43	35	36	29	15	16	20	19	31	
EXF-04-01 Exhaust					42	34	35	28	14	15	19	18	30	
EFX-B1-03 Exhaust					34	41	32	22	19	21	19	17	30	
EXF-05-01 Exhaust					41	32	33	26	12	11	15	14	28	
EFX-B1-02 Exhaust					37	41	26	18	7	8	9	8	26	
EXF-06-01 Exhaust					40	31	31	24	8	6	10	9	26	
EXF-07-01 Exhaust					39	30	30	23	7	5	9	8	25	
EFX-B1-05 Exhaust					38	32	30	16	10	10	11	15	24	
EXF-08-01 Exhaust					38	29	29	22	6	4	8	7	24	
AHU1 exhaust					21	32	24	19	15	14	11	11	23	
AHU2 fresh air inlet					9	4	5	0	0	0	0	0	0	
AHU1 fresh air inlet					7	14	0	0	0	0	0	0	0	
Total Free field Lp and dBA					60	56	52	42	35	33	33	34	47	
Source noise levels at receiver: 1st floor Chancery Court Hotel E														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBa	
EFX-B1-04 Exhaust					55	55	50	36	25	21	25	25	44	
EFX-B1-01 Exhaust					40	35	42	25	14	17	15	17	34	
Roof mounted chiller					39	37	37	27	25	22	19	12	32	
EFX-B1-03 Exhaust					35	42	33	23	20	22	20	18	31	
EXF-01-01 Exhaust					43	34	35	28	14	13	17	16	30	
EXF-00-01 Exhaust					43	34	35	28	14	13	17	16	30	
EXF-02-01 Exhaust					42	33	34	27	13	12	16	15	29	
EXF-03-01 Exhaust					42	33	34	27	13	12	16	15	29	
EXF-04-01 Exhaust					41	32	33	26	12	11	15	14	28	
EFX-B1-02 Exhaust					38	42	27	19	8	9	10	9	27	
EXF-05-01 Exhaust					40	31	32	25	11	10	14	13	27	
EXF-06-01 Exhaust					39	30	31	24	10	9	13	12	26	
EFX-B1-05 Exhaust					39	33	31	17	11	11	12	16	25	
Roof mounted pumps					47	35	25	16	12	11	11	13	25	
EXF-07-01 Exhaust					38	29	30	23	9	8	12	11	25	
AHU1 exhaust					22	33	25	20	16	15	12	12	24	
EXF-08-01 Exhaust					37	28	28	21	5	3	7	6	23	
AHU1 fresh air inlet					10	18	3	0	0	0	0	0	4	
AHU2 fresh air inlet					12	8	10	0	0	0	0	0	4	
Total Free field Lp and dBA					57	56	52	39	30	28	29	29	46	
Source noise levels at receiver: 1st floor Chancery Court Hotel C														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBa	
EFX-B1-04 Exhaust					51	50	45	30	17	13	17	17	39	
Roof mounted chiller					39	36	36	26	24	21	18	11	31	
EFX-B1-01 Exhaust					36	31	37	20	8	9	7	9	29	
EFX-B1-03 Exhaust					31	38	28	18	14	14	12	10	26	
Roof mounted pumps					47	35	25	16	11	10	10	12	25	
EFX-B1-02 Exhaust					34	38	22	14	2	1	2	1	23	
EXF-01-01 Exhaust					39	29	28	21	3	0	3	2	23	
EXF-00-01 Exhaust					38	28	27	20	2	0	2	1	22	
EXF-02-01 Exhaust					38	28	27	20	2	0	2	1	22	
EXF-03-01 Exhaust					38	28	27	20	2	0	2	1	22	
EXF-04-01 Exhaust					38	28	27	20	2	0	2	1	22	
EXF-05-01 Exhaust					37	27	26	19	1	0	1	0	21	
EXF-06-01 Exhaust					37	27	26	19	1	0	1	0	21	
EFX-B1-05 Exhaust					35	29	26	12	5	3	4	8	20	
EXF-07-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-08-01 Exhaust					35	25	24	17	0	0	0	0	19	
AHU1 exhaust					18	28	20	14	8	7	4	4	18	
AHU2 fresh air inlet					17	16	23	15	2	0	0	0	16	
AHU1 fresh air inlet					20	29	15	0	0	0	0	0	14	
Total Free field Lp and dBA					54	51	47	34	26	23	22	21	41	

Source noise levels at receiver: 1st floor Chancery Court Hotel A														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
EFX-B1-04 Exhaust					46	46	38	19	3	0	3	3	33	
Roof mounted chiller					38	35	36	26	23	20	17	10	31	
Roof mounted pumps					45	33	23	14	9	8	8	10	23	
EFX-B1-01 Exhaust					32	26	30	13	0	0	0	0	22	
EXF-02-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-00-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-01-01 Exhaust					36	26	25	18	0	0	0	0	20	
EFX-B1-03 Exhaust					27	33	21	11	3	0	0	0	19	
EXF-04-01 Exhaust					35	25	24	17	0	0	0	0	19	
EXF-03-01 Exhaust					35	25	24	17	0	0	0	0	19	
EXF-06-01 Exhaust					35	25	24	17	0	0	0	0	19	
EXF-05-01 Exhaust					35	25	24	17	0	0	0	0	19	
EFX-B1-02 Exhaust					30	33	15	7	0	0	0	0	18	
EXF-08-01 Exhaust					34	24	23	16	0	0	0	0	18	
EXF-07-01 Exhaust					34	24	23	16	0	0	0	0	18	
AHU2 fresh air inlet					14	15	21	16	7	8	5	2	17	
AHU1 fresh air inlet					18	30	20	10	5	2	0	0	17	
EFX-B1-05 Exhaust					31	24	19	5	0	0	0	0	13	
AHU1 exhaust					13	24	13	3	0	0	0	0	10	
Total Free field Lp and dBA					50	47	42	30	23	21	18	14	36	
Source noise levels at receiver: 1st floor Chancery Court Hotel														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
EFX-B1-04 Exhaust					53	52	47	32	21	17	21	21	41	
Roof mounted chiller					40	37	37	27	25	22	19	12	32	
EFX-B1-01 Exhaust					37	33	39	22	10	13	11	13	31	
EFX-B1-03 Exhaust					32	40	30	20	16	18	16	14	28	
EXF-02-01 Exhaust					40	31	31	24	8	6	10	9	26	
EXF-00-01 Exhaust					40	31	31	24	8	6	10	9	26	
EXF-01-01 Exhaust					40	31	31	24	8	6	10	9	26	
EXF-03-01 Exhaust					40	31	31	24	8	6	10	9	26	
EFX-B1-02 Exhaust					35	40	24	16	4	5	6	5	25	
EXF-04-01 Exhaust					39	30	30	23	7	5	9	8	25	
Roof mounted pumps					47	34	24	15	11	10	10	12	25	
EXF-05-01 Exhaust					38	29	29	22	6	4	8	7	24	
EXF-06-01 Exhaust					38	29	29	22	6	4	8	7	24	
EXF-07-01 Exhaust					37	28	28	21	5	3	7	6	23	
EFX-B1-05 Exhaust					36	31	28	14	7	7	8	12	22	
EXF-08-01 Exhaust					36	27	27	20	4	2	6	5	22	
AHU1 exhaust					20	30	22	16	12	11	8	8	20	
AHU2 fresh air inlet					14	11	15	7	0	0	0	0	9	
AHU1 fresh air inlet					12	21	8	0	0	0	0	0	6	
Total Free field Lp and dBA					55	53	49	36	28	25	25	25	43	
Source noise levels at receiver: 1st floor Chancery Court Hotel														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
EFX-B1-04 Exhaust					49	47	42	25	11	7	11	11	36	
Roof mounted chiller					39	36	36	26	24	21	18	11	31	
EFX-B1-01 Exhaust					34	29	34	17	3	3	1	3	26	
Roof mounted pumps					46	34	24	15	10	9	9	11	24	
EFX-B1-03 Exhaust					29	36	25	15	9	8	6	4	23	
EFX-B1-02 Exhaust					32	36	19	11	0	0	0	0	21	
EXF-02-01 Exhaust					37	27	26	19	1	0	1	0	21	
EXF-03-01 Exhaust					37	27	26	19	1	0	1	0	21	
EXF-01-01 Exhaust					37	27	26	19	1	0	1	0	21	
EXF-00-01 Exhaust					37	27	26	19	1	0	1	0	21	
EXF-04-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-05-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-06-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-07-01 Exhaust					35	25	24	17	0	0	0	0	19	
EXF-08-01 Exhaust					35	25	24	17	0	0	0	0	19	
AHU2 fresh air inlet					16	16	22	17	8	7	4	1	18	
AHU1 fresh air inlet					19	31	21	9	4	1	0	0	18	
EFX-B1-05 Exhaust					33	27	23	9	0	0	0	2	17	
AHU1 exhaust					16	25	17	9	2	1	0	0	14	
Total Free field Lp and dBA					52	49	44	32	25	22	20	17	38	

Source noise levels at receiver: 268-270 High Holborn to rear grd floor														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
AHU2 fresh air inlet					26	27	34	30	22	23	20	17	31	
AHU1 fresh air inlet					31	44	35	25	20	17	15	10	31	
Roof mounted chiller					38	35	35	26	24	21	18	11	31	
EFX-B1-04 Exhaust					44	40	30	9	0	0	0	0	26	
Roof mounted pumps					44	31	21	13	10	9	9	11	22	
EFX-B1-01 Exhaust					32	23	22	2	0	0	0	0	15	
EFX-B1-03 Exhaust					27	30	13	0	0	0	0	0	15	
EFX-B1-02 Exhaust					30	30	7	0	0	0	0	0	15	
EXF-00-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-02-01 Exhaust					33	19	13	3	0	0	0	0	11	
EXF-01-01 Exhaust					33	19	13	3	0	0	0	0	10	
EFX-B1-05 Exhaust					31	21	11	0	0	0	0	0	9	
EXF-03-01 Exhaust					32	18	12	2	0	0	0	0	9	
EXF-04-01 Exhaust					32	18	12	2	0	0	0	0	9	
EXF-05-01 Exhaust					31	17	11	1	0	0	0	0	8	
EXF-07-01 Exhaust					30	16	10	0	0	0	0	0	7	
EXF-06-01 Exhaust					30	16	10	0	0	0	0	0	7	
EXF-08-01 Exhaust					29	15	9	0	0	0	0	0	5	
AHU1 exhaust					11	18	5	0	0	0	0	0	4	
Total Free field Lp and dBA					49	46	40	32	27	26	23	19	37	
Source noise levels at receiver: 268-270 High Holborn to rear 4th floor														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted chiller					43	41	41	31	29	26	23	16	36	
Roof mounted pumps					49	37	27	18	15	14	14	16	27	
EFX-B1-04 Exhaust					40	36	26	5	0	0	0	0	22	
AHU2 fresh air inlet					16	15	22	14	1	0	0	0	15	
AHU1 fresh air inlet					19	28	14	0	0	0	0	0	13	
EXF-03-01 Exhaust					34	20	14	4	0	0	0	0	12	
EXF-04-01 Exhaust					34	20	14	4	0	0	0	0	12	
EFX-B1-01 Exhaust					28	19	18	0	0	0	0	0	11	
EFX-B1-03 Exhaust					23	26	9	0	0	0	0	0	10	
EFX-B1-02 Exhaust					26	26	3	0	0	0	0	0	10	
EXF-02-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-06-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-01-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-00-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-05-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-07-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-08-01 Exhaust					33	19	12	3	0	0	0	0	10	
EFX-B1-05 Exhaust					27	17	7	0	0	0	0	0	5	
AHU1 exhaust					7	14	1	0	0	0	0	0	0	
Total Free field Lp and dBA					51	44	41	31	29	26	24	19	37	
Source noise levels at receiver: 268-270 High Holborn to rear 5th floor														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted chiller					44	41	41	31	28	25	22	15	36	
Roof mounted pumps					50	37	27	18	14	13	13	15	28	
EFX-B1-04 Exhaust					41	37	28	8	0	0	0	0	24	
AHU2 fresh air inlet					14	14	19	14	3	1	0	0	14	
AHU1 fresh air inlet					16	28	16	3	0	0	0	0	13	
EFX-B1-01 Exhaust					29	20	20	1	0	0	0	0	13	
EXF-08-01 Exhaust					34	21	15	6	0	0	0	0	12	
EXF-07-01 Exhaust					34	21	15	6	0	0	0	0	12	
EXF-06-01 Exhaust					34	20	15	6	0	0	0	0	12	
EXF-02-01 Exhaust					34	20	15	5	0	0	0	0	12	
EXF-04-01 Exhaust					34	20	15	5	0	0	0	0	12	
EXF-05-01 Exhaust					34	20	15	5	0	0	0	0	12	
EXF-03-01 Exhaust					34	20	15	5	0	0	0	0	12	
EFX-B1-03 Exhaust					24	27	11	0	0	0	0	0	12	
EFX-B1-02 Exhaust					27	27	5	0	0	0	0	0	12	
EXF-01-01 Exhaust					33	20	14	5	0	0	0	0	11	
EXF-00-01 Exhaust					32	19	13	4	0	0	0	0	10	
EFX-B1-05 Exhaust					28	18	9	0	0	0	0	0	6	
AHU1 exhaust					8	15	3	0	0	0	0	0	0	
Total Free field Lp and dBA					52	44	42	31	28	25	23	18	37	

Source noise levels at receiver: 1st floor Chancery Court Hotel G													
Period:	Day time				Mid frequency octave bands (Hz)								
					63	125	250	500	1k	2k	4k	8k	dBA
Roof mounted pumps					57	47	40	34	31	30	30	32	40
EFX-B1-04 Exhaust					51	50	45	30	17	13	17	17	39
EXF-01-01 Exhaust					48	40	43	36	23	24	28	27	38
EXF-00-01 Exhaust					48	40	42	35	22	23	27	26	37
EXF-02-01 Exhaust					47	38	40	33	20	21	25	24	35
EXF-03-01 Exhaust					45	37	38	31	17	18	22	21	33
Roof mounted chiller					37	34	34	26	24	21	18	11	30
EXF-04-01 Exhaust					43	34	35	28	14	13	17	16	30
EFX-B1-01 Exhaust					36	31	37	20	8	9	7	9	29
EXF-05-01 Exhaust					42	33	33	26	10	8	12	11	28
EXF-06-01 Exhaust					40	31	31	24	8	6	10	9	26
EFX-B1-03 Exhaust					31	38	28	18	14	14	12	10	26
EFX-B1-02 Exhaust					34	38	22	14	2	1	2	1	23
EXF-07-01 Exhaust					39	29	28	21	3	0	3	2	23
EXF-08-01 Exhaust					38	28	27	20	2	0	2	1	22
EFX-B1-05 Exhaust					35	29	26	12	5	3	4	8	20
AHU1 exhaust					18	28	20	14	8	7	4	4	18
AHU1 fresh air inlet					4	10	0	0	0	0	0	0	0
AHU2 fresh air inlet					6	0	1	0	0	0	0	0	0
Total Free field Lp and dBA					60	53	50	42	33	33	35	35	46
Source noise levels at receiver: 2nd floor Chancery Court Hotel G													
Period:	Day time				Mid frequency octave bands (Hz)								
					63	125	250	500	1k	2k	4k	8k	dBA
Roof mounted pumps					57	47	40	34	31	30	30	32	40
EXF-01-01 Exhaust					48	40	43	36	23	24	28	27	38
EXF-02-01 Exhaust					48	40	43	36	23	24	28	27	38
EFX-B1-04 Exhaust					50	49	44	29	16	12	16	16	38
EXF-00-01 Exhaust					47	38	40	33	20	21	25	24	35
EXF-03-01 Exhaust					47	38	40	33	20	21	25	24	35
EXF-04-01 Exhaust					45	37	38	31	17	18	22	21	33
Roof mounted chiller					38	35	35	27	25	22	19	12	31
EXF-05-01 Exhaust					43	34	35	28	14	13	17	16	30
EFX-B1-01 Exhaust					35	30	36	19	7	8	6	8	28
EXF-06-01 Exhaust					42	33	33	26	10	8	12	11	28
EXF-07-01 Exhaust					40	31	31	24	8	6	10	9	26
EFX-B1-03 Exhaust					30	37	27	17	13	13	11	9	25
EXF-08-01 Exhaust					39	29	28	21	3	0	3	2	23
EFX-B1-02 Exhaust					33	37	21	13	1	0	1	0	22
EFX-B1-05 Exhaust					34	28	25	11	4	2	3	7	19
AHU1 exhaust					17	27	19	13	7	6	3	3	17
AHU1 fresh air inlet					3	9	0	0	0	0	0	0	0
AHU2 fresh air inlet					5	0	0	0	0	0	0	0	0
Total Free field Lp and dBA					60	53	51	43	34	33	35	35	47
Source noise levels at receiver: 3rd floor Chancery Court Hotel G													
Period:	Day time				Mid frequency octave bands (Hz)								
					63	125	250	500	1k	2k	4k	8k	dBA
Roof mounted pumps					58	48	41	35	32	31	31	33	41
EXF-03-01 Exhaust					48	40	43	36	23	24	28	27	38
EXF-02-01 Exhaust					48	40	43	36	23	24	28	27	38
EFX-B1-04 Exhaust					49	48	43	28	15	11	15	15	37
EXF-04-01 Exhaust					47	38	40	33	20	21	25	24	35
EXF-01-01 Exhaust					47	38	40	33	20	21	25	24	35
EXF-05-01 Exhaust					45	37	38	31	17	18	22	21	33
Roof mounted chiller					39	37	37	28	26	23	20	13	33
EXF-00-01 Exhaust					44	35	36	29	15	14	18	17	31
EXF-06-01 Exhaust					43	34	35	28	14	13	17	16	30
EXF-07-01 Exhaust					42	33	33	26	10	8	12	11	28
EFX-B1-01 Exhaust					34	29	35	18	6	7	5	7	27
EXF-08-01 Exhaust					40	31	31	24	8	6	10	9	26
EFX-B1-03 Exhaust					29	36	26	16	12	12	10	8	24
EFX-B1-02 Exhaust					32	36	20	12	0	0	0	0	21
EFX-B1-05 Exhaust					33	27	24	10	3	1	2	6	18
AHU1 exhaust					16	26	18	12	6	5	2	2	16
AHU1 fresh air inlet					3	9	0	0	0	0	0	0	0
AHU2 fresh air inlet					5	0	0	0	0	0	0	0	0
Total Free field Lp and dBA					60	53	51	43	34	34	36	36	47

Source noise levels at receiver: 4th floor Chancery Court Hotel G														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps					57	49	42	36	33	32	32	34	42	
EXF-03-01 Exhaust					48	40	43	36	23	24	28	27	38	
EXF-04-01 Exhaust					48	40	43	36	23	24	28	27	38	
EFX-B1-04 Exhaust					48	47	42	27	14	10	14	14	36	
EXF-02-01 Exhaust					47	38	40	33	20	21	25	24	35	
EXF-05-01 Exhaust					47	38	40	33	20	21	25	24	35	
EXF-01-01 Exhaust					45	37	38	31	17	18	22	21	33	
EXF-06-01 Exhaust					45	37	38	31	17	18	22	21	33	
Roof mounted chiller					40	37	37	28	26	23	20	13	33	
EXF-00-01 Exhaust					43	34	35	28	14	13	17	16	30	
EXF-07-01 Exhaust					43	34	35	28	14	13	17	16	30	
EXF-08-01 Exhaust					42	33	33	26	10	8	12	11	28	
EFX-B1-01 Exhaust					33	28	34	17	5	6	4	6	26	
EFX-B1-03 Exhaust					28	35	25	15	11	11	9	7	23	
EFX-B1-02 Exhaust					31	35	19	11	0	0	0	0	20	
EFX-B1-05 Exhaust					32	26	23	9	2	0	1	5	17	
AHU1 exhaust					15	25	17	11	5	4	1	1	15	
AHU1 fresh air inlet					2	8	0	0	0	0	0	0	0	
AHU2 fresh air inlet					4	0	0	0	0	0	0	0	0	
Total Free field Lp and dBA					60	53	51	43	35	34	36	36	47	
Source noise levels at receiver: 5th floor Chancery Court Hotel G														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps					56	47	43	37	34	33	33	35	42	
EXF-05-01 Exhaust					48	40	43	36	23	24	28	27	38	
EXF-04-01 Exhaust					48	40	43	36	23	24	28	27	38	
EXF-03-01 Exhaust					47	38	40	33	20	21	25	24	35	
EXF-06-01 Exhaust					47	38	40	33	20	21	25	24	35	
EFX-B1-04 Exhaust					47	46	41	26	13	9	13	13	35	
Roof mounted chiller					42	39	39	29	27	24	21	14	34	
EXF-02-01 Exhaust					45	37	38	31	17	18	22	21	33	
EXF-07-01 Exhaust					45	37	38	31	17	18	22	21	33	
EXF-08-01 Exhaust					43	34	35	28	14	13	17	16	30	
EXF-01-01 Exhaust					43	34	35	28	14	13	17	16	30	
EXF-00-01 Exhaust					41	32	32	25	9	7	11	10	27	
EFX-B1-01 Exhaust					32	27	33	16	4	5	3	5	25	
EFX-B1-03 Exhaust					27	34	24	14	10	10	8	6	22	
EFX-B1-02 Exhaust					30	34	18	10	0	0	0	0	19	
EFX-B1-05 Exhaust					31	25	22	8	1	0	0	4	16	
AHU1 exhaust					14	24	16	10	4	3	0	0	13	
AHU1 fresh air inlet					2	8	0	0	0	0	0	0	0	
AHU2 fresh air inlet					4	0	0	0	0	0	0	0	0	
Total Free field Lp and dBA					59	52	51	43	36	35	37	37	47	
Source noise levels at receiver: 6th floor Chancery Court Hotel G														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps					60	50	43	37	34	33	33	35	43	
EXF-05-01 Exhaust					48	40	43	36	23	24	28	27	38	
EXF-06-01 Exhaust					48	40	43	36	23	24	28	27	38	
Roof mounted chiller					43	40	41	31	27	24	21	14	35	
EXF-07-01 Exhaust					47	38	40	33	20	21	25	24	35	
EXF-04-01 Exhaust					47	38	40	33	20	21	25	24	35	
EXF-08-01 Exhaust					45	37	38	31	17	18	22	21	33	
EXF-03-01 Exhaust					45	37	38	31	17	18	22	21	33	
EFX-B1-04 Exhaust					46	44	39	22	8	4	8	8	33	
EXF-02-01 Exhaust					43	34	35	28	14	13	17	16	30	
EXF-01-01 Exhaust					41	32	32	25	9	7	11	10	27	
EXF-00-01 Exhaust					40	31	31	24	8	6	10	9	26	
EFX-B1-01 Exhaust					31	26	31	14	0	0	0	0	23	
EFX-B1-03 Exhaust					26	33	22	12	6	5	3	1	20	
EFX-B1-02 Exhaust					29	33	16	8	0	0	0	0	18	
EFX-B1-05 Exhaust					30	24	20	6	0	0	0	0	14	
AHU1 exhaust					13	22	14	6	0	0	0	0	10	
AHU1 fresh air inlet					1	7	0	0	0	0	0	0	0	
AHU2 fresh air inlet					3	0	0	0	0	0	0	0	0	
Total Free field Lp and dBA					61	53	51	43	36	35	36	37	47	

Source noise levels at receiver: 7th floor Chancery Court Hotel G														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps					60	50	43	37	34	33	33	35	43	
EXF-06-01 Exhaust					48	40	43	36	23	24	28	27	38	
EXF-07-01 Exhaust					48	40	43	36	23	24	28	27	38	
Roof mounted chiller					45	42	43	33	28	24	21	14	37	
EXF-05-01 Exhaust					47	38	40	33	20	21	25	24	35	
EXF-08-01 Exhaust					47	38	40	33	20	21	25	24	35	
EXF-04-01 Exhaust					45	37	38	31	17	18	22	21	33	
EFX-B1-04 Exhaust					46	44	39	22	8	4	8	8	33	
EXF-03-01 Exhaust					43	34	35	28	14	13	17	16	30	
EXF-02-01 Exhaust					41	32	32	25	9	7	11	10	27	
EXF-01-01 Exhaust					40	31	31	24	8	6	10	9	26	
EXF-00-01 Exhaust					39	29	28	21	3	0	3	2	23	
EFX-B1-01 Exhaust					31	26	31	14	0	0	0	0	23	
EFX-B1-03 Exhaust					26	33	22	12	6	5	3	1	20	
EFX-B1-02 Exhaust					29	33	16	8	0	0	0	0	18	
EFX-B1-05 Exhaust					30	24	20	6	0	0	0	0	14	
AHU1 exhaust					13	22	14	6	0	0	0	0	10	
AHU1 fresh air inlet					0	6	0	0	0	0	0	0	0	
AHU2 fresh air inlet					2	0	0	0	0	0	0	0	0	
Total Free field Lp and dBA					61	53	51	43	36	35	36	37	47	
Source noise levels at receiver: 8th floor Chancery Court Hotel G														
Period:	Day time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps					60	50	43	37	34	33	33	35	43	
Roof mounted chiller					47	46	47	38	34	28	22	14	41	
EXF-08-01 Exhaust					48	40	43	36	23	24	28	27	38	
EXF-07-01 Exhaust					48	40	42	35	22	23	27	26	37	
EXF-06-01 Exhaust					47	38	40	33	20	21	25	24	35	
EFX-B1-04 Exhaust					45	43	38	21	7	3	7	7	32	
EXF-05-01 Exhaust					44	35	36	29	15	14	18	17	31	
EXF-04-01 Exhaust					43	34	35	28	14	13	17	16	30	
EXF-03-01 Exhaust					41	32	32	25	9	7	11	10	27	
EXF-02-01 Exhaust					40	30	29	22	4	0	4	3	24	
EXF-01-01 Exhaust					39	29	28	21	3	0	3	2	23	
EFX-B1-01 Exhaust					30	25	30	13	0	0	0	0	22	
EXF-00-01 Exhaust					37	27	26	19	1	0	1	0	21	
EFX-B1-03 Exhaust					25	32	21	11	5	4	2	0	19	
EFX-B1-02 Exhaust					28	32	15	7	0	0	0	0	17	
EFX-B1-05 Exhaust					29	23	19	5	0	0	0	0	13	
AHU1 exhaust					12	21	13	5	0	0	0	0	9	
AHU1 fresh air inlet					0	6	0	0	0	0	0	0	0	
AHU2 fresh air inlet					2	0	0	0	0	0	0	0	0	
Total Free field Lp and dBA					61	53	51	44	37	35	36	36	47	

APPENDIX E

CALCULATIONS –SUMMARY (2000-2200 HOURS)

Overall receptor listings														
Period:	Night-time					Mid frequency octave bands (Hz)								
					63	125	250	500	1k	2k	4k	8k	dBA	
Top floor Chancery Court Hotel F					64	55	55	48	46	43	41	39	52	
8th floor Chancery Court Hotel G					61	52	50	43	36	35	36	36	47	
6th floor Chancery Court Hotel G					61	52	50	43	35	35	36	37	47	
7th floor Chancery Court Hotel G					61	52	50	43	35	35	36	37	47	
Top floor Chancery Court Hotel E					61	52	51	43	38	34	30	26	46	
5th floor Chancery Court Hotel G					59	50	50	43	35	35	36	37	46	
4th floor Chancery Court Hotel G					59	51	50	43	35	34	36	36	46	
3rd floor Chancery Court Hotel G					60	51	50	43	34	33	35	36	46	
2nd floor Chancery Court Hotel G					59	50	50	42	33	33	35	35	46	
1st floor Chancery Court Hotel G					59	50	49	42	33	32	34	35	45	
1st floor Chancery Court Hotel F					58	51	48	40	33	32	33	34	44	
Top floor Chancery Court Hotel D					59	50	48	39	34	29	24	21	43	
Top floor Chancery Court Hotel C					57	48	47	38	32	27	22	18	42	
1st floor Chancery Court Hotel E					53	48	46	37	27	27	27	26	41	
Top floor Chancery Court Hotel B					55	46	45	36	31	25	20	15	40	
Top floor Chancery Court Hotel A					54	45	43	34	29	24	18	14	38	
1st floor Chancery Court Hotel					51	46	43	34	24	23	23	22	38	
268-270 High Holborn to rear grd floor					47	45	39	32	26	25	22	19	36	
1st floor Chancery Court Hotel C					51	44	41	31	22	20	19	17	36	
1st floor Chancery Court Hotel					49	43	39	30	21	19	17	14	34	
268-270 High Holborn to rear 4th floor					50	41	38	28	25	23	20	17	34	
268-270 High Holborn to rear 5th floor					51	41	38	28	24	22	19	16	34	
1st floor Chancery Court Hotel A					48	41	37	29	20	17	15	12	32	

Source noise levels at receiver: Top floor Chancery Court Hotel F															
Period:	Night-time				Mid frequency octave bands (Hz)										
					63	125	250	500	1k	2k	4k	8k	dBA		
Roof mounted chiller					51	51	54	47	45	42	39	32	51		
Roof mounted pumps					63	53	46	40	37	36	36	38	46		
EXF-08-01 Exhaust					45	37	38	31	17	18	22	21	33		
EXF-07-01 Exhaust					45	37	38	31	17	18	22	21	33		
EXF-06-01 Exhaust					44	36	37	30	16	17	21	20	32		
EXF-05-01 Exhaust					43	35	36	29	15	16	20	19	31		
EXF-04-01 Exhaust					42	33	34	27	13	12	16	15	29		
EXF-03-01 Exhaust					41	32	33	26	12	11	15	14	28		
EXF-02-01 Exhaust					40	31	31	24	8	6	10	9	26		
EXF-01-01 Exhaust					39	30	30	23	7	5	9	8	25		
EXF-00-01 Exhaust					37	27	26	19	1	0	1	0	21		
EFX-B1-01 Exhaust					30	24	28	11	0	0	0	0	20		
EFX-B1-03 Exhaust					25	31	19	9	1	0	0	0	17		
EFX-B1-02 Exhaust					28	31	13	5	0	0	0	0	16		
EFX-B1-05 Exhaust					29	22	17	3	0	0	0	0	11		
AHU1 exhaust					11	22	11	1	0	0	0	0	8		
AHU1 fresh air inlet					1	8	0	0	0	0	0	0	0		
AHU2 fresh air inlet					3	0	0	0	0	0	0	0	0		
Total Free field Lp and dBA					64	55	55	48	46	43	41	39	52		
Source noise levels at receiver: Top floor Chancery Court Hotel E															
Period:	Night-time				Mid frequency octave bands (Hz)										
					63	125	250	500	1k	2k	4k	8k	dBA		
Roof mounted chiller					49	48	50	42	38	33	27	17	45		
Roof mounted pumps					60	49	40	32	27	24	21	20	39		
EXF-08-01 Exhaust					43	34	35	28	14	13	17	16	30		
EXF-07-01 Exhaust					43	34	35	28	14	13	17	16	30		
EXF-06-01 Exhaust					42	33	34	27	13	12	16	15	29		
EXF-05-01 Exhaust					41	32	33	26	12	11	15	14	28		
EXF-04-01 Exhaust					41	32	33	26	12	11	15	14	28		
EXF-03-01 Exhaust					40	31	32	25	11	10	14	13	27		
EXF-02-01 Exhaust					39	30	31	24	10	9	13	12	26		
EXF-01-01 Exhaust					38	29	30	23	9	8	12	11	25		
EXF-00-01 Exhaust					37	28	28	21	5	3	7	6	23		
EFX-B1-01 Exhaust					30	24	28	11	0	0	0	0	20		
EFX-B1-03 Exhaust					25	31	19	9	1	0	0	0	17		
EFX-B1-02 Exhaust					28	31	13	5	0	0	0	0	16		
EFX-B1-05 Exhaust					29	22	17	3	0	0	0	0	11		
AHU1 exhaust					11	22	11	1	0	0	0	0	8		
AHU1 fresh air inlet					5	12	0	0	0	0	0	0	0		
AHU2 fresh air inlet					7	2	4	0	0	0	0	0	0		
Total Free field Lp and dBA					61	52	51	43	38	34	30	26	46		
Source noise levels at receiver: Top floor Chancery Court Hotel D															
Period:	Night-time				Mid frequency octave bands (Hz)										
					63	125	250	500	1k	2k	4k	8k	dBA		
Roof mounted chiller					47	46	47	38	34	28	22	12	41		
Roof mounted pumps					58	46	37	29	23	19	16	18	36		
EXF-08-01 Exhaust					40	31	31	24	8	6	10	9	26		
EXF-07-01 Exhaust					40	31	31	24	8	6	10	9	26		
EXF-06-01 Exhaust					40	31	31	24	8	6	10	9	26		
EXF-05-01 Exhaust					40	31	31	24	8	6	10	9	26		
EXF-04-01 Exhaust					39	30	30	23	7	5	9	8	25		
EXF-03-01 Exhaust					38	29	29	22	6	4	8	7	24		
EXF-02-01 Exhaust					38	29	29	22	6	4	8	7	24		
EXF-01-01 Exhaust					37	28	28	21	5	3	7	6	23		
EXF-00-01 Exhaust					36	27	27	20	4	2	6	5	22		
EFX-B1-01 Exhaust					30	24	28	11	0	0	0	0	20		
EFX-B1-03 Exhaust					25	31	19	9	1	0	0	0	17		
EFX-B1-02 Exhaust					28	31	13	5	0	0	0	0	16		
EFX-B1-05 Exhaust					29	22	17	3	0	0	0	0	11		
AHU1 exhaust					11	22	11	1	0	0	0	0	8		
AHU1 fresh air inlet					6	15	2	0	0	0	0	0	0		
AHU2 fresh air inlet					8	5	9	1	0	0	0	0	0		
Total Free field Lp and dBA					59	50	48	39	34	29	24	21	43		

Source noise levels at receiver: Top floor Chancery Court Hotel C														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted chiller					45	44	46	37	32	27	21	11	40	
Roof mounted pumps					56	44	35	26	20	16	14	16	34	
EXF-08-01 Exhaust					39	29	28	21	3	0	3	2	23	
EXF-07-01 Exhaust					39	29	28	21	3	0	3	2	23	
EXF-06-01 Exhaust					38	28	27	20	2	0	2	1	22	
EXF-05-01 Exhaust					38	28	27	20	2	0	2	1	22	
EXF-04-01 Exhaust					38	28	27	20	2	0	2	1	22	
EFX-B1-01 Exhaust					30	25	30	13	0	0	0	0	22	
EXF-02-01 Exhaust					37	27	26	19	1	0	1	0	21	
EXF-03-01 Exhausr					37	27	26	19	1	0	1	0	21	
EXF-01-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-00-01 Exhaust					35	25	24	17	0	0	0	0	19	
EFX-B1-03 Exhaust					25	32	21	11	5	4	2	0	19	
EFX-B1-02 Exhaust					28	32	15	7	0	0	0	0	17	
EFX-B1-05 Exhaust					29	23	19	5	0	0	0	0	13	
AHU2 fresh air inlet					11	10	17	9	0	0	0	0	11	
AHU1 exhaust					12	21	13	5	0	0	0	0	9	
AHU1 fresh air inlet					14	23	9	0	0	0	0	0	8	
Total Free field Lp and dBA					57	48	47	38	32	27	22	18	42	
Source noise levels at receiver: Top floor Chancery Court Hotel B														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted chiller					43	42	44	35	31	25	19	9	38	
Roof mounted pumps					54	42	32	24	18	14	12	14	32	
EXF-08-01 Exhaust					37	27	26	19	1	0	1	0	21	
EXF-07-01 Exhaust					37	27	26	19	1	0	1	0	21	
EXF-06-01 Exhaust					37	27	26	19	1	0	1	0	21	
EXF-05-01 Exhaust					37	27	26	19	1	0	1	0	21	
EFX-B1-01 Exhaust					29	24	29	12	0	0	0	0	21	
EXF-04-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-02-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-03-01 Exhausr					36	26	25	18	0	0	0	0	20	
EXF-01-01 Exhaust					35	25	24	17	0	0	0	0	19	
EXF-00-01 Exhaust					34	24	23	16	0	0	0	0	18	
EFX-B1-03 Exhaust					24	31	20	10	4	3	1	0	18	
EFX-B1-02 Exhaust					27	31	14	6	0	0	0	0	16	
EFX-B1-05 Exhaust					28	22	18	4	0	0	0	0	12	
AHU2 fresh air inlet					10	10	15	10	0	0	0	0	10	
AHU1 fresh air inlet					12	24	12	0	0	0	0	0	10	
AHU1 exhaust					11	20	12	4	0	0	0	0	8	
Total Free field Lp and dBA					55	46	45	36	31	25	20	15	40	
Source noise levels at receiver: Top floor Chancery Court Hotel A														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted chiller					42	41	42	33	29	23	17	8	36	
Roof mounted pumps					53	41	32	23	17	14	11	13	31	
EXF-08-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-07-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-06-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-05-01 Exhaust					35	25	24	17	0	0	0	0	19	
EXF-02-01 Exhaust					35	25	24	17	0	0	0	0	19	
EXF-04-01 Exhaust					35	25	24	17	0	0	0	0	19	
EXF-03-01 Exhausr					35	25	24	17	0	0	0	0	19	
EFX-B1-01 Exhaust					28	22	26	9	0	0	0	0	18	
EXF-01-01 Exhaust					34	24	23	16	0	0	0	0	18	
EXF-00-01 Exhaust					34	24	23	16	0	0	0	0	18	
EFX-B1-03 Exhaust					23	29	17	7	0	0	0	0	15	
EFX-B1-02 Exhaust					26	29	11	3	0	0	0	0	14	
AHU2 fresh air inlet					10	10	16	11	2	1	0	0	12	
AHU1 fresh air inlet					13	25	15	3	0	0	0	0	11	
EFX-B1-05 Exhaust					27	20	15	1	0	0	0	0	9	
AHU1 exhaust					9	20	9	0	0	0	0	0	5	
Total Free field Lp and dBA					54	45	43	34	29	24	18	14	38	

Source noise levels at receiver: 1st floor Chancery Court Hotel F										
Period:	Night-time					Mid frequency octave bands (Hz)				
						63	125	250	500	1k 2k 4k 8k dBA
Roof mounted pumps						57	47	40	34	31 30 30 32 40
Roof mounted chiller						41	40	41	32	27 21 15 8 35
EXF-00-01 Exhaust						45	37	38	31	17 18 22 21 33
EXF-01-01 Exhaust						45	37	38	31	17 18 22 21 33
EFX-B1-01 Exhaust						39	34	41	24	13 16 14 16 33
EXF-02-01 Exhaust						44	36	37	30	16 17 21 20 32
EXF-03-01 Exhaust						43	35	36	29	15 16 20 19 31
EXF-04-01 Exhaust						42	34	35	28	14 15 19 18 30
EFX-B1-03 Exhaust						34	41	32	22	19 21 19 17 30
EXF-05-01 Exhaust						41	32	33	26	12 11 15 14 28
EFX-B1-02 Exhaust						37	41	26	18	7 8 9 8 26
EXF-06-01 Exhaust						40	31	31	24	8 6 10 9 26
EXF-07-01 Exhaust						39	30	30	23	7 5 9 8 25
EFX-B1-05 Exhaust						38	32	30	16	10 10 11 15 24
EXF-08-01 Exhaust						38	29	29	22	6 4 8 7 24
AHU1 exhaust						21	32	24	19	15 14 11 11 23
AHU2 fresh air inlet						9	4	5	0	0 0 0 0 0
AHU1 fresh air inlet						7	14	0	0	0 0 0 0 0
Total Free field Lp and dBA						58	51	48	40	33 32 33 34 44
Source noise levels at receiver: 1st floor Chancery Court Hotel E										
Period:	Night-time					Mid frequency octave bands (Hz)				
						63	125	250	500	1k 2k 4k 8k dBA
EFX-B1-01 Exhaust						40	35	42	25	14 17 15 17 34
EFX-B1-03 Exhaust						35	42	33	23	20 22 20 18 31
EXF-00-01 Exhaust						43	34	35	28	14 13 17 16 30
EXF-01-01 Exhaust						43	34	35	28	14 13 17 16 30
EXF-03-01 Exhaust						42	33	34	27	13 12 16 15 29
EXF-02-01 Exhaust						42	33	34	27	13 12 16 15 29
Roof mounted chiller						35	33	33	23	21 18 15 8 28
EXF-04-01 Exhaust						41	32	33	26	12 11 15 14 28
EFX-B1-02 Exhaust						38	42	27	19	8 9 10 9 27
EXF-05-01 Exhaust						40	31	32	25	11 10 14 13 27
EXF-06-01 Exhaust						39	30	31	24	10 9 13 12 26
EFX-B1-05 Exhaust						39	33	31	17	11 11 12 16 25
Roof mounted pumps						47	35	25	16	12 11 11 13 25
EXF-07-01 Exhaust						38	29	30	23	9 8 12 11 25
AHU1 exhaust						22	33	25	20	16 15 12 12 24
EXF-08-01 Exhaust						37	28	28	21	5 3 7 6 23
AHU1 fresh air inlet						10	18	3	0	0 0 0 0 4
AHU2 fresh air inlet						12	8	10	0	0 0 0 0 4
Total Free field Lp and dBA						53	48	46	37	27 27 27 26 41
Source noise levels at receiver: 1st floor Chancery Court Hotel C										
Period:	Night-time					Mid frequency octave bands (Hz)				
						63	125	250	500	1k 2k 4k 8k dBA
EFX-B1-01 Exhaust						36	31	37	20	8 9 7 9 29
Roof mounted chiller						35	32	32	22	20 17 14 7 27
EFX-B1-03 Exhaust						31	38	28	18	14 14 12 10 26
Roof mounted pumps						47	35	25	16	11 10 10 12 25
EFX-B1-02 Exhaust						34	38	22	14	2 1 2 1 23
EXF-01-01 Exhaust						39	29	28	21	3 0 3 2 23
EXF-02-01 Exhaust						38	28	27	20	2 0 2 1 22
EXF-04-01 Exhaust						38	28	27	20	2 0 2 1 22
EXF-03-01 Exhaust						38	28	27	20	2 0 2 1 22
EXF-00-01 Exhaust						38	28	27	20	2 0 2 1 22
EXF-05-01 Exhaust						37	27	26	19	1 0 1 0 21
EXF-06-01 Exhaust						37	27	26	19	1 0 1 0 21
EFX-B1-05 Exhaust						35	29	26	12	5 3 4 8 20
EXF-07-01 Exhaust						36	26	25	18	0 0 0 0 20
EXF-08-01 Exhaust						35	25	24	17	0 0 0 0 19
AHU1 exhaust						18	28	20	14	8 7 4 4 18
AHU2 fresh air inlet						17	16	23	15	2 0 0 0 16
AHU1 fresh air inlet						20	29	15	0	0 0 0 0 14
Total Free field Lp and dBA						51	44	41	31	22 20 19 17 36

Source noise levels at receiver: 1st floor Chancery Court Hotel A															
Period:	Night-time				Mid frequency octave bands (Hz)										
					63	125	250	500	1k	2k	4k	8k	dBA		
Roof mounted chiller					34	31	32	22	19	16	13	6	27		
Roof mounted pumps					45	33	23	14	9	8	8	10	23		
EFX-B1-01 Exhaust					32	26	30	13	0	0	0	0	22		
EXF-00-01 Exhaust					36	26	25	18	0	0	0	0	20		
EXF-02-01 Exhaust					36	26	25	18	0	0	0	0	20		
EXF-01-01 Exhaust					36	26	25	18	0	0	0	0	20		
EFX-B1-03 Exhaust					27	33	21	11	3	0	0	0	19		
EXF-04-01 Exhaust					35	25	24	17	0	0	0	0	19		
EXF-03-01 Exhaust					35	25	24	17	0	0	0	0	19		
EXF-06-01 Exhaust					35	25	24	17	0	0	0	0	19		
EXF-05-01 Exhaust					35	25	24	17	0	0	0	0	19		
EFX-B1-02 Exhaust					30	33	15	7	0	0	0	0	18		
EXF-08-01 Exhaust					34	24	23	16	0	0	0	0	18		
EXF-07-01 Exhaust					34	24	23	16	0	0	0	0	18		
AHU2 fresh air inlet					14	15	21	16	7	8	5	2	17		
AHU1 fresh air inlet					18	30	20	10	5	2	0	0	17		
EFX-B1-05 Exhaust					31	24	19	5	0	0	0	0	13		
AHU1 exhaust					13	24	13	3	0	0	0	0	10		
Total Free field Lp and dBA					48	41	37	29	20	17	15	12	32		
Source noise levels at receiver: 1st floor Chancery Court Hotel															
Period:	Night-time				Mid frequency octave bands (Hz)										
					63	125	250	500	1k	2k	4k	8k	dBA		
EFX-B1-01 Exhaust					37	33	39	22	10	13	11	13	31		
Roof mounted chiller					36	33	33	23	21	18	15	8	28		
EFX-B1-03 Exhaust					32	40	30	20	16	18	16	14	28		
EXF-00-01 Exhaust					40	31	31	24	8	6	10	9	26		
EXF-02-01 Exhaust					40	31	31	24	8	6	10	9	26		
EXF-01-01 Exhaust					40	31	31	24	8	6	10	9	26		
EXF-03-01 Exhaust					40	31	31	24	8	6	10	9	26		
EFX-B1-02 Exhaust					35	40	24	16	4	5	6	5	25		
EXF-04-01 Exhaust					39	30	30	23	7	5	9	8	25		
Roof mounted pumps					47	34	24	15	11	10	10	12	25		
EXF-05-01 Exhaust					38	29	29	22	6	4	8	7	24		
EXF-06-01 Exhaust					38	29	29	22	6	4	8	7	24		
EXF-07-01 Exhaust					37	28	28	21	5	3	7	6	23		
EFX-B1-05 Exhaust					36	31	28	14	7	7	8	12	22		
EXF-08-01 Exhaust					36	27	27	20	4	2	6	5	22		
AHU1 exhaust					20	30	22	16	12	11	8	8	20		
AHU2 fresh air inlet					14	11	15	7	0	0	0	0	9		
AHU1 fresh air inlet					12	21	8	0	0	0	0	0	6		
Total Free field Lp and dBA					51	46	43	34	24	23	23	22	38		
Source noise levels at receiver: 1st floor Chancery Court Hotel															
Period:	Night-time				Mid frequency octave bands (Hz)										
					63	125	250	500	1k	2k	4k	8k	dBA		
Roof mounted chiller					35	32	32	22	20	17	14	7	27		
EFX-B1-01 Exhaust					34	29	34	17	3	3	1	3	26		
Roof mounted pumps					46	34	24	15	10	9	9	11	24		
EFX-B1-03 Exhaust					29	36	25	15	9	8	6	4	23		
EFX-B1-02 Exhaust					32	36	19	11	0	0	0	0	21		
EXF-00-01 Exhaust					37	27	26	19	1	0	1	0	21		
EXF-03-01 Exhaust					37	27	26	19	1	0	1	0	21		
EXF-01-01 Exhaust					37	27	26	19	1	0	1	0	21		
EXF-02-01 Exhaust					37	27	26	19	1	0	1	0	21		
EXF-04-01 Exhaust					36	26	25	18	0	0	0	0	20		
EXF-05-01 Exhaust					36	26	25	18	0	0	0	0	20		
EXF-06-01 Exhaust					36	26	25	18	0	0	0	0	20		
EXF-07-01 Exhaust					35	25	24	17	0	0	0	0	19		
EXF-08-01 Exhaust					35	25	24	17	0	0	0	0	19		
AHU2 fresh air inlet					16	16	22	17	8	7	4	1	18		
AHU1 fresh air inlet					19	31	21	9	4	1	0	0	18		
EFX-B1-05 Exhaust					33	27	23	9	0	0	0	2	17		
AHU1 exhaust					16	25	17	9	2	1	0	0	14		
Total Free field Lp and dBA					49	43	39	30	21	19	17	14	38		

Source noise levels at receiver: 268-270 High Holborn to rear grd floor														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
AHU2 fresh air inlet					26	27	34	30	22	23	20	17	31	
AHU1 fresh air inlet					31	44	35	25	20	17	15	10	31	
Roof mounted chiller					34	31	31	22	20	17	14	7	27	
Roof mounted pumps					44	31	21	13	10	9	9	11	22	
EFX-B1-01 Exhaust					32	23	22	2	0	0	0	0	15	
EFX-B1-03 Exhaust					27	30	13	0	0	0	0	0	15	
EFX-B1-02 Exhaust					30	30	7	0	0	0	0	0	15	
EXF-02-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-00-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-01-01 Exhaust					33	19	13	3	0	0	0	0	10	
EFX-B1-05 Exhaust					31	21	11	0	0	0	0	0	9	
EXF-03-01 Exhaust					32	18	12	2	0	0	0	0	9	
EXF-04-01 Exhaust					32	18	12	2	0	0	0	0	9	
EXF-05-01 Exhaust					31	17	11	1	0	0	0	0	8	
EXF-07-01 Exhaust					30	16	10	0	0	0	0	0	7	
EXF-06-01 Exhaust					30	16	10	0	0	0	0	0	7	
EXF-08-01 Exhaust					29	15	9	0	0	0	0	0	5	
AHU1 exhaust					11	18	5	0	0	0	0	0	4	
Total Free field Lp and dBA					47	45	39	32	26	25	22	19	36	
Source noise levels at receiver: 268-270 High Holborn to rear 4th floor														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted chiller					39	37	37	27	25	22	19	12	32	
Roof mounted pumps					49	37	27	18	15	14	14	16	27	
AHU2 fresh air inlet					16	15	22	14	1	0	0	0	15	
AHU1 fresh air inlet					19	28	14	0	0	0	0	0	13	
EXF-03-01 Exhaust					34	20	14	4	0	0	0	0	12	
EXF-04-01 Exhaust					34	20	14	4	0	0	0	0	12	
EFX-B1-01 Exhaust					28	19	18	0	0	0	0	0	11	
EFX-B1-03 Exhaust					23	26	9	0	0	0	0	0	10	
EFX-B1-02 Exhaust					26	26	3	0	0	0	0	0	10	
EXF-00-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-06-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-01-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-02-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-05-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-07-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-08-01 Exhaust					33	19	12	3	0	0	0	0	10	
EFX-B1-05 Exhaust					27	17	7	0	0	0	0	0	5	
AHU1 exhaust					7	14	1	0	0	0	0	0	0	
Total Free field Lp and dBA					50	41	38	28	25	23	20	17	34	
Source noise levels at receiver: 268-270 High Holborn to rear 5th floor														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted chiller					40	37	37	27	24	21	18	11	32	
Roof mounted pumps					50	37	27	18	14	13	13	15	28	
AHU2 fresh air inlet					14	14	19	14	3	1	0	0	14	
AHU1 fresh air inlet					16	28	16	3	0	0	0	0	13	
EFX-B1-01 Exhaust					29	20	20	1	0	0	0	0	13	
EXF-08-01 Exhaust					34	21	15	6	0	0	0	0	12	
EXF-07-01 Exhaust					34	21	15	6	0	0	0	0	12	
EXF-06-01 Exhaust					34	20	15	6	0	0	0	0	12	
EXF-02-01 Exhaust					34	20	15	5	0	0	0	0	12	
EXF-03-01 Exhaust					34	20	15	5	0	0	0	0	12	
EXF-05-01 Exhaust					34	20	15	5	0	0	0	0	12	
EXF-04-01 Exhaust					34	20	15	5	0	0	0	0	12	
EFX-B1-03 Exhaust					24	27	11	0	0	0	0	0	12	
EFX-B1-02 Exhaust					27	27	5	0	0	0	0	0	12	
EXF-01-01 Exhaust					33	20	14	5	0	0	0	0	11	
EXF-00-01 Exhaust					32	19	13	4	0	0	0	0	10	
EFX-B1-05 Exhaust					28	18	9	0	0	0	0	0	6	
AHU1 exhaust					8	15	3	0	0	0	0	0	0	
Total Free field Lp and dBA					51	41	38	28	24	22	19	16	34	

Source noise levels at receiver: 1st floor Chancery Court Hotel G										
Period:	Night-time					Mid frequency octave bands (Hz)				
						63	125	250	500	1k 2k 4k 8k dBA
Roof mounted pumps						57	47	40	34	31 30 30 32 40
EXF-01-01 Exhaust						48	40	43	36	23 24 28 27 38
EXF-00-01 Exhaust						48	40	42	35	22 23 27 26 37
EXF-02-01 Exhaust						47	38	40	33	20 21 25 24 35
EXF-03-01 Exhaust						45	37	38	31	17 18 22 21 33
EXF-04-01 Exhaust						43	34	35	28	14 13 17 16 30
EFX-B1-01 Exhaust						36	31	37	20	8 9 7 9 29
EXF-05-01 Exhaust						42	33	33	26	10 8 12 11 28
Roof mounted chiller						33	30	30	22	20 17 14 7 26
EXF-06-01 Exhaust						40	31	31	24	8 6 10 9 26
EFX-B1-03 Exhaust						31	38	28	18	14 14 12 10 26
EFX-B1-02 Exhaust						34	38	22	14	2 1 2 1 23
EXF-07-01 Exhaust						39	29	28	21	3 0 3 2 23
EXF-08-01 Exhaust						38	28	27	20	2 0 2 1 22
EFX-B1-05 Exhaust						35	29	26	12	5 3 4 8 20
AHU1 exhaust						18	28	20	14	8 7 4 4 18
AHU1 fresh air inlet						4	10	0	0	0 0 0 0 0
AHU2 fresh air inlet						6	0	1	0	0 0 0 0 0
Total Free field Lp and dBA						59	50	49	42	33 32 34 35 45
Source noise levels at receiver: 2nd floor Chancery Court Hotel G										
Period:	Night-time					Mid frequency octave bands (Hz)				
						63	125	250	500	1k 2k 4k 8k dBA
Roof mounted pumps						57	47	40	34	31 30 30 32 40
EXF-01-01 Exhaust						48	40	43	36	23 24 28 27 38
EXF-02-01 Exhaust						48	40	43	36	23 24 28 27 38
EXF-00-01 Exhaust						47	38	40	33	20 21 25 24 35
EXF-03-01 Exhaust						47	38	40	33	20 21 25 24 35
EXF-04-01 Exhaust						45	37	38	31	17 18 22 21 33
EXF-05-01 Exhaust						43	34	35	28	14 13 17 16 30
EFX-B1-01 Exhaust						35	30	36	19	7 8 6 8 28
EXF-06-01 Exhaust						42	33	33	26	10 8 12 11 28
Roof mounted chiller						34	31	31	23	21 18 15 8 27
EXF-07-01 Exhaust						40	31	31	24	8 6 10 9 26
EFX-B1-03 Exhaust						30	37	27	17	13 13 11 9 25
EXF-08-01 Exhaust						39	29	28	21	3 0 3 2 23
EFX-B1-02 Exhaust						33	37	21	13	1 0 1 0 22
EFX-B1-05 Exhaust						34	28	25	11	4 2 3 7 19
AHU1 exhaust						17	27	19	13	7 6 3 3 17
AHU1 fresh air inlet						3	9	0	0	0 0 0 0 0
AHU2 fresh air inlet						5	0	0	0	0 0 0 0 0
Total Free field Lp and dBA						59	50	50	42	33 33 35 35 46
Source noise levels at receiver: 3rd floor Chancery Court Hotel G										
Period:	Night-time					Mid frequency octave bands (Hz)				
						63	125	250	500	1k 2k 4k 8k dBA
Roof mounted pumps						58	48	41	35	32 31 31 33 41
EXF-02-01 Exhaust						48	40	43	36	23 24 28 27 38
EXF-03-01 Exhaust						48	40	43	36	23 24 28 27 38
EXF-01-01 Exhaust						47	38	40	33	20 21 25 24 35
EXF-04-01 Exhaust						47	38	40	33	20 21 25 24 35
EXF-05-01 Exhaust						45	37	38	31	17 18 22 21 33
EXF-00-01 Exhaust						44	35	36	29	15 14 18 17 31
EXF-06-01 Exhaust						43	34	35	28	14 13 17 16 30
Roof mounted chiller						35	33	33	24	22 19 16 9 29
EXF-07-01 Exhaust						42	33	33	26	10 8 12 11 28
EFX-B1-01 Exhaust						34	29	35	18	6 7 5 7 27
EXF-08-01 Exhaust						40	31	31	24	8 6 10 9 26
EFX-B1-03 Exhaust						29	36	26	16	12 12 10 8 24
EFX-B1-02 Exhaust						32	36	20	12	0 0 0 0 21
EFX-B1-05 Exhaust						33	27	24	10	3 1 2 6 18
AHU1 exhaust						16	26	18	12	6 5 2 2 16
AHU1 fresh air inlet						3	9	0	0	0 0 0 0 0
AHU2 fresh air inlet						5	0	0	0	0 0 0 0 0
Total Free field Lp and dBA						60	51	50	43	34 33 35 36 46

Source noise levels at receiver: 4th floor Chancery Court Hotel G													
Period:	Night-time				Mid frequency octave bands (Hz)								
					63	125	250	500	1k	2k	4k	8k	dBA
Roof mounted pumps					57	49	42	36	33	32	32	34	42
EXF-03-01 Exhausr					48	40	43	36	23	24	28	27	38
EXF-04-01 Exhaust					48	40	43	36	23	24	28	27	38
EXF-02-01 Exhaust					47	38	40	33	20	21	25	24	35
EXF-05-01 Exhaust					47	38	40	33	20	21	25	24	35
EXF-01-01 Exhaust					45	37	38	31	17	18	22	21	33
EXF-06-01 Exhaust					45	37	38	31	17	18	22	21	33
EXF-00-01 Exhaust					43	34	35	28	14	13	17	16	30
EXF-07-01 Exhaust					43	34	35	28	14	13	17	16	30
Roof mounted chiller					36	33	33	24	22	19	16	9	29
EXF-08-01 Exhaust					42	33	33	26	10	8	12	11	28
EFX-B1-01 Exhaust					33	28	34	17	5	6	4	6	26
EFX-B1-03 Exhaust					28	35	25	15	11	11	9	7	23
EFX-B1-02 Exhaust					31	35	19	11	0	0	0	0	20
EFX-B1-05 Exhaust					32	26	23	9	2	0	1	5	17
AHU1 exhaust					15	25	17	11	5	4	1	1	15
AHU1 fresh air inlet					2	8	0	0	0	0	0	0	0
AHU2 fresh air inlet					4	0	0	0	0	0	0	0	0
Total Free field Lp and dBA					59	51	50	43	35	34	36	36	46
Source noise levels at receiver: 5th floor Chancery Court Hotel G													
Period:	Night-time				Mid frequency octave bands (Hz)								
					63	125	250	500	1k	2k	4k	8k	dBA
Roof mounted pumps					56	47	43	37	34	33	33	35	42
EXF-04-01 Exhaust					48	40	43	36	23	24	28	27	38
EXF-05-01 Exhaust					48	40	43	36	23	24	28	27	38
EXF-03-01 Exhausr					47	38	40	33	20	21	25	24	35
EXF-06-01 Exhaust					47	38	40	33	20	21	25	24	35
EXF-02-01 Exhaust					45	37	38	31	17	18	22	21	33
EXF-07-01 Exhaust					45	37	38	31	17	18	22	21	33
Roof mounted chiller					38	35	35	25	23	20	17	10	30
EXF-01-01 Exhaust					43	34	35	28	14	13	17	16	30
EXF-08-01 Exhaust					43	34	35	28	14	13	17	16	30
EXF-00-01 Exhaust					41	32	32	25	9	7	11	10	27
EFX-B1-01 Exhaust					32	27	33	16	4	5	3	5	25
EFX-B1-03 Exhaust					27	34	24	14	10	10	8	6	22
EFX-B1-02 Exhaust					30	34	18	10	0	0	0	0	19
EFX-B1-05 Exhaust					31	25	22	8	1	0	0	4	16
AHU1 exhaust					14	24	16	10	4	3	0	0	13
AHU1 fresh air inlet					2	8	0	0	0	0	0	0	0
AHU2 fresh air inlet					4	0	0	0	0	0	0	0	0
Total Free field Lp and dBA					59	50	50	43	35	35	36	37	46
Source noise levels at receiver: 6th floor Chancery Court Hotel G													
Period:	Night-time				Mid frequency octave bands (Hz)								
					63	125	250	500	1k	2k	4k	8k	dBA
Roof mounted pumps					60	50	43	37	34	33	33	35	43
EXF-05-01 Exhaust					48	40	43	36	23	24	28	27	38
EXF-06-01 Exhaust					48	40	43	36	23	24	28	27	38
EXF-04-01 Exhaust					47	38	40	33	20	21	25	24	35
EXF-07-01 Exhaust					47	38	40	33	20	21	25	24	35
EXF-03-01 Exhausr					45	37	38	31	17	18	22	21	33
EXF-08-01 Exhaust					45	37	38	31	17	18	22	21	33
Roof mounted chiller					39	36	37	27	23	20	17	10	31
EXF-02-01 Exhaust					43	34	35	28	14	13	17	16	30
EXF-01-01 Exhaust					41	32	32	25	9	7	11	10	27
EXF-00-01 Exhaust					40	31	31	24	8	6	10	9	26
EFX-B1-01 Exhaust					31	26	31	14	0	0	0	0	23
EFX-B1-03 Exhaust					26	33	22	12	6	5	3	1	20
EFX-B1-02 Exhaust					29	33	16	8	0	0	0	0	18
EFX-B1-05 Exhaust					30	24	20	6	0	0	0	0	14
AHU1 exhaust					13	22	14	6	0	0	0	0	10
AHU1 fresh air inlet					1	7	0	0	0	0	0	0	0
AHU2 fresh air inlet					3	0	0	0	0	0	0	0	0
Total Free field Lp and dBA					61	52	50	43	35	35	36	37	47

Source noise levels at receiver: 7th floor Chancery Court Hotel G														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps					60	50	43	37	34	33	33	35	43	
EXF-06-01 Exhaust					48	40	43	36	23	24	28	27	38	
EXF-07-01 Exhaust					48	40	43	36	23	24	28	27	38	
EXF-05-01 Exhaust					47	38	40	33	20	21	25	24	35	
EXF-08-01 Exhaust					47	38	40	33	20	21	25	24	35	
EXF-04-01 Exhaust					45	37	38	31	17	18	22	21	33	
Roof mounted chiller					41	38	39	29	24	20	17	10	33	
EXF-03-01 Exhaust					43	34	35	28	14	13	17	16	30	
EXF-02-01 Exhaust					41	32	32	25	9	7	11	10	27	
EXF-01-01 Exhaust					40	31	31	24	8	6	10	9	26	
EXF-00-01 Exhaust					39	29	28	21	3	0	3	2	23	
EFX-B1-01 Exhaust					31	26	31	14	0	0	0	0	23	
EFX-B1-03 Exhaust					26	33	22	12	6	5	3	1	20	
EFX-B1-02 Exhaust					29	33	16	8	0	0	0	0	18	
EFX-B1-05 Exhaust					30	24	20	6	0	0	0	0	14	
AHU1 exhaust					13	22	14	6	0	0	0	0	10	
AHU1 fresh air inlet					0	6	0	0	0	0	0	0	0	
AHU2 fresh air inlet					2	0	0	0	0	0	0	0	0	
Total Free field Lp and dBA					61	52	50	43	35	35	36	37	47	
Source noise levels at receiver: 8th floor Chancery Court Hotel G														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps					60	50	43	37	34	33	33	35	43	
EXF-08-01 Exhaust					48	40	43	36	23	24	28	27	38	
Roof mounted chiller					43	42	43	34	30	24	18	10	38	
EXF-07-01 Exhaust					48	40	42	35	22	23	27	26	37	
EXF-06-01 Exhaust					47	38	40	33	20	21	25	24	35	
EXF-05-01 Exhaust					44	35	36	29	15	14	18	17	31	
EXF-04-01 Exhaust					43	34	35	28	14	13	17	16	30	
EXF-03-01 Exhaust					41	32	32	25	9	7	11	10	27	
EXF-02-01 Exhaust					40	30	29	22	4	0	4	3	24	
EXF-01-01 Exhaust					39	29	28	21	3	0	3	2	23	
EFX-B1-01 Exhaust					30	25	30	13	0	0	0	0	22	
EXF-00-01 Exhaust					37	27	26	19	1	0	1	0	21	
EFX-B1-03 Exhaust					25	32	21	11	5	4	2	0	19	
EFX-B1-02 Exhaust					28	32	15	7	0	0	0	0	17	
EFX-B1-05 Exhaust					29	23	19	5	0	0	0	0	13	
AHU1 exhaust					12	21	13	5	0	0	0	0	9	
AHU1 fresh air inlet					0	6	0	0	0	0	0	0	0	
AHU2 fresh air inlet					2	0	0	0	0	0	0	0	0	
Total Free field Lp and dBA					61	52	50	43	36	35	36	36	47	

APPENDIX F

CALCULATIONS –SUMMARY (2200-MIDNIGHT)

Overall receptor listings														
Period:	Night-time					Mid frequency octave bands (Hz)								
					63	125	250	500	1k	2k	4k	8k	dBA	
Top floor Chancery Court Hotel F					63	54	50	44	41	39	38	39	49	
7th floor Chancery Court Hotel G					61	52	50	43	35	35	36	37	47	
6th floor Chancery Court Hotel G					61	52	50	43	35	35	36	37	47	
5th floor Chancery Court Hotel G					59	50	50	43	35	35	36	37	46	
4th floor Chancery Court Hotel G					59	51	50	43	34	34	36	36	46	
3rd floor Chancery Court Hotel G					60	51	50	43	34	33	35	36	46	
8th floor Chancery Court Hotel G					61	52	49	42	35	34	36	36	46	
2nd floor Chancery Court Hotel G					59	50	49	42	33	33	35	35	45	
1st floor Chancery Court Hotel G					59	50	49	42	33	32	34	35	45	
1st floor Chancery Court Hotel F					58	50	48	40	32	32	33	34	44	
Top floor Chancery Court Hotel E					61	50	46	39	33	29	27	25	43	
1st floor Chancery Court Hotel E					53	48	46	36	26	26	27	26	40	
Top floor Chancery Court Hotel D					59	48	44	36	29	24	21	21	40	
Top floor Chancery Court Hotel C					57	46	42	34	26	22	18	17	38	
1st floor Chancery Court Hotel					51	46	43	33	22	22	22	22	37	
Top floor Chancery Court Hotel B					55	44	40	32	25	20	16	14	36	
268-270 High Holborn to rear grd floor					47	45	38	31	25	24	22	19	35	
1st floor Chancery Court Hotel C					50	44	40	31	19	18	17	17	35	
Top floor Chancery Court Hotel A					54	43	38	30	23	18	14	13	34	
1st floor Chancery Court Hotel					49	42	38	29	17	15	14	13	33	
1st floor Chancery Court Hotel A					48	40	36	28	15	13	11	11	31	
268-270 High Holborn to rear 5th floor					51	39	33	23	19	17	15	15	30	
268-270 High Holborn to rear 4th floor					50	39	32	23	20	18	16	16	30	

Source noise levels at receiver: Top floor Chancery Court Hotel F														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps					63	53	46	40	37	36	36	38	46	
Roof mounted chiller					43	43	46	40	38	35	32	25	44	
EXF-07-01 Exhaust					45	37	38	31	17	18	22	21	33	
EXF-08-01 Exhaust					45	37	38	31	17	18	22	21	33	
EXF-06-01 Exhaust					44	36	37	30	16	17	21	20	32	
EXF-05-01 Exhaust					43	35	36	29	15	16	20	19	31	
EXF-04-01 Exhaust					42	33	34	27	13	12	16	15	29	
EXF-03-01 Exhaust					41	32	33	26	12	11	15	14	28	
EXF-02-01 Exhaust					40	31	31	24	8	6	10	9	26	
EXF-01-01 Exhaust					39	30	30	23	7	5	9	8	25	
EXF-00-01 Exhaust					37	27	26	19	1	0	1	0	21	
EFX-B1-01 Exhaust					30	24	28	11	0	0	0	0	20	
EFX-B1-03 Exhaust					25	31	19	9	1	0	0	0	17	
EFX-B1-02 Exhaust					28	31	13	5	0	0	0	0	16	
EFX-B1-05 Exhaust					29	22	17	3	0	0	0	0	11	
AHU1 exhaust					11	22	11	1	0	0	0	0	8	
AHU1 fresh air inlet					1	8	0	0	0	0	0	0	0	
AHU2 fresh air inlet					3	0	0	0	0	0	0	0	0	
Total Free field Lp and dBA					63	54	50	44	41	39	38	39	49	
Source noise levels at receiver: Top floor Chancery Court Hotel E														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps					60	49	40	32	27	24	21	20	39	
Roof mounted chiller					41	40	42	35	31	26	20	10	38	
EXF-07-01 Exhaust					43	34	35	28	14	13	17	16	30	
EXF-08-01 Exhaust					43	34	35	28	14	13	17	16	30	
EXF-06-01 Exhaust					42	33	34	27	13	12	16	15	29	
EXF-05-01 Exhaust					41	32	33	26	12	11	15	14	28	
EXF-04-01 Exhaust					41	32	33	26	12	11	15	14	28	
EXF-03-01 Exhaust					40	31	32	25	11	10	14	13	27	
EXF-02-01 Exhaust					39	30	31	24	10	9	13	12	26	
EXF-01-01 Exhaust					38	29	30	23	9	8	12	11	25	
EXF-00-01 Exhaust					37	28	28	21	5	3	7	6	23	
EFX-B1-01 Exhaust					30	24	28	11	0	0	0	0	20	
EFX-B1-03 Exhaust					25	31	19	9	1	0	0	0	17	
EFX-B1-02 Exhaust					28	31	13	5	0	0	0	0	16	
EFX-B1-05 Exhaust					29	22	17	3	0	0	0	0	11	
AHU1 exhaust					11	22	11	1	0	0	0	0	8	
AHU1 fresh air inlet					5	12	0	0	0	0	0	0	0	
AHU2 fresh air inlet					7	2	4	0	0	0	0	0	0	
Total Free field Lp and dBA					61	50	46	39	33	29	27	25	43	
Source noise levels at receiver: Top floor Chancery Court Hotel D														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps					58	46	37	29	23	19	16	18	36	
Roof mounted chiller					39	38	39	31	27	21	15	5	34	
EXF-07-01 Exhaust					40	31	31	24	8	6	10	9	26	
EXF-08-01 Exhaust					40	31	31	24	8	6	10	9	26	
EXF-06-01 Exhaust					40	31	31	24	8	6	10	9	26	
EXF-05-01 Exhaust					40	31	31	24	8	6	10	9	26	
EXF-04-01 Exhaust					39	30	30	23	7	5	9	8	25	
EXF-03-01 Exhaust					38	29	29	22	6	4	8	7	24	
EXF-02-01 Exhaust					38	29	29	22	6	4	8	7	24	
EXF-01-01 Exhaust					37	28	28	21	5	3	7	6	23	
EXF-00-01 Exhaust					36	27	27	20	4	2	6	5	22	
EFX-B1-01 Exhaust					30	24	28	11	0	0	0	0	20	
EFX-B1-03 Exhaust					25	31	19	9	1	0	0	0	17	
EFX-B1-02 Exhaust					28	31	13	5	0	0	0	0	16	
EFX-B1-05 Exhaust					29	22	17	3	0	0	0	0	11	
AHU1 exhaust					11	22	11	1	0	0	0	0	8	
AHU1 fresh air inlet					6	15	2	0	0	0	0	0	0	
AHU2 fresh air inlet					8	5	9	1	0	0	0	0	0	
Total Free field Lp and dBA					59	48	44	36	29	24	21	21	40	

Source noise levels at receiver: Top floor Chancery Court Hotel C															
Period:	Night-time				Mid frequency octave bands (Hz)										
					63	125	250	500	1k	2k	4k	8k	dBA		
Roof mounted pumps					56	44	35	26	20	16	14	16	34		
Roof mounted chiller					37	36	38	30	25	20	14	4	33		
EXF-07-01 Exhaust					39	29	28	21	3	0	3	2	23		
EXF-08-01 Exhaust					39	29	28	21	3	0	3	2	23		
EXF-06-01 Exhaust					38	28	27	20	2	0	2	1	22		
EXF-05-01 Exhaust					38	28	27	20	2	0	2	1	22		
EXF-04-01 Exhaust					38	28	27	20	2	0	2	1	22		
EFX-B1-01 Exhaust					30	25	30	13	0	0	0	0	22		
EXF-02-01 Exhaust					37	27	26	19	1	0	1	0	21		
EXF-03-01 Exhausr					37	27	26	19	1	0	1	0	21		
EXF-01-01 Exhaust					36	26	25	18	0	0	0	0	20		
EXF-00-01 Exhaust					35	25	24	17	0	0	0	0	19		
EFX-B1-03 Exhaust					25	32	21	11	5	4	2	0	19		
EFX-B1-02 Exhaust					28	32	15	7	0	0	0	0	17		
EFX-B1-05 Exhaust					29	23	19	5	0	0	0	0	13		
AHU2 fresh air inlet					11	10	17	9	0	0	0	0	11		
AHU1 exhaust					12	21	13	5	0	0	0	0	9		
AHU1 fresh air inlet					14	23	9	0	0	0	0	0	8		
Total Free field Lp and dBA					57	46	42	34	26	22	18	17	38		
Source noise levels at receiver: Top floor Chancery Court Hotel B															
Period:	Night-time				Mid frequency octave bands (Hz)										
					63	125	250	500	1k	2k	4k	8k	dBA		
Roof mounted pumps					54	42	32	24	18	14	12	14	32		
Roof mounted chiller					35	34	36	28	24	18	12	2	31		
EXF-07-01 Exhaust					37	27	26	19	1	0	1	0	21		
EXF-08-01 Exhaust					37	27	26	19	1	0	1	0	21		
EXF-06-01 Exhaust					37	27	26	19	1	0	1	0	21		
EXF-05-01 Exhaust					37	27	26	19	1	0	1	0	21		
EFX-B1-01 Exhaust					29	24	29	12	0	0	0	0	21		
EXF-04-01 Exhaust					36	26	25	18	0	0	0	0	20		
EXF-02-01 Exhaust					36	26	25	18	0	0	0	0	20		
EXF-03-01 Exhausr					36	26	25	18	0	0	0	0	20		
EXF-01-01 Exhaust					35	25	24	17	0	0	0	0	19		
EXF-00-01 Exhaust					34	24	23	16	0	0	0	0	18		
EFX-B1-03 Exhaust					24	31	20	10	4	3	1	0	18		
EFX-B1-02 Exhaust					27	31	14	6	0	0	0	0	16		
EFX-B1-05 Exhaust					28	22	18	4	0	0	0	0	12		
AHU2 fresh air inlet					10	10	15	10	0	0	0	0	10		
AHU1 fresh air inlet					12	24	12	0	0	0	0	0	10		
AHU1 exhaust					11	20	12	4	0	0	0	0	8		
Total Free field Lp and dBA					55	44	40	32	25	20	16	14	36		
Source noise levels at receiver: Top floor Chancery Court Hotel A															
Period:	Night-time				Mid frequency octave bands (Hz)										
					63	125	250	500	1k	2k	4k	8k	dBA		
Roof mounted pumps					53	41	32	23	17	14	11	13	31		
Roof mounted chiller					34	33	34	26	22	16	10	1	29		
EXF-07-01 Exhaust					36	26	25	18	0	0	0	0	20		
EXF-08-01 Exhaust					36	26	25	18	0	0	0	0	20		
EXF-06-01 Exhaust					36	26	25	18	0	0	0	0	20		
EXF-05-01 Exhaust					35	25	24	17	0	0	0	0	19		
EXF-02-01 Exhaust					35	25	24	17	0	0	0	0	19		
EXF-04-01 Exhaust					35	25	24	17	0	0	0	0	19		
EXF-03-01 Exhausr					35	25	24	17	0	0	0	0	19		
EFX-B1-01 Exhaust					28	22	26	9	0	0	0	0	18		
EXF-01-01 Exhaust					34	24	23	16	0	0	0	0	18		
EXF-00-01 Exhaust					34	24	23	16	0	0	0	0	18		
EFX-B1-03 Exhaust					23	29	17	7	0	0	0	0	15		
EFX-B1-02 Exhaust					26	29	11	3	0	0	0	0	14		
AHU2 fresh air inlet					10	10	16	11	2	1	0	0	12		
AHU1 fresh air inlet					13	25	15	3	0	0	0	0	11		
EFX-B1-05 Exhaust					27	20	15	1	0	0	0	0	9		
AHU1 exhaust					9	20	9	0	0	0	0	0	5		
Total Free field Lp and dBA					54	43	38	30	23	18	14	13	34		

Source noise levels at receiver: 1st floor Chancery Court Hotel F															
Period:	Night-time					Mid frequency octave bands (Hz)									
						63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps						57	47	40	34	31	30	30	32	40	
EXF-00-01 Exhaust						45	37	38	31	17	18	22	21	33	
EXF-01-01 Exhaust						45	37	38	31	17	18	22	21	33	
EFX-B1-01 Exhaust						39	34	41	24	13	16	14	16	33	
EXF-02-01 Exhaust						44	36	37	30	16	17	21	20	32	
EXF-03-01 Exhausr						43	35	36	29	15	16	20	19	31	
EXF-04-01 Exhaust						42	34	35	28	14	15	19	18	30	
EFX-B1-03 Exhaust						34	41	32	22	19	21	19	17	30	
EXF-05-01 Exhaust						41	32	33	26	12	11	15	14	28	
Roof mounted chiller						33	32	33	25	20	14	8	1	28	
EFX-B1-02 Exhaust						37	41	26	18	7	8	9	8	26	
EXF-06-01 Exhaust						40	31	31	24	8	6	10	9	26	
EXF-07-01 Exhaust						39	30	30	23	7	5	9	8	25	
EFX-B1-05 Exhaust						38	32	30	16	10	10	11	15	24	
EXF-08-01 Exhaust						38	29	29	22	6	4	8	7	24	
AHU1 exhaust						21	32	24	19	15	14	11	11	23	
AHU2 fresh air inlet						9	4	5	0	0	0	0	0	0	
AHU1 fresh air inlet						7	14	0	0	0	0	0	0	0	
Total Free field Lp and dBA						58	50	48	40	32	32	33	34	44	
Source noise levels at receiver: 1st floor Chancery Court Hotel E															
Period:	Night-time					Mid frequency octave bands (Hz)									
						63	125	250	500	1k	2k	4k	8k	dBA	
EFX-B1-01 Exhaust						40	35	42	25	14	17	15	17	34	
EFX-B1-03 Exhaust						35	42	33	23	20	22	20	18	31	
EXF-00-01 Exhaust						43	34	35	28	14	13	17	16	30	
EXF-01-01 Exhaust						43	34	35	28	14	13	17	16	30	
EXF-03-01 Exhausr						42	33	34	27	13	12	16	15	29	
EXF-02-01 Exhaust						42	33	34	27	13	12	16	15	29	
EXF-04-01 Exhaust						41	32	33	26	12	11	15	14	28	
EFX-B1-02 Exhaust						38	42	27	19	8	9	10	9	27	
EXF-05-01 Exhaust						40	31	32	25	11	10	14	13	27	
EXF-06-01 Exhaust						39	30	31	24	10	9	13	12	26	
EFX-B1-05 Exhaust						39	33	31	17	11	11	12	16	25	
Roof mounted pumps						47	35	25	16	12	11	11	13	25	
EXF-07-01 Exhaust						38	29	30	23	9	8	12	11	25	
AHU1 exhaust						22	33	25	20	16	15	12	12	24	
EXF-08-01 Exhaust						37	28	28	21	5	3	7	6	23	
Roof mounted chiller						27	25	25	16	14	11	8	1	21	
AHU1 fresh air inlet						10	18	3	0	0	0	0	0	4	
AHU2 fresh air inlet						12	8	10	0	0	0	0	0	4	
Total Free field Lp and dBA						53	48	46	36	26	26	27	26	40	
Source noise levels at receiver: 1st floor Chancery Court Hotel C															
Period:	Night-time					Mid frequency octave bands (Hz)									
						63	125	250	500	1k	2k	4k	8k	dBA	
EFX-B1-01 Exhaust						36	31	37	20	8	9	7	9	29	
EFX-B1-03 Exhaust						31	38	28	18	14	14	12	10	26	
Roof mounted pumps						47	35	25	16	11	10	10	12	25	
EFX-B1-02 Exhaust						34	38	22	14	2	1	2	1	23	
EXF-01-01 Exhaust						39	29	28	21	3	0	3	2	23	
EXF-02-01 Exhaust						38	28	27	20	2	0	2	1	22	
EXF-03-01 Exhausr						38	28	27	20	2	0	2	1	22	
EXF-00-01 Exhaust						38	28	27	20	2	0	2	1	22	
EXF-04-01 Exhaust						38	28	27	20	2	0	2	1	22	
EXF-05-01 Exhaust						37	27	26	19	1	0	1	0	21	
EXF-06-01 Exhaust						37	27	26	19	1	0	1	0	21	
EFX-B1-05 Exhaust						35	29	26	12	5	3	4	8	20	
Roof mounted chiller						27	24	24	15	13	10	7	0	20	
EXF-07-01 Exhaust						36	26	25	18	0	0	0	0	20	
EXF-08-01 Exhaust						35	25	24	17	0	0	0	0	19	
AHU1 exhaust						18	28	20	14	8	7	4	4	18	
AHU2 fresh air inlet						17	16	23	15	2	0	0	0	16	
AHU1 fresh air inlet						20	29	15	0	0	0	0	0	14	
Total Free field Lp and dBA						50	44	40	31	19	18	17	17	35	

Source noise levels at receiver: 1st floor Chancery Court Hotel A														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps					45	33	23	14	9	8	8	10	23	
EFX-B1-01 Exhaust					32	26	30	13	0	0	0	0	22	
EXF-02-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-00-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-01-01 Exhaust					36	26	25	18	0	0	0	0	20	
Roof mounted chiller					26	23	24	15	12	9	6	0	19	
EFX-B1-03 Exhaust					27	33	21	11	3	0	0	0	19	
EXF-04-01 Exhaust					35	25	24	17	0	0	0	0	19	
EXF-03-01 Exhausr					35	25	24	17	0	0	0	0	19	
EXF-05-01 Exhaust					35	25	24	17	0	0	0	0	19	
EXF-06-01 Exhaust					35	25	24	17	0	0	0	0	19	
EFX-B1-02 Exhaust					30	33	15	7	0	0	0	0	18	
EXF-07-01 Exhaust					34	24	23	16	0	0	0	0	18	
EXF-08-01 Exhaust					34	24	23	16	0	0	0	0	18	
AHU2 fresh air inlet					14	15	21	16	7	8	5	2	17	
AHU1 fresh air inlet					18	30	20	10	5	2	0	0	17	
EFX-B1-05 Exhaust					31	24	19	5	0	0	0	0	13	
AHU1 exhaust					13	24	13	3	0	0	0	0	10	
Total Free field Lp and dBA					48	40	36	28	15	13	11	11	31	
Source noise levels at receiver: 1st floor Chancery Court Hotel														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
EFX-B1-01 Exhaust					37	33	39	22	10	13	11	13	31	
EFX-B1-03 Exhaust					32	40	30	20	16	18	16	14	28	
EXF-02-01 Exhaust					40	31	31	24	8	6	10	9	26	
EXF-00-01 Exhaust					40	31	31	24	8	6	10	9	26	
EXF-01-01 Exhaust					40	31	31	24	8	6	10	9	26	
EXF-03-01 Exhausr					40	31	31	24	8	6	10	9	26	
EFX-B1-02 Exhaust					35	40	24	16	4	5	6	5	25	
EXF-04-01 Exhaust					39	30	30	23	7	5	9	8	25	
Roof mounted pumps					47	34	24	15	11	10	10	12	25	
EXF-06-01 Exhaust					38	29	29	22	6	4	8	7	24	
EXF-05-01 Exhaust					38	29	29	22	6	4	8	7	24	
EXF-07-01 Exhaust					37	28	28	21	5	3	7	6	23	
EFX-B1-05 Exhaust					36	31	28	14	7	7	8	12	22	
EXF-08-01 Exhaust					36	27	27	20	4	2	6	5	22	
Roof mounted chiller					28	25	25	16	14	11	8	1	21	
AHU1 exhaust					20	30	22	16	12	11	8	8	20	
AHU2 fresh air inlet					14	11	15	7	0	0	0	0	9	
AHU1 fresh air inlet					12	21	8	0	0	0	0	0	6	
Total Free field Lp and dBA					51	46	43	33	22	22	22	22	37	
Source noise levels at receiver: 1st floor Chancery Court Hotel														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
EFX-B1-01 Exhaust					34	29	34	17	3	3	1	3	26	
Roof mounted pumps					46	34	24	15	10	9	9	11	24	
EFX-B1-03 Exhaust					29	36	25	15	9	8	6	4	23	
EFX-B1-02 Exhaust					32	36	19	11	0	0	0	0	21	
EXF-02-01 Exhaust					37	27	26	19	1	0	1	0	21	
EXF-03-01 Exhausr					37	27	26	19	1	0	1	0	21	
EXF-01-01 Exhaust					37	27	26	19	1	0	1	0	21	
EXF-00-01 Exhaust					37	27	26	19	1	0	1	0	21	
Roof mounted chiller					27	24	24	15	13	10	7	0	20	
EXF-04-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-05-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-06-01 Exhaust					36	26	25	18	0	0	0	0	20	
EXF-07-01 Exhaust					35	25	24	17	0	0	0	0	19	
EXF-08-01 Exhaust					35	25	24	17	0	0	0	0	19	
AHU2 fresh air inlet					16	16	22	17	8	7	4	1	18	
AHU1 fresh air inlet					19	31	21	9	4	1	0	0	18	
EFX-B1-05 Exhaust					33	27	23	9	0	0	0	2	17	
AHU1 exhaust					16	25	17	9	2	1	0	0	14	
Total Free field Lp and dBA					49	42	38	29	17	15	14	13	33	

Source noise levels at receiver: 268-270 High Holborn to rear grd floor														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
AHU2 fresh air inlet					26	27	34	30	22	23	20	17	31	
AHU1 fresh air inlet					31	44	35	25	20	17	15	10	31	
Roof mounted pumps					44	31	21	13	10	9	9	11	22	
Roof mounted chiller					26	23	23	15	13	10	7	0	19	
EFX-B1-01 Exhaust					32	23	22	2	0	0	0	0	15	
EFX-B1-03 Exhaust					27	30	13	0	0	0	0	0	15	
EFX-B1-02 Exhaust					30	30	7	0	0	0	0	0	15	
EXF-00-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-01-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-02-01 Exhaust					33	19	13	3	0	0	0	0	10	
EFX-B1-05 Exhaust					31	21	11	0	0	0	0	0	9	
EXF-03-01 Exhaust					32	18	12	2	0	0	0	0	9	
EXF-04-01 Exhaust					32	18	12	2	0	0	0	0	9	
EXF-05-01 Exhaust					31	17	11	1	0	0	0	0	8	
EXF-07-01 Exhaust					30	16	10	0	0	0	0	0	7	
EXF-06-01 Exhaust					30	16	10	0	0	0	0	0	7	
EXF-08-01 Exhaust					29	15	9	0	0	0	0	0	5	
AHU1 exhaust					11	18	5	0	0	0	0	0	4	
Total Free field Lp and dBA					47	45	38	31	25	24	22	19	35	
Source noise levels at receiver: 268-270 High Holborn to rear 4th floor														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps					49	37	27	18	15	14	14	16	27	
Roof mounted chiller					31	29	29	20	18	15	12	5	25	
AHU2 fresh air inlet					16	15	22	14	1	0	0	0	15	
AHU1 fresh air inlet					19	28	14	0	0	0	0	0	13	
EXF-03-01 Exhaust					34	20	14	4	0	0	0	0	12	
EXF-04-01 Exhaust					34	20	14	4	0	0	0	0	12	
EFX-B1-01 Exhaust					28	19	18	0	0	0	0	0	11	
EFX-B1-03 Exhaust					23	26	9	0	0	0	0	0	10	
EFX-B1-02 Exhaust					26	26	3	0	0	0	0	0	10	
EXF-01-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-06-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-02-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-00-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-05-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-07-01 Exhaust					33	19	13	3	0	0	0	0	10	
EXF-08-01 Exhaust					33	19	12	3	0	0	0	0	10	
EFX-B1-05 Exhaust					27	17	7	0	0	0	0	0	5	
AHU1 exhaust					7	14	1	0	0	0	0	0	0	
Total Free field Lp and dBA					50	39	32	23	20	18	16	16	30	
Source noise levels at receiver: 268-270 High Holborn to rear 5th floor														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps					50	37	27	18	14	13	13	15	28	
Roof mounted chiller					32	29	29	20	17	14	11	4	24	
AHU2 fresh air inlet					14	14	19	14	3	1	0	0	14	
AHU1 fresh air inlet					16	28	16	3	0	0	0	0	13	
EFX-B1-01 Exhaust					29	20	20	1	0	0	0	0	13	
EXF-08-01 Exhaust					34	21	15	6	0	0	0	0	12	
EXF-07-01 Exhaust					34	21	15	6	0	0	0	0	12	
EXF-06-01 Exhaust					34	20	15	6	0	0	0	0	12	
EXF-03-01 Exhaust					34	20	15	5	0	0	0	0	12	
EXF-02-01 Exhaust					34	20	15	5	0	0	0	0	12	
EXF-05-01 Exhaust					34	20	15	5	0	0	0	0	12	
EXF-04-01 Exhaust					34	20	15	5	0	0	0	0	12	
EFX-B1-03 Exhaust					24	27	11	0	0	0	0	0	12	
EFX-B1-02 Exhaust					27	27	5	0	0	0	0	0	12	
EXF-01-01 Exhaust					33	20	14	5	0	0	0	0	11	
EXF-00-01 Exhaust					32	19	13	4	0	0	0	0	10	
EFX-B1-05 Exhaust					28	18	9	0	0	0	0	0	6	
AHU1 exhaust					8	15	3	0	0	0	0	0	0	
Total Free field Lp and dBA					51	39	33	23	19	17	15	15	30	

Source noise levels at receiver: 1st floor Chancery Court Hotel G															
Period:	Night-time					Mid frequency octave bands (Hz)									
						63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps						57	47	40	34	31	30	30	32	40	
EXF-01-01 Exhaust						48	40	43	36	23	24	28	27	38	
EXF-00-01 Exhaust						48	40	42	35	22	23	27	26	37	
EXF-02-01 Exhaust						47	38	40	33	20	21	25	24	35	
EXF-03-01 Exhaust						45	37	38	31	17	18	22	21	33	
EXF-04-01 Exhaust						43	34	35	28	14	13	17	16	30	
EFX-B1-01 Exhaust						36	31	37	20	8	9	7	9	29	
EXF-05-01 Exhaust						42	33	33	26	10	8	12	11	28	
EXF-06-01 Exhaust						40	31	31	24	8	6	10	9	26	
EFX-B1-03 Exhaust						31	38	28	18	14	14	12	10	26	
EFX-B1-02 Exhaust						34	38	22	14	2	1	2	1	23	
EXF-07-01 Exhaust						39	29	28	21	3	0	3	2	23	
EXF-08-01 Exhaust						38	28	27	20	2	0	2	1	22	
EFX-B1-05 Exhaust						35	29	26	12	5	3	4	8	20	
Roof mounted chiller						25	22	22	15	13	10	7	0	19	
AHU1 exhaust						18	28	20	14	8	7	4	4	18	
AHU1 fresh air inlet						4	10	0	0	0	0	0	0	0	
AHU2 fresh air inlet						6	0	1	0	0	0	0	0	0	
Total Free field Lp and dBA						59	50	49	42	33	32	34	35	45	
Source noise levels at receiver: 2nd floor Chancery Court Hotel G															
Period:	Night-time					Mid frequency octave bands (Hz)									
						63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps						57	47	40	34	31	30	30	32	40	
EXF-01-01 Exhaust						48	40	43	36	23	24	28	27	38	
EXF-02-01 Exhaust						48	40	43	36	23	24	28	27	38	
EXF-00-01 Exhaust						47	38	40	33	20	21	25	24	35	
EXF-03-01 Exhaust						47	38	40	33	20	21	25	24	35	
EXF-04-01 Exhaust						45	37	38	31	17	18	22	21	33	
EXF-05-01 Exhaust						43	34	35	28	14	13	17	16	30	
EFX-B1-01 Exhaust						35	30	36	19	7	8	6	8	28	
EXF-06-01 Exhaust						42	33	33	26	10	8	12	11	28	
EXF-07-01 Exhaust						40	31	31	24	8	6	10	9	26	
EFX-B1-03 Exhaust						30	37	27	17	13	13	11	9	25	
EXF-08-01 Exhaust						39	29	28	21	3	0	3	2	23	
EFX-B1-02 Exhaust						33	37	21	13	1	0	1	0	22	
Roof mounted chiller						26	23	23	16	14	11	8	1	20	
EFX-B1-05 Exhaust						34	28	25	11	4	2	3	7	19	
AHU1 exhaust						17	27	19	13	7	6	3	3	17	
AHU1 fresh air inlet						3	9	0	0	0	0	0	0	0	
AHU2 fresh air inlet						5	0	0	0	0	0	0	0	0	
Total Free field Lp and dBA						59	50	49	42	33	33	35	35	45	
Source noise levels at receiver: 3rd floor Chancery Court Hotel G															
Period:	Night-time					Mid frequency octave bands (Hz)									
						63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps						58	48	41	35	32	31	31	33	41	
EXF-02-01 Exhaust						48	40	43	36	23	24	28	27	38	
EXF-03-01 Exhaust						48	40	43	36	23	24	28	27	38	
EXF-01-01 Exhaust						47	38	40	33	20	21	25	24	35	
EXF-04-01 Exhaust						47	38	40	33	20	21	25	24	35	
EXF-05-01 Exhaust						45	37	38	31	17	18	22	21	33	
EXF-00-01 Exhaust						44	35	36	29	15	14	18	17	31	
EXF-06-01 Exhaust						43	34	35	28	14	13	17	16	30	
EXF-07-01 Exhaust						42	33	33	26	10	8	12	11	28	
EFX-B1-01 Exhaust						34	29	35	18	6	7	5	7	27	
EXF-08-01 Exhaust						40	31	31	24	8	6	10	9	26	
EFX-B1-03 Exhaust						29	36	26	16	12	12	10	8	24	
Roof mounted chiller						27	25	25	17	15	12	9	2	21	
EFX-B1-02 Exhaust						32	36	20	12	0	0	0	0	21	
EFX-B1-05 Exhaust						33	27	24	10	3	1	2	6	18	
AHU1 exhaust						16	26	18	12	6	5	2	2	16	
AHU1 fresh air inlet						3	9	0	0	0	0	0	0	0	
AHU2 fresh air inlet						5	0	0	0	0	0	0	0	0	
Total Free field Lp and dBA						60	51	50	43	34	33	35	36	46	

Source noise levels at receiver: 4th floor Chancery Court Hotel G												
Period:	Night-time					Mid frequency octave bands (Hz)						
						63	125	250	500	1k	2k	4k 8k dBA
Roof mounted pumps						57	49	42	36	33	32	32 34 42
EXF-03-01 Exhausr						48	40	43	36	23	24	28 27 38
EXF-04-01 Exhaust						48	40	43	36	23	24	28 27 38
EXF-02-01 Exhaust						47	38	40	33	20	21	25 24 35
EXF-05-01 Exhaust						47	38	40	33	20	21	25 24 35
EXF-01-01 Exhaust						45	37	38	31	17	18	22 21 33
EXF-06-01 Exhaust						45	37	38	31	17	18	22 21 33
EXF-00-01 Exhaust						43	34	35	28	14	13	17 16 30
EXF-07-01 Exhaust						43	34	35	28	14	13	17 16 30
EXF-08-01 Exhaust						42	33	33	26	10	8	12 11 28
EFX-B1-01 Exhaust						33	28	34	17	5	6	4 6 26
EFX-B1-03 Exhaust						28	35	25	15	11	11	9 7 23
Roof mounted chiller						28	25	25	17	15	12	9 2 21
EFX-B1-02 Exhaust						31	35	19	11	0	0	0 0 20
EFX-B1-05 Exhaust						32	26	23	9	2	0	1 5 17
AHU1 exhaust						15	25	17	11	5	4	1 1 15
AHU1 fresh air inlet						2	8	0	0	0	0	0 0 0
AHU2 fresh air inlet						4	0	0	0	0	0	0 0 0
Total Free field Lp and dBA						59	51	50	43	34	34	36 36 46
Source noise levels at receiver: 5th floor Chancery Court Hotel G												
Period:	Night-time					Mid frequency octave bands (Hz)						
						63	125	250	500	1k	2k	4k 8k dBA
Roof mounted pumps						56	47	43	37	34	33	33 35 42
EXF-04-01 Exhaust						48	40	43	36	23	24	28 27 38
EXF-05-01 Exhaust						48	40	43	36	23	24	28 27 38
EXF-03-01 Exhausr						47	38	40	33	20	21	25 24 35
EXF-06-01 Exhaust						47	38	40	33	20	21	25 24 35
EXF-02-01 Exhaust						45	37	38	31	17	18	22 21 33
EXF-07-01 Exhaust						45	37	38	31	17	18	22 21 33
EXF-01-01 Exhaust						43	34	35	28	14	13	17 16 30
EXF-08-01 Exhaust						43	34	35	28	14	13	17 16 30
EXF-00-01 Exhaust						41	32	32	25	9	7	11 10 27
EFX-B1-01 Exhaust						32	27	33	16	4	5	3 5 25
Roof mounted chiller						30	27	27	18	16	13	10 3 23
EFX-B1-03 Exhaust						27	34	24	14	10	10	8 6 22
EFX-B1-02 Exhaust						30	34	18	10	0	0	0 0 19
EFX-B1-05 Exhaust						31	25	22	8	1	0	0 4 16
AHU1 exhaust						14	24	16	10	4	3	0 0 13
AHU1 fresh air inlet						2	8	0	0	0	0	0 0 0
AHU2 fresh air inlet						4	0	0	0	0	0	0 0 0
Total Free field Lp and dBA						59	50	50	43	35	35	36 37 46
Source noise levels at receiver: 6th floor Chancery Court Hotel G												
Period:	Night-time					Mid frequency octave bands (Hz)						
						63	125	250	500	1k	2k	4k 8k dBA
Roof mounted pumps						60	50	43	37	34	33	33 35 43
EXF-05-01 Exhaust						48	40	43	36	23	24	28 27 38
EXF-06-01 Exhaust						48	40	43	36	23	24	28 27 38
EXF-04-01 Exhaust						47	38	40	33	20	21	25 24 35
EXF-07-01 Exhaust						47	38	40	33	20	21	25 24 35
EXF-03-01 Exhausr						45	37	38	31	17	18	22 21 33
EXF-08-01 Exhaust						45	37	38	31	17	18	22 21 33
EXF-02-01 Exhaust						43	34	35	28	14	13	17 16 30
EXF-01-01 Exhaust						41	32	32	25	9	7	11 10 27
EXF-00-01 Exhaust						40	31	31	24	8	6	10 9 26
Roof mounted chiller						31	28	29	20	16	13	10 3 24
EFX-B1-01 Exhaust						31	26	31	14	0	0	0 0 23
EFX-B1-03 Exhaust						26	33	22	12	6	5	3 1 20
EFX-B1-02 Exhaust						29	33	16	8	0	0	0 0 18
EFX-B1-05 Exhaust						30	24	20	6	0	0	0 0 14
AHU1 exhaust						13	22	14	6	0	0	0 0 10
AHU1 fresh air inlet						1	7	0	0	0	0	0 0 0
AHU2 fresh air inlet						3	0	0	0	0	0	0 0 0
Total Free field Lp and dBA						61	52	50	43	35	35	36 37 47

Source noise levels at receiver: 7th floor Chancery Court Hotel G														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps					60	50	43	37	34	33	33	35	43	
EXF-06-01 Exhaust					48	40	43	36	23	24	28	27	38	
EXF-07-01 Exhaust					48	40	43	36	23	24	28	27	38	
EXF-05-01 Exhaust					47	38	40	33	20	21	25	24	35	
EXF-08-01 Exhaust					47	38	40	33	20	21	25	24	35	
EXF-04-01 Exhaust					45	37	38	31	17	18	22	21	33	
EXF-03-01 Exhaust					43	34	35	28	14	13	17	16	30	
EXF-02-01 Exhaust					41	32	32	25	9	7	11	10	27	
EXF-01-01 Exhaust					40	31	31	24	8	6	10	9	26	
Roof mounted chiller					33	30	31	22	17	13	10	3	26	
EXF-00-01 Exhaust					39	29	28	21	3	0	3	2	23	
EFX-B1-01 Exhaust					31	26	31	14	0	0	0	0	23	
EFX-B1-03 Exhaust					26	33	22	12	6	5	3	1	20	
EFX-B1-02 Exhaust					29	33	16	8	0	0	0	0	18	
EFX-B1-05 Exhaust					30	24	20	6	0	0	0	0	14	
AHU1 exhaust					13	22	14	6	0	0	0	0	10	
AHU1 fresh air inlet					0	6	0	0	0	0	0	0	0	
AHU2 fresh air inlet					2	0	0	0	0	0	0	0	0	
Total Free field Lp and dBA					61	52	50	43	35	35	36	37	47	
Source noise levels at receiver: 8th floor Chancery Court Hotel G														
Period:	Night-time				Mid frequency octave bands (Hz)									
					63	125	250	500	1k	2k	4k	8k	dBA	
Roof mounted pumps					60	50	43	37	34	33	33	35	43	
EXF-08-01 Exhaust					48	40	43	36	23	24	28	27	38	
EXF-07-01 Exhaust					48	40	42	35	22	23	27	26	37	
EXF-06-01 Exhaust					47	38	40	33	20	21	25	24	35	
EXF-05-01 Exhaust					44	35	36	29	15	14	18	17	31	
Roof mounted chiller					35	34	35	27	23	17	11	3	30	
EXF-04-01 Exhaust					43	34	35	28	14	13	17	16	30	
EXF-03-01 Exhaust					41	32	32	25	9	7	11	10	27	
EXF-02-01 Exhaust					40	30	29	22	4	0	4	3	24	
EXF-01-01 Exhaust					39	29	28	21	3	0	3	2	23	
EFX-B1-01 Exhaust					30	25	30	13	0	0	0	0	22	
EXF-00-01 Exhaust					37	27	26	19	1	0	1	0	21	
EFX-B1-03 Exhaust					25	32	21	11	5	4	2	0	19	
EFX-B1-02 Exhaust					28	32	15	7	0	0	0	0	17	
EFX-B1-05 Exhaust					29	23	19	5	0	0	0	0	13	
AHU1 exhaust					12	21	13	5	0	0	0	0	9	
AHU1 fresh air inlet					0	6	0	0	0	0	0	0	0	
AHU2 fresh air inlet					2	0	0	0	0	0	0	0	0	
Total Free field Lp and dBA					61	52	49	42	35	34	36	36	46	

APPENDIX G

SITE LAYOUT DRAWING

APPENDIX H

ENVIRONMENTAL SURVEY DATA

,

Date	L _{Aeq5min}	L _{Afmax}	L _{A[90]5min}
(2013/03/20 10:20:00.00)	68.9	93.8	60.6
(2013/03/20 10:25:00.00)	62.8	69.5	60
(2013/03/20 10:30:00.00)	62.8	74.1	60
(2013/03/20 10:35:00.00)	62.7	71.5	60.4
(2013/03/20 10:40:00.00)	63.4	78.9	60.9
(2013/03/20 10:45:00.00)	63	77.1	60.7
(2013/03/20 10:50:00.00)	73.1	86.5	60.7
(2013/03/20 10:55:00.00)	62.2	76.2	59.9
(2013/03/20 11:00:00.00)	63.4	77.3	61
(2013/03/20 11:05:00.00)	61.1	71.8	58.8
(2013/03/20 11:10:00.00)	62.3	72.5	59.4
(2013/03/20 11:15:00.00)	61.9	72.8	58.8
(2013/03/20 11:20:00.00)	62.8	73.2	60.7
(2013/03/20 11:25:00.00)	63	72.4	60.5
(2013/03/20 11:30:00.00)	62.3	72.7	59.6
(2013/03/20 11:35:00.00)	62.3	69.5	59.7
(2013/03/20 11:40:00.00)	62.5	72.3	60.2
(2013/03/20 11:45:00.00)	62.2	72.3	59.8
(2013/03/20 11:50:00.00)	62.1	73	59.4
(2013/03/20 11:55:00.00)	63.4	79.5	60.6
(2013/03/20 12:00:00.00)	62.8	75.4	60.6
(2013/03/20 12:05:00.00)	62.5	71.1	59.9
(2013/03/20 12:10:00.00)	63.6	74.5	60.3
(2013/03/20 12:15:00.00)	62	70.9	59.5
(2013/03/20 12:20:00.00)	62.4	70	60.5
(2013/03/20 12:25:00.00)	62.6	75	60.2
(2013/03/20 12:30:00.00)	63	77.6	59.9
(2013/03/20 12:35:00.00)	63.6	72.8	60.1
(2013/03/20 12:40:00.00)	62.3	71.5	60.4
(2013/03/20 12:45:00.00)	61.9	69.8	59.6
(2013/03/20 12:50:00.00)	62.6	70.4	60.1
(2013/03/20 12:55:00.00)	62.8	70.5	60.6
(2013/03/20 13:00:00.00)	60.9	74.1	58.7
(2013/03/20 13:05:00.00)	61.4	67.4	58.6
(2013/03/20 13:10:00.00)	62.9	70.2	59.5
(2013/03/20 13:14:59.00)	63.9	75.3	61.1
(2013/03/20 13:20:00.00)	62.3	78.1	59.6
(2013/03/20 13:25:00.00)	62.6	76.6	60.3
(2013/03/20 13:30:00.00)	63.7	74	61
(2013/03/20 13:35:00.00)	62	73.8	59.6
(2013/03/20 13:40:00.00)	69.5	87	59.6
(2013/03/20 13:45:00.00)	63.9	73.2	61.1

Date	L _{Aeq5min}	L _{Afmax}	L _{A(90)5min}
(2013/03/20 13:50:00.00)	62.9	73.3	60.5
(2013/03/20 13:55:00.00)	64.4	76.6	60.7
(2013/03/20 14:00:00.00)	69.7	86.8	61.1
(2013/03/20 14:05:00.00)	61.9	70.6	59.4
(2013/03/20 14:10:00.00)	63.3	74.6	60.1
(2013/03/20 14:15:00.00)	63	72.1	60.5
(2013/03/20 14:20:00.00)	62.3	70.3	59.8
(2013/03/20 14:25:00.00)	62.5	73.1	59.6
(2013/03/20 14:30:00.00)	61.3	73.5	58.1
(2013/03/20 14:35:00.00)	61.9	76.9	57.3
(2013/03/20 14:40:00.00)	62.3	76	57.8
(2013/03/20 14:45:00.00)	62.4	72.7	59.4
(2013/03/20 14:50:00.00)	62.7	70.4	59
(2013/03/20 14:55:00.00)	62.5	82.3	57.7
(2013/03/20 15:00:00.00)	64.2	78.8	59.5
(2013/03/20 15:05:00.00)	63.1	73.2	60.7
(2013/03/20 15:10:00.00)	62.5	74.8	59.2
(2013/03/20 15:15:00.00)	65	78.9	58.9
(2013/03/20 15:20:00.00)	61.7	70.5	58.7
(2013/03/20 15:25:00.00)	62.1	71.5	58.2
(2013/03/20 15:30:00.00)	62.2	70.2	58.2
(2013/03/20 15:35:00.00)	61.2	70.3	58.2
(2013/03/20 15:40:00.00)	63	71.3	59.8
(2013/03/20 15:45:00.00)	64.4	73.2	61.6
(2013/03/20 15:50:00.00)	63.8	77.3	61
(2013/03/20 15:55:00.00)	63.4	77.7	60.4
(2013/03/20 16:00:00.00)	64.3	78.7	61.3
(2013/03/20 16:05:00.00)	62.6	76.2	59.1
(2013/03/20 16:10:00.00)	62	74.7	58.5
(2013/03/20 16:14:59.00)	70.3	88.6	59.8
(2013/03/20 16:20:00.00)	61.8	70.2	59
(2013/03/20 16:25:00.00)	62.4	72.8	58.4
(2013/03/20 16:29:59.00)	62.6	75.4	58.4
(2013/03/20 16:35:00.00)	62.4	72.6	60.3
(2013/03/20 16:40:00.00)	63.1	74.5	59.9
(2013/03/20 16:45:00.00)	63	75.8	60.2
(2013/03/20 16:50:00.00)	62.7	73.4	59.4
(2013/03/20 16:55:00.00)	61.9	73.7	59.2
(2013/03/20 17:00:00.00)	63.1	72.8	60.6
(2013/03/20 17:05:00.00)	63	75	60.4
(2013/03/20 17:10:00.00)	66.6	82.9	60.2
(2013/03/20 17:15:00.00)	63	72.9	59.3
(2013/03/20 17:20:00.00)	62.3	71.4	59.1
(2013/03/20 17:25:00.00)	62.4	73.4	60.1

Date	L _{Aeq5min}	L _{Afmax}	L _{A(90)5min}
(2013/03/20 17:30:00.00)	63.8	72	60.2
(2013/03/20 17:35:00.00)	62.7	73.5	60
(2013/03/20 17:40:00.00)	63.1	74.7	60.3
(2013/03/20 17:45:00.00)	63.9	83.2	61.1
(2013/03/20 17:50:00.00)	62.9	71.6	60.4
(2013/03/20 17:55:00.00)	63.1	73.9	60.6
(2013/03/20 18:00:00.00)	63	73.6	60.7
(2013/03/20 18:05:00.00)	63.3	76.9	60.8
(2013/03/20 18:10:00.00)	63	77	59.1
(2013/03/20 18:15:00.00)	62.9	76.9	60.4
(2013/03/20 18:20:00.00)	63.5	73.3	60.8
(2013/03/20 18:25:00.00)	62.2	69	60.4
(2013/03/20 18:30:00.00)	61.7	72.9	59.9
(2013/03/20 18:35:00.00)	62.7	71.8	60.5
(2013/03/20 18:40:00.00)	63.9	72	61.7
(2013/03/20 18:45:00.00)	63.7	74	61.9
(2013/03/20 18:50:00.00)	63	75.4	61.2
(2013/03/20 18:55:00.00)	62	70.8	60.1
(2013/03/20 19:00:00.00)	63.2	75.3	60.9
(2013/03/20 19:05:00.00)	63	73.3	61.1
(2013/03/20 19:10:00.00)	62.3	72.2	60.1
(2013/03/20 19:15:00.00)	62.7	71.5	60.8
(2013/03/20 19:20:00.00)	63.2	73	60.2
(2013/03/20 19:25:00.00)	62.8	71.6	60.5
(2013/03/20 19:30:00.00)	61.7	74.5	58.7
(2013/03/20 19:35:00.00)	62.4	71.4	59.5
(2013/03/20 19:40:00.00)	68.3	83.9	59.9
(2013/03/20 19:45:00.00)	63.4	74.3	61.5
(2013/03/20 19:50:00.00)	62.1	71.2	60.1
(2013/03/20 19:55:00.00)	62.2	69.1	59.6
(2013/03/20 20:00:00.00)	61.3	72.1	57.5
(2013/03/20 20:05:00.00)	61.5	66.8	57.8
(2013/03/20 20:10:00.00)	63.5	72.1	58.5
(2013/03/20 20:15:00.00)	61.7	72.4	57.5
(2013/03/20 20:20:00.00)	62.5	77.2	55.8
(2013/03/20 20:25:00.00)	61.3	67.2	57.8
(2013/03/20 20:30:00.00)	60.9	69.4	56.2
(2013/03/20 20:35:00.00)	61.1	71	55.9
(2013/03/20 20:40:00.00)	61.8	69.6	57.5
(2013/03/20 20:45:00.00)	67.9	85	56.9
(2013/03/20 20:50:00.00)	62.1	69.2	57.6
(2013/03/20 20:55:00.00)	60.2	68.5	56.4
(2013/03/20 21:00:00.00)	61.4	70.5	57.1
(2013/03/20 21:05:00.00)	61.7	75.8	56.2

Date	L _{Aeq5min}	L _{Afmax}	L _{A(90)5min}
(2013/03/20 21:10:00.00)	61.7	78.6	57.8
(2013/03/20 21:15:00.00)	61.3	77.5	56
(2013/03/20 21:20:00.00)	60.8	71	56.2
(2013/03/20 21:25:00.00)	62	78.6	57.6
(2013/03/20 21:30:00.00)	61.4	76.1	55.6
(2013/03/20 21:35:00.00)	61.6	77.1	56.6
(2013/03/20 21:40:00.00)	61.5	78.1	55.5
(2013/03/20 21:45:00.00)	61.9	72.5	57.1
(2013/03/20 21:50:00.00)	62	70.2	57.6
(2013/03/20 21:55:00.00)	61	71.9	56.5
(2013/03/20 22:00:00.00)	60.7	76.6	55.2
(2013/03/20 22:05:00.00)	60.6	69.4	56.3
(2013/03/20 22:10:00.00)	60.6	73.5	56.1
(2013/03/20 22:15:00.00)	61.9	79.1	56
(2013/03/20 22:20:00.00)	61.4	71.3	56.8
(2013/03/20 22:25:00.00)	61.6	69.1	56.1
(2013/03/20 22:30:00.00)	61.5	70.9	55.8
(2013/03/20 22:35:00.00)	62.4	72.1	56.4
(2013/03/20 22:40:00.00)	61.2	70.3	56.8
(2013/03/20 22:45:00.00)	60.5	70.5	53.9
(2013/03/20 22:50:00.00)	60.7	67.7	56.2
(2013/03/20 22:55:00.00)	61.5	67.5	57.6
(2013/03/20 23:00:00.00)	63.5	74.6	58.4
(2013/03/20 23:05:00.00)	61.8	73.1	56.4
(2013/03/20 23:10:00.00)	61.6	70.2	54.6
(2013/03/20 23:15:00.00)	61.3	68.7	56.1
(2013/03/20 23:20:00.00)	60.2	67.3	53.8
(2013/03/20 23:25:00.00)	61.6	74.6	54.6
(2013/03/20 23:30:00.00)	60.7	73.6	53.3
(2013/03/20 23:35:00.00)	60.9	73.2	56.1
(2013/03/20 23:40:00.00)	63.1	78.3	55.4
(2013/03/20 23:45:00.00)	61.3	73.4	55.9
(2013/03/20 23:50:00.00)	61.4	75	54.2
(2013/03/20 23:55:00.00)	60.7	79.1	54.9
(2013/03/21 00:00:00.00)	61.1	78	54.3
(2013/03/21 00:05:00.00)	60.5	74.8	53.4
(2013/03/21 00:10:00.00)	61.6	80.8	54.3
(2013/03/21 00:15:00.00)	60.7	68.9	54.9
(2013/03/21 00:20:00.00)	59.7	76.6	53.9
(2013/03/21 00:25:00.00)	61.2	70.8	51.2
(2013/03/21 00:30:00.00)	60.1	71.8	52.7
(2013/03/21 00:35:00.00)	59.6	70.3	50.7
(2013/03/21 00:40:00.00)	59.5	68.3	49.9
(2013/03/21 00:45:00.00)	59.6	76.7	50.9

Date	L _{Aeq5min}	L _{Afmax}	L _{A(90)5min}
(2013/03/21 00:50:00.00)	59.7	69.4	51
(2013/03/21 00:55:00.00)	61.3	78.8	51.9
(2013/03/21 01:00:00.00)	59.9	71.2	53.4
(2013/03/21 01:05:00.00)	57.8	65.8	49.7
(2013/03/21 01:10:00.00)	59.3	77.1	50
(2013/03/21 01:15:00.00)	59.3	74.9	49.6
(2013/03/21 01:20:00.00)	59.2	72.5	51.5
(2013/03/21 01:25:00.00)	56.5	66.7	48.7
(2013/03/21 01:30:00.00)	56.8	66	48.8
(2013/03/21 01:35:00.00)	57.7	65	48.2
(2013/03/21 01:40:00.00)	60	73	53.2
(2013/03/21 01:45:00.00)	59.3	77.3	52
(2013/03/21 01:50:00.00)	61.2	77.6	53.2
(2013/03/21 01:55:00.00)	57.2	67.6	49.4
(2013/03/21 02:00:00.00)	59.8	70.8	52.7
(2013/03/21 02:05:00.00)	56.1	66.3	47.7
(2013/03/21 02:10:00.00)	59	73	50.4
(2013/03/21 02:15:00.00)	57.6	75.4	49
(2013/03/21 02:20:00.00)	58.6	76.4	48.9
(2013/03/21 02:25:00.00)	58.4	66.5	49.3
(2013/03/21 02:30:00.00)	58.4	72.6	49.5
(2013/03/21 02:35:00.00)	58.5	73.6	49.1
(2013/03/21 02:40:00.00)	57.4	66.5	48.7
(2013/03/21 02:45:00.00)	57	67	48
(2013/03/21 02:50:00.00)	56.6	68	48.8
(2013/03/21 02:55:00.00)	58.9	73.1	49.1
(2013/03/21 03:00:00.00)	58.7	67	50.3
(2013/03/21 03:05:00.00)	59	69	48.8
(2013/03/21 03:10:00.00)	58.6	66.9	49.4
(2013/03/21 03:15:00.00)	58	73	48.3
(2013/03/21 03:20:00.00)	60.5	79.5	51.8
(2013/03/21 03:25:00.00)	58.8	72	49.8
(2013/03/21 03:30:00.00)	57.5	73.8	49.3
(2013/03/21 03:35:00.00)	58.3	69.3	48.2
(2013/03/21 03:40:00.00)	58.6	75.1	50.1
(2013/03/21 03:45:00.00)	57.9	78.5	46.8
(2013/03/21 03:50:00.00)	57.3	68.9	48.4
(2013/03/21 03:55:00.00)	58.9	71.1	51
(2013/03/21 04:00:00.00)	57.2	73.4	51
(2013/03/21 04:05:00.00)	54.4	65	46.1
(2013/03/21 04:10:00.00)	58.7	66.4	52.1
(2013/03/21 04:15:00.00)	57.5	66.4	48.5
(2013/03/21 04:20:00.00)	57.8	68.5	47.1
(2013/03/21 04:25:00.00)	57.1	71	47.7

Date	L _{Aeq5min}	L _{Afmax}	L _{A(90,5min)}
(2013/03/21 04:30:00.00)	54.8	65.5	47.1
(2013/03/21 04:35:00.00)	58.8	70.9	47.9
(2013/03/21 04:40:00.00)	59.9	68.5	53.3
(2013/03/21 04:45:00.00)	57.7	65.8	49.4
(2013/03/21 04:50:00.00)	56.8	67.5	47.3
(2013/03/21 04:55:00.00)	59.8	68	51.6
(2013/03/21 05:00:00.00)	58.6	77	48.4
(2013/03/21 05:05:00.00)	59.1	69.4	52.2
(2013/03/21 05:10:00.00)	57.8	66.6	51.1
(2013/03/21 05:15:00.00)	60.3	76.7	51.5
(2013/03/21 05:20:00.00)	60	68.8	55.3
(2013/03/21 05:25:00.00)	59.9	68.9	55.7
(2013/03/21 05:30:00.00)	59.5	68.4	51.9
(2013/03/21 05:35:00.00)	60.6	74.9	53
(2013/03/21 05:40:00.00)	64.1	68.5	59.7
(2013/03/21 05:45:00.00)	61	70	55.9
(2013/03/21 05:50:00.00)	61.3	68.8	54
(2013/03/21 05:55:00.00)	61.5	72	53.3
(2013/03/21 06:00:00.00)	61.2	68.1	54.2
(2013/03/21 06:05:00.00)	62	73.3	56.3
(2013/03/21 06:10:00.00)	61.7	72.8	55
(2013/03/21 06:15:00.00)	61	69.8	54.3
(2013/03/21 06:20:00.00)	61.5	71.1	55.2
(2013/03/21 06:25:00.00)	63.7	78.2	56.8
(2013/03/21 06:30:00.00)	65.4	76.5	59.7
(2013/03/21 06:35:00.00)	61.8	76.2	56.3
(2013/03/21 06:40:00.00)	62.6	77.5	57.8
(2013/03/21 06:45:00.00)	62.8	74.8	56.8
(2013/03/21 06:50:00.00)	62.4	73.5	56
(2013/03/21 06:55:00.00)	62.1	73.7	57.6
(2013/03/21 07:00:00.00)	62.2	75.8	56.7
(2013/03/21 07:05:00.00)	62.5	73.1	57.2
(2013/03/21 07:10:00.00)	62.6	68.4	58.3
(2013/03/21 07:15:00.00)	67.3	81.8	57.2
(2013/03/21 07:20:00.00)	62.4	76.3	57.2
(2013/03/21 07:24:59.00)	62.9	74.3	57.7
(2013/03/21 07:30:00.00)	62.1	70.9	58
(2013/03/21 07:35:00.00)	62.8	73.5	58
(2013/03/21 07:39:59.00)	63.1	73.9	58.8
(2013/03/21 07:45:00.00)	64.9	82.5	58.6
(2013/03/21 07:50:00.00)	62.2	76.5	59.1
(2013/03/21 07:55:00.00)	61.8	71.8	58.4
(2013/03/21 08:00:00.00)	62.8	74.1	58.9
(2013/03/21 08:05:00.00)	62.1	71.4	58.5

Date	L _{Aeq5min}	L _{Afmax}	L _{A(90L5min)}
(2013/03/21 08:10:00.00)	62.7	71.7	59.2
(2013/03/21 08:15:00.00)	61.4	67.1	58.5
(2013/03/21 08:20:00.00)	62.6	71.6	58.8
(2013/03/21 08:25:00.00)	75.8	94	58.9
(2013/03/21 08:30:00.00)	62.5	67.9	59.4
(2013/03/21 08:35:00.00)	62.1	75.3	59.1
(2013/03/21 08:40:00.00)	70.8	87	58.8
(2013/03/21 08:45:00.00)	64.4	78.1	59.2
(2013/03/21 08:50:00.00)	73	92.6	60.2
(2013/03/21 08:55:00.00)	62.6	67.7	60.8
(2013/03/21 09:00:00.00)	64	72.7	60.9
(2013/03/21 09:05:00.00)	62.8	73	59.2
(2013/03/21 09:10:00.00)	63.1	75.7	60.6
(2013/03/21 09:15:00.00)	63.4	77.5	58.7
(2013/03/21 09:20:00.00)	60.8	72.7	57.6
(2013/03/21 09:25:00.00)	61.6	72.6	59
(2013/03/21 09:30:00.00)	62.7	72.3	60.3
(2013/03/21 09:35:00.00)	63.1	73.8	60.5
(2013/03/21 09:40:00.00)	64.2	78.9	61.1
(2013/03/21 09:45:00.00)	65.3	80.4	61.2
(2013/03/21 09:50:00.00)	64.3	80.9	60.3