
From: Miles Martin <Miles.Martin@socotec.com>

Sent: 24 April 2020 09:08

To: David Snaith <david.snaith@symmetrys.com>

Subject: Re: D9036-19 - 28 Redington Road, London - Response to checking engineer query.

Morning David,

Further to our conversation earlier this week regarding the statement made by the checking engineer (copy attached), our proposed response to Query No 1 of the statement is as follows:

- To date, information on the ground conditions across the overall site has been obtained by SOCOTEC's investigation No. D5513-15, an assessment of which was made in the report No D9036-19, dated October 2019. Subsequently, additional trial pits have been undertaken across the site by Symmetrys to gain further information on the existing foundations. We consider that the information currently available should be sufficiently representative of the ground conditions to allow a preliminary design to be undertaken, and for the planning application to be progressed. As stated in our report, however, for final design the ground conditions in the south-west corner of the site (an area not accessible during the initial investigation) should be investigated further in order to verify that the ground conditions present agree with those anticipated. One of the trial pits by Symmetrys was located in this area, and provided preliminary information. This should be supplemented by deeper investigation once suitable access has been arranged.

We trust this meets with your approval, but should you have any further comments or questions do let us know.

Regards

Miles

Miles Martin

Principal Engineer

0118 932 8888 / 07803 262 235

INFRASTRUCTURE AND ENERGY

Glossop House, Hogwood Lane Industrial Estate,
Finchampstead, Wokingham, RG40 4QW

www.socotec.co.uk

