


- NOTES**
- 1.00** THIS DRAWING IS REPRESENTATIVE OF PRIMARY CONTAINMENT INSTALLATIONS. ANY ADDITIONAL CABLE CONTAINMENT OR CONDUIT RUNS REQUIRED BY THE SPECIFICATION OR REQUIRED BY THE CONTRACTOR TO PROVIDE A COMPLETE INSTALLATION WILL BE DEEMED TO BE INCLUDED.
- 2.00** THIS DRAWING IS TO READ IN CONJUNCTION WITH ALL OTHER SERVICES INSTALLATION DRAWINGS AND WITH CO-ORDINATED MECHANICAL AND ELECTRICAL DRAWINGS PREPARED BY IN2 ENGINEERING DESIGN PARTNERSHIP.
- 3.00** ALL CABLE CONTAINMENT SYSTEMS AT ROOF LEVEL SHALL BE OF GALVANISED STEEL CONSTRUCTION RAISED "OFF" THE ROOF LEVEL ON UNI-STRUT SUPPORT BRACKETS.
- 4.00** A SPACING OF 300mm WILL BE PROVIDED BETWEEN ALL L.V. POWER DISTRIBUTION CABLE TRAY / LADDER SYSTEMS AND FIRE DETECTION CONTAINMENT SYSTEMS

- CABLE CONTAINMENT SYSTEM REFERENCE KEY**
- 225x50mm GALVANISED STEEL CABLE TRAY AT HIGH LEVEL FOR SUB-MAINS CABLE INSTALLATION.
- 100x50mm GALVANISED STEEL TRUNKING AT HIGH LEVEL FOR LIGHTING & GENERAL SERVICES.
- 150x50mm COMBINED ELV GALVANISED STEEL CABLE TRAY FOR I.T. STRUCTURED CABLING & FIRE ALARM.



DETAIL OF CABLE TRAY CROSS OVER

NOTE: ARCHITECTURAL DRAWING USED FOR COMPILATION OF IN2 DRAWING. ARCHITECTURAL DRAWING REVISION : P6 DATE RECEIVED : 28.09.2018

STATUS	DATE	DESCRIPTION	DRN	ENG	APP	REV
S4	18.10.2018	CONSTRUCTION ISSUE	KO	TH	BF	C1
D2	27.07.2018	TENDER ISSUE	JDT	JW	BF	T1



IN2
ENGINEERING DESIGN PARTNERSHIP
DUBLIN . ATHLONE . BELFAST . LONDON



PROJECT
BELSIZE PARK FIRESTATION

CLIENT
PLATINUM LAND

DRAWING TITLE
ELECTRICAL SERVICES INSTALLATION
FIRST FLOOR LEVEL
CABLE CONTAINMENT SERVICES LAYOUT

SCALE
1:100 @ A1
1:200 @ A3

SIZE
A1

PROJECT REF:
L18051

DRAWING No.
L18051-IN2-00-01-DR-E-7001

STATUS
S4

REVISION
C1