



- NOTES**
- THE INTRUDER ALARM SYSTEM SHALL BE WIRED IN MULTICORE SECURITY SYSTEM CABLING BY THE ELECTRICAL CONTRACTOR. TAMPER PROOF PROTECTION IS TO BE PROVIDED TO ALL CIRCUITS & DEVICES.
 - THE SYSTEM IS TO BE INSTALLED, TESTED & COMMISSIONED & CERTIFIED IN FULL COMPLIANCE WITH BS EN 50136-1:2012.
 - THE ELECTRICAL CONTRACTOR SHALL EMPLOY THE SERVICES OF A REGISTERED ALARM INSTALLER.
 - THE POWER SUPPLY FOR THE INTRUDER ALARM SYSTEM SHALL BE COMPLETELY DEDICATED WITH THE MAIN DISCONNECTION DEVICE SECURED FROM UNAUTHORISED OPERATION.
 - ALL CABLING ASSOCIATED WITH CCTV SYSTEM TO BE CARRIED OUT BY THE ELECTRICAL CONTRACTOR UNDER THE INSTRUCTION OF THE SPECIALIST SECURITY CONTRACTOR.

- DOOR INTERCOM / DOOR ACCESS SYSTEM**
- INTERCOM CALL STATION STATION. IP65 RATED & VANDAL RESISTANT
 - WALL MOUNTED VIDEO PHONE HANDSET C/W DOOR RELEASE FUNCTION AND INDUCTIVE AUDIO COUPLER.
 - GREEN BREAK GLASS UNIT FOR EMERGENCY RELEASE.
 - DOOR ACCESS REQUEST TO EXIT BUTTON (STAINLESS STEEL FINISH)
 - TRANSOMAGNETIC DOOR LOCKS C/W INTEGRAL INTRUDER ALARM CONTACTS.
 - ACD CARD READER
 - POWER SUPPLY UNIT
 - INTRUDER ALARM PANEL.
 - CCTV - FIXED CCTV CAMERA C/W VANDAL PROOF HOUSING.
 - INTERNAL INTRUDER ALARM SOUNDER (SOUND BOMB TYPE).
 - INTRUDER ALARM REMOTE KEYPAD AT 1350mm AFFL.

DOOR ACCESS REQUEST TO EXIT



CCTV CAMERA - TYPE 3



KEY OPERATED GREEN EMERGENCY BREAK GLASS UNIT



EXTERNAL VIDEO / AUDIO INTERCOM



CCTV CAMERA - TYPE 2



CCTV CAMERA - TYPE 1



INTERNAL VIDEO / AUDIO INTERCOM



NOTE: ARCHITECTURAL DRAWING USED FOR COMPILATION OF IN2 DRAWING. ARCHITECTURAL DRAWING REVISION: DATE RECEIVED:

STATUS	DATE	DESCRIPTION	DRN	ENG	APP	REV
S4	18.10.2018	CONSTRUCTION ISSUE	KO	TH	BF	C1
D2	20.06.2018	TENDER ISSUE	KO	EB	BF	T1



IN2
ENGINEERING DESIGN PARTNERSHIP
DUBLIN . ATHLONE . BELFAST . LONDON



PROJECT
BELSIZE PARK FIRESTATION
CLIENT
PLATINUM LAND

DRAWING TITLE
**ELECTRICAL SERVICES INSTALLATION
FIRST FLOOR LEVEL
SECURITY & ACCESS CONTROL SERVICES LAYOUT**
SCALE
1:100 @ A1
1:200 @ A3
SIZE
A1
PROJECT REF:
L18051
DRAWING No.
L18051-IN2-00-01-DR-E-8001

STATUS
S4
REVISION
C1