


Printed on: 18/05/2020 09:10:05

Application No:	Consultees Name:	Received:	Comment:	Response:
2020/1134/P		15/05/2020 17:40:51	WREP	<p>I would be very concerned if the noise levels impact the amenity of my flat, which is directly above where the refrigeration units will be installed.</p> <p>It is therefore critical that the planning consent, if granted, includes your standard planning condition to ensure that the equipment installed does indeed meet Camden's noise requirements, namely:</p> <p>"Noise levels at a point 1 metre external to sensitive facades shall be at least 10dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment (or any part of it) is in operation etc etc."</p>
