

## Project name

**No 18 Park Square East - Be Green****As designed****Date:** Fri May 15 07:44:25 2020

## Administrative information

## Building Details

**Address:** 18 Park Square East, London,

## Certification tool

**Calculation engine:** Apache**Calculation engine version:** 7.0.12**Interface to calculation engine:** IES Virtual Environment**Interface to calculation engine version:** 7.0.12**BRUKL compliance check version:** v5.6.a.1

## Owner Details

**Name:****Telephone number:****Address:** , ,

## Certifier details

**Name:** Cundall**Telephone number:** +442074381600**Address:** One Carter Lane, London, EC4V 5ER**Criterion 1: The calculated CO<sub>2</sub> emission rate for the building must not exceed the target**

|  |                     |
|--|---------------------|
| CO <sub>2</sub> emission rate from the notional building, kgCO <sub>2</sub> /m <sup>2</sup> .annum | 19.4                |
| Target CO <sub>2</sub> emission rate (TER), kgCO <sub>2</sub> /m <sup>2</sup> .annum               | 19.4                |
| Building CO <sub>2</sub> emission rate (BER), kgCO <sub>2</sub> /m <sup>2</sup> .annum             | 15.7                |
| Are emissions from the building less than or equal to the target?                                  | BER ≤ TER           |
| Are as built details the same as used in the BER calculations?                                     | Separate submission |

**Criterion 2: The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency**

Values which do not achieve the standards in the Non-Domestic Building Services Compliance Guide and Part L are displayed in red.

## Building fabric

| Element   | U <sub>a</sub> -Limit | U <sub>a</sub> -Calc | U <sub>i</sub> -Calc | Surface where the maximum value occurs*  |
|---|-----------------------|----------------------|----------------------|--|
| Wall**  | 0.35                  | 0.2                  | 0.22                 | RM000008:Surf[2]                         |
| Floor   | 0.25                  | 0.2                  | 0.58                 | BC000003:Surf[3]                         |
| Roof  | 0.25                  | 0.14                 | 0.14                 | RM000008:Surf[0]                         |
| Windows***, roof windows, and rooflights  | 2.2                   | 1.33                 | 1.4                  | F3000000:Surf[0]                         |
| Personnel doors   | 2.2                   | -                    | -                    | No Personnel doors in building           |
| Vehicle access & similar large doors  | 1.5                   | -                    | -                    | No Vehicle access doors in building      |
| High usage entrance doors   | 3.5                   | -                    | -                    | No High usage entrance doors in building |
| U <sub>a</sub> -Limit = Limiting area-weighted average U-values [W/(m <sup>2</sup> K)]<br>U <sub>a</sub> -Calc = Calculated area-weighted average U-values [W/(m <sup>2</sup> K)]<br>U <sub>i</sub> -Calc = Calculated maximum individual element U-values [W/(m <sup>2</sup> K)] |                       |                      |                      |  |
| * There might be more than one surface where the maximum U-value occurs.  |                       |                      |                      |  |
| ** Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.  |                       |                      |                      |  |
| *** Display windows and similar glazing are excluded from the U-value check.  |                       |                      |                      |  |
| N.B.: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.  |                       |                      |                      |  |

| Air Permeability                             | Worst acceptable standard | This building |
|--|---------------------------|---------------|
| m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa | 10                        | 3             |

## Building services

The standard values listed below are minimum values for efficiencies and maximum values for SFPs. Refer to the Non-Domestic Building Services Compliance Guide for details.

|  |       |
|--|-------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES   |
| Whole building electric power factor achieved by power factor correction                     | >0.95 |

### 1- Be Green VRF FCUs - AHU (Reception, Atrium and Meeting Rms)

|   | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|---|--------------------|--------------------|--------------------|---------------|---------------|
| This system   | 3                  | 4.5                | 0                  | 1.6           | 0.75          |
| Standard value  | 2.5*               | 3.2                | N/A                | 1.6^          | 0.65          |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system   |                    |                    |                    |               | YES           |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. For types <=12 kW output, refer to EN 14825 for limiting standards.                   |                    |                    |                    |               |               |
| ^ Limiting SFP may be extended by the amounts specified in the Non-Domestic Building Services Compliance Guide if the system includes additional components as listed in the Guide. |                    |                    |                    |               |               |

### 2- Be Green Electric Heaters - MVHR (Basement chg rms and showers)

|   | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|---|--------------------|--------------------|--------------------|---------------|---------------|
| This system   | 1                  | -                  | 0.2                | 0             | 0.75          |
| Standard value  | N/A                | N/A                | N/A                | N/A           | 0.5           |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system |                    |                    |                    |               | YES           |

### 3- Be Green VRF CAM-V system - AHU (Open Plan Offices)

|   | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|---|--------------------|--------------------|--------------------|---------------|---------------|
| This system   | 3                  | 4.5                | 0                  | 0             | 0.75          |
| Standard value  | 2.5*               | 3.2                | N/A                | N/A           | 0.65          |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system   |                    |                    |                    |               | YES           |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. For types <=12 kW output, refer to EN 14825 for limiting standards. |                    |                    |                    |               |               |

"No HWS in project, or hot water is provided by HVAC system"

### Local mechanical ventilation, exhaust, and terminal units

| ID | System type in Non-domestic Building Services Compliance Guide  |
|----|---|
| A  | Local supply or extract ventilation units serving a single area   |
| B  | Zonal supply system where the fan is remote from the zone   |
| C  | Zonal extract system where the fan is remote from the zone  |
| D  | Zonal supply and extract ventilation units serving a single room or zone with heating and heat recovery |
| E  | Local supply and extract ventilation system serving a single area with heating and heat recovery        |
| F  | Other local ventilation units   |
| G  | Fan-assisted terminal VAV unit  |
| H  | Fan coil units  |
| I  | Zonal extract system where the fan is remote from the zone with grease filter                           |

| Zone name       | SFP [W/(l/s)]     |     |     |     |     |     |     |     |     |   | HR efficiency |          |
|-----------------|-------------------|-----|-----|-----|-----|-----|-----|-----|-----|---|---------------|----------|
|                 | ID of system type | A   | B   | C   | D   | E   | F   | G   | H   | I |               |          |
|                 | Standard value    | 0.3 | 1.1 | 0.5 | 1.9 | 1.6 | 0.5 | 1.1 | 0.5 | 1 | Zone          | Standard |
| F3 - Atrium     |                   | -   | -   | -   | -   | -   | -   | -   | 0.3 | - | -             | N/A      |
| F3 - Atrium     |                   | -   | -   | -   | -   | -   | -   | -   | 0.3 | - | -             | N/A      |
| B - Circulation |                   | -   | -   | -   | 1.6 | -   | -   | -   | -   | - | -             | N/A      |

| Zone name                 | SFP [W/(l/s)] |     |     |     |     |     |     |     |   |      | HR efficiency |  |
|---------------------------|---------------|-----|-----|-----|-----|-----|-----|-----|---|------|---------------|--|
| ID of system type         | A             | B   | C   | D   | E   | F   | G   | H   | I |      |               |  |
| Standard value            | 0.3           | 1.1 | 0.5 | 1.9 | 1.6 | 0.5 | 1.1 | 0.5 | 1 | Zone | Standard      |  |
| B - Shower                | -             | -   | -   | 1.6 | -   | -   | -   | -   | - | -    | N/A           |  |
| B - Toilets               | -             | -   | -   | 1.6 | -   | -   | -   | -   | - | -    | N/A           |  |
| B - Female Changing Rms   | -             | -   | -   | 1.6 | -   | -   | -   | -   | - | -    | N/A           |  |
| B - Shower                | -             | -   | -   | 1.6 | -   | -   | -   | -   | - | -    | N/A           |  |
| B - Acc WC                | -             | -   | -   | 1.6 | -   | -   | -   | -   | - | -    | N/A           |  |
| B - Shower                | -             | -   | -   | 1.6 | -   | -   | -   | -   | - | -    | N/A           |  |
| B - Shower                | -             | -   | -   | 1.6 | -   | -   | -   | -   | - | -    | N/A           |  |
| B - Toilets               | -             | -   | -   | 1.6 | -   | -   | -   | -   | - | -    | N/A           |  |
| B - Circulation           | -             | -   | -   | 1.6 | -   | -   | -   | -   | - | -    | N/A           |  |
| B - Male Changing Room    | -             | -   | -   | 1.6 | -   | -   | -   | -   | - | -    | N/A           |  |
| F3 - Meeting Room         | -             | -   | -   | -   | -   | -   | -   | 0.3 | - | -    | N/A           |  |
| F3 - Toilets              | -             | -   | -   | 1.6 | -   | -   | -   | -   | - | -    | N/A           |  |
| F3 - Staircase            | -             | -   | -   | 1.6 | -   | -   | -   | -   | - | -    | N/A           |  |
| F3 - Open Plan Office     | -             | -   | -   | 1.6 | -   | -   | -   | -   | - | -    | N/A           |  |
| F3 - Open Plan Office Per | -             | -   | -   | 1.6 | -   | -   | -   | -   | - | -    | N/A           |  |

| General lighting and display lighting |                | Luminous efficacy [lm/W] |      |              | General lighting [W] |
|---------------------------------------|----------------|--------------------------|------|--------------|----------------------|
| Zone name                             |                | Luminaire                | Lamp | Display lamp |                      |
|                                       | Standard value | 60                       | 60   | 22           |                      |
| B - UKPN                              |                | 80                       | -    | -            | 113                  |
| F3 - Atrium                           |                | -                        | 80   | -            | 49                   |
| F3 - Atrium                           |                | -                        | 80   | -            | 92                   |
| B - Circulation                       |                | -                        | 80   | -            | 50                   |
| B - Shower                            |                | -                        | 80   | -            | 26                   |
| B - Toilets                           |                | -                        | 80   | -            | 52                   |
| B - Female Changing Rms               |                | -                        | 80   | -            | 27                   |
| B - Shower                            |                | -                        | 80   | -            | 23                   |
| B - Acc WC                            |                | -                        | 80   | -            | 58                   |
| B - Plant                             |                | 80                       | -    | -            | 172                  |
| B - Shower                            |                | -                        | 80   | -            | 16                   |
| B - Shower                            |                | -                        | 80   | -            | 24                   |
| B - Toilets                           |                | -                        | 80   | -            | 54                   |
| B - Plant                             |                | 80                       | -    | -            | 54                   |
| B - LV switchroom                     |                | 80                       | -    | -            | 145                  |
| B - Comms Room                        |                | 80                       | -    | -            | 41                   |
| B - Circulation                       |                | -                        | 80   | -            | 87                   |
| B - Male Changing Room                |                | -                        | 80   | -            | 41                   |
| F3 - Meeting Room                     |                | 120                      | -    | -            | 334                  |
| F3 - Toilets                          |                | -                        | 80   | -            | 93                   |
| F3 - Staircase                        |                | -                        | 80   | -            | 43                   |
| F3 - Open Plan Office                 |                | 120                      | -    | -            | 1063                 |
| F3 - Open Plan Office Per             |                | 120                      | -    | -            | 1258                 |

### Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains

| Zone                      | Solar gain limit exceeded? (%) | Internal blinds used? |
|---------------------------|--------------------------------|-----------------------|
| F3 - Atrium               | YES (+53.6%)                   | NO                    |
| F3 - Atrium               | YES (+279.2%)                  | NO                    |
| F3 - Meeting Room         | NO (-86%)                      | NO                    |
| F3 - Toilets              | N/A                            | N/A                   |
| F3 - Staircase            | N/A                            | N/A                   |
| F3 - Open Plan Office     | NO (-68.7%)                    | NO                    |
| F3 - Open Plan Office Per | NO (-36.3%)                    | NO                    |

### Criterion 4: The performance of the building, as built, should be consistent with the calculated BER

Separate submission

### Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place

Separate submission

### EPBD (Recast): Consideration of alternative energy systems

|  |     |
|--|-----|
| Were alternative energy systems considered and analysed as part of the design process? | YES |
| Is evidence of such assessment available as a separate submission?                     | NO  |
| Are any such measures included in the proposed design?                                 | YES |

# Technical Data Sheet (Actual vs. Notional Building)

## Building Global Parameters

|   | Actual | Notional |
|---|--------|----------|
| Area [m <sup>2</sup> ]                                | 804.8  | 804.8    |
| External area [m <sup>2</sup> ]                       | 1606.2 | 1606.2   |
| Weather   | LON    | LON      |
| Infiltration [m <sup>3</sup> /hm <sup>2</sup> @ 50Pa] | 3      | 3        |
| Average conductance [W/K]                             | 465.58 | 553.8    |
| Average U-value [W/m <sup>2</sup> K]                  | 0.29   | 0.34     |
| Alpha value* [%]                                      | 12.42  | 10       |

\* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

## Building Use

| % Area | Building Type  |
|--------|--|
|        | A1/A2 Retail/Financial and Professional services                   |
|        | A3/A4/A5 Restaurants and Cafes/Drinking Est./Takeaways             |
| 100    | <b>B1 Offices and Workshop businesses</b>                          |
|        | B2 to B7 General Industrial and Special Industrial Groups          |
|        | B8 Storage or Distribution   |
|        | C1 Hotels  |
|        | C2 Residential Institutions: Hospitals and Care Homes              |
|        | C2 Residential Institutions: Residential schools                   |
|        | C2 Residential Institutions: Universities and colleges             |
|        | C2A Secure Residential Institutions                                |
|        | Residential spaces   |
|        | D1 Non-residential Institutions: Community/Day Centre              |
|        | D1 Non-residential Institutions: Libraries, Museums, and Galleries |
|        | D1 Non-residential Institutions: Education                         |
|        | D1 Non-residential Institutions: Primary Health Care Building      |
|        | D1 Non-residential Institutions: Crown and County Courts           |
|        | D2 General Assembly and Leisure, Night Clubs, and Theatres         |
|        | Others: Passenger terminals  |
|        | Others: Emergency services   |
|        | Others: Miscellaneous 24hr activities                              |
|        | Others: Car Parks 24 hrs   |
|        | Others: Stand alone utility block                                  |

## Energy Consumption by End Use [kWh/m<sup>2</sup>]

|                 | Actual       | Notional     |
|-----------------|--------------|--------------|
| Heating         | 3.77         | 4.75         |
| Cooling         | 5.21         | 5.12         |
| Auxiliary       | 7.48         | 3.18         |
| Lighting        | 8.7          | 17.17        |
| Hot water       | 5.89         | 8.85         |
| Equipment*      | 56.23        | 56.23        |
| <b>TOTAL **</b> | <b>31.05</b> | <b>39.09</b> |

\* Energy used by equipment does not count towards the total for consumption or calculating emissions.

\*\* Total is net of any electrical energy displaced by CHP generators, if applicable.

## Energy Production by Technology [kWh/m<sup>2</sup>]

|                       | Actual | Notional |
|-----------------------|--------|----------|
| Photovoltaic systems  | 0      | 0        |
| Wind turbines         | 0      | 0        |
| CHP generators        | 0      | 0        |
| Solar thermal systems | 0      | 0        |

## Energy & CO<sub>2</sub> Emissions Summary

|   | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m <sup>2</sup> ] | 99.48  | 102.7    |
| Primary energy* [kWh/m <sup>2</sup> ]         | 119.52 | 148.94   |
| Total emissions [kg/m <sup>2</sup> ]          | 15.7   | 19.4     |

\* Primary energy is net of any electrical energy displaced by CHP generators, if applicable.

| HVAC Systems Performance  |                   |                   |                    |                    |                   |               |               |                  |                  |      |
|---|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|------|
| System Type   | Heat dem<br>MJ/m2 | Cool dem<br>MJ/m2 | Heat con<br>kWh/m2 | Cool con<br>kWh/m2 | Aux con<br>kWh/m2 | Heat<br>SSEFF | Cool<br>SSEER | Heat gen<br>SEFF | Cool gen<br>SEER |      |
| [ST] Fan coil systems, [HS] Heat pump (electric): air source, [HFT] Electricity, [CFT] Electricity                        |                   |                   |                    |                    |                   |               |               |                  |                  |      |
|   | Actual            | 38.1              | 155                | 3.5                | 12                | 16.8          | 3             | 3.58             | 3                | 4.5  |
|   | Notional          | 17.8              | 75.8               | 1.9                | 5.6               | 10.7          | 2.56          | 3.79             | ----             | ---- |
| [ST] Split or multi-split system, [HS] Heat pump (electric): air source, [HFT] Electricity, [CFT] Electricity             |                   |                   |                    |                    |                   |               |               |                  |                  |      |
|   | Actual            | 42.4              | 67.1               | 3.9                | 5.5               | 6             | 3             | 3.36             | 3                | 4.5  |
|   | Notional          | 38.9              | 93.3               | 4.2                | 6.8               | 2.1           | 2.56          | 3.79             | ----             | ---- |
| [ST] Central heating using water: radiators, [HS] Direct or storage electric heater, [HFT] Electricity, [CFT] Electricity |                   |                   |                    |                    |                   |               |               |                  |                  |      |
|   | Actual            | 27.8              | 0                  | 7.7                | 0                 | 7.6           | 1             | 0                | 1                | 0    |
|   | Notional          | 55.3              | 0                  | 17.8               | 0                 | 3.3           | 0.86          | 0                | ----             | ---- |
| [ST] No Heating or Cooling  |                   |                   |                    |                    |                   |               |               |                  |                  |      |
|   | Actual            | 0                 | 0                  | 0                  | 0                 | 0             | 0             | 0                | 0                | 0    |
|   | Notional          | 0                 | 0                  | 0                  | 0                 | 0             | 0             | 0                | ----             | ---- |

## Key to terms

|                   |   |
|-------------------|---|
| Heat dem [MJ/m2]  | = Heating energy demand   |
| Cool dem [MJ/m2]  | = Cooling energy demand   |
| Heat con [kWh/m2] | = Heating energy consumption  |
| Cool con [kWh/m2] | = Cooling energy consumption  |
| Aux con [kWh/m2]  | = Auxiliary energy consumption  |
| Heat SSEFF        | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER        | = Cooling system seasonal energy efficiency ratio   |
| Heat gen SSEFF    | = Heating generator seasonal efficiency   |
| Cool gen SSEER    | = Cooling generator seasonal energy efficiency ratio  |
| ST                | = System type   |
| HS                | = Heat source   |
| HFT               | = Heating fuel type   |
| CFT               | = Cooling fuel type   |

# Key Features

The Building Control Body is advised to give particular attention to items whose specifications are better than typically expected.

## Building fabric

| Element  | U <sub>i-Typ</sub> | U <sub>i-Min</sub>   | Surface where the minimum value occurs*  |
|--|--------------------|--|--|
| Wall   | 0.23               | 0.14   | RM000003:Surf[1]                         |
| Floor  | 0.2                | 0.18   | RM000008:Surf[1]                         |
| Roof   | 0.15               | 0.14   | RM000008:Surf[0]                         |
| Windows, roof windows, and rooflights                                    | 1.5                | 1.1  | F300000B:Surf[0]                         |
| Personnel doors  | 1.5                | -  | No Personnel doors in building           |
| Vehicle access & similar large doors                                     | 1.5                | -  | No Vehicle access doors in building      |
| High usage entrance doors  | 1.5                | -  | No High usage entrance doors in building |
| U <sub>i-Typ</sub> = Typical individual element U-values [W/(m²K)]       |                    | U <sub>i-Min</sub> = Minimum individual element U-values [W/(m²K)] |  |
| * There might be more than one surface where the minimum U-value occurs. |                    |  |  |

| Air Permeability   | Typical value | This building |
|--------------------|---------------|---------------|
| m³/(h.m²) at 50 Pa | 5             | 3             |