



New ceiling mounted air-conditioning unit. Product Fujitsu ARYG09LLTA - Indoor unit. Unit to be mounted within ceiling void. Refer to drawing 548 (1) 4.102 for details.

New external condenser unit (AOYG30LAT4 - Multi Outdoor Unit -1No.) to be isolated from the structure of the building on neoprene-in-shears, anti-vibration mounts, MTEC WCAC30 Acousting cladding panels to be fixed to walls adjacent to unit. Refer to page 9 of Emtec Acoustic report.

New ceiling mounted air-conditioning unit. Fujitsu product ARYG09LLTA - Indoor Unit. Unit to be mounted within ceiling void. Refer to drawing 548 (1) 4.102 for details.

Proposed Lower Ground Floor Plan

rev.	date	description	revised by	audited by
B	2019.12.10	For planning	CC	HJ
A	2019.09.06	For planning	CC	HJ

stage	drawing title
PLANNING	PROPOSED Lower Ground Floor Plan

CONTRACTORS ARE NOT TO SCALE DIMENSIONS FROM THIS DRAWING

LIPTON PLANT ARCHITECTS

Seatem House
39 Moreland St
London
EC1V 8BB

T +44 (0)20 7288 1333
F +44 (0)20 7288 0333
E mail@lparchitects.co.uk
W www.lparchitects.co.uk

client
West Hill Projects Ltd

project
16 Cleveland Street
London
W1T 4HX

scale	date issued	drawn by	audited by	drawing no	revision
1:50 @A1 1:100 @A3	2019.09.05	CC	HJ	548 (1) 1.101	B