

Application ref: 2020/0187/P  
Contact: Alyce Jeffery  
Tel: 020 7974 3292  
Email: [Alyce.Jeffery@camden.gov.uk](mailto:Alyce.Jeffery@camden.gov.uk)  
Date: 2 July 2020

**Development Management**  
Regeneration and Planning  
London Borough of Camden  
Town Hall  
Judd Street  
London  
WC1H 9JE  
Phone: 020 7974 4444  
[planning@camden.gov.uk](mailto:planning@camden.gov.uk)  
[www.camden.gov.uk/planning](http://www.camden.gov.uk/planning)

Daniel Watney LLP  
165 Fleet Street  
London  
EC4A 2DW

Dear Sir/Madam

## **DECISION**

Town and Country Planning Act 1990 (as amended)

### **Full Planning Permission Granted**

Address:  
**Ground & Basement Floors**  
**4-5 Centric Close**  
**London**  
**NW1 7EP**

#### **Proposal:**

Alteration to the existing fenestration to side elevation (northern elevation); installation of a roof light above ground floor roof; and erection of plant including 5 x condenser units and an acoustic enclosure to the rear of the site at ground floor.

Drawing Nos: Covering Letter; Noise Impact Assessment rev 1; PURY data; Heat gains covering letter; CIBSE heat gains calculations; Window Specification NBS Alitherm Heritage; Window Brochure Alitherm Heritage; Faade design life datasheet; EEC Acoustiline Wall Lining System; EEC Acoustic Screen Specification; EEC Acoustic Panelwork; EEC Louvres; 19136 PLN 03 rev A; 19136 PLN 04 rev A; 19136 PLN 05 rev A; 19136 PLN 09 rev B; 19136 PLN 01 rev A; 19136 PLN 02 rev A; 19136 PLN 06 rev B; 19136 PLN 07 rev A; 19136 PLN 08 rev C; 19136 PLN 10 rev B; QAL5496-57-M02 rev B.

The Council has considered your application and decided to grant permission subject to the following condition(s):

#### **Condition(s) and Reason(s):**

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 of the London Borough of Camden Local Plan 2017.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans [19136 PLN 01 rev A; 19136 PLN 02 rev A; 19136 PLN 06 rev B; 19136 PLN 07 rev A; 19136 PLN 08 rev C; 19136 PLN 10 rev B; QAL5496-57-M02 rev B]

Reason: For the avoidance of doubt and in the interest of proper planning.

- 4 The external noise level emitted from plant, machinery or equipment at the development hereby approved shall be lower than the lowest existing background noise level by at least 10dBA, by 15dBA where the source is tonal, as assessed according to BS4142:1997 at the nearest and/or most affected noise sensitive premises, with all machinery operating together at maximum capacity.

Reason: To safeguard the amenities of neighbouring noise sensitive receptors in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 5 Before the use commences, plant shall be provided with acoustic isolation, and anti-vibration measures. All such measures shall thereafter be retained and maintained in accordance with the manufacturers' recommendations.

Reason: To prevent the transmission of noise and vibration throughout the building and or into any neighbouring premises, thus safeguarding the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant licence from the Council's Streetworks Authorisations & Compliance Team London Borough of Camden 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444) . Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106

agreement), no licence or authorisation will be granted until the Construction Management Plan is approved by the Council.

- 2 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website at <https://beta.camden.gov.uk/documents/20142/1269042/Camden+Minimum+Requirements+%281%29.pdf/bb2cd0a2-88b1-aa6d-61f9-525ca0f71319> or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these hours.

- 3 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2019.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully



Daniel Pope  
Director of Economy, Regeneration and Investment