

HORIZON AIR CONDITIONING PARTS AND GENERAL SPECIFICATION AIR CONDITIONING EQUIPMENT & TYPE AHU MODEL C/U MODEL UNIT HANGING METHOD REFRIGERATION PIPEWORK SIZES DRAIN OF AHU SIZE C/U DRAIN SIZE DUCTWORK SUPPLY RETURN FRESH AIR TOILET EXTRACTION TOILET SUPPLY GENERAL EXTRACTION SMOKE EXTRACTION TERMINAL INSULATION FANS, SIZE & TYPE SUPPLY EXTRACTION TOILET SMOKE OVER DOOR HEATER ELECTRIC DUCT HEATER GENERAL REQUIREMENTS; ELECTRICAL CONTRACTOR TO PROVIDE THE FOLLOWING SUPPLIES TO SWITCHED FUSED ISOLATOR POINTS ADJACENT TO AIR CONDITIONING PLANT AND GENERAL ELECTRICAL REQUIREMENTS, ELECTRICAL CONTRACTOR SHOULD ALLOW FOR CONTROL WIRING BETWEEN FIRE ALARM PANELS AND AIR CONDITIONING CONTROL PANELS TO THE APPROVAL CLIENT/ARCHITECT.
PLEASE NOTE: RUNNING CURRENTS OF AIR CONDITIONING/ VENTILATION PLANT ARE SHOWN A»OVE THEREFORE, FUSES SHOULD BE H.R.C. TYPE OR SIMILAR TO ACCOUNT FOR INITIAL STARTING CURRENTS. ALL WORK TO BE IN ACCORDANCE WITH I.E.E. REGULATIONS. SHOPFITTER/BUILDING WORK MAIN CONTRACTOR TO ALLOW FOR ALL BUILDERS WORK RELATED TO THE AIR CONDITIONING AND VENTILATION WORKS AND MAKING GOOD OF THE SAME ON COMPLETION OF THE INSTALLATION TO ALLOW FOR POSITIONING OF DUCTWORK. PIPEWORK, ELECTRICAL CABLE AND OTHER ASSOCIATED WORKS.



HORIZON AIR CONDITIONING LTD
UNIT 8,EMBASSY INDUSTRIAL ESTATE
ATTWOOD STREET,LYE
STOURBRIDGE
WEST MIDLANDS,DY9 8RY
TEL: 01384 893139 WEB: WWW.HORIZONAC.CO.UK
FAX: 01384 892854 E-MAIL: CONTACT@HORIZONAC.CO.

FAX: 01384 892854 E-MAIL: CONTACT@HORIZONAC.CO.UK

CLIENT TAMARES

IDL SITE LOCATION

MAIN CONTRACTOR

19 FITZROY SQUARE LONDON

HVAC - FIRST FLOOR

DRAWING TITLE

DRAWN BY CHECKED BY JRM SM

I:50@AI I:100@A3 DRAWING No

J 200000 - 03 FF

O ZOOOO

REVISIONS

Α. Χ

В. Х

c. X

D. X

THIS DRAWING IS THE PROPERTY OF HORIZON AIR CONDITIONING LTD. COPYRIGHT IS RESERVED BY THEM AND THE DRAWING IS ISSUED ON CONDITION THAT IT IS NOT COPIED, REPRODUCED, RETAINED OR DISCLOSED TO ANY UNAUTHORISED PERSON. EITHER WHOLLY OR IN PART WITHOUT THE CONSENT IN WRITING OF HORIZON AIR CONDITIONING LTD.