

Application No:	Consultees Name:	Received:	Comment:	Response:
2017/6876/L	Richard Simpson for Primrose Hill CAAC	27/08/2020 18:16:52	NOBJ	<p>ADVICE from Primrose Hill Conservation Area Advisory Committee 12A Manley Street, London NW1 8LT</p> <p>20 August 2020</p> <p>14 Gloucester Crescent NW1 7DS 2017/6876/L</p> <p>No objection & comment</p> <p>We advised on 17 January 2018 that the drawings for this scheme were inadequate for the assessment of work to the Listed Building. This is an acceptable application.</p> <p>We advise on two technical issues. A lime-cement-sand mortar would be preferable to cement-sand to improve the breathability of the mortar. A locally sourced natural slate, Welsh slate, should be preferred to imported slate, to reduce the carbon footprint of the work. Welsh slate was the original roofing material used on these houses.</p> <p>Richard Simpson FSA Chair</p>
