


- 1. THIS DRAWING IS THE PROPERTY OF HITEK CONSULTANTS LIMITED AND IS PROTECTED UNDER THE COPYRIGHTS DESIGNS AND PATENTS ACT 1988. ALL RIGHTS RESERVED. THIS DRAWING IS ISSUED ON CONDITION THAT IT IS NOT COPIED. REPRINTED OR REPRODUCED, WHOLLY OR IN PART, WITHOUT THE CONSENT OF HITEK CONSULTANTS LIMITED.
- 2. DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS AND SETTING OUT TO BE TAKEN FROM ARCHITECTURAL DRAWINGS.
- 3. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE ARCHITECTS, STRUCTURAL ENGINEERS AND ALL OTHER SERVICES DRAWINGS AND SPECIFICATIONS.
- 4. THE INFORMATION CONTAINED ON THIS DRAWING HAS BEEN PRODUCED FROM A NON DESTRUCTIVE VISUAL SURVEY AND RECORD DOCUMENTATION ONLY. IT IS THE THE CONTRACTORS RESPONSIBILITY TO VERIFY ALL INFORMATION PRIOR
- TO ANY SERVICES BEING ISOLATED AND STRIPPED OUT. 5. NEW DUCTWORK EXPOSED WITH GALVANISED FINISH AND COMPLETELY CLEAN WITH NO BLEMISHES.
- 6. NEW CROSSTALK ATTENUATORS EXPOSED WITH GALVANISED FINISH.
- 7. CHILLED WATER PIPEWORK AND VALVES TO BE PROVIDED WITH FOIL FACED THERMAL INSULATION FULLY VAPOUR PROOFED
- 8. CONDENSATE PIPEWORK TO BE PROVIDED WITH FOIL FACED THERMAL INSULATION FOR 1ST 3.0m RUN
- 9. ROOM CONDITIONER TO BE 4 WAY CASSETTE SUSPENDED FROM SOFFIT
- 10. THIS DRAWING INDICATES ENGINEERING SERVICES INSTALLATION WORK ONLY
- 11. THE CONTRACTOR SHALL CO-ORDINATE ALL SERVICE ACCESS POSITIONS WITH

AND MUST NOT BE TAKEN AS ACCURATELY REPRESENTING ANY OTHER DETAIL.

- OTHER TRADES.
- 12. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED.
- 13. ALL SERVICES ARE TO BE FIRE STOPPED IN ACCORDANCE WITH THE LATEST
- 14. UNISTRUT AND DROP RODS TO BE FITTED WITH RUBBER END CAPS.
- 15. CHILLED WATER TO LINK CORRIDOR AND PHILLIPS BUILDING CORRIDOR TO BE INSTALLED OUTSIDE NORMAL WORKING HOURS AS DETAILED WITHIN THE
- SPECIFICATION TYPICALLY 22.00 08.00 HOURS. 16. NO FIXINGS ARE ALLOWED INTO CONCRETE COLUMNS.
- 17. FOR SECTIONS REFER TO DRAWING No. 5975/M100



FOR TENDER ONLY

P1 18.12.19 PRELIMINARY ISSUE CAM	1101	Dute	Details		Onc
	Rev	Date	Details	Rv	Cho
TI TO.OZ.ZO TENDER ISSUE	P1	18.12.19	PRELIMINARY ISSUE		DTS
T1 10.02.20 TENDER ISSUE CAM F	T1	10.02.20	TENDER ISSUE		FMc



## Hitek Consultants Ltd

Chartered Building Services Consulting Engineers The Stables

Parsonage Farm Hollow Hill Lane Iver, Bucks

T 01753 650 310 T 0844 880 5701 F 0844 880 5702

E info@hitekconsultants.co.uk cad@hitekconsultants.co.uk www.hitekconsultants.co.uk

SOAS UNIVERSITY OF LONDON LTM 2019, PHILIPS BUILDING, LIBRARY LEVEL A

SOAS

KENDALL KINGSCOTT

LIBRARY LEVEL A PROPOSED VENTILATION & COMFORT COOLING LAYOUT

Scale		Drawing no.
	1:100 <b>@</b> A1	5975/M200
Date	DECEMBER 2019	Revision T1
Designed	FMc	Cad ref 5975M200-T1
Drawn	CAM	Checked DTS
	<u>CC</u>	PYRIGHT NOTICE
		RTY OF HITEK CONSULTANTS LIMITED. COPIES OF ARE PROHIBITED WITHOUT EXPRESS PERMISSION