

Application ref: 2019/6233/P
Contact: Alyce Jeffery
Tel: 020 7974 3292
Email: Alyce.Jeffery@camden.gov.uk
Date: 15 September 2020

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE

Phone: 020 7974 4444

planning@camden.gov.uk
www.camden.gov.uk/planning

Montagu Evans LLP
5 Bolton Street
London
W1J 8BA

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Householder Application Granted

Address:

**30 Great James Street
London
WC1N 3EY**

Proposal:

Installation of 2 x air condensing units at roof level; replacement of the existing glass balustrade and steel handrail to the first floor rear roof terrace and lower ground floor courtyard with painted wrought iron railings; replacement of existing modern tiles at the front door step with Yorkstone.

Drawing Nos: Cover Letter; Design & Access Statement; Planning and Heritage Statement; Noise Report Rev C; Cooling Hierarchy Statement; P1-0B; P100_REVB; P101_REVB; P102_REVB; P103_REVB; P104 Rev A; P200 Rev A; P300 Rev B; P601; P602; P603; P604]

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 and D2 of the London Borough of Camden Local Plan 2017.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans [P1-0B; P100_REVB; P101_REVB; P102_REVB; P103_REVB; P104 Rev A; P200 Rev A; P300 Rev B; P601; P602; P603; P604]

Reason: For the avoidance of doubt and in the interest of proper planning.

- 4 Before the relevant part of the work is begun, detailed drawings and manufacturer's specification details of the courtyard railings shall be submitted to and approved in writing by the Local Planning Authority. The relevant part of the works shall be carried out in accordance with the details thus approved.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policies D1 and D2 of the London Borough of Camden Local Plan 2017.

- 5 The external noise level emitted from plant, machinery or equipment at the development hereby approved shall be lower than the typical background noise level by at least 10dBA, by 15dBA where the source is tonal, as assessed according to BS4142:2014 at the nearest and/or most affected noise sensitive premises, with all machinery operating together at maximum capacity

Reason: To safeguard the amenities of neighbouring noise sensitive receptors in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 6 Prior to use, machinery, plant or equipment and ducting at the development shall be mounted with proprietary anti-vibration isolators and fan motors shall be vibration isolated from the casing and adequately silenced and maintained as such.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building

Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS
(tel: 020-7974 6941).

- 2 You are advised that any works of alterations or upgrading not included on the approved drawings which are required to satisfy Building Regulations or Fire Certification may require a further application for listed building consent.
- 3 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website at <https://beta.camden.gov.uk/documents/20142/1269042/Camden+Minimum+Requirements+%281%29.pdf/bb2cd0a2-88b1-aa6d-61f9-525ca0f71319> or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these hours.

- 4 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant licence from the Council's Streetworks Authorisations & Compliance Team London Borough of Camden 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444) . Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106 agreement), no licence or authorisation will be granted until the Construction Management Plan is approved by the Council.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2019.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully



Daniel Pope
Director of Economy, Regeneration and Investment