CU 1	Split condensing unit	Basement	Comms Room	New	Daikin RZQ71	7.1 kW / 8.0 kW	770 x 900 x 320	67 kg	48 dBA	20amp SP&N
CU 2	Split condensing unit	Basement	Staff Room	New	Daikin RXS50	3.3 kW / 4.0 kW	735 x 825 x 300	48 kg	48 dBA	20amp SP&N
CU 3	Split condensing unit	Basement	Bull Pen	New	Daikin RXS50	3.3 kW / 4.0 kW	735 x 825 x 300	48 kg	48 dBA	20amp SP&N

[redacted]

NOTES

1. THIS DRAWING IS BASED ON AEGIS DESIGN DRAWING REFERENCE:

ISSUE	DESCRIPTION	BY	DATE

air cool engineering
Midlands Limited
Fairway House, Falcon Park,
Neachells Lane, Wolverhampton
Telephone 01902 497 000
Fax 01902 497 001
Email: mail@aircoolmidlands.co.uk
www.aircoolengineering

PROJECT
BARCLAYS BANK – HAMPSTEAD HIGH STREET REMODEL

CLIENT
KILLBY & GAYFORD

DWG. TITLE
BASEMENT
HVAC LAYOUT

DRAWN: ST	CHECKED: VN
DATE: 25.05.2011	SCALE: 1:100@A3
DRAWING NUMBER: ACE-HAMPSTEAD-M/00/D1	REVISION: *

This drawing is the copyright of Air Cool Engineering Limited
It must not be copied or reproduced without the
permission in writing of Air Cool Engineering Limited.

COPYRIGHT Air Cool Engineering Limited 2001