




269 Camden High Street, NW/1

Internal Daylight Assessment for Planning

Job No: 3531
Issued: September, 2020
Issue: 1





Contents

1.0	Introduction.....	3
2.0	Project Summary.....	4
3.0	Methodology.....	5
4.0	Room Schedules.....	6
5.0	Daylight Results.....	8
6.0	Conclusions.....	11

Document Control

Originator

Sam Westover

Date

14.09.20

Signature

Checker

Bernice Waterman

Date

14.09.20

Signature



1.0 Introduction

1.1 This daylight and sunlight assessment has been prepared to support a planning application for the proposed redevelopment of 269 Camden High Street, NW1.


1.2 The report assesses the proposals in respect of daylight matters within habitable rooms in the proposed development, having regard to industry standard guidance. The report concludes that the proposal is acceptable and in accordance with planning policy requirements in relation to daylight for those rooms assessed.

1.3 There is no existing specific National Planning Policy relating to the prospective impacts of developments on daylight and sunlight on their surrounding environment.


1.4 However, the BRE Report 'Site Layout Planning for Daylight and Sunlight: A Guide to Good Practice' is the established National guidance to aid the developer to prevent and/or minimise the impact of a new development on the availability of daylight within new proposals. It has been developed in conjunction with daylight and sunlight recommendations in BS 8206: Part 2: 'Lighting for Buildings - Code of Practice for Daylighting'

1.5 This reference document is accepted as the authoritative work in the field on daylight, sunlight and overshadowing and is specifically referred to in many Local Authorities' planning policy guidance for daylighting. The methodology therein has been used in numerous lighting analyses and the standards of natural light are accepted as the industry standards.

2.0 Project Summary



Site Location



- 2.1 The proposal site is currently occupied by a terraced building on Camden High Street. The basement and ground floor are occupied by commercial units; first and second floors are occupied by residential.
- 2.2 The proposal is for the refurbishment and extension of the existing first and second floors.
- 2.3 The design team wish to ensure that habitable rooms in the first and second floor will receive sufficient daylight for their intended uses, in excess of the minimum values prescribed by BS8206:2
- 2.4 2D CAD drawings have been provided to us by the project Architect. These have been used to construct a 3D analysis model in order to assess the internal daylight levels within each room.
- 2.5 Computer simulation modelling has been used to produce the results, presented below.

3.0 Methodology

3.1 This report looks at the internal daylight that the new dwellings will receive using the standard methodology as prescribed by BRE and British Standard guidance:

- Average Daylight Factor (ADF) - Daylight availability

3.2 The ADF is derived from British Standard BS 8206 and is a complex and representative calculation to determine natural internal luminance (daylight).

3.3 It takes into account such factors as window size, number of windows available to the room, room size and layout, room surface reflectance, and the angle of visible sky reaching the window.

3.4 Due to the complexity of the daylight entering the proposed rooms, ADF is the most suitable calculation to give a realistic indication of the internal illuminance that will be experienced.

3.5 Calculations have been undertaken in accordance with BRE methodology, using a CIE overcast sky at an illuminance value of 8500 lux.


3.6 The internal finishes of the rooms were modelled as:

- Walls - plaster - Reflectance 0.561
- Floor - mid grey finish - Reflectance 0.592
- Ceiling - white finish - Reflectance 0.702

3.7 Daylight levels are then calculated at nodal points across a nodal grid set 850mm above the finished floor level. The rooms to be assessed are shown below along with the numerical results and distribution diagrams have for all rooms been provided.

First Floor as Proposed

4.0 Room Schedules



Second Floor as Proposed



5.0 Daylight Results

Average Daylight Factor				
Unit	Floor	Room	Target ADF	Actual ADF
1	First	Kitchen/Living/Bedroom	2.00%	3.35%
2	First	Kitchen/Living/Bedroom	2.00%	10.03%
3	First	Kitchen/Living/Bedroom	2.00%	3.43%
4	First	Kitchen/Living/Bedroom	2.00%	2.99%
5	Second	Kitchen/Living/Bedroom	2.00%	3.95%
6	Second	Kitchen/Living/Bedroom	2.00%	10.98%






Proposed First Floor

Daylight Distribution Diagrams

Not to Scale



Proposed Second Floor

Daylight Distribution Diagrams

Not to Scale

6.0 Conclusions

6.1 The proposed development at 269 Camden High Street, NW1 has been assessed for internal daylight levels using the Average Daylight Factor (ADF) test as prescribed by the BRE guidance and BS8206:2.

6.2 The design team has endeavoured to provide a solution to lighting the rooms within the constraints of the site.

6.3 This has been successfully achieved, as demonstrated by the positive results presented within this report.

6.4 The assessed rooms meet and exceed the recommendations of BS8206 and the BRE guidance using the ADF test.

6.5 This means the future occupants will enjoy a well lit environment, with reduced reliance on artificial lighting.

6.6 It is therefore the conclusion of this report that the assessed rooms meet the guidance levels for daylight and are therefore acceptable in planning terms.

T16 Design Ltd.
Studio 105,
37 Queen Street
Colchester
CO1 2PQ

01206 572452
info@t16design.com
www.t16design.com

This report has been prepared for the exclusive use of the commissioning party and may not be reproduced without prior written permission from T16 Design. All work has been carried out within the terms of the brief using all reasonable skill, care and diligence. No liability is accepted by T16 Design for the accuracy of data or opinions provided by others in the preparation of this report, or for any use of this report other than for the purpose for which it was produced.

© 2020 - T16 Design Ltd.

