

This drawing is the copyright of SVM. It may not be copied or disclosed to any third party for any purpose except as authorised in writing by SVM. This drawing is to be read in conjunction with all other relevant drawings and specifications and any discrepancy, variation or ommision is to be reported to SVM before the affected work commences. All dimensions in millimetres unless otherwise stated. Do not scale from this drawing. Figured dimensions only are to be used. Dimensions are to be checked on site before work



THE CONTRACTOR SHALL BE AWARE OF THEIR RESPONSIBILITIES WITH REGARD TO THE CONSTRUCTION (DESIGN AND MANAGEMENT) REGULATIONS AND SHALL UNDERTAKE THE DESIGN AND SUBSEQUENT INSTALLATION OF THESE SERVICES HAVING TAKEN DUE CONSIDERATION OF THESE REGULATIONS.

IN CONJUNCTION WITH THE INFORMATION DETAILED UPON THIS DRAWING THE CONTRACTOR SHALL FAMILIARISE THEMSELVES WITH ALL RELATED SERVICES AND TRADE DRAWINGS, SPECIFICATIONS AND SCHEDULES, ETC., ASSOCIATED WITH THESE WORKS. THIS SHALL INCLUDE, BUT NOT LIMITED TO, THE ELECTRICAL, MECHANICAL, PUBLIC

HEALTH, ARCHITECTURAL AND STRUCTURAL WORKS.

3. THE CONTRACTOR SHALL FULLY COORDINATE ALL SERVICES USING THE COORDINATION AND INSTALLATION (WORKING) DRAWING PROCESS. THE CONTRACTOR SHALL COORDINATE WITH OTHER TRADES AND DISCIPLINES AND GENERAL COORDINATION WITH THE BUILDING FABRIC, STRUCTURE, ARCHITECTURAL FINISHES AND SPECIALIST TRADES.

. INFORMATION AND DETAILS RELATING TO THIS DRAWING ARE FOR INFORMATION PURPOSES ONLY AND DO NOT CONSTITUTE THE EXTENT OF THE DESIGN INFORMATION OR ANY PART THEREOF. SIZES, DUTIES, RATINGS ETC. OF ANY PLANT OR EQUIPMENT DETAILED UPON THESE DRAWINGS ARE FOR GUIDANCE PURPOSES ONLY AND SHOULD BE CONFIRMED BY THE DESIGN AND BUILD CONTRACTOR.

5. THIS DRAWING IS NOT FOR CONSTRUCTION. 6. ALL DEVICES TO BE LEFT WITH 3m OF CABLE COILED UP TO ALLOW FOR RELOCATION OF DEVICE.

FIRE ALARM LOCKABLE SWITCH AS MK ELECTRIC K4780WHI

WP WEATHERPROOF

FIRE ALARM BREAK GLASS UNIT )) SMOKE DETECTOR WITH INTEGRAL SOUNDER

SMOKE DETECTOR WITH INTEGRAL SOUNDER & FLASHING BEACON

RI REMOTE INDICATOR

FAP FIRE ALARM PANEL

INTERFACE UNIT
1) SECURITY
2) AHU's
3) BMS
4) KOKO SOCIAL
5) MEDIA/AV
6) IT

FIRE ALARM BELL

/ 31.12.2001 Description
Rev. Date Details

STAGE 3

Consulting Engineers Building Services

Archer Humphryes Architects

Structural Engineer

Heyne Tillet Steel

Gardiner & Theobald LLP

Koko Camden Palace

The Mint Group

First Floor Fire Alarm Layout

Scale Date Orig. By Drawn By Checked 1:50@A0 AUG 2020 KD AL CBD

3100.E3.130