

Centric Close, Oval Road London, NW1 7EP

Mechanical Services Plant Noise Impact Assessment

Report ref.

RK2892/19443/Rev 2

Issued to

ThirdWay Interiors

Prepared by

Rob Kirkaldy BSc (Hons) MIOA
Senior Consultant

Version	Remarks	Date
Rev 0	Initial report issue.	02.01.2020
Rev 1	Revised as per updated scheme.	14.01.2020
Rev 2	Revised as per updated scheme.	18.08.2020



SECTION	TITLE	PAGE
1.	INTRODUCTION	1
2.	SITE DESCRIPTION & PROPOSALS	1
3.	NOISE CRITERIA	1
3.1	BS 4142:2014 METHODS FOR RATING AND ASSESSING INDUSTRIAL AND COMMERCIAL SOUND	1
3.2	GUIDELINES FOR COMMUNITY NOISE - WORLD HEALTH ORGANIZATION, 1999 (WHO)	2
3.3	CAMDEN COUNCIL'S PLANT NOISE CRITERIA	2
4.	BACKGROUND NOISE MEASUREMENT SURVEY	3
5.	ASSESSMENT OF NOISE IMPACT	5
5.1	PROJECTED NOISE FROM MECHANICAL PLANT	5
5.2	MECHANICAL PLANT NOISE IMPACT ASSESSMENT	6
6.	CONCLUSIONS	7
APPENDIX A:	Existing Site Location Plan	
APPENDIX B:	Scheme Proposals and Manufacturer's Data Sheets	
APPENDIX C:	Mechanical Plant Noise Prediction Model	



1. INTRODUCTION

Thirdway Interiors are seeking planning permission to install new mechanical services plant at Block A, 425 Centric Close in Camden. The proposed units would be located externally at the rear of a ground floor commercial unit which has flats directly above. Accordingly, a noise impact assessment is required.

Spectrum Acoustic Consultants have been instructed by Thirdway Interiors, to carry out a Noise Impact Assessment to support the application. This report is submitted with the intention of providing sufficient information to both inform and satisfy the requirements of the Local Planning Authority.

2. SITE DESCRIPTION & PROPOSALS

The development site is located at 425 Centric Close, Oval Road, NW1 7EP. The scheme is part of a wider development consisting of commercial units at ground floor level, with apartments directly above. Bounding the site to the north are existing flats. To the east are existing commercial and residential properties fronting on to Oval Road. Bounding the site to the south and west is a busy railway line leading Euston Station. An existing site location plan is included in Appendix A.

Proposals involve installing three external air conditioning condensers, as well as a ventilation system which discharges to atmosphere on the north side of the building. The units would provide cooling and ventilation air to a commercial unit which occupies the basement and ground floor levels of the building. The commercial unit would be used during normal office hours only i.e. typically 08:00 to 18:00. Scheme proposals are included in Appendix B.

3. NOISE CRITERIA

3.1 BS 4142:2014 METHODS FOR RATING AND ASSESSING INDUSTRIAL AND COMMERCIAL SOUND

The noise impact assessment relating to mechanical plant will be carried out in accordance with the procedures set out in BS 4142:2014 *Methods for rating and assessing industrial and commercial sound*. The principle of BS 4142 is to determine an initial estimate of impact of industrial/commercial sound on nearby residents by comparing the Rating Level (sound level from the industrial/commercial source, with a correction applied for any acoustic features that characterise the sound) with the Background Sound Level (L_{A90} as measured in absence of the industrial/commercial source).

Generally, the greater the difference by which the Rating Level exceeds the Background Sound Level, the greater the magnitude of impact. BS 4142 states that *'a difference of around +10 dB or more is likely to be an indication of a significant adverse impact [...]. A difference of around +5 dB is likely to be an indication of an adverse impact [...]. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact.'*

However, BS 4142 also advises that *'when making assessments and arriving at decisions [...] it is essential to place the sound in context'* so in each case, the context in which the sound is placed must be considered and the initial estimate of impact should be modified accordingly. For example it advises *'Where background sound levels and rating levels are low, absolute levels might be as, or more, relevant than the margin by which the rating level exceeds the background. This is especially true at night.'* It also indicates that impacts estimated during *'the middle of the night can be distinctly different (and potentially of lesser importance) compared to the start or end of the night-time period for sleep purposes.'*



3.2 GUIDELINES FOR COMMUNITY NOISE - WORLD HEALTH ORGANIZATION, 1999 (WHO)

Table 4.1 of WHO references a guideline façade level of $L_{Aeq,8 \text{ hour}}$ 45dB outside of bedrooms during the night time to avoid sleep disturbance. During the daytime and evening, Table 4.1 recommends a guideline noise level of $L_{Aeq,16 \text{ hour}}$ 55dB for outdoor living areas to avoid serious annoyance. Whilst noise levels outside of living rooms during the daytime are not listed in Table 4.1, a guideline internal level of $L_{Aeq,16 \text{ hour}}$ 35dB for habitable rooms is provided to avoid moderate annoyance. Given that a difference of 15dB(A) between noise levels outside and inside of bedrooms during the night time is stated, a guideline noise level of $L_{Aeq,16 \text{ hour}}$ 50dB outside of living rooms may be assumed.

3.3 CAMDEN COUNCIL'S PLANT NOISE CRITERIA

Industrial and Commercial Noise Sources

A relevant standard or guidance document should be referenced when determining values for LOAEL and SOAEL for non-anonymous noise. Where appropriate and within the scope of the document it is expected that British Standard 4142:2014 'Methods for rating and assessing industrial and commercial sound' (BS 4142) will be used. For such cases a 'Rating Level' of 10 dB below background (15dB if tonal components are present) should be considered as the design criterion).

Existing Noise sensitive receptor	Assessment Location	Design Period	LOAEL (Green)	LOAEL to SOAEL (Amber)	SOAL (Red)
Dwellings**	Garden used for main amenity (free field) and Outside living or dining or bedroom window (façade)	Day	'Rating level' 10dB* below background	'Rating level' between 9dB below and 5dB above background	'Rating level' greater than 5dB above background
Dwellings**	Outside bedroom window (façade)	Night	'Rating level' 10dB* below background and no events exceeding 57dBLAmax	'Rating level' between 9dB below and 5dB above background or noise events between 57dB and 88dB LAmax	'Rating level' greater than 5dB above background and/or events exceeding 88dBLAmax

Table 1: Noise levels applicable to proposed industrial and commercial developments (including plant and machinery)

*10dB should be increased to 15dB if the noise contains audible tonal elements (day and night). However, if it can be demonstrated that there is no significant difference in the character of the residual background noise and the specific noise from the proposed development then this reduction may not be required. In addition, a frequency analysis (to include, the use of Noise Rating (NR) curves or other criteria curves) for the assessment of tonal or low frequency noise may be required.



**levels given are for dwellings, however, levels are use specific and different levels will apply dependent on the use of the premises. The periods in Table 1 correspond to 0700 hours to 2300 hours for the day and 2300 hours to 0700 hours for the night. The Council will take into account the likely times of occupation for types of development and will be amended according to the times of operation of the establishment under consideration.

There are certain smaller pieces of equipment on commercial premises, such as extract ventilation, air conditioning units and condensers, where achievement of the rating levels (ordinarily determined by a BS:4142 assessment) may not afford the necessary protection. In these cases, the Council will generally also require a NR curve specification of NR35 or below, dependant on the room (based upon measured or predicted Leq,5mins noise levels in octave bands) 1 metre from the façade of affected premises, where the noise sensitive premise is located in a quiet background area.

4. BACKGROUND NOISE MEASUREMENT SURVEY

To inform the noise impact assessment, measurements of existing background noise levels were carried out during a noise survey conducted at the site from Thursday 12 to Tuesday 17 December 2019. Weather conditions during the survey were warm and dry, with low wind speeds, presenting good conditions for noise measurement purposes.

Measurements of noise were carried out at the rear of the building at first floor level, in accordance with BS 4142:2014 using an unattended noise logger. The monitoring location is considered representative of the nearest noise sensitive residential receptor locations to the proposed condenser units. Measurements consisted of continuous 15 minute periods. The microphone was mounted on a pole at first floor level. The location of the microphone is shown on the existing site location plan included in Appendix A.

The following instrumentation was used during the survey.

- Bruel & Kjaer Type 2250 Sound Level Meter s/n 3010945
- Bruel & Kjaer Type 4189 Microphone s/n 3060807
- Bruel & Kjaer Type 4231 Acoustic Calibrator s/n 3010648

Before and after the survey, the sound level meter was field-calibrated in accordance with the manufacturer's guidelines, and no significant drift was observed. The meter, microphone and field calibrator are laboratory calibrated biennially in accordance with UKAS procedures or to traceable National Standards.

Measurements made were of the following parameters:

- Maximum Noise Level – defined as the maximum (L_{Amax} the maximum noise level)
- Residual Noise Level – defined as the Energy Average Level of a period, in the absence of noise from the proposed development (L_{Aeq})
- Background Noise Level – defined as level exceeded for 90% of a period, in the absence of the noise from the proposed development (L_{A90})

The measured noise profile at the noise monitoring location is shown in the following chart.




Chart 1: Ambient noise profile – Thursday 12 to Tuesday 17 December 2019.

When determining the representative background $L_{A90,T}$ level for the relevant period, BS 4142¹ guidance states “a representative level ought to account for the range in background levels and ought not automatically to be assumed to be either the minimum or modal value.” With this in mind, statistical analysis has been used to determine the typical background $L_{A90,T}$ noise level. This analysis derives the Mode, Mean and Mean -1 standard deviation values. Once these three values have been established, a judgement is made as to which value is considered representative. In this instance, both the mean and modal values were the same. Therefore this value is regarded as being representative.

Table 2 shows the representative background noise level measured at the nearest noise sensitive receptor location, during the daytime period when the plant items would be operating.

Measurement Location	Period	Background Noise Level
Nearest Flats directly above	08:00 – 18:00	$L_{A90,1hour}$ 49 dB

Table 2: Summary of the representative background noise level measured during the sensitive night-time period

As shown in Table 2, the representative background noise level at the nearest noise sensitive receptors to the proposed mechanical plant is $L_{A90,1hour}$ 49dB during the daytime when the units would be operating. This reflects a typical steady noise profile controlled by other nearby mechanical plant in the area.

¹ BS 4142:2014 Methods for rating and assessing industrial and commercial sound

5. ASSESSMENT OF NOISE IMPACT

5.1 PROJECTED NOISE FROM MECHANICAL PLANT

The proposed mechanical services plant items would be located at the rear of the building. The external condenser units would be located within a dedicated acoustic enclosure. The manufacturer's data sheets are included in Appendix B. The noise outputs (sound power levels) generated by the units are set out in Table 3 below.

Plant Item	No. of	Overall Sound Power Level dB(A)
Mitsubishi PURY-P250YNW-A	1	80
Mitsubishi PURY-P450YNW-A	1	89
Mitsubishi PUZ-ZM71VHA	1	70
HRU G.1 - Mitsubishi LGH-150RVXT-E	1	66
HRU G.2 - Mitsubishi LGH-200RVXT-E	1	68
HRU B.1 - Mitsubishi LGH-200RVXT-E	1	68
EF B.1 - TD-500/150 SILENT 3V	1	45
EF G.1 - TD-1300/250 SILENT 3V	1	54

Table 3: Sound power levels of the proposed external mechanical plant

The condenser units operate on thermostatic, speed and timer controls according to heat loads and occupation rates and so would not be operating 100% of the time. Whilst a typical on-time for this type of equipment might only 20-35%, a conservative and therefore more robust assessment assumes a 50% on-time for a typical worst-case scenario (ie 50% of all condensers operating at any one time).

Predictions of how the noise from the plant items propagates to the sensitive receptors is determined through modelling undertaken using proprietary software (Predictor²) which meets the requirements of ISO 9613 Part 2:1996³. The noise model takes account of the following in its calculations procedures:

- Source sound power level (for point, line and area sources)
- Reflection from nearby structures and source directivity
- Distance from noise source (geometric spreading)
- Atmospheric absorption
- Acoustic screening of intervening structures and topography
- Ground absorption
- Ground effects (which includes the height of ground relative to the noise source)

Detailed noise calculations of the totals at each receptor location are then computed. To illustrate the model, a diagram showing the distribution and locations of the mechanical plant noise sources, superimposed on a 3D view of the site is included in Appendix C.

² *Brueel and Kjaer – Predictor V11 Environmental Noise Calculation Software Package, Type 7810*

³ *ISO 9613-2:1996 "Acoustics – Attenuation of sound during propagation outdoors – Part 2: General method of calculation to determine Noise Levels"*

A first model simulation has been completed, based on the sound power levels of standard (un-silenced) equipment. The results showed an excess over the noise limits, thereby indicating that the following equipment requires noise control mitigation, as specified in Table 4.

Required Noise Mitigation
<ul style="list-style-type: none"> • Operate each external condenser units in low noise mode. • Incorporate 10dB in-line silencers into the Heat Recovery Unit supply and extract ducts.

Table 4: Recommended noise control mitigation for mechanical plant items, as specified

The noise contour map and full table of results are also included in Appendix C for reference.

5.2 MECHANICAL PLANT NOISE IMPACT ASSESSMENT

The proposed plant items would run during office hours only. Therefore, the predicted plant rating levels will be compared with the representative $L_{A90,1hour}$ background noise level measured during the daytime at the nearest sensitive receptor locations.

Table 5 shows a BS 4142 assessment covering the mechanical plant noise impact during the daytime. None of the plant items emit any distinct impulses or tones. However, the plant does emit other characteristics that are distinctive against the existing residual acoustic environment. Therefore, a feature correction has been included in the rating level.

Residential Location	Specific Level (dB)	Character Correction (dB)	Rating Level (dB)	Background L_{A90} Noise Level (dB)	Assessment Level (dB) (Background excess)
R1. Plot 36	32	+3	34	49	-15
R2. Plot 37	24	+3	27	49	-22
R3. Plot 38	0	+3	3	49	-46
R4. Plot 70	33	+3	36	49	-13

Table 5: Predicted rating levels from the proposed plant items at the nearby sensitive receptor locations, compared with the representative background $L_{A90,1hour}$

As indicated in Table 5, the predicted rating levels would be 3-36dB at the nearby residential receptor locations. The predicted rating levels would be 13-46dB lower than the representative background $L_{A90,1hour}$ level. In line with BS 4142:2014, the noise impact would be very low. The difference between the rating levels and background levels is such that any uncertainty would have no significance on the outcome of the assessment.

The predicted rating levels would not exceed Camden Council's target noise criteria of no higher than 10dB(A) below the measured background noise level at all of the nearby residential receptor locations.

The predicted plant noise levels outside each of the nearest sensitive properties during the daytime are compared with the NR35 criteria below in Table 6.



Receiver Location	dB (A)	Octave Band Centre Frequency (Hz)							
		63	125	250	500	1000	2000	4000	8000
R1. Plot 36	32	27	27	24	19	21	15	8	3
R2. Plot 37	24	19	20	16	10	9	1	-	-
R3. Plot 38	0	-	-	-	-	-	-	-	-
R4. Plot 70	33	28	30	26	20	21	15	8	1
NR35		63.1	52.4	44.5	38.9	35.0	32.0	29.8	28.0

Table 6: Predicted plant noise levels compared with the NR35 daytime criteria curve

Specific noise levels from mechanical plant would be comfortably lower than the NR35 criteria. Furthermore, specific noise levels from mechanical plant would also be comfortably lower than the WHO $L_{Aeq,16\text{ hour}}$ 50dB advised daytime criteria at all of the nearby residential receptor locations.

In view of the above, noise levels from mechanical services plant would have a very low impact and would therefore be acceptable.

6. CONCLUSIONS


At the request of the Local Planning Authority, a noise assessment has been completed relating to the potential impact of noise produced by the operation of proposed mechanical services plant at Block A, 425 Centric Close in Camden, NW1 7EP.

A background noise measurement survey has been conducted at a location representative of the nearest noise sensitive receptors to the proposed plant and predictions of noise have been completed.


Noise limits for the proposed mechanical plant have been established for the sensitive daytime period, based on the representative background noise level and taking account of BS 4142, WHO and Camden Council's criteria for noise. Predictions have indicated that noise levels from mechanical services plant would have a very low impact and would therefore be acceptable.

APPENDIX A


Existing Site Location Plan



01 SITE LOCATION PLAN
Scale: 1:1250



02 BLOCK PLAN
Scale: 1:500



THIRDWAY

NOTES

THIRDWAY INTERIORS DO NOT ACCEPT LIABILITY FOR ANY ERRORS AND OMISSIONS ARISING FROM THE PREPARATION OF BASE BUILD DRAWINGS WHICH ARE DERIVED FROM ORIGINAL MATERIAL PROVIDED BY OTHERS.


ALL DISCREPANCIES ARE TO BE REPORTED TO THIRDWAY INTERIORS.

GRID LINES ARE FOR REFERENCE PURPOSES ONLY. ALL DIMENSIONS TO BE VERIFIED BY CONTRACTOR ON SITE PRIOR TO ANY WORKS COMMENCING.

DO NOT SCALE FROM THIS DRAWING.

THIS DOCUMENT IS THE PROPERTY OF THIRDWAY INTERIORS. COPYRIGHT IS RESERVED BY THEM, AND THE DRAWING IS ISSUED ON THE CONDITION THAT IT IS NOT COPIED, REPRODUCED OR RETAINED BY, NOR DISCLOSED TO ANY UNAUTHORISED PERSON, EITHER WHOLLY OR IN PART, WITHOUT THE CONSENT IN WRITING FROM THIRDWAY INTERIORS.

● **THIRDWAY INTERIORS**



STATUS

- ☒ **Approval / Comment**
- ☐ **Building Control**
- ☐ **Contract**
- ☐ **Construction**
- ☐ **As-Built**

REVISION DETAIL

REV	DETAIL	BY	DATE
A	ISSUE FOR PLANNING	RS	10/12

CLIENT

JOHN ADAM FASHION

PROJECT ADDRESS

**MODE, CENTRIC CLOSE
OVAL ROAD
CAMDEN, LONDON.
NW1 7EP**

PLANNING APPLICATION

DRAWING TITLE

**EXISTING SITE LOCATION
AND BLOCK PLAN**

DWG NO: **19136 PLN 01**

REVISION: **A**

SCALE @A1: **AS SHOWN**


DATE: **10/12/19**

DRAWN BY: **RS**


CHECKED BY: **TL**

A P P E N D I X B

Scheme Proposals and Manufacturer's Data Sheets




GROUND FLOOR




BASEMENT PLAN




FIRST FLOOR




THIRD FLOOR




FIFTH FLOOR




ROOF PLAN



SECOND FLOOR



FOURTH FLOOR



SIXTH FLOOR

FOR APPROVAL

This drawing and any related notes are protected by copyright. To the extent that this is a design document it is, in addition, protected by design right. All rights in them are reserved. They are provided for your information only. No part of them or any design to which they relate may be reproduced in any form or by any means without the prior written permission of Fairview New Homes Limited, except as expressly permitted by law. The doing of any unauthorised act in relation to them may result in both a civil claim and criminal prosecution.

NOTES:

KEY:

- Site Boundary
- Commercial Unit Premises Demise
- Housing Association Freehold area
- Vehicular / pedestrian right of way
- Area of Management Company responsibility
- Private roads to be maintained by management company with HA right to pass and re pass with or without vehicles.
- DPHA Disabled Parking bay for Housing Association
- UDPH Disabled Parking bay
- UDPH (*) indicates Plot Number bay is allocated to
- DPC Disabled Parking for Commercial / Community Unit
- CSHA Cycle Store for use by HA units
- CS Cycle Store/Stand for use by Private units
- CSC Cycle Store/Stand for use by Commercial Units
- RS Refuse/Recycling Store for Private units
- RBHA Refuse/Recycling Store for Housing Association
- RSC Refuse/Recycling Store for Commercial units
- SS Sub-Station
- Tree pt / tree grid
- Double Car Charging Point

DRAFT AWAITING APPROVAL

REV AMENDMENTS BY DATE

Fairview
NEW HOMES Ltd.

Technical Department,
50 Lancaster Road, Enfield, Middlesex EN2 0BY
Telephone No: 020-8366-1271 Facsimile No: 020-8342-3861
Website: www.fairview.co.uk E-mail: technical@fnhnltd.co.uk

Drawn: P.J. Date: 20-07-17 Scale: 1:1000 @ A3
Checked: Approved:

Title:

Commercial Unit 2
Ground Floor and
Basement Demise

Project: 425 Centric Close
Camden NW1-7EP

Drawing Number: FNH 425-Comm. Unit 2_01 Rev:

dwp: FNH 425 CENTRIC CLOSE.dwg A1



This drawing is protected under Copyright and at no time must any portion of this drawing be reproduced or copied in any way, without the permission of 361 Degree LLP.

All dimensions must be checked on site and NOT scaled from this drawing.

NOTES:

THIS DRAWING SHOWS A CONSTRUCTION STAGE LAYOUT BUT WILL BE SUBJECT TO CHANGE AS THE PROJECT DEVELOPS.

F	20.07.20	UPDATED LAYOUT INCORPORATED	IK	-
E	15.07.20	UPDATED TO CLIENT COMMENTS DIMS ADDED	IK	-
D	10.07.20	DX AND CONTROLS RELOCATED	IK	-
C	01.07.20	COORDINATED WITH LIGHTING	IK	-
B	30.06.20	CONDENSER UNITS, REFRIG PIPE WORK AND CONTROLLERS SHOWN	IK	-
A	30.06.20	HVAC B.I. RELOCATED, SMOKE VENT TRANSFER GRILLES ADDED	IK	-

Rev	Date	Revision	Drawn By
1			

361°
a degree further

Client: THIRDWAY INTERIORS





Project: JON ADAM FASHION

Title: MECHANICAL SERVICES
HVAC LAYOUT

Scale: 1:100 @ A1 Date: 25.06.20

Drawing No. 361-BG-22381-M Rev:

361-BG-22381-M F



TECHNICAL CHARACTERISTICS

TD-SILENT	Speed (r.p.m.)	Maximum absorbed power (W)	Maximum absorbed current (A)	Maximum airflow (m³/h)	Sound pressure level* (dB(A))	Min-Max air temperature (°C)	Weight (kg)	Duct diameter (mm)	3-speed switch	Speed con- troller	Wiring diagram** (nº)
TD-160/100 N SILENT	2400	29	0,17	180	24	-20/+40	1,4	100	COM-2 REGUL-2	RMB-1,5 REB-1	9, 10
	2200	18	0,11	150	22						
TD-250/100 SILENT	2210	27	0,12	250	25	-20/+40	5,4	100	COM-2 REGUL-2	RMB-1,5 REB-1	9, 10
	1680	21	0,1	200	20						
TD-350/125 SILENT	2100	27	0,12	330	23	-20/+40	5	125	COM-2 REGUL-2	RMB-1,5 REB-1	9, 10
	1650	21	0,1	260	18						
TD-500/150-160 SILENT 3V	2480	59	0,26	550	27	-20/+60	6	150/160	COM-3 INTER 4P	RMB-1,5 REB-1	9, 10
	2060	50	0,22	450	22						
	1610	45	0,2	350	17						
TD-800/200 SILENT 3V	2170	102	0,5	910	28	-20/+60	8,7	200	COM-3 INTER 4P	RMB-1,5 REB-1	9, 10
	1870	92	0,47	780	24						
	1660	90	0,46	690	22						
TD-1000/200 SILENT 3V	2450	130	0,55	1.040	29	-20/+60	8,7	200	COM-3 INTER 4P	RMB-1,5 REB-1	9, 10
	2210	127	0,55	910	27						
	1920	122	0,53	790	24						
TD-1300/250 SILENT 3V	2530	204	0,85	1.320	36	-20/+60	20	250	COM-3 INTER 4P	RMB-1,5 REB-1	12, 13
	2230	163	0,68	1.160	33						
	2030	144	0,6	1.040	31						
TD-2000/315 SILENT 3V	2670	293	1,25	1.770	39	-40/+60	25	315	COM-3 INTER 4P	RMB-1,5 REB-2,5	12, 13
	2490	232	0,97	1.610	38						
	2240	190	0,78	1.480	36						

* Sound pressure level radiated at 3 m at free air conditions with rigid ducts at the inlet and at the outlet.

** See section of Wiring Diagrams.

TD-SILENT	Speed (r.p.m.)	Maximum absorbed power (W)	Maximum absorbed current (A)	Maximum airflow (m³/h)	Sound pressure level* (dB(A))	Min-Max air temperature (°C)	Weight (kg)	Duct diameter (mm)
TD-160/100 NT SILENT	2400	29	0,17	180	24	-20/+40	1,4	100
TD-250/100 SILENT T	2140	28	0,12	250	34	-20/+40	2	100
TD-350/125 SILENT T	2050	26	0,11	330	33	-20/+40	2	125
TD-500/150-160 SILENT T 3V**	2590	53	0,21	560	35	-20/+60	2,7	150
	2150	44	0,19	470	31			
	1820	41	0,18	390	26			
TD-800/200 SILENT T 3V**	2170	102	0,5	910	28	-20/+60	8,7	200
	1870	92	0,47	780	24			
	1660	90	0,46	690	22			
TD-1000/200 SILENT T 3V**	2450	130	0,55	1.040	29	-20/+60	8,7	200
	2210	127	0,55	910	27			
	1920	122	0,53	790	24			

* Radiated sound pressure level measured at 3 m, in free field conditions, with rigid ducts at the inlet and outlet.

** Temporisation only on high speed

TECHNICAL CHARACTERISTICS

TD-SILENT	Speed (r.p.m.)	Maximum absorbed power (W)	Maximum absorbed current (A)	Maximum airflow (m³/h)	Sound pressure level* (dB(A))	Min-Max air temperature (°C)	Weight (kg)	Duct diameter (mm)	3-speed switch	Speed con- troller	Wiring diagram** (nº)
TD-160/100 N SILENT	2400	29	0,17	180	24	-20/+40	1,4	100	COM-2 REGUL-2	RMB-1,5 REB-1	9, 10
	2200	18	0,11	150	22						
TD-250/100 SILENT	2210	27	0,12	250	25	-20/+40	5,4	100	COM-2 REGUL-2	RMB-1,5 REB-1	9, 10
	1680	21	0,1	200	20						
TD-350/125 SILENT	2100	27	0,12	330	23	-20/+40	5	125	COM-2 REGUL-2	RMB-1,5 REB-1	9, 10
	1650	21	0,1	260	18						
TD-500/150-160 SILENT 3V	2480	59	0,26	550	27	-20/+60	6	150/160	COM-3 INTER 4P	RMB-1,5 REB-1	9, 10
	2060	50	0,22	450	22						
	1610	45	0,2	350	17						
TD-800/200 SILENT 3V	2170	102	0,5	910	28	-20/+60	8,7	200	COM-3 INTER 4P	RMB-1,5 REB-1	9, 10
	1870	92	0,47	780	24						
	1660	90	0,46	690	22						
TD-1000/200 SILENT 3V	2450	130	0,55	1.040	29	-20/+60	8,7	200	COM-3 INTER 4P	RMB-1,5 REB-1	9, 10
	2210	127	0,55	910	27						
	1920	122	0,53	790	24						
TD-1300/250 SILENT 3V	2530	204	0,85	1.320	36	-20/+60	20	250	COM-3 INTER 4P	RMB-1,5 REB-1	12, 13
	2230	163	0,68	1.160	33						
	2030	144	0,6	1.040	31						
TD-2000/315 SILENT 3V	2670	293	1,25	1.770	39	-40/+60	25	315	COM-3 INTER 4P	RMB-1,5 REB-2,5	12, 13
	2490	232	0,97	1.610	38						
	2240	190	0,78	1.480	36						

* Sound pressure level radiated at 3 m at free air conditions with rigid ducts at the inlet and at the outlet.

** See section of Wiring Diagrams.

TD-SILENT	Speed (r.p.m.)	Maximum absorbed power (W)	Maximum absorbed current (A)	Maximum airflow (m³/h)	Sound pressure level* (dB(A))	Min-Max air temperature (°C)	Weight (kg)	Duct diameter (mm)
TD-160/100 NT SILENT	2400	29	0,17	180	24	-20/+40	1,4	100
TD-250/100 SILENT T	2140	28	0,12	250	25	-20/+40	2	100
TD-350/125 SILENT T	2050	26	0,11	330	23	-20/+40	2	125
TD-500/150-160 SILENT T 3V**	2590	53	0,21	560	27	-20/+60	2,7	150
	2150	44	0,19	470	22			
	1820	41	0,18	390	17			
TD-800/200 SILENT T 3V**	2170	102	0,5	910	28	-20/+60	8,7	200
	1870	92	0,47	780	24			
	1660	90	0,46	690	22			
TD-1000/200 SILENT T 3V**	2450	130	0,55	1.040	29	-20/+60	8,7	200
	2210	127	0,55	910	27			
	1920	122	0,53	790	24			


* Radiated sound pressure level measured at 3 m, in free field conditions, with rigid ducts at the inlet and outlet.

** Temporisation only on high speed

NC Curves (Calculated induct PWL)


Model	LGH-150RVXT-E
Background noise [dB]	25dB or less (A range)
Measurement site	Anechoic chamber
Ventilation mode	Lossnay ventilation
Power supply	Single phase 230V, 50Hz

Unit (View from side)



SA (Supply Air) duct (1m)


Calculation point



NC Curves (Calculated induct PWL)


Model	LGH-200RVXT-E
Background noise [dB]	25dB or less (A range)
Measurement site	Anechoic chamber
Ventilation mode	Lossnay ventilation
Power supply	Single phase 230V, 50Hz

Unit (View from side)



SA (Supply Air) duct (1m)

Calculation point



1. SPECIFICATIONS

Outdoor units

Model			PURY-P250YNW-A (-BS)			
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz			
Cooling capacity (Nominal)	*1	kW	28.0			
		kcal/h	25,000			
		BTU/h	95,500			
		Power input	kW	5.97		
		Current input	A	10.0-9.5-9.2		
		EER	kW/kW	4.69		
Temp. range of cooling	Indoor	W.B.	15.0~24.0°C (59~75°F)			
	Outdoor	D.B.	-5.0~52.0°C (23~126°F)			
Heating capacity (Max)	*2	kW	31.5			
		kcal/h	27,100			
		BTU/h	107,500			
		Power input	kW	6.06		
		Current input	A	10.2-9.7-9.3		
		COP	kW/kW	5.19		
	(Nominal)	*3	kW	28.0		
			kcal/h	25,000		
			BTU/h	95,500		
			Power input	kW	5.27	
			Current input	A	8.8-8.4-8.1	
			COP	kW/kW	5.31	
Temp. range of heating	Indoor	D.B.	15.0~27.0°C (59~81°F)			
	Outdoor	W.B.	-20.0~15.5°C (-4~60°F)			
Indoor unit connectable	Total capacity		50~150%			
	Model/Quantity		P15~P250/1~25			
Sound pressure level (measured in anechoic room) *4		dB <A>	60.5/61.0			
Sound power level (measured in anechoic room) *4		dB <A>	78.5/80.0			
Refrigerant piping diameter	High pressure	mm (in.)	19.05 (3/4) Brazed			
	Low pressure	mm (in.)	22.2 (7/8) Brazed			
FAN	Type x Quantity		Propeller fan x 1			
	Air flow rate	m³/min	185			
		L/s	3,083			
		cfm	6,532			
		Control, Driving mechanism		Inverter-control, Direct-driven by motor		
	Motor output	kW	0.92 x 1			
	*5 External static press.		0 Pa (0 mmH₂O)			
	Compressor	Type		Inverter scroll hermetic compressor		
Manufacture		AC&R Works, MITSUBISHI ELECTRIC CORPORATION				
Starting method		Inverter				
Motor output		kW	7.0			
Case heater		kW	-			
Lubricant		MEL32				
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>			
External dimension H x W x D		mm	1,858 (1,798 without legs) x 920 x 740			
		in.	73-3/16 (70-13/16 without legs) x 36-1/4 x 29-3/16			
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)			
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection			
	Compressor		-			
	Fan motor		-			
Refrigerant	Type x original charge		R410A x 5.2 kg (12 lbs)			
	Control		Indoor LEV and BC controller			
Net weight		kg (lbs)	229 (505)			
Heat exchanger			Salt-resistant cross fin & copper tube			
HIC circuit (HIC: Heat Inter-Changer)			-			
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)			
Drawing	External		WKS94T748			
	Wiring		WKE94G339			
Standard attachment	Document		Installation Manual			
	Accessory		-			
Optional parts			Joint: CMY-Y102SS-G2,CMY-Y102LS-G2,CMY-R160-J1 BC controller: CMB-P104,106,108,1012,1016V-J Main BC controller: CMB-P108,1012,1016V-JA,CMB-P1016V-KA Sub BC controller: CMB-P104, 108V-KB			
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.			

Notes:		Unit converter
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		BTU/h = kW x 3,412
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		cfm = m ³ /min x 35.31
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered		lbs = kg/0.4536
4. Cooling mode/Heating mode		
5. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.		*Above specification data is subject to rounding variation.

1. SPECIFICATIONS


Outdoor units

Model			PURY-P450YNW-A (-BS)	
Power source			3-phase 4-wire 380-400-415 V 50/60 Hz	
Cooling capacity (Nominal)	*1	kW	50.0	
		kcal/h	45,000	
		BTU/h	170,600	
	Power input	kW	12.37	
		A	20.8-19.8-19.1	
		EER	4.04	
Temp. range of cooling	Indoor	W.B.	15.0~24.0°C (59~75°F)	
	Outdoor	D.B.	-5.0~52.0°C (23~126°F)	
Heating capacity (Max)	*2	kW	56.0	
		kcal/h	50,000	
		BTU/h	191,100	
	Power input	kW	13.48	
		A	22.7-21.6-20.8	
		COP	4.15	
	(Nominal) *3	kW	50.0	
		kcal/h	45,000	
		BTU/h	170,600	
	Power input	kW	10.91	
		A	18.4-17.4-16.8	
		COP	4.58	
Temp. range of heating	Indoor	D.B.	15.0~27.0°C (59~81°F)	
	Outdoor	W.B.	-20.0~15.5°C (-4~60°F)	
Indoor unit connectable	Total capacity		50~150%	
	Model/Quantity		P15~P250/1~45	
Sound pressure level (measured in anechoic room) *4		dB <A>	65.5/70.0	
Sound power level (measured in anechoic room) *4		dB <A>	83.0/89.0	
Refrigerant piping diameter	High pressure	mm (in.)	22.2 (7/8) Brazed	
	Low pressure	mm (in.)	28.58 (1-1/8) Brazed	
FAN	Type x Quantity		Propeller fan x 2	
	Air flow rate	m³/min	315	
		L/s	5,250	
		cfm	11,123	
	Control, Driving mechanism		Inverter-control, Direct-driven by motor	
	Motor output	kW	0.46 x 2	
Compressor	*5 External static press.		0 Pa (0 mmH ₂ O)	
	Type		Inverter scroll hermetic compressor	
	Manufacture		AC&R Works, MITSUBISHI ELECTRIC CORPORATION	
	Starting method		Inverter	
	Motor output	kW	12.4	
	Case heater	kW	-	
	Lubricant		MEL32	
External finish			Pre-coated galvanized steel sheets (+powder coating for -BS type) <MUNSELL 5Y 8/1 or similar>	
External dimension H x W x D		mm	1,858 (1,798 without legs) x 1,240 x 740	
		in.	73-3/16 (70-13/16 without legs) x 48-7/8 x 29-3/16	
Protection devices	High pressure protection		High pressure sensor, High pressure switch at 4.15 MPa (601 psi)	
	Inverter circuit (COMP./FAN)		Over-heat protection, Over-current protection	
	Compressor		-	
	Fan motor		-	
Refrigerant	Type x original charge		R410A x 10.8 kg (24 lbs)	
	Control		Indoor LEV and BC controller	
Net weight		kg (lbs)	293 (646)	
Heat exchanger			Salt-resistant cross fin & copper tube	
HIC circuit (HIC: Heat Inter-Changer)			-	
Defrosting method			Auto-defrost mode (Reversed refrigerant cycle)	
Drawing	External		WKS94T749	
	Wiring		WKE94G341	
Standard attachment	Document		Installation Manual	
	Accessory		-	
Optional parts			Joint: CMY-Y102SS-G2, CMY-Y102LS-G2, CMY-R160-J1 Main BC controller: CMB-P108, 1012, 1016V-JA, CMB-P1016V-KA Sub BC controller: CMB-P104, 108V-KB	
Remarks			Details on foundation work, duct work, insulation work, electrical wiring, power source switch, and other items shall be referred to the Installation Manual. Due to continuing improvement, above specifications may be subject to change without notice.	


Notes:		Unit converter
1. Nominal cooling conditions (subject to JIS B8615-2) Indoor: 27°C D.B./19°C W.B. (81°F D.B./66°F W.B.), Outdoor: 35°C D.B./24°C W.B. (95°F D.B./75°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		BTU/h = kW x 3,412
2. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.)		cfm = m³/min x 35.31
3. Nominal heating conditions (subject to JIS B8615-2) Indoor: 20°C D.B. (68°F D.B.), Outdoor: 7°C D.B./6°C W.B. (45°F D.B./43°F W.B.) Pipe length: 7.5 m (24-9/16 ft.), Level difference: 0 m (0 ft.) Eurovent registered		lbs = kg/0.4536
4. Cooling mode/Heating mode		
5. External static pressure option is available (30 Pa, 60 Pa, 80 Pa/3.1 mmH ₂ O, 6.1 mmH ₂ O, 8.2 mmH ₂ O). Consult your dealer about the specification when setting External static pressure option.		*Above specification data is subject to rounding variation.

5-1. Sound levels in cooling mode

Measurement condition PURY-P200, 250, 300YNW-A(-BS)




Sound level of PURY-P300YNW-A(-BS)



		63	125	250	500	1k	2k	4k	8k	
Standard	50/60Hz	75.5	62.5	62.5	60.0	54.0	49.5	44.5	40.0	dB(A)
Low noise mode	50/60Hz	54.5	53.0	47.0	46.0	40.0	35.0	33.0	33.5	47.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.


Sound level of PURY-P200YNW-A(-BS)



		63	125	250	500	1k	2k	4k	8k	
Standard Cooling	50/60Hz	77.0	61.0	60.5	57.5	51.0	46.5	44.0	41.5	59.0
Low noise mode	50/60Hz	51.0	49.5	43.0	39.5	37.5	29.0	33.0	39.0	44.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P250YNW-A(-BS)




		63	125	250	500	1k	2k	4k	8k	
Standard Cooling	50/60Hz	78.0	62.5	61.5	59.0	52.0	48.5	48.5	43.0	60.5
Low noise mode	50/60Hz	53.0	51.5	41.5	42.0	35.0	31.5	38.0	38.5	45.0


When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

- Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required.
- For BC controller, it is recommended to be installed in places such as ceilings of corridor, rest rooms and plant rooms.

Measurement condition PURY-P350, 400, 450YNW-A(-BS)




Sound level of PURY-P450YNW-A(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard	50/60Hz	73.5	64.0	66.5	64.5	59.5	55.0	49.5	45.5	65.5
Low noise mode	50/60Hz	64.5	57.0	52.0	49.5	47.5	44.0	39.5	43.5	53.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.


Sound level of PURY-P350YNW-A(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard	50/60Hz	69.0	63.5	64.0	61.5	56.5	51.5	46.5	40.0	62.5
Low noise mode	50/60Hz	55.0	55.0	50.5	47.0	42.5	37.0	35.5	34.5	49.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

Sound level of PURY-P400YNW-A(-BS)



		63	125	250	500	1k	2k	4k	8k	dB(A)
Standard	50/60Hz	73.5	63.5	66.0	64.0	59.0	54.5	48.5	45.0	65.0
Low noise mode	50/60Hz	64.0	57.0	51.0	48.0	46.5	42.5	38.0	43.5	52.0

When Low noise mode is set, the A/C system's capacity is limited. The system could return to normal operation from Low noise mode automatically in the case that the operation condition is severe.

- Depending on the operation conditions, the unit generates noise caused by valve actuation, refrigerant flow, and pressure changes when operating normally. Please consider to avoid location where quietness is required.
- For BC controller, it is recommended to be installed in places such as ceilings of corridor, rest rooms and plant rooms.

APPENDIX C

Mechanical Plant Noise Prediction Model

Equipment List Sound Power Levels



Revision	Date	Comment

[illegible]



Rev. No.	Date	Details

WEST AND EAST FACADES AREAS, EACH (m ²) =	4.784
NORTH AND SOUTH FACADES AREAS, EACH (m ²) =	14.35
ROOF AREA (m ²) =	7.68
TOTAL SURFACE AREA INCLUDING FLOOR (m²) =	54


DOORS AND GRILLS		Area(m ²) of each door or grille	Details


SOURCE	LwA	Octaves Band Sound Power Level										No. off
		31	63	125	250	500	1k	2k	4k	8k		
Mitsubishi PURY-P250YNW-A	64		72	71	61	54	51	57	58		1	
Mitsubishi PURY-P450YNW-A	72		84	76	71	69	67	63	59	63	1	
Mitsubishi PUZ-ZM71VHA	70		74	73	74	65	64	59	54	48	1	
	7											
	7											
	7											
	7											
	7											
	7											
	7											
	7											
	7											
	7											
	7											
	7											
	7											
	7											
TOTAL	74	5	84	79	76	71	69	65	62	64		

Sound Absorption Coefficient		Octave Band								
Enclosure Surface		31	63	125	250	500	1k	2k	4k	8k
Walls		0.12	0.12	0.12	0.28	0.55	0.71	0.74	0.83	0.90
Ceiling		0.12	0.12	0.12	0.28	0.55	0.71	0.74	0.83	0.90
Floor including equipment		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
MEAN		0.13	0.13	0.13	0.27	0.50	0.64	0.66	0.74	0.80

ignores the internal absorption of wall louvres

Sound Pressure Level (reverberant)		Octave Band								
	dB(A)	31	63	125	250	500	1k	2k	4k	8k
10Log(4/Rc)		-3	-3	-3	-7	-11	-14	-14	-16	-17
T60 (Norris Eyring) (s)		0.5	0.5	0.5	0.2	0.1	0.1	0.1	0.1	0.0
Lp rev	65	2	81	75	69	59	55	50	46	47





Centric Close, Camden

Predicted Plant Noise Levels


Report: Table of Results
Model: Rev 2 - August 2020 Scheme
LAeq per octave: total results for receivers
Group: (main group)
Group Reduction: No

Name			Day								
Receiver	Description	Height	Total	63	125	250	500	1000	2000	4000	8000
_A	R1. Plot 36	4.50	32	27	27	24	19	21	15	8	3
_A	R2. Plot 37	5.00	24	19	20	16	10	9	1	--	--
_A	R3. Plot 38	5.00	--	--	--	--	--	--	--	--	--
_A	R4. Plot 70	8.00	33	28	30	26	20	21	15	8	1

All shown dB values are A-weighted


Predictor V2019.3

18/08/2020 06:37:44



Head Office

Spectrum Acoustic Consultants Ltd
27-29 High Street
Biggleswade
Bedfordshire
SG18 0JE
UNITED KINGDOM

 +44 (0)1767 318871

 enquiries@spectrumacoustic.com

 www.spectrumacoustic.com