

Application ref: 2020/0950/P
Contact: Nathaniel Young
Tel: 020 7974 3386
Email: Nathaniel.Young@camden.gov.uk
Date: 26 October 2020

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE

Phone: 020 7974 4444

planning@camden.gov.uk
www.camden.gov.uk/planning

Iceni Projects
Da Vinci House,
44 Saffron Hill
London
EC1N 8FH
United Kingdom

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted

Address:

Flat A
3 Chester Gate
London
NW1 4JH

Proposal: Removal of existing external grills, intercom panel and boiler flue. Installation of new intercom panel, boiler flue and air bricks serving an internal MVHR unit.

Drawing Nos: D048.00, D048.05, D048.07, D048.08, D048.09, Design and Access statement 25.02.20, Heritage Statement 25.02.20, Structural Report ref: 2003-1, Design and Access statement addendum 03.08.20, Comfosystems Zhender ComfoAir 160 manufacturer brochure

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 and D2 of the London Borough of Camden Local Plan 2017.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans D048.00, D048.05, D048.07, D048.08, D048.09, Design and Access statement 25.02.20, Heritage Statement 25.02.20, Structural Report ref: 2003-1, Design and Access statement addendum 03.08.20, Comfosystems Zhender ComfoAir 160 manufacturer brochure.

Reason: For the avoidance of doubt and in the interest of proper planning.

- 4 Prior to use, details shall be submitted to and approved in writing by the Council, of the external noise level emitted from plant equipment (the MVHR unit) and proposed mitigation measures. The measures shall ensure that the external noise level emitted from plant, machinery/ equipment will be lower than the lowest existing background noise level by at least 10dBA, by 15dBA where the source is tonal, as assessed according to BS4142:2014 at the nearest and/or most affected noise sensitive premises, with machinery operating at maximum capacity.

Reason: To ensure that the amenity of surrounding residential premises is not adversely affected by noise from the equipment in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 5 Prior to use, the MVHR unit shall be mounted with proprietary anti-vibration isolators and fan motors shall be vibration isolated from the casing and adequately silenced and maintained as such.

Reason: To ensure that the amenity of occupiers of the development site and surrounding premises are not adversely affected by vibration in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).
- 2 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant

licence from the Council's Streetworks Authorisations & Compliance Team
London Borough of Camden 5 Pancras Square c/o Town Hall, Judd Street
London WC1H 9JE (Tel. No 020 7974 4444) . Licences and authorisations
need to be sought in advance of proposed works. Where development is
subject to a Construction Management Plan (through a requirement in a S106
agreement), no licence or authorisation will be granted until the Construction
Management Plan is approved by the Council.

- 3 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website at <https://beta.camden.gov.uk/documents/20142/1269042/Camden+Minimum+Requirements+%281%29.pdf/bb2cd0a2-88b1-aa6d-61f9-525ca0f71319> or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these hours.

- 4 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Noise and Licensing Enforcement Team, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (Tel. No. 020 7974 4444 or search for 'environmental health' on the Camden website or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2019.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully



Daniel Pope

