

Dawson (development), Barry

From: BCTAdmin@thameswater.co.uk
Sent: 27 October 2020 11:47
To: Planning
Subject: 3rd Party Planning Application - 2020/1671/P

[EXTERNAL EMAIL] Beware – This email originated outside Camden Council and may be malicious Please take extra care with any links, attachments, requests to take action or for you to verify your password etc. Please note there have been reports of emails purporting to be about Covid 19 being used as cover for scams so extra vigilance is required.

London Borough of Camden Our DTS Ref: 67154
Camden Town Hall Your Ref: 2020/1671/P
Argyle Street
Euston Road
London
WC1H 8EQ

27 October 2020

Dear Sir/Madam

Re: 2, HILLFIELD ROAD, LONDON, GREATER LONDON , NW6 1QE

Waste Comments

As required by Building regulations part H paragraph 2.36, Thames Water requests that the Applicant should incorporate within their proposal, protection to the property to prevent sewage flooding, by installing a positive pumped device (or equivalent reflecting technological advances), on the assumption that the sewerage network may surcharge to ground level during storm conditions. If as part of the basement development there is a proposal to discharge ground water to the public network, this would require a Groundwater Risk Management Permit from Thames Water. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures will be undertaken to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 02035779483 or by emailing wwriskmanagement@thameswater.co.uk. Application forms should be completed on line via www.thameswater.co.uk. Please refer to the Wholesale; Business customers; Groundwater discharges section.

With the information provided, Thames Water has been unable to determine the waste water infrastructure needs of this application. Thames Water has contacted the developer in an attempt to obtain this information and agree a position for FOUL WATER drainage, but have been unable to do so in the time available and as such, Thames Water request that the following condition be added to any planning permission. "No development shall be occupied until confirmation has been provided that either:- 1. Capacity exists off site to serve the development, or 2. A development and infrastructure phasing plan has been agreed with the Local Authority in consultation with Thames Water. Where a development and infrastructure phasing plan is agreed, no occupation shall take place other than in accordance with the agreed development and infrastructure phasing plan, or 3. All wastewater network upgrades required to accommodate the additional flows from the development have been completed. Reason - Network reinforcement works may be required to accommodate the proposed development. Any reinforcement works identified will be necessary in order to avoid sewage flooding and/or potential pollution incidents. The developer can request information to

support the discharge of this condition by visiting the Thames Water website at thameswater.co.uk/preplanning. Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (telephone 0203 577 9998) prior to the planning application approval.

With the information provided Thames Water has been unable to determine the waste water infrastructure needs of this application. Thames Water has contacted the developer in an attempt to obtain this information and agree a position for SURFACE WATER drainage, but have been unable to do so in the time available and as such Thames Water request that the following condition be added to any planning permission. "No development shall be occupied until confirmation has been provided that either:- 1. Capacity exists off site to serve the development or 2. A development and infrastructure phasing plan has been agreed with the Local Authority in consultation with Thames Water. Where a development and infrastructure phasing plan is agreed, no occupation shall take place other than in accordance with the agreed development and infrastructure phasing plan. Or 3. All wastewater network upgrades required to accommodate the additional flows from the development have been completed. Reason - Network reinforcement works may be required to accommodate the proposed development. Any reinforcement works identified will be necessary in order to avoid flooding and/or potential pollution incidents. The developer can request information to support the discharge of this condition by visiting the Thames Water website at thameswater.co.uk/preplanning. Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (telephone 0203 577 9998) prior to the planning application approval.

Water Comments

On the basis of information provided, Thames Water would advise that with regard to water network infrastructure capacity, we would not have any objection to the above planning application. Thames Water recommend the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Supplementary Comments

There is no drainage strategy and this needs to be provided.

Yours faithfully
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ
Tel:020 3577 9998
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk

Visit us online www.thameswater.co.uk , follow us on twitter www.twitter.com/thameswater or find us on www.facebook.com/thameswater. We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.