

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 004 - Be Lean			
Address :	AC 004, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	74.4 (1a)	x (2a)	= 215.76 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	74.4 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	215.76 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					x 10 = 0 (7a)
Number of passive vents					x 10 = 0 (7b)
Number of flueless gas fires					x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 0 ÷ (5) = 0
(8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] =

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) =

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] =

Infiltration rate incorporating shelter factor (21) = (18) x (20) =

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

DER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.11	0.11	0.1	0.09	0.09	0.08	0.08	0.08	0.08	0.09	0.1	0.1
------	------	-----	------	------	------	------	------	------	------	-----	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.21	0.21	0.22
---------	------	------	------	------	------	-----	-----	-----	------	------	------

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.2	0.21	0.21	0.22
--------	------	------	------	------	------	-----	-----	-----	-----	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m²)	Openings m²	Net Area A ,m²	U-value W/m²K	A X U (W/K)	k-value kJ/m²·K	A X k kJ/K
Windows Type 1			2.69	x1/[1/(1.4)+ 0.04] =	3.57		(27)
Windows Type 2			11.21	x1/[1/(1.4)+ 0.04] =	14.86		(27)
Windows Type 3			1.8	x1/[1/(1.4)+ 0.04] =	2.39		(27)
Windows Type 4			1.8	x1/[1/(1.4)+ 0.04] =	2.39		(27)
Windows Type 5			3.24	x1/[1/(1.4)+ 0.04] =	4.3		(27)
Floor			74.4	x 0.12 =	8.928		(28)
Walls	49.53	20.74	28.79	x 0.12 =	3.46		(29)
Total area of elements, m²			123.93				(31)
Party wall			49.76	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 39.88 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 11.69 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 51.57 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	16.08	15.93	15.78	15.02	14.87	14.12	14.12	13.96	14.42	14.87	15.17	15.48

(38)

Heat transfer coefficient, W/K (39)m = (37) + (38)m

(39)m=	67.65	67.5	67.35	66.59	66.44	65.68	65.68	65.53	65.98	66.44	66.74	67.04
--------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Stroma FSAP 2012 Version: 1.0.5.8 (SAP 9.92) - http://www.stroma.com Average = Sum(39)₁...₁₂ / 12= 66.55 (39)

Page 2 of 8

DER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	0.91	0.91	0.91	0.9	0.89	0.88	0.88	0.88	0.89	0.89	0.9	0.9	
													Average = Sum(40) _{1...12} /12=

$$(40)m = (39)m \div (4)$$

0.89 (40)

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(41)m=	31	28	31	30	31	30	31	31	30	31	30	31

(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

2.35

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

89.97

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	98.96	95.36	91.77	88.17	84.57	80.97	80.97	84.57	88.17	91.77	95.36	98.96
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

$$\text{Total} = \text{Sum}(44)_{1...12} =$$

1079.59

(44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	146.76	128.36	132.45	115.47	110.8	95.61	88.6	101.67	102.88	119.9	130.88	142.13
--------	--------	--------	--------	--------	-------	-------	------	--------	--------	-------	--------	--------

$$\text{Total} = \text{Sum}(45)_{1...12} =$$

1415.52

(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	22.01	19.25	19.87	17.32	16.62	14.34	13.29	15.25	15.43	17.99	19.63	21.32
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(46)

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0

(48)

Temperature factor from Table 2b

0

(49)

Energy lost from water storage, kWh/year

$$(48) \times (49) =$$

110

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0.02

(51)

If community heating see section 4.3

Volume factor from Table 2a

1.03

(52)

Temperature factor from Table 2b

0.6

(53)

Energy lost from water storage, kWh/year

$$(47) \times (51) \times (52) \times (53) =$$

1.03

(54)

Enter (50) or (54) in (55)

1.03

(55)

Water storage loss calculated for each month

$$((56)m = (55) \times (41)m)$$

(56)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(56)

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(57)

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(59)

DER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	202.04	178.28	187.73	168.97	166.08	149.11	143.88	156.95	156.38	175.18	184.37	197.4	(62)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	202.04	178.28	187.73	168.97	166.08	149.11	143.88	156.95	156.38	175.18	184.37	197.4	
Output from water heater (annual) 1...12												2066.36	(64)

Heat gains from water heating, kWh/month 0.25 $[0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	93.02	82.62	88.26	81.19	81.06	74.59	73.68	78.03	77	84.09	86.31	91.48	(65)
--------	-------	-------	-------	-------	-------	-------	-------	-------	----	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m=	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	18.48	16.42	13.35	10.11	7.56	6.38	6.89	8.96	12.03	15.27	17.82	19	(67)
--------	-------	-------	-------	-------	------	------	------	------	-------	-------	-------	----	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	207.34	209.49	204.07	192.53	177.96	164.26	155.12	152.96	158.39	169.93	184.5	198.19	(68)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	0	0	0	0	0	0	0	0	0	0	0	0	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	125.03	122.95	118.63	112.76	108.96	103.59	99.03	104.87	106.95	113.02	119.88	122.96	(72)
--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	------

Total internal gains =

$$(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$$

(73)m=	409.07	407.08	394.27	373.62	352.69	332.46	319.26	325.02	335.58	356.44	380.42	398.37	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)	
South	0.9x	0.77	x 2.69	x 46.75	x 0.4	x 0.8 = 27.89	(78)
South	0.9x	0.77	x 11.21	x 46.75	x 0.4	x 0.8 = 116.22	(78)
South	0.9x	0.77	x 2.69	x 76.57	x 0.4	x 0.8 = 45.68	(78)
South	0.9x	0.77	x 11.21	x 76.57	x 0.4	x 0.8 = 190.34	(78)
South	0.9x	0.77	x 2.69	x 97.53	x 0.4	x 0.8 = 58.18	(78)

DER WorkSheet: New dwelling design stage

South	0.9x	0.77	x	11.21	x	97.53	x	0.4	x	0.8	=	242.46	(78)
South	0.9x	0.77	x	2.69	x	110.23	x	0.4	x	0.8	=	65.76	(78)
South	0.9x	0.77	x	11.21	x	110.23	x	0.4	x	0.8	=	274.04	(78)
South	0.9x	0.77	x	2.69	x	114.87	x	0.4	x	0.8	=	68.52	(78)
South	0.9x	0.77	x	11.21	x	114.87	x	0.4	x	0.8	=	285.56	(78)
South	0.9x	0.77	x	2.69	x	110.55	x	0.4	x	0.8	=	65.95	(78)
South	0.9x	0.77	x	11.21	x	110.55	x	0.4	x	0.8	=	274.81	(78)
South	0.9x	0.77	x	2.69	x	108.01	x	0.4	x	0.8	=	64.43	(78)
South	0.9x	0.77	x	11.21	x	108.01	x	0.4	x	0.8	=	268.51	(78)
South	0.9x	0.77	x	2.69	x	104.89	x	0.4	x	0.8	=	62.57	(78)
South	0.9x	0.77	x	11.21	x	104.89	x	0.4	x	0.8	=	260.76	(78)
South	0.9x	0.77	x	2.69	x	101.89	x	0.4	x	0.8	=	60.78	(78)
South	0.9x	0.77	x	11.21	x	101.89	x	0.4	x	0.8	=	253.28	(78)
South	0.9x	0.77	x	2.69	x	82.59	x	0.4	x	0.8	=	49.27	(78)
South	0.9x	0.77	x	11.21	x	82.59	x	0.4	x	0.8	=	205.3	(78)
South	0.9x	0.77	x	2.69	x	55.42	x	0.4	x	0.8	=	33.06	(78)
South	0.9x	0.77	x	11.21	x	55.42	x	0.4	x	0.8	=	137.76	(78)
South	0.9x	0.77	x	2.69	x	40.4	x	0.4	x	0.8	=	24.1	(78)
South	0.9x	0.77	x	11.21	x	40.4	x	0.4	x	0.8	=	100.43	(78)
West	0.9x	0.77	x	1.8	x	19.64	x	0.4	x	0.8	=	7.84	(80)
West	0.9x	0.77	x	1.8	x	19.64	x	0.4	x	0.8	=	7.84	(80)
West	0.9x	0.77	x	3.24	x	19.64	x	0.4	x	0.8	=	14.11	(80)
West	0.9x	0.77	x	1.8	x	38.42	x	0.4	x	0.8	=	15.34	(80)
West	0.9x	0.77	x	3.24	x	38.42	x	0.4	x	0.8	=	15.34	(80)
West	0.9x	0.77	x	1.8	x	38.42	x	0.4	x	0.8	=	27.61	(80)
West	0.9x	0.77	x	3.24	x	63.27	x	0.4	x	0.8	=	25.26	(80)
West	0.9x	0.77	x	1.8	x	63.27	x	0.4	x	0.8	=	25.26	(80)
West	0.9x	0.77	x	3.24	x	63.27	x	0.4	x	0.8	=	45.46	(80)
West	0.9x	0.77	x	1.8	x	92.28	x	0.4	x	0.8	=	36.84	(80)
West	0.9x	0.77	x	1.8	x	92.28	x	0.4	x	0.8	=	36.84	(80)
West	0.9x	0.77	x	3.24	x	92.28	x	0.4	x	0.8	=	66.3	(80)
West	0.9x	0.77	x	1.8	x	113.09	x	0.4	x	0.8	=	45.14	(80)
West	0.9x	0.77	x	1.8	x	113.09	x	0.4	x	0.8	=	45.14	(80)
West	0.9x	0.77	x	3.24	x	113.09	x	0.4	x	0.8	=	81.26	(80)
West	0.9x	0.77	x	1.8	x	115.77	x	0.4	x	0.8	=	46.21	(80)
West	0.9x	0.77	x	1.8	x	115.77	x	0.4	x	0.8	=	46.21	(80)
West	0.9x	0.77	x	3.24	x	115.77	x	0.4	x	0.8	=	83.18	(80)
West	0.9x	0.77	x	1.8	x	110.22	x	0.4	x	0.8	=	44	(80)
West	0.9x	0.77	x	3.24	x	110.22	x	0.4	x	0.8	=	44	(80)
West	0.9x	0.77	x	1.8	x	110.22	x	0.4	x	0.8	=	79.19	(80)
West	0.9x	0.77	x	3.24	x	94.68	x	0.4	x	0.8	=	37.79	(80)

DER WorkSheet: New dwelling design stage

West	0.9x	0.77	x	1.8	x	94.68	x	0.4	x	0.8	=	37.79	(80)
West	0.9x	0.77	x	3.24	x	94.68	x	0.4	x	0.8	=	68.02	(80)
West	0.9x	0.77	x	1.8	x	73.59	x	0.4	x	0.8	=	29.37	(80)
West	0.9x	0.77	x	1.8	x	73.59	x	0.4	x	0.8	=	29.37	(80)
West	0.9x	0.77	x	3.24	x	73.59	x	0.4	x	0.8	=	52.87	(80)
West	0.9x	0.77	x	1.8	x	45.59	x	0.4	x	0.8	=	18.2	(80)
West	0.9x	0.77	x	1.8	x	45.59	x	0.4	x	0.8	=	18.2	(80)
West	0.9x	0.77	x	3.24	x	45.59	x	0.4	x	0.8	=	32.76	(80)
West	0.9x	0.77	x	1.8	x	24.49	x	0.4	x	0.8	=	9.78	(80)
West	0.9x	0.77	x	1.8	x	24.49	x	0.4	x	0.8	=	9.78	(80)
West	0.9x	0.77	x	3.24	x	24.49	x	0.4	x	0.8	=	17.6	(80)
West	0.9x	0.77	x	1.8	x	16.15	x	0.4	x	0.8	=	6.45	(80)
West	0.9x	0.77	x	1.8	x	16.15	x	0.4	x	0.8	=	6.45	(80)
West	0.9x	0.77	x	3.24	x	16.15	x	0.4	x	0.8	=	11.6	(80)

Solar gains in watts, calculated for each month

(83)m = Sum(74)m ... (82)m

(83)m= 173.9 294.3 396.62 479.77 525.63 516.36 500.13 466.94 425.68 323.72 207.97 149.02 (83)

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m= 582.97 701.37 790.89 853.39 878.32 848.82 819.39 791.96 761.26 680.16 588.39 547.39 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(86)m= 0.99	0.97	0.93	0.83	0.68	0.49	0.35	0.38	0.59	0.87	0.98	0.99

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m= 20.27 20.47 20.68 20.88 20.97 21 21 21 20.99 20.87 20.53 20.23 (87)

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m= 20.16 20.16 20.16 20.17 20.17 20.18 20.18 20.18 20.18 20.17 20.17 20.17 (88)

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m= 0.99 0.97 0.92 0.8 0.63 0.43 0.29 0.31 0.52 0.83 0.97 0.99 (89)

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m= 19.2 19.48 19.78 20.04 20.15 20.18 20.18 20.18 20.17 20.04 19.58 19.15 (90)

fLA = Living area ÷ (4) =

0.37

(91)

Mean internal temperature (for the whole dwelling) = fLA × T1 + (1 – fLA) × T2

(92)m= 19.59 19.84 20.11 20.35 20.45 20.48 20.48 20.48 20.47 20.34 19.93 19.54 (92)

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m= 19.59 19.84 20.11 20.35 20.45 20.48 20.48 20.48 20.47 20.34 19.93 19.54 (93)

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that $Ti,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m= 0.99 0.96 0.91 0.81 0.64 0.45 0.31 0.34 0.55 0.84 0.97 0.99 (94)

DER WorkSheet: New dwelling design stage

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	575.11	676.2	723.24	689.22	565.14	384.63	254.85	267.36	415.69	570.3	568.83	542	(95)
--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	-------	--------	-----	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W =[(39)m x [(93)m– (96)m]

(97)m=	1034.54	1008.6	916.85	762.23	581.28	386.18	254.97	267.56	420.44	647.11	856.46	1028.65	(97)
--------	---------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	---------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m – (95)m] x (41)m

(98)m=	341.81	223.38	144.05	52.57	12.01	0	0	0	57.15	207.09	362.07	
--------	--------	--------	--------	-------	-------	---	---	---	-------	--------	--------	--

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1..5,9..12} = 1400.12 \quad (98)$$

Space heating requirement in kWh/m²/year

$$18.82 \quad (99)$$

9b. Energy requirements – Community heating scheme

This part is used for space heating, space cooling or water heating provided by a community scheme.

Fraction of space heat from secondary/supplementary heating (Table 11) '0' if none

$$0 \quad (301)$$

Fraction of space heat from community system 1 – (301) =

$$1 \quad (302)$$

The community scheme may obtain heat from several sources. The procedure allows for CHP and up to four other heat sources; the latter includes boilers, heat pumps, geothermal and waste heat from power stations. See Appendix C.

Fraction of heat from Community boilers

$$1 \quad (303a)$$

Fraction of total space heat from Community boilers

$$(302) \times (303a) = 1 \quad (304a)$$

Factor for control and charging method (Table 4c(3)) for community heating system

$$1 \quad (305)$$

Distribution loss factor (Table 12c) for community heating system

$$1.1 \quad (306)$$

Space heating

Annual space heating requirement

$$1400.12$$

Space heat from Community boilers

$$(98) \times (304a) \times (305) \times (306) = 1540.14 \quad (307a)$$

Efficiency of secondary/supplementary heating system in % (from Table 4a or Appendix E)

$$0 \quad (308)$$

Space heating requirement from secondary/supplementary system

$$(98) \times (301) \times 100 \div (308) = 0 \quad (309)$$

Water heating

Annual water heating requirement

$$2066.36$$

If DHW from community scheme:

Water heat from Community boilers

$$(64) \times (303a) \times (305) \times (306) = 2272.99 \quad (310a)$$

Electricity used for heat distribution

$$0.01 \times [(307a) \dots (307e) + (310a) \dots (310e)] = 38.13 \quad (313)$$

Cooling System Energy Efficiency Ratio

$$0 \quad (314)$$

Space cooling (if there is a fixed cooling system, if not enter 0)

$$= (107) \div (314) = 0 \quad (315)$$

Electricity for pumps and fans within dwelling (Table 4f):

mechanical ventilation - balanced, extract or positive input from outside

$$164.52 \quad (330a)$$

warm air heating system fans

$$0 \quad (330b)$$

pump for solar water heating

$$0 \quad (330g)$$

Total electricity for the above, kWh/year

$$=(330a) + (330b) + (330g) = 164.52 \quad (331)$$

Energy for lighting (calculated in Appendix L)

$$326.44 \quad (332)$$

12b. CO2 Emissions – Community heating scheme

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
--	--------------------	-------------------------------	--------------------------

DER WorkSheet: New dwelling design stage

CO2 from other sources of space and water heating (not CHP)

Efficiency of heat source 1 (%)

If there is CHP using two fuels repeat (363) to (366) for the second fuel

95

(367a)

CO2 associated with heat source 1

$[(307b)+(310b)] \times 100 \div (367b) \times$

0.22

=

866.98

(367)

Electrical energy for heat distribution

$[(313) \times$

0.52

=

19.79

(372)

Total CO2 associated with community systems

(363)...(366) + (368)...(372)

=

886.77

(373)

CO2 associated with space heating (secondary)

$(309) \times$

0

=

0

(374)

CO2 associated with water from immersion heater or instantaneous heater

$(312) \times$

0.22

=

0

(375)

Total CO2 associated with space and water heating

$(373) + (374) + (375) =$

=

886.77

(376)

CO2 associated with electricity for pumps and fans within dwelling

$(331)) \times$

0.52

=

85.38

(378)

CO2 associated with electricity for lighting

$(332))) \times$

0.52

=

169.42

(379)

Total CO2, kg/year sum of (376)...(382) =

1141.58

(383)

Dwelling CO2 Emission Rate $(383) \div (4) =$

15.34

(384)

EI rating (section 14)

87.19

(385)

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 004 - Be Lean			
Address :	AC 004, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	74.4 (1a)	x (2a)	= 215.76 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	74.4 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	215.76 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					3 x 10 = 30 (7a)
Number of passive vents					0 x 10 = 0 (7b)
Number of flueless gas fires					0 x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =	30	÷ (5) = 0.14 (8)
---	----	---------------------

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration $0.25 - [0.2 \times (14) \div 100] =$

Infiltration rate $(8) + (10) + (11) + (12) + (13) + (15) =$

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area

If based on air permeability value, then $(18) = [(17) \div 20] + (8)$, otherwise $(18) = (16)$

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor $(20) = 1 - [0.075 \times (19)] =$

Infiltration rate incorporating shelter factor $(21) = (18) \times (20) =$

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

TER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.42	0.41	0.41	0.36	0.36	0.31	0.31	0.31	0.33	0.36	0.37	0.39
------	------	------	------	------	------	------	------	------	------	------	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0.59	0.59	0.58	0.57	0.56	0.55	0.55	0.55	0.56	0.57	0.58
---------	------	------	------	------	------	------	------	------	------	------	------

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.59	0.59	0.58	0.57	0.56	0.55	0.55	0.55	0.56	0.57	0.58
--------	------	------	------	------	------	------	------	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Windows Type 1			2.41	x1/[1/(1.4) + 0.04] =	3.2		(27)
Windows Type 2			10.05	x1/[1/(1.4)+ 0.04] =	13.32		(27)
Windows Type 3			1.61	x1/[1/(1.4)+ 0.04] =	2.13		(27)
Windows Type 4			1.61	x1/[1/(1.4)+ 0.04] =	2.13		(27)
Windows Type 5			2.91	x1/[1/(1.4)+ 0.04] =	3.86		(27)
Floor			74.4	x 0.13 =	9.672		(28)
Walls	49.53	18.59	30.94	x 0.18 =	5.57		(29)
Total area of elements, m ²			123.93				(31)
Party wall			49.76	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 39.89 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 8.03 (36)

if details of thermal bridging are not known (36) = 0.05 x (31) (33) + (36) =

Total fabric heat loss (33) + (36) = 47.92 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	41.93	41.68	41.44	40.31	40.1	39.11	39.11	38.93	39.49	40.1	40.53	40.98

(38)

Heat transfer coefficient, W/K (39)m = (37) + (38)m

(39)m=	89.85	89.61	89.36	88.23	88.02	87.04	87.04	86.85	87.42	88.02	88.45	88.9
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

TER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	1.21	1.2	1.2	1.19	1.18	1.17	1.17	1.17	1.17	1.18	1.19	1.19	(40)m = (39)m ÷ (4)
													Average = Sum(40) _{1...12} / 12 = 1.19

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(41)
(41)m= 31	28	31	30	31	30	31	31	30	31	30	31	

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

2.35

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)^2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

89.97

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m= 98.96	95.36	91.77	88.17	84.57	80.97	80.97	84.57	88.17	91.77	95.36	98.96	Total = Sum(44) _{1...12} = 1079.59 (44)
--------------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m= 146.76	128.36	132.45	115.47	110.8	95.61	88.6	101.67	102.88	119.9	130.88	142.13	Total = Sum(45) _{1...12} = 1415.52 (45)
---------------	--------	--------	--------	-------	-------	------	--------	--------	-------	--------	--------	--

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m= 22.01	19.25	19.87	17.32	16.62	14.34	13.29	15.25	15.43	17.99	19.63	21.32	(46)
--------------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

150

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

1.39

(48)

Temperature factor from Table 2b

0.54

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

0.75

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0

(51)

If community heating see section 4.3

Volume factor from Table 2a

0

(52)

Temperature factor from Table 2b

0

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

0

(54)

Enter (50) or (54) in (55)

0.75

(55)

Water storage loss calculated for each month

((56)m = (55) x (41)m)

(56)m= 23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	(56)
--------------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m= 23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	(57)
--------------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m= 23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26	(59)
--------------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

TER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	193.35	170.44	179.05	160.57	157.4	140.7	135.19	148.26	147.98	166.5	175.97	188.72	(62)
--------	--------	--------	--------	--------	-------	-------	--------	--------	--------	-------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	193.35	170.44	179.05	160.57	157.4	140.7	135.19	148.26	147.98	166.5	175.97	188.72	
Output from water heater (annual) 1...12												1964.13	(64)

Heat gains from water heating, kWh/month 0.25 [$0.85 \times (45)m + (61)m$] + $0.8 \times [(46)m + (57)m + (59)m]$]

(65)m=	86.07	76.35	81.32	74.47	74.12	67.86	66.74	71.08	70.28	77.14	79.59	84.53	(65)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m=	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	18.48	16.42	13.35	10.11	7.56	6.38	6.89	8.96	12.03	15.27	17.82	19	(67)
--------	-------	-------	-------	-------	------	------	------	------	-------	-------	-------	----	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	207.34	209.49	204.07	192.53	177.96	164.26	155.12	152.96	158.39	169.93	184.5	198.19	(68)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	3	3	3	3	3	3	3	3	3	3	3	3	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	115.69	113.61	109.3	103.43	99.62	94.26	89.7	95.54	97.61	103.69	110.54	113.62	(72)
--------	--------	--------	-------	--------	-------	-------	------	-------	-------	--------	--------	--------	------

Total internal gains = $(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$

(73)m=	402.74	400.74	387.94	367.29	346.35	326.12	312.93	318.68	329.25	350.11	374.08	392.03	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)	
South	0.9x	0.77	x 2.41	x 46.75	x 0.63	x 0.7	= 34.43
South	0.9x	0.77	x 10.05	x 46.75	x 0.63	x 0.7	= 143.59
South	0.9x	0.77	x 2.41	x 76.57	x 0.63	x 0.7	= 56.39
South	0.9x	0.77	x 10.05	x 76.57	x 0.63	x 0.7	= 235.17
South	0.9x	0.77	x 2.41	x 97.53	x 0.63	x 0.7	= 71.84

TER WorkSheet: New dwelling design stage

South	0.9x	0.77	x	10.05	x	97.53	x	0.63	x	0.7	=	299.57	(78)
South	0.9x	0.77	x	2.41	x	110.23	x	0.63	x	0.7	=	81.19	(78)
South	0.9x	0.77	x	10.05	x	110.23	x	0.63	x	0.7	=	338.58	(78)
South	0.9x	0.77	x	2.41	x	114.87	x	0.63	x	0.7	=	84.61	(78)
South	0.9x	0.77	x	10.05	x	114.87	x	0.63	x	0.7	=	352.82	(78)
South	0.9x	0.77	x	2.41	x	110.55	x	0.63	x	0.7	=	81.42	(78)
South	0.9x	0.77	x	10.05	x	110.55	x	0.63	x	0.7	=	339.54	(78)
South	0.9x	0.77	x	2.41	x	108.01	x	0.63	x	0.7	=	79.55	(78)
South	0.9x	0.77	x	10.05	x	108.01	x	0.63	x	0.7	=	331.75	(78)
South	0.9x	0.77	x	2.41	x	104.89	x	0.63	x	0.7	=	77.26	(78)
South	0.9x	0.77	x	10.05	x	104.89	x	0.63	x	0.7	=	322.17	(78)
South	0.9x	0.77	x	2.41	x	101.89	x	0.63	x	0.7	=	75.04	(78)
South	0.9x	0.77	x	10.05	x	101.89	x	0.63	x	0.7	=	312.93	(78)
South	0.9x	0.77	x	2.41	x	82.59	x	0.63	x	0.7	=	60.83	(78)
South	0.9x	0.77	x	10.05	x	82.59	x	0.63	x	0.7	=	253.65	(78)
South	0.9x	0.77	x	2.41	x	55.42	x	0.63	x	0.7	=	40.82	(78)
South	0.9x	0.77	x	10.05	x	55.42	x	0.63	x	0.7	=	170.21	(78)
South	0.9x	0.77	x	2.41	x	40.4	x	0.63	x	0.7	=	29.75	(78)
South	0.9x	0.77	x	10.05	x	40.4	x	0.63	x	0.7	=	124.08	(78)
West	0.9x	0.77	x	1.61	x	19.64	x	0.63	x	0.7	=	9.66	(80)
West	0.9x	0.77	x	1.61	x	19.64	x	0.63	x	0.7	=	9.66	(80)
West	0.9x	0.77	x	2.91	x	19.64	x	0.63	x	0.7	=	17.47	(80)
West	0.9x	0.77	x	1.61	x	38.42	x	0.63	x	0.7	=	18.9	(80)
West	0.9x	0.77	x	1.61	x	38.42	x	0.63	x	0.7	=	18.9	(80)
West	0.9x	0.77	x	2.91	x	38.42	x	0.63	x	0.7	=	34.17	(80)
West	0.9x	0.77	x	1.61	x	63.27	x	0.63	x	0.7	=	31.13	(80)
West	0.9x	0.77	x	1.61	x	63.27	x	0.63	x	0.7	=	31.13	(80)
West	0.9x	0.77	x	2.91	x	63.27	x	0.63	x	0.7	=	56.27	(80)
West	0.9x	0.77	x	1.61	x	92.28	x	0.63	x	0.7	=	45.41	(80)
West	0.9x	0.77	x	1.61	x	92.28	x	0.63	x	0.7	=	45.41	(80)
West	0.9x	0.77	x	2.91	x	92.28	x	0.63	x	0.7	=	82.07	(80)
West	0.9x	0.77	x	1.61	x	113.09	x	0.63	x	0.7	=	55.65	(80)
West	0.9x	0.77	x	1.61	x	113.09	x	0.63	x	0.7	=	55.65	(80)
West	0.9x	0.77	x	2.91	x	113.09	x	0.63	x	0.7	=	100.58	(80)
West	0.9x	0.77	x	1.61	x	115.77	x	0.63	x	0.7	=	56.96	(80)
West	0.9x	0.77	x	1.61	x	115.77	x	0.63	x	0.7	=	56.96	(80)
West	0.9x	0.77	x	2.91	x	115.77	x	0.63	x	0.7	=	102.96	(80)
West	0.9x	0.77	x	1.61	x	110.22	x	0.63	x	0.7	=	54.23	(80)
West	0.9x	0.77	x	1.61	x	110.22	x	0.63	x	0.7	=	54.23	(80)
West	0.9x	0.77	x	2.91	x	110.22	x	0.63	x	0.7	=	98.02	(80)
West	0.9x	0.77	x	1.61	x	94.68	x	0.63	x	0.7	=	46.58	(80)

TER WorkSheet: New dwelling design stage

West	0.9x	0.77	x	1.61	x	94.68	x	0.63	x	0.7	=	46.58	(80)
West	0.9x	0.77	x	2.91	x	94.68	x	0.63	x	0.7	=	84.2	(80)
West	0.9x	0.77	x	1.61	x	73.59	x	0.63	x	0.7	=	36.21	(80)
West	0.9x	0.77	x	1.61	x	73.59	x	0.63	x	0.7	=	36.21	(80)
West	0.9x	0.77	x	2.91	x	73.59	x	0.63	x	0.7	=	65.45	(80)
West	0.9x	0.77	x	1.61	x	45.59	x	0.63	x	0.7	=	22.43	(80)
West	0.9x	0.77	x	1.61	x	45.59	x	0.63	x	0.7	=	22.43	(80)
West	0.9x	0.77	x	2.91	x	45.59	x	0.63	x	0.7	=	40.54	(80)
West	0.9x	0.77	x	1.61	x	24.49	x	0.63	x	0.7	=	12.05	(80)
West	0.9x	0.77	x	1.61	x	24.49	x	0.63	x	0.7	=	12.05	(80)
West	0.9x	0.77	x	2.91	x	24.49	x	0.63	x	0.7	=	21.78	(80)
West	0.9x	0.77	x	1.61	x	16.15	x	0.63	x	0.7	=	7.95	(80)
West	0.9x	0.77	x	1.61	x	16.15	x	0.63	x	0.7	=	7.95	(80)
West	0.9x	0.77	x	2.91	x	16.15	x	0.63	x	0.7	=	14.36	(80)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m=	214.82	363.54	489.94	592.64	649.29	637.84	617.79	576.8	525.84	399.89	256.9	184.09	(83)
--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	-------	--------	------

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=	617.56	764.29	877.88	959.93	995.65	963.97	930.71	895.48	855.08	749.99	630.99	576.12	(84)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m=	0.99	0.98	0.95	0.87	0.74	0.56	0.41	0.44	0.66	0.9	0.98	0.99	(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	19.89	20.13	20.42	20.71	20.9	20.98	21	20.99	20.95	20.7	20.23	19.85	(87)
--------	-------	-------	-------	-------	------	-------	----	-------	-------	------	-------	-------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	19.91	19.92	19.92	19.93	19.93	19.94	19.94	19.95	19.94	19.93	19.93	19.92	(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.99	0.97	0.93	0.84	0.68	0.48	0.31	0.34	0.58	0.87	0.97	0.99	(89)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.46	18.81	19.22	19.62	19.84	19.93	19.94	19.94	19.91	19.62	18.97	18.41	(90)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

$$fLA = \text{Living area} \div 4 =$$

0.37

(91)

Mean internal temperature (for the whole dwelling) = fLA × T1 + (1 – fLA) × T2

(92)m=	18.99	19.3	19.66	20.02	20.23	20.32	20.33	20.33	20.29	20.02	19.44	18.94	(92)
--------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	18.99	19.3	19.66	20.02	20.23	20.32	20.33	20.33	20.29	20.02	19.44	18.94	(93)
--------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that $Ti,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	0.99	0.97	0.93	0.84	0.7	0.51	0.35	0.38	0.61	0.87	0.97	0.99	(94)
--------	------	------	------	------	-----	------	------	------	------	------	------	------	------

TER WorkSheet: New dwelling design stage

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	609.09	738.39	812.16	805.89	694.01	488.29	323.47	339.56	519.11	652.13	612	570.19	(95)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-----	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W =[(39)m x [(93)m – (96)m]

(97)m=	1319.74	1289.95	1175.85	981.05	750.88	497.54	324.61	341.32	541.33	828.72	1091.18	1310.05	(97)
--------	---------	---------	---------	--------	--------	--------	--------	--------	--------	--------	---------	---------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m – (95)m] x (41)m

(98)m=	528.72	370.64	270.59	126.12	42.32	0	0	0	0	131.39	345.01	550.46	
--------	--------	--------	--------	--------	-------	---	---	---	---	--------	--------	--------	--

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1,5,9,12} = 2365.25 \quad (98)$$

Space heating requirement in kWh/m²/year

$$31.79 \quad (99)$$

9a. Energy requirements – Individual heating systems including micro-CHP

Space heating:

Fraction of space heat from secondary/supplementary system

$$0 \quad (201)$$

Fraction of space heat from main system(s)

$$(202) = 1 - (201) = 1 \quad (202)$$

Fraction of total heating from main system 1

$$(204) = (202) \times [1 - (203)] = 1 \quad (204)$$

Efficiency of main space heating system 1

$$93.5 \quad (206)$$

Efficiency of secondary/supplementary heating system, %

$$0 \quad (208)$$

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

528.72	370.64	270.59	126.12	42.32	0	0	0	0	131.39	345.01	550.46	
--------	--------	--------	--------	-------	---	---	---	---	--------	--------	--------	--

$$(211)m = \{[(98)m \times (204)]\} \times 100 \div (206) \quad (211)$$

565.48	396.41	289.4	134.89	45.26	0	0	0	0	140.52	368.99	588.72	
--------	--------	-------	--------	-------	---	---	---	---	--------	--------	--------	--

$$\text{Total (kWh/year)} = \text{Sum}(211)_{1,5,10,12} = 2529.68 \quad (211)$$

Space heating fuel (secondary), kWh/month

$$= \{[(98)m \times (201)]\} \times 100 \div (208)$$

(215)m=	0	0	0	0	0	0	0	0	0	0	0	0	
---------	---	---	---	---	---	---	---	---	---	---	---	---	--

$$\text{Total (kWh/year)} = \text{Sum}(215)_{1,5,10,12} = 0 \quad (215)$$

Water heating

Output from water heater (calculated above)

193.35	170.44	179.05	160.57	157.4	140.7	135.19	148.26	147.98	166.5	175.97	188.72	
--------	--------	--------	--------	-------	-------	--------	--------	--------	-------	--------	--------	--

$$79.8 \quad (216)$$

Efficiency of water heater

(217)m=	87.36	86.83	85.91	84.18	81.85	79.8	79.8	79.8	84.19	86.58	87.5	
---------	-------	-------	-------	-------	-------	------	------	------	-------	-------	------	--

$$217 \quad (217)$$

Fuel for water heating, kWh/month

$$(219)m = (64)m \times 100 \div (217)m$$

(219)m=	221.32	196.29	208.41	190.75	192.3	176.32	169.42	185.79	185.43	197.76	203.25	215.67	
---------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--

$$\text{Total} = \text{Sum}(219a)_{1,5,12} = 2342.71 \quad (219)$$

Annual totals

Space heating fuel used, main system 1

$$\text{kWh/year}$$

$$2529.68$$

Water heating fuel used

$$\text{kWh/year}$$

$$2342.71$$

Electricity for pumps, fans and electric keep-hot

central heating pump:

$$30 \quad (230c)$$

TER WorkSheet: New dwelling design stage

boiler with a fan-assisted flue	45	(230e)
Total electricity for the above, kWh/year	sum of (230a)...(230g) =	75 (231)
Electricity for lighting	326.44 (232)	

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating (main system 1)	(211) x	0.216	= 546.41 (261)
Space heating (secondary)	(215) x	0.519	= 0 (263)
Water heating	(219) x	0.216	= 506.02 (264)
Space and water heating	(261) + (262) + (263) + (264) =		1052.43 (265)
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	= 38.93 (267)
Electricity for lighting	(232) x	0.519	= 169.42 (268)
Total CO2, kg/year		sum of (265)...(271) =	1260.78 (272)

TER = 16.95 (273)

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name: John Simpson **Stroma Number:** STRO006273
Software Name: Stroma FSAP 2012 **Software Version:** Version: 1.0.5.8

Property Address: AC 005 - Be Lean

Address : AC 005, Aspen Court, Maitland Park Estate, London, NW3 2EH

1. Overall dwelling dimensions:

	Area(m ²)	Av. Height(m)	Volume(m ³)
Ground floor	52.2	(1a) x (2a) =	151.38 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	52.2 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	151.38 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m ³ per hour
Number of chimneys	0	+	0	= 0	x 40 = 0 (6a)
Number of open flues	0	+	0	= 0	x 20 = 0 (6b)
Number of intermittent fans					x 10 = 0 (7a)
Number of passive vents					x 10 = 0 (7b)
Number of flueless gas fires					x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 0 ÷ (5) = 0 (8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

If both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] = 0 (15)

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) =

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area 2 (17)

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] =

Infiltration rate incorporating shelter factor (21) = (18) x (20) =

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(22)m= 5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7

Wind Factor (22a)m = (22)m ÷ 4

(22a)m= 1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
--------------	------	------	-----	------	------	------	------	---	------	------	------

DER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.11	0.11	0.1	0.09	0.09	0.08	0.08	0.08	0.08	0.09	0.1	0.1
------	------	-----	------	------	------	------	------	------	------	-----	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.21	0.21	0.22
---------	------	------	------	------	------	-----	-----	-----	------	------	------

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.2	0.21	0.21	0.22
--------	------	------	------	------	------	-----	-----	-----	-----	------	------	------

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Doors			2.95	x 1.4 =	4.13		(26)
Windows Type 1			4.91	x1/[1/(1.4)+ 0.04] =	6.51		(27)
Windows Type 2			7.06	x1/[1/(1.4)+ 0.04] =	9.36		(27)
Windows Type 3			1.8	x1/[1/(1.4)+ 0.04] =	2.39		(27)
Floor			52.2	x 0.12 =	6.264		(28)
Walls	34.57	16.72	17.85	x 0.12 =	2.14		(29)
Total area of elements, m ²			86.77				(31)
Party wall			49.76	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U)

(26)...(30) + (32) = 30.79 (33)

Heat capacity Cm = S(A x k)

((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K

Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K

9.46 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 40.25 (37)

Ventilation heat loss calculated monthly

(38)m = 0.33 x (25)m x (5)

(38)m=	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
	11.28	11.18	11.07	10.54	10.43	9.9	9.9	9.8	10.12	10.43	10.65	10.86

Heat transfer coefficient, W/K

(39)m = (37) + (38)m

(39)m=	51.53	51.43	51.32	50.79	50.68	50.15	50.15	50.05	50.36	50.68	50.89	51.11
	Average = Sum(39) _{1...12} /12=											

50.76 (39)

DER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	0.99	0.99	0.98	0.97	0.97	0.96	0.96	0.96	0.96	0.97	0.97	0.98			
													Average = Sum(40) _{1...12} /12=	0.97	(40)

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
(41)m=	31	28	31	30	31	30	31	31	30	31	30	31		(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

1.75

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd,\text{average} = (25 \times N) + 36$

75.88

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	83.47	80.43	77.4	74.36	71.33	68.29	68.29	71.33	74.36	77.4	80.43	83.47
--------	-------	-------	------	-------	-------	-------	-------	-------	-------	------	-------	-------

Total = Sum(44)_{1...12} =

910.57

(44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	123.78	108.26	111.71	97.4	93.45	80.64	74.73	85.75	86.78	101.13	110.39	119.88
--------	--------	--------	--------	------	-------	-------	-------	-------	-------	--------	--------	--------

Total = Sum(45)_{1...12} =

1193.9

(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	18.57	16.24	16.76	14.61	14.02	12.1	11.21	12.86	13.02	15.17	16.56	17.98
--------	-------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0

(48)

Temperature factor from Table 2b

0

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

110

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0.02

(51)

If community heating see section 4.3

Volume factor from Table 2a

1.03

(52)

Temperature factor from Table 2b

0.6

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

1.03

(54)

Enter (50) or (54) in (55)

1.03

(55)

Water storage loss calculated for each month

((56)m = (55) x (41)m)

(56)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

0

(58)

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(59)

DER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	179.06	158.19	166.99	150.89	148.73	134.14	130	141.03	140.27	156.41	163.88	175.15	(62)
--------	--------	--------	--------	--------	--------	--------	-----	--------	--------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	179.06	158.19	166.99	150.89	148.73	134.14	130	141.03	140.27	156.41	163.88	175.15	
Output from water heater (annual) 1...12												1844.74	(64)

Heat gains from water heating, kWh/month 0.25 [$0.85 \times (45)m + (61)m$] + $0.8 \times [(46)m + (57)m + (59)m]$]

(65)m=	85.38	75.94	81.37	75.18	75.29	69.61	69.07	72.73	71.65	77.85	79.5	84.08	(65)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(66)m=	87.75	87.75	87.75	87.75	87.75	87.75	87.75	87.75	87.75	87.75	87.75	87.75

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	13.64	12.11	9.85	7.46	5.57	4.71	5.08	6.61	8.87	11.26	13.15	14.01	(67)
--------	-------	-------	------	------	------	------	------	------	------	-------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	152.94	154.53	150.53	142.02	131.27	121.17	114.42	112.83	116.83	125.35	136.09	146.2	(68)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	31.77	31.77	31.77	31.77	31.77	31.77	31.77	31.77	31.77	31.77	31.77	31.77	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	0	0	0	0	0	0	0	0	0	0	0	0	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-70.2	-70.2	-70.2	-70.2	-70.2	-70.2	-70.2	-70.2	-70.2	-70.2	-70.2	-70.2	(71)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Water heating gains (Table 5)

(72)m=	114.76	113	109.36	104.42	101.2	96.68	92.83	97.76	99.51	104.63	110.42	113.01	(72)
--------	--------	-----	--------	--------	-------	-------	-------	-------	-------	--------	--------	--------	------

Total internal gains =

$$(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$$

(73)m=	330.66	328.97	319.07	303.21	287.37	271.88	261.66	266.53	274.54	290.57	308.98	322.55	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_ Table 6b	FF Table 6c	Gains (W)
East	0.9x	0.77	x 4.91	x 19.64	x 0.4	x 0.8 = 21.39 (76)
East	0.9x	0.77	x 4.91	x 38.42	x 0.4	x 0.8 = 41.83 (76)
East	0.9x	0.77	x 4.91	x 63.27	x 0.4	x 0.8 = 68.89 (76)
East	0.9x	0.77	x 4.91	x 92.28	x 0.4	x 0.8 = 100.48 (76)
East	0.9x	0.77	x 4.91	x 113.09	x 0.4	x 0.8 = 123.14 (76)

DER WorkSheet: New dwelling design stage

East	0.9x	0.77	x	4.91	x	115.77	x	0.4	x	0.8	=	126.06	(76)
East	0.9x	0.77	x	4.91	x	110.22	x	0.4	x	0.8	=	120.01	(76)
East	0.9x	0.77	x	4.91	x	94.68	x	0.4	x	0.8	=	103.09	(76)
East	0.9x	0.77	x	4.91	x	73.59	x	0.4	x	0.8	=	80.13	(76)
East	0.9x	0.77	x	4.91	x	45.59	x	0.4	x	0.8	=	49.64	(76)
East	0.9x	0.77	x	4.91	x	24.49	x	0.4	x	0.8	=	26.66	(76)
East	0.9x	0.77	x	4.91	x	16.15	x	0.4	x	0.8	=	17.59	(76)
West	0.9x	0.77	x	7.06	x	19.64	x	0.4	x	0.8	=	30.75	(80)
West	0.9x	0.77	x	1.8	x	19.64	x	0.4	x	0.8	=	7.84	(80)
West	0.9x	0.77	x	7.06	x	38.42	x	0.4	x	0.8	=	60.15	(80)
West	0.9x	0.77	x	1.8	x	38.42	x	0.4	x	0.8	=	15.34	(80)
West	0.9x	0.77	x	7.06	x	63.27	x	0.4	x	0.8	=	99.06	(80)
West	0.9x	0.77	x	1.8	x	63.27	x	0.4	x	0.8	=	25.26	(80)
West	0.9x	0.77	x	7.06	x	92.28	x	0.4	x	0.8	=	144.48	(80)
West	0.9x	0.77	x	1.8	x	92.28	x	0.4	x	0.8	=	36.84	(80)
West	0.9x	0.77	x	7.06	x	113.09	x	0.4	x	0.8	=	177.06	(80)
West	0.9x	0.77	x	1.8	x	113.09	x	0.4	x	0.8	=	45.14	(80)
West	0.9x	0.77	x	7.06	x	115.77	x	0.4	x	0.8	=	181.25	(80)
West	0.9x	0.77	x	1.8	x	115.77	x	0.4	x	0.8	=	46.21	(80)
West	0.9x	0.77	x	7.06	x	110.22	x	0.4	x	0.8	=	172.56	(80)
West	0.9x	0.77	x	1.8	x	110.22	x	0.4	x	0.8	=	44	(80)
West	0.9x	0.77	x	7.06	x	94.68	x	0.4	x	0.8	=	148.23	(80)
West	0.9x	0.77	x	1.8	x	94.68	x	0.4	x	0.8	=	37.79	(80)
West	0.9x	0.77	x	7.06	x	73.59	x	0.4	x	0.8	=	115.21	(80)
West	0.9x	0.77	x	1.8	x	73.59	x	0.4	x	0.8	=	29.37	(80)
West	0.9x	0.77	x	7.06	x	45.59	x	0.4	x	0.8	=	71.38	(80)
West	0.9x	0.77	x	1.8	x	45.59	x	0.4	x	0.8	=	18.2	(80)
West	0.9x	0.77	x	7.06	x	24.49	x	0.4	x	0.8	=	38.34	(80)
West	0.9x	0.77	x	1.8	x	24.49	x	0.4	x	0.8	=	9.78	(80)
West	0.9x	0.77	x	7.06	x	16.15	x	0.4	x	0.8	=	25.29	(80)
West	0.9x	0.77	x	1.8	x	16.15	x	0.4	x	0.8	=	6.45	(80)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m=	59.97	117.32	193.21	281.79	345.34	353.52	336.57	289.11	224.71	139.21	74.78	49.32	(83)
--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	-------	------

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=	390.63	446.29	512.28	585	632.72	625.4	598.23	555.63	499.25	429.78	383.76	371.87	(84)
--------	--------	--------	--------	-----	--------	-------	--------	--------	--------	--------	--------	--------	------

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m=	0.99	0.99	0.96	0.87	0.7	0.51	0.37	0.41	0.67	0.92	0.99	1	(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	20.12	20.28	20.53	20.81	20.95	20.99	21	21	20.97	20.76	20.39	20.09	(87)
--------	-------	-------	-------	-------	-------	-------	----	----	-------	-------	-------	-------	------

DER WorkSheet: New dwelling design stage

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	20.09	20.1	20.1	20.11	20.11	20.12	20.12	20.12	20.11	20.11	20.1	20.1	(88)
--------	-------	------	------	-------	-------	-------	-------	-------	-------	-------	------	------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.99	0.98	0.95	0.84	0.65	0.44	0.29	0.33	0.59	0.9	0.98	0.99	(89)
--------	------	------	------	------	------	------	------	------	------	-----	------	------	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.94	19.16	19.52	19.89	20.07	20.11	20.12	20.12	20.09	19.84	19.33	18.9	(90)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------	------

$$fLA = \text{Living area} \div (4) = 0.47 \quad (91)$$

Mean internal temperature (for the whole dwelling) = $fLA \times T1 + (1 - fLA) \times T2$

(92)m=	19.49	19.69	20	20.32	20.48	20.53	20.53	20.53	20.51	20.27	19.83	19.46	(92)
--------	-------	-------	----	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.49	19.69	20	20.32	20.48	20.53	20.53	20.53	20.51	20.27	19.83	19.46	(93)
--------	-------	-------	----	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that $Ti,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	0.99	0.98	0.95	0.85	0.67	0.47	0.33	0.37	0.63	0.9	0.98	0.99	(94)
--------	------	------	------	------	------	------	------	------	------	-----	------	------	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	386.85	437.2	484.8	496.34	425.98	295.14	196.91	206.32	313.1	387.72	375.81	369.05	(95)
--------	--------	-------	-------	--------	--------	--------	--------	--------	-------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W = [(39)m x [(93)m – (96)m]

(97)m=	782.96	760.47	692.56	580.12	445.1	297.21	197.12	206.73	322.68	490.27	647.67	779.77	(97)
--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m – (95)m] x (41)m

(98)m=	294.7	217.24	154.57	60.32	14.23	0	0	0	76.29	195.74	305.58	
--------	-------	--------	--------	-------	-------	---	---	---	-------	--------	--------	--

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1...5,9...12} = 1318.67 \quad (98)$$

Space heating requirement in kWh/m²/year

$$25.26 \quad (99)$$

9b. Energy requirements – Community heating scheme

This part is used for space heating, space cooling or water heating provided by a community scheme.

Fraction of space heat from secondary/supplementary heating (Table 11) '0' if none

$$0 \quad (301)$$

Fraction of space heat from community system 1 – (301) =

$$1 \quad (302)$$

The community scheme may obtain heat from several sources. The procedure allows for CHP and up to four other heat sources; the latter includes boilers, heat pumps, geothermal and waste heat from power stations. See Appendix C.

Fraction of heat from Community boilers

$$1 \quad (303a)$$

Fraction of total space heat from Community boilers

$$(302) \times (303a) = 1 \quad (304a)$$

Factor for control and charging method (Table 4c(3)) for community heating system

$$1 \quad (305)$$

Distribution loss factor (Table 12c) for community heating system

$$1.1 \quad (306)$$

Space heating

Annual space heating requirement

$$1318.67$$

Space heat from Community boilers

$$(98) \times (304a) \times (305) \times (306) = 1450.53 \quad (307a)$$

Efficiency of secondary/supplementary heating system in % (from Table 4a or Appendix E)

$$0 \quad (308)$$

DER WorkSheet: New dwelling design stage

Space heating requirement from secondary/supplementary system	$(98) \times (301) \times 100 \div (308) =$	0	(309)
Water heating			
Annual water heating requirement		1844.74	
If DHW from community scheme:			
Water heat from Community boilers	$(64) \times (303a) \times (305) \times (306) =$	2029.21	(310a)
Electricity used for heat distribution	$0.01 \times [(307a) \dots (307e) + (310a) \dots (310e)] =$	34.8	(313)
Cooling System Energy Efficiency Ratio		0	(314)
Space cooling (if there is a fixed cooling system, if not enter 0)	$= (107) \div (314) =$	0	(315)
Electricity for pumps and fans within dwelling (Table 4f):			
mechanical ventilation - balanced, extract or positive input from outside		115.43	(330a)
warm air heating system fans		0	(330b)
pump for solar water heating		0	(330g)
Total electricity for the above, kWh/year	$= (330a) + (330b) + (330g) =$	115.43	(331)
Energy for lighting (calculated in Appendix L)		240.8	(332)

12b. CO2 Emissions – Community heating scheme

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
CO2 from other sources of space and water heating (not CHP)			
Efficiency of heat source 1 (%)	If there is CHP using two fuels repeat (363) to (366) for the second fuel		
CO2 associated with heat source 1	$[(307b)+(310b)] \times 100 \div (367b) \times$	0.22	= 791.18 (367)
Electrical energy for heat distribution	$[(313) \times$	0.52	= 18.06 (372)
Total CO2 associated with community systems	$(363) \dots (366) + (368) \dots (372)$		= 809.24 (373)
CO2 associated with space heating (secondary)	$(309) \times$	0	= 0 (374)
CO2 associated with water from immersion heater or instantaneous heater	$(312) \times$	0.22	= 0 (375)
Total CO2 associated with space and water heating	$(373) + (374) + (375) =$		809.24 (376)
CO2 associated with electricity for pumps and fans within dwelling	$(331)) \times$	0.52	= 59.91 (378)
CO2 associated with electricity for lighting	$(332)) \times$	0.52	= 124.98 (379)
Total CO2, kg/year	sum of (376)...(382) =		994.13 (383)
Dwelling CO2 Emission Rate	$(383) \div (4) =$		19.04 (384)
EI rating (section 14)			86.29 (385)

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 005 - Be Lean			
Address :	AC 005, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	52.2 (1a)	x (2a)	= 151.38 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	52.2 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	151.38 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					2 x 10 = 20 (7a)
Number of passive vents					0 x 10 = 0 (7b)
Number of flueless gas fires					0 x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 20	÷ (5) = 0.13 (8)
<i>If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)</i>	
Number of storeys in the dwelling (ns)	0 (9)
Additional infiltration	[(9)-1]x0.1 = 0 (10)
Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction	0 (11)

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0	0 (12)
If no draught lobby, enter 0.05, else enter 0	0 (13)
Percentage of windows and doors draught stripped	0 (14)
Window infiltration	0.25 - [0.2 x (14) ÷ 100] = 0 (15)
Infiltration rate	(8) + (10) + (11) + (12) + (13) + (15) = 0 (16)
Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area	5 (17)
If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)	0.38 (18)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered	2 (19)
Shelter factor	(20) = 1 - [0.075 x (19)] = 0.85 (20)
Infiltration rate incorporating shelter factor	(21) = (18) x (20) = 0.32 (21)

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

TER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.41	0.41	0.4	0.36	0.35	0.31	0.31	0.3	0.32	0.35	0.37	0.38
------	------	-----	------	------	------	------	-----	------	------	------	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0.59	0.58	0.58	0.56	0.56	0.55	0.55	0.55	0.56	0.57	0.57
---------	------	------	------	------	------	------	------	------	------	------	------

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.59	0.58	0.58	0.56	0.56	0.55	0.55	0.55	0.56	0.57	0.57
--------	------	------	------	------	------	------	------	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Doors			2.95	x 1.2 =	3.54		
Windows Type 1			3.6	x1/[1/(1.4)+ 0.04] =	4.77		
Windows Type 2			5.18	x1/[1/(1.4)+ 0.04] =	6.87		
Windows Type 3			1.32	x1/[1/(1.4)+ 0.04] =	1.75		
Floor			52.2	x 0.13 =	6.786		
Walls	34.57	13.05	21.52	x 0.18 =	3.87		
Total area of elements, m ²			86.77				
Party wall			49.76	x 0 =	0		

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U)

(26)...(30) + (32) = 27.59 (33)

Heat capacity Cm = S(A x k)

((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K

Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K

6.41 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss

(33) + (36) = 34 (37)

Ventilation heat loss calculated monthly

(38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	29.26	29.09	28.93	28.17	28.02	27.36	27.36	27.23	27.61	28.02	28.31	28.62

(38)

Heat transfer coefficient, W/K

(39)m = (37) + (38)m

(39)m=	63.27	63.1	62.94	62.17	62.03	61.36	61.36	61.24	61.62	62.03	62.32	62.62
Average = Sum(39) _{1...12} /12=	62.17 (39)											

TER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	1.21	1.21	1.21	1.19	1.19	1.18	1.18	1.17	1.18	1.19	1.19	1.2	Average = Sum(40) _{1...12} /12=	1.19	(40)
--------	------	------	------	------	------	------	------	------	------	------	------	-----	--	------	------

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(41)m=	31	28	31	30	31	30	31	30	31	30	31	(41)
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	--------	----	----	----	----	----	----	----	----	----	----	----	------

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

1.75

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

75.88

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	83.47	80.43	77.4	74.36	71.33	68.29	68.29	71.33	74.36	77.4	80.43	83.47	Total = Sum(44) _{1...12} =	910.57	(44)
--------	-------	-------	------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------------------------------------	--------	------

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	123.78	108.26	111.71	97.4	93.45	80.64	74.73	85.75	86.78	101.13	110.39	119.88	Total = Sum(45) _{1...12} =	1193.9	(45)
--------	--------	--------	--------	------	-------	-------	-------	-------	-------	--------	--------	--------	-------------------------------------	--------	------

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	18.57	16.24	16.76	14.61	14.02	12.1	11.21	12.86	13.02	15.17	16.56	17.98	(46)
--------	-------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

150

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

1.39

(48)

Temperature factor from Table 2b

0.54

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

0.75

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0

(51)

If community heating see section 4.3

Volume factor from Table 2a

0

(52)

Temperature factor from Table 2b

0

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

0

(54)

Enter (50) or (54) in (55)

0.75

(55)

Water storage loss calculated for each month

((56)m = (55) x (41)m)

(56)m=

23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	(57)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26	(59)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

TER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	170.38	150.35	158.31	142.49	140.05	125.74	121.32	132.35	131.87	147.72	155.48	166.47	(62)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	170.38	150.35	158.31	142.49	140.05	125.74	121.32	132.35	131.87	147.72	155.48	166.47	
Output from water heater (annual) 1...12												1742.51	(64)

Heat gains from water heating, kWh/month 0.25 $[0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	78.43	69.67	74.42	68.46	68.35	62.89	62.12	65.79	64.93	70.9	72.78	77.13	(65)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m=	87.75	87.75	87.75	87.75	87.75	87.75	87.75	87.75	87.75	87.75	87.75	87.75	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	13.64	12.11	9.85	7.46	5.57	4.71	5.08	6.61	8.87	11.26	13.15	14.01	(67)
--------	-------	-------	------	------	------	------	------	------	------	-------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	152.94	154.53	150.53	142.02	131.27	121.17	114.42	112.83	116.83	125.35	136.09	146.2	(68)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	31.77	31.77	31.77	31.77	31.77	31.77	31.77	31.77	31.77	31.77	31.77	31.77	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	3	3	3	3	3	3	3	3	3	3	3	3	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-70.2	-70.2	-70.2	-70.2	-70.2	-70.2	-70.2	-70.2	-70.2	-70.2	-70.2	-70.2	(71)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Water heating gains (Table 5)

(72)m=	105.42	103.67	100.03	95.08	91.87	87.34	83.5	88.43	90.18	95.3	101.08	103.68	(72)
--------	--------	--------	--------	-------	-------	-------	------	-------	-------	------	--------	--------	------

Total internal gains =

$$(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$$

(73)m=	324.33	322.64	312.73	296.88	281.04	265.54	255.33	260.19	268.2	284.23	302.65	316.21	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)	
East	0.9x	0.77	x 3.6	x 19.64	x 0.63	x 0.7	= 21.61
East	0.9x	0.77	x 3.6	x 38.42	x 0.63	x 0.7	= 42.27
East	0.9x	0.77	x 3.6	x 63.27	x 0.63	x 0.7	= 69.61
East	0.9x	0.77	x 3.6	x 92.28	x 0.63	x 0.7	= 101.53
East	0.9x	0.77	x 3.6	x 113.09	x 0.63	x 0.7	= 124.43

TER WorkSheet: New dwelling design stage

East	0.9x	0.77	x	3.6	x	115.77	x	0.63	x	0.7	=	127.37	(76)
East	0.9x	0.77	x	3.6	x	110.22	x	0.63	x	0.7	=	121.26	(76)
East	0.9x	0.77	x	3.6	x	94.68	x	0.63	x	0.7	=	104.16	(76)
East	0.9x	0.77	x	3.6	x	73.59	x	0.63	x	0.7	=	80.96	(76)
East	0.9x	0.77	x	3.6	x	45.59	x	0.63	x	0.7	=	50.16	(76)
East	0.9x	0.77	x	3.6	x	24.49	x	0.63	x	0.7	=	26.94	(76)
East	0.9x	0.77	x	3.6	x	16.15	x	0.63	x	0.7	=	17.77	(76)
West	0.9x	0.77	x	5.18	x	19.64	x	0.63	x	0.7	=	31.09	(80)
West	0.9x	0.77	x	1.32	x	19.64	x	0.63	x	0.7	=	7.92	(80)
West	0.9x	0.77	x	5.18	x	38.42	x	0.63	x	0.7	=	60.82	(80)
West	0.9x	0.77	x	1.32	x	38.42	x	0.63	x	0.7	=	15.5	(80)
West	0.9x	0.77	x	5.18	x	63.27	x	0.63	x	0.7	=	100.17	(80)
West	0.9x	0.77	x	1.32	x	63.27	x	0.63	x	0.7	=	25.52	(80)
West	0.9x	0.77	x	5.18	x	92.28	x	0.63	x	0.7	=	146.09	(80)
West	0.9x	0.77	x	1.32	x	92.28	x	0.63	x	0.7	=	37.23	(80)
West	0.9x	0.77	x	5.18	x	113.09	x	0.63	x	0.7	=	179.03	(80)
West	0.9x	0.77	x	1.32	x	113.09	x	0.63	x	0.7	=	45.62	(80)
West	0.9x	0.77	x	5.18	x	115.77	x	0.63	x	0.7	=	183.27	(80)
West	0.9x	0.77	x	1.32	x	115.77	x	0.63	x	0.7	=	46.7	(80)
West	0.9x	0.77	x	5.18	x	110.22	x	0.63	x	0.7	=	174.48	(80)
West	0.9x	0.77	x	1.32	x	110.22	x	0.63	x	0.7	=	44.46	(80)
West	0.9x	0.77	x	5.18	x	94.68	x	0.63	x	0.7	=	149.88	(80)
West	0.9x	0.77	x	1.32	x	94.68	x	0.63	x	0.7	=	38.19	(80)
West	0.9x	0.77	x	5.18	x	73.59	x	0.63	x	0.7	=	116.5	(80)
West	0.9x	0.77	x	1.32	x	73.59	x	0.63	x	0.7	=	29.69	(80)
West	0.9x	0.77	x	5.18	x	45.59	x	0.63	x	0.7	=	72.17	(80)
West	0.9x	0.77	x	1.32	x	45.59	x	0.63	x	0.7	=	18.39	(80)
West	0.9x	0.77	x	5.18	x	24.49	x	0.63	x	0.7	=	38.77	(80)
West	0.9x	0.77	x	1.32	x	24.49	x	0.63	x	0.7	=	9.88	(80)
West	0.9x	0.77	x	5.18	x	16.15	x	0.63	x	0.7	=	25.57	(80)
West	0.9x	0.77	x	1.32	x	16.15	x	0.63	x	0.7	=	6.52	(80)

Solar gains in watts, calculated for each month

(83)m = Sum(74)m ... (82)m

(83)m=

60.62	118.59	195.3	284.84	349.08	357.35	340.21	292.24	227.15	140.72	75.59	49.85
-------	--------	-------	--------	--------	--------	--------	--------	--------	--------	-------	-------

 (83)

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=

384.95	441.23	508.04	581.72	630.12	622.89	595.54	552.43	495.35	424.95	378.24	366.06
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		(86)m=
1	0.99	0.97	0.92	0.79	0.6	0.45	0.5	0.76	0.95	0.99	1		

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=

19.8	19.97	20.26	20.61	20.86	20.97	20.99	20.99	20.91	20.57	20.12	19.77
------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (87)

TER WorkSheet: New dwelling design stage

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	19.91	19.91	19.92	19.93	19.93	19.94	19.94	19.94	19.94	19.93	19.92	19.92		(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.99	0.99	0.96	0.89	0.73	0.52	0.34	0.39	0.68	0.93	0.99	0.99		(89)
--------	------	------	------	------	------	------	------	------	------	------	------	------	--	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.33	18.58	18.99	19.49	19.8	19.92	19.94	19.94	19.87	19.45	18.81	18.3		(90)
--------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	------	--	------

$$fLA = \text{Living area} \div (4) = 0.47 \quad (91)$$

Mean internal temperature (for the whole dwelling) = $fLA \times T1 + (1 - fLA) \times T2$

(92)m=	19.02	19.23	19.58	20.01	20.3	20.41	20.43	20.43	20.36	19.98	19.43	18.99		(92)
--------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	--	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.02	19.23	19.58	20.01	20.3	20.41	20.43	20.43	20.36	19.98	19.43	18.99		(93)
--------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	--	------

8. Space heating requirement

Set T_i to the mean internal temperature obtained at step 11 of Table 9b, so that $T_{i,m} = (76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	0.99	0.98	0.96	0.89	0.75	0.56	0.39	0.44	0.71	0.93	0.98	0.99		(94)
--------	------	------	------	------	------	------	------	------	------	------	------	------	--	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	381.74	434.06	488.06	519.46	475.51	346.7	233.79	244.36	353.55	395.72	372.08	363.62		(95)
--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2		(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	--	------

Heat loss rate for mean internal temperature, Lm , W = [(39)m x [(93)m - (96)m]

(97)m=	931.44	904.27	823.46	691.02	533.37	356.79	235.25	246.92	385.84	581.53	768.14	926.29		(97)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m - (95)m] x (41)m

(98)m=	408.98	315.98	249.54	123.52	43.05	0	0	0	0	138.24	285.16	418.63		
--------	--------	--------	--------	--------	-------	---	---	---	---	--------	--------	--------	--	--

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1...5,9...12} = 1983.1 \quad (98)$$

Space heating requirement in kWh/m²/year

$$37.99 \quad (99)$$

9a. Energy requirements – Individual heating systems including micro-CHP)

Space heating:

Fraction of space heat from secondary/supplementary system

$$0 \quad (201)$$

Fraction of space heat from main system(s)

$$(202) = 1 - (201) = 1 \quad (202)$$

Fraction of total heating from main system 1

$$(204) = (202) \times [1 - (203)] = 1 \quad (204)$$

Efficiency of main space heating system 1

$$93.5 \quad (206)$$

Efficiency of secondary/supplementary heating system, %

$$0 \quad (208)$$

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

408.98	315.98	249.54	123.52	43.05	0	0	0	0	138.24	285.16	418.63	
--------	--------	--------	--------	-------	---	---	---	---	--------	--------	--------	--

$$(211)m = \{[(98)m \times (204)]\} \times 100 \div (206) \quad (211)$$

437.41	337.95	266.89	132.11	46.04	0	0	0	0	147.85	304.98	447.73	
--------	--------	--------	--------	-------	---	---	---	---	--------	--------	--------	--

$$\text{Total (kWh/year)} = \text{Sum}(211)_{1...5,10...12} = 2120.96 \quad (211)$$

Space heating fuel (secondary), kWh/month

$$= \{(98)m \times (201)\} \times 100 \div (208)$$

(215)m=	0	0	0	0	0	0	0	0	0	0	0	0	
---------	---	---	---	---	---	---	---	---	---	---	---	---	--

$$\text{Total (kWh/year)} = \text{Sum}(215)_{1...5,10...12} = 0 \quad (215)$$

TER WorkSheet: New dwelling design stage

Water heating

Output from water heater (calculated above)

170.38	150.35	158.31	142.49	140.05	125.74	121.32	132.35	131.87	147.72	155.48	166.47
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

Efficiency of water heater

79.8

(216)

(217)m=	87.07	86.75	86.02	84.44	82.08	79.8	79.8	79.8	84.64	86.41	87.17		(217)
---------	-------	-------	-------	-------	-------	------	------	------	-------	-------	-------	--	-------

Fuel for water heating, kWh/month

$$(219)m = (64)m \times 100 \div (217)m$$

(219)m=	195.68	173.31	184.03	168.75	170.62	157.56	152.03	165.85	165.25	174.54	179.93	190.96
---------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

$$\text{Total} = \text{Sum}(219a)_{1\dots 12} =$$

2078.52

(219)

Annual totals

Space heating fuel used, main system 1

kWh/year

2120.96

Water heating fuel used

kWh/year

2078.52

Electricity for pumps, fans and electric keep-hot

central heating pump:

30

(230c)

boiler with a fan-assisted flue

45

(230e)

Total electricity for the above, kWh/year

$$\text{sum of (230a)\dots(230g)} =$$

75

(231)

Electricity for lighting

240.8

(232)

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating (main system 1)	(211) x	0.216	= 458.13
Space heating (secondary)	(215) x	0.519	= 0
Water heating	(219) x	0.216	= 448.96
Space and water heating	(261) + (262) + (263) + (264) =		907.09
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	= 38.93
Electricity for lighting	(232) x	0.519	= 124.98
Total CO2, kg/year		sum of (265)\dots(271) =	1070.99

TER =

20.52

(273)

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 006 - Be Lean			
Address :	AC 006, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	54.8 (1a)	x (2a)	= 158.92 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	54.8 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	158.92 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					0 = 0 x 10 = 0 (7a)
Number of passive vents					0 = 0 x 10 = 0 (7b)
Number of flueless gas fires					0 = 0 x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 0 ÷ (5) = 0
(8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] =

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) =

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] =

Infiltration rate incorporating shelter factor (21) = (18) x (20) =

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

DER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.11	0.11	0.1	0.09	0.09	0.08	0.08	0.08	0.08	0.09	0.1	0.1
------	------	-----	------	------	------	------	------	------	------	-----	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.21	0.21	0.22
---------	------	------	------	------	------	-----	-----	-----	------	------	------

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.2	0.21	0.21	0.22
--------	------	------	------	------	------	-----	-----	-----	-----	------	------	------

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Doors			2.77	x 1.4 =	3.878		(26)
Windows Type 1			4.91	x1/[1/(1.4)+ 0.04] =	6.51		(27)
Windows Type 2			7.06	x1/[1/(1.4)+ 0.04] =	9.36		(27)
Windows Type 3			1.8	x1/[1/(1.4)+ 0.04] =	2.39		(27)
Floor			54.8	x 0.12 =	6.576		(28)
Walls	36.37	16.54	19.83	x 0.12 =	2.38		(29)
Total area of elements, m ²			91.17				(31)
Party wall			49.76	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[1/(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U)

$$(26)\dots(30) + (32) =$$

31.09 (33)

Heat capacity Cm = S(A x k)

$$((28)\dots(30) + (32) + (32a)\dots(32e) =$$

0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K

Indicative Value: Medium

250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K

9.58 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss

$$(33) + (36) =$$

40.67 (37)

Ventilation heat loss calculated monthly

$$(38)m = 0.33 \times (25)m \times (5)$$

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	11.85	11.73	11.62	11.07	10.95	10.4	10.4	10.29	10.62	10.95	11.18	11.4

(38)

Heat transfer coefficient, W/K

$$(39)m = (37) + (38)m$$

(39)m=	52.52	52.4	52.29	51.74	51.62	51.07	51.07	50.96	51.29	51.62	51.85	52.07
Average = Sum(39) _{1...12} / 12 =												51.71 (39)

DER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	0.96	0.96	0.95	0.94	0.94	0.93	0.93	0.93	0.94	0.94	0.95	0.95	
													Average = Sum(40) _{1...12} /12=

$$(40)m = (39)m \div (4)$$

0.94 (40)

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(41)m=	31	28	31	30	31	30	31	31	30	31	30	31

(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

1.83

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

77.7

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$											

(44)m=	85.47	82.36	79.25	76.14	73.04	69.93	69.93	73.04	76.14	79.25	82.36	85.47

$$\text{Total} = \text{Sum}(44)_{1...12} =$$

932.38

(44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	126.75	110.85	114.39	99.73	95.69	82.57	76.52	87.81	88.85	103.55	113.03	122.75

$$\text{Total} = \text{Sum}(45)_{1...12} =$$

1222.49

(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	19.01	16.63	17.16	14.96	14.35	12.39	11.48	13.17	13.33	15.53	16.96	18.41

(46)

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0

(48)

Temperature factor from Table 2b

0

(49)

Energy lost from water storage, kWh/year

$$(48) \times (49) =$$

110

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0.02

(51)

If community heating see section 4.3

Volume factor from Table 2a

1.03

(52)

Temperature factor from Table 2b

0.6

(53)

Energy lost from water storage, kWh/year

$$(47) \times (51) \times (52) \times (53) =$$

1.03

(54)

Enter (50) or (54) in (55)

1.03

(55)

Water storage loss calculated for each month

$$((56)m = (55) \times (41)m)$$

(56)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01

(56)

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01

(57)

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26

(59)

DER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	182.02	160.78	169.67	153.22	150.97	136.07	131.79	143.08	142.35	158.83	166.53	178.02	(62)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	182.02	160.78	169.67	153.22	150.97	136.07	131.79	143.08	142.35	158.83	166.53	178.02	Output from water heater (annual) 1...12	1873.33	(64)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--	---------	------

Heat gains from water heating, kWh/month 0.25 $[0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	86.36	76.8	82.26	75.95	76.04	70.25	69.66	73.42	72.34	78.65	80.38	85.03	(65)
--------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(66)m=	91.57	91.57	91.57	91.57	91.57	91.57	91.57	91.57	91.57	91.57	91.57	91.57	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	14.23	12.64	10.28	7.78	5.82	4.91	5.31	6.9	9.26	11.76	13.72	14.63	(67)
--------	-------	-------	-------	------	------	------	------	-----	------	-------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	159.67	161.33	157.15	148.26	137.04	126.5	119.45	117.8	121.97	130.86	142.08	152.62	(68)
--------	--------	--------	--------	--------	--------	-------	--------	-------	--------	--------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	32.16	32.16	32.16	32.16	32.16	32.16	32.16	32.16	32.16	32.16	32.16	32.16	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	0	0	0	0	0	0	0	0	0	0	0	0	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-73.26	-73.26	-73.26	-73.26	-73.26	-73.26	-73.26	-73.26	-73.26	-73.26	-73.26	-73.26	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	116.08	114.29	110.56	105.49	102.2	97.57	93.63	98.68	100.47	105.72	111.64	114.29	(72)
--------	--------	--------	--------	--------	-------	-------	-------	-------	--------	--------	--------	--------	------

Total internal gains =

$$(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$$

(73)m=	340.46	338.73	328.47	312.01	295.54	279.45	268.87	273.85	282.17	298.81	317.91	332.02	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)
East	0.9x	0.77	x 4.91	x 19.64	x 0.4	x 0.8 = 21.39
East	0.9x	0.77	x 4.91	x 38.42	x 0.4	x 0.8 = 41.83
East	0.9x	0.77	x 4.91	x 63.27	x 0.4	x 0.8 = 68.89
East	0.9x	0.77	x 4.91	x 92.28	x 0.4	x 0.8 = 100.48
East	0.9x	0.77	x 4.91	x 113.09	x 0.4	x 0.8 = 123.14

DER WorkSheet: New dwelling design stage

East	0.9x	0.77	x	4.91	x	115.77	x	0.4	x	0.8	=	126.06	(76)
East	0.9x	0.77	x	4.91	x	110.22	x	0.4	x	0.8	=	120.01	(76)
East	0.9x	0.77	x	4.91	x	94.68	x	0.4	x	0.8	=	103.09	(76)
East	0.9x	0.77	x	4.91	x	73.59	x	0.4	x	0.8	=	80.13	(76)
East	0.9x	0.77	x	4.91	x	45.59	x	0.4	x	0.8	=	49.64	(76)
East	0.9x	0.77	x	4.91	x	24.49	x	0.4	x	0.8	=	26.66	(76)
East	0.9x	0.77	x	4.91	x	16.15	x	0.4	x	0.8	=	17.59	(76)
West	0.9x	0.77	x	7.06	x	19.64	x	0.4	x	0.8	=	30.75	(80)
West	0.9x	0.77	x	1.8	x	19.64	x	0.4	x	0.8	=	7.84	(80)
West	0.9x	0.77	x	7.06	x	38.42	x	0.4	x	0.8	=	60.15	(80)
West	0.9x	0.77	x	1.8	x	38.42	x	0.4	x	0.8	=	15.34	(80)
West	0.9x	0.77	x	7.06	x	63.27	x	0.4	x	0.8	=	99.06	(80)
West	0.9x	0.77	x	1.8	x	63.27	x	0.4	x	0.8	=	25.26	(80)
West	0.9x	0.77	x	7.06	x	92.28	x	0.4	x	0.8	=	144.48	(80)
West	0.9x	0.77	x	1.8	x	92.28	x	0.4	x	0.8	=	36.84	(80)
West	0.9x	0.77	x	7.06	x	113.09	x	0.4	x	0.8	=	177.06	(80)
West	0.9x	0.77	x	1.8	x	113.09	x	0.4	x	0.8	=	45.14	(80)
West	0.9x	0.77	x	7.06	x	115.77	x	0.4	x	0.8	=	181.25	(80)
West	0.9x	0.77	x	1.8	x	115.77	x	0.4	x	0.8	=	46.21	(80)
West	0.9x	0.77	x	7.06	x	110.22	x	0.4	x	0.8	=	172.56	(80)
West	0.9x	0.77	x	1.8	x	110.22	x	0.4	x	0.8	=	44	(80)
West	0.9x	0.77	x	7.06	x	94.68	x	0.4	x	0.8	=	148.23	(80)
West	0.9x	0.77	x	1.8	x	94.68	x	0.4	x	0.8	=	37.79	(80)
West	0.9x	0.77	x	7.06	x	73.59	x	0.4	x	0.8	=	115.21	(80)
West	0.9x	0.77	x	1.8	x	73.59	x	0.4	x	0.8	=	29.37	(80)
West	0.9x	0.77	x	7.06	x	45.59	x	0.4	x	0.8	=	71.38	(80)
West	0.9x	0.77	x	1.8	x	45.59	x	0.4	x	0.8	=	18.2	(80)
West	0.9x	0.77	x	7.06	x	24.49	x	0.4	x	0.8	=	38.34	(80)
West	0.9x	0.77	x	1.8	x	24.49	x	0.4	x	0.8	=	9.78	(80)
West	0.9x	0.77	x	7.06	x	16.15	x	0.4	x	0.8	=	25.29	(80)
West	0.9x	0.77	x	1.8	x	16.15	x	0.4	x	0.8	=	6.45	(80)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m= 59.97 117.32 193.21 281.79 345.34 353.52 336.57 289.11 224.71 139.21 74.78 49.32 (83)

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m= 400.43 456.05 521.68 593.8 640.88 632.97 605.43 562.95 506.89 438.02 392.69 381.34 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m= 0.99	0.99	0.96	0.88	0.71	0.51	0.37	0.42	0.67	0.93	0.99	1		(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m= 20.15 20.3 20.54 20.81 20.96 20.99 21 21 20.98 20.77 20.41 20.12 (87)

DER WorkSheet: New dwelling design stage

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	20.12	20.12	20.12	20.13	20.13	20.14	20.14	20.14	20.14	20.13	20.13		(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.99	0.98	0.95	0.85	0.66	0.44	0.3	0.34	0.6	0.9	0.98	0.99	(89)
--------	------	------	------	------	------	------	-----	------	-----	-----	------	------	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.99	19.21	19.56	19.92	20.09	20.14	20.14	20.14	20.12	19.88	19.37	18.95	(90)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

$$fLA = \text{Living area} \div (4) = 0.48 \quad (91)$$

Mean internal temperature (for the whole dwelling) = $fLA \times T1 + (1 - fLA) \times T2$

(92)m=	19.55	19.73	20.03	20.35	20.51	20.55	20.55	20.55	20.53	20.3	19.87	19.51	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.55	19.73	20.03	20.35	20.51	20.55	20.55	20.55	20.53	20.3	19.87	19.51	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that $Ti,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	0.99	0.98	0.95	0.85	0.68	0.48	0.33	0.38	0.63	0.91	0.98	0.99	(94)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	396.88	447.46	495.4	507.19	435.5	301.79	201.65	211.24	320.39	396.89	385.13	378.71	(95)
--------	--------	--------	-------	--------	-------	--------	--------	--------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W = [(39)m x [(93)m– (96)m]

(97)m=	800.72	777.38	707.62	592.4	454.62	303.78	201.84	211.62	329.81	500.95	662.06	797.33	(97)
--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m – (95)m] x (41)m

(98)m=	300.46	221.7	157.89	61.35	14.22	0	0	0	77.43	199.39	311.45	
--------	--------	-------	--------	-------	-------	---	---	---	-------	--------	--------	--

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1...5,9...12} = 1343.89 \quad (98)$$

Space heating requirement in kWh/m²/year

$$24.52 \quad (99)$$

9b. Energy requirements – Community heating scheme

This part is used for space heating, space cooling or water heating provided by a community scheme.

Fraction of space heat from secondary/supplementary heating (Table 11) '0' if none

$$0 \quad (301)$$

Fraction of space heat from community system 1 – (301) =

$$1 \quad (302)$$

The community scheme may obtain heat from several sources. The procedure allows for CHP and up to four other heat sources; the latter includes boilers, heat pumps, geothermal and waste heat from power stations. See Appendix C.

Fraction of heat from Community boilers

$$1 \quad (303a)$$

Fraction of total space heat from Community boilers

$$(302) \times (303a) = 1 \quad (304a)$$

Factor for control and charging method (Table 4c(3)) for community heating system

$$1 \quad (305)$$

Distribution loss factor (Table 12c) for community heating system

$$1.1 \quad (306)$$

Space heating

Annual space heating requirement

$$1343.89$$

Space heat from Community boilers

$$(98) \times (304a) \times (305) \times (306) = 1478.28 \quad (307a)$$

Efficiency of secondary/supplementary heating system in % (from Table 4a or Appendix E)

$$0 \quad (308)$$

DER WorkSheet: New dwelling design stage

Space heating requirement from secondary/supplementary system	$(98) \times (301) \times 100 \div (308) =$	0	(309)
Water heating			
Annual water heating requirement		1873.33	
If DHW from community scheme:			
Water heat from Community boilers	$(64) \times (303a) \times (305) \times (306) =$	2060.67	(310a)
Electricity used for heat distribution	$0.01 \times [(307a) \dots (307e) + (310a) \dots (310e)] =$	35.39	(313)
Cooling System Energy Efficiency Ratio		0	(314)
Space cooling (if there is a fixed cooling system, if not enter 0)	$= (107) \div (314) =$	0	(315)
Electricity for pumps and fans within dwelling (Table 4f):			
mechanical ventilation - balanced, extract or positive input from outside		121.18	(330a)
warm air heating system fans		0	(330b)
pump for solar water heating		0	(330g)
Total electricity for the above, kWh/year	$= (330a) + (330b) + (330g) =$	121.18	(331)
Energy for lighting (calculated in Appendix L)		251.39	(332)

12b. CO2 Emissions – Community heating scheme

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
CO2 from other sources of space and water heating (not CHP)			
Efficiency of heat source 1 (%)	If there is CHP using two fuels repeat (363) to (366) for the second fuel		
CO2 associated with heat source 1	$[(307b)+(310b)] \times 100 \div (367b) \times$	0.22	= 804.64 (367)
Electrical energy for heat distribution	$[(313) \times$	0.52	= 18.37 (372)
Total CO2 associated with community systems	$(363) \dots (366) + (368) \dots (372)$		= 823.01 (373)
CO2 associated with space heating (secondary)	$(309) \times$	0	= 0 (374)
CO2 associated with water from immersion heater or instantaneous heater	$(312) \times$	0.22	= 0 (375)
Total CO2 associated with space and water heating	$(373) + (374) + (375) =$		823.01 (376)
CO2 associated with electricity for pumps and fans within dwelling	$(331)) \times$	0.52	= 62.89 (378)
CO2 associated with electricity for lighting	$(332)) \times$	0.52	= 130.47 (379)
Total CO2, kg/year	sum of (376)...(382) =		1016.37 (383)
Dwelling CO2 Emission Rate	$(383) \div (4) =$		18.55 (384)
EI rating (section 14)			86.35 (385)

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 006 - Be Lean			
Address :	AC 006, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	54.8 (1a)	x (2a)	= 158.92 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	54.8 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	158.92 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					2 x 10 = 20 (7a)
Number of passive vents					0 x 10 = 0 (7b)
Number of flueless gas fires					0 x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =	20	÷ (5) = 0.13 (8)
If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)		
Number of storeys in the dwelling (ns)	0	(9)
Additional infiltration	[(9)-1]x0.1 = 0	(10)
Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction	0	(11)

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0	0 (12)
If no draught lobby, enter 0.05, else enter 0	0 (13)
Percentage of windows and doors draught stripped	0 (14)
Window infiltration	0.25 - [0.2 x (14) ÷ 100] = 0 (15)
Infiltration rate	(8) + (10) + (11) + (12) + (13) + (15) = 0 (16)
Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area	5 (17)
If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)	0.38 (18)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered	2 (19)
Shelter factor	(20) = 1 - [0.075 x (19)] = 0.85 (20)
Infiltration rate incorporating shelter factor	(21) = (18) x (20) = 0.32 (21)

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

TER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.41	0.4	0.39	0.35	0.34	0.3	0.3	0.3	0.32	0.34	0.36	0.38
------	-----	------	------	------	-----	-----	-----	------	------	------	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0.58	0.58	0.58	0.56	0.56	0.55	0.55	0.54	0.55	0.56	0.56	0.57
---------	------	------	------	------	------	------	------	------	------	------	------	------

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.58	0.58	0.58	0.56	0.56	0.55	0.55	0.54	0.55	0.56	0.56	0.57
--------	------	------	------	------	------	------	------	------	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Doors			2.77	x 1.2 =	3.324		
Windows Type 1			3.9	x1/[1/(1.4)+ 0.04] =	5.17		
Windows Type 2			5.6	x1/[1/(1.4)+ 0.04] =	7.42		
Windows Type 3			1.43	x1/[1/(1.4)+ 0.04] =	1.9		
Floor			54.8	x 0.13 =	7.124		
Walls	36.37	13.7	22.67	x 0.18 =	4.08		
Total area of elements, m ²			91.17				
Party wall			49.76	x 0 =	0		

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U)

(26)...(30) + (32) = 29.02 (33)

Heat capacity Cm = S(A x k)

((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K

Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K

6.55 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss

(33) + (36) = 35.57 (37)

Ventilation heat loss calculated monthly

(38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	30.57	30.4	30.24	29.46	29.31	28.64	28.64	28.51	28.9	29.31	29.61	29.92

(38)

Heat transfer coefficient, W/K

(39)m = (37) + (38)m

(39)m=	66.15	65.98	65.81	65.03	64.89	64.21	64.21	64.08	64.47	64.89	65.18	65.49
Average = Sum(39) _{1...12} /12=	65.03 (39)											

TER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	1.21	1.2	1.2	1.19	1.18	1.17	1.17	1.17	1.18	1.18	1.19	1.2	Average = Sum(40) _{1...12} /12=	1.19	(40)
--------	------	-----	-----	------	------	------	------	------	------	------	------	-----	--	------	------

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(41)m=	31	28	31	30	31	30	31	30	31	30	31	(41)
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	--------	----	----	----	----	----	----	----	----	----	----	----	------

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

1.83

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)^2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

77.7

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	85.47	82.36	79.25	76.14	73.04	69.93	69.93	73.04	76.14	79.25	82.36	85.47	Total = Sum(44) _{1...12} =	932.38	(44)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------------------------------------	--------	------

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	126.75	110.85	114.39	99.73	95.69	82.57	76.52	87.81	88.85	103.55	113.03	122.75	Total = Sum(45) _{1...12} =	1222.49	(45)
--------	--------	--------	--------	-------	-------	-------	-------	-------	-------	--------	--------	--------	-------------------------------------	---------	------

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	19.01	16.63	17.16	14.96	14.35	12.39	11.48	13.17	13.33	15.53	16.96	18.41	(46)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

150

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

1.39

(48)

Temperature factor from Table 2b

0.54

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

0.75

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0

(51)

If community heating see section 4.3

Volume factor from Table 2a

0

(52)

Temperature factor from Table 2b

0

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

0

(54)

Enter (50) or (54) in (55)

0.75

(55)

Water storage loss calculated for each month

((56)m = (55) x (41)m)

(56)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	(56)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	(57)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26	(59)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

TER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	173.34	152.94	160.99	144.82	142.29	127.67	123.11	134.4	133.95	150.15	158.13	169.34	(62)
--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRS applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	173.34	152.94	160.99	144.82	142.29	127.67	123.11	134.4	133.95	150.15	158.13	169.34	Output from water heater (annual) 1...12	1771.11	(64)
--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--	---------	------

Heat gains from water heating, kWh/month 0.25 $[0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	79.42	70.53	75.31	69.23	69.09	63.53	62.72	66.47	65.62	71.71	73.66	78.09	(65)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

(66)m=	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(66)
	91.57	91.57	91.57	91.57	91.57	91.57	91.57	91.57	91.57	91.57	91.57	91.57	

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	14.23	12.64	10.28	7.78	5.82	4.91	5.31	6.9	9.26	11.76	13.72	14.63	(67)
--------	-------	-------	-------	------	------	------	------	-----	------	-------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	159.67	161.33	157.15	148.26	137.04	126.5	119.45	117.8	121.97	130.86	142.08	152.62	(68)
--------	--------	--------	--------	--------	--------	-------	--------	-------	--------	--------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	32.16	32.16	32.16	32.16	32.16	32.16	32.16	32.16	32.16	32.16	32.16	32.16	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	3	3	3	3	3	3	3	3	3	3	3	3	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-73.26	-73.26	-73.26	-73.26	-73.26	-73.26	-73.26	-73.26	-73.26	-73.26	-73.26	-73.26	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	106.75	104.95	101.22	96.16	92.87	88.24	84.3	89.34	91.14	96.38	102.3	104.96	(72)
--------	--------	--------	--------	-------	-------	-------	------	-------	-------	-------	-------	--------	------

Total internal gains = $(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$

(73)m=	334.12	332.39	322.13	305.68	289.2	273.12	262.53	267.51	275.84	292.47	311.58	325.69	(73)
--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)	
East	0.9x	0.77	x 3.9	x 19.64	x 0.63	= 0.7	(76)
East	0.9x	0.77	x 3.9	x 38.42	x 0.63	= 0.7	(76)
East	0.9x	0.77	x 3.9	x 63.27	x 0.63	= 0.7	(76)
East	0.9x	0.77	x 3.9	x 92.28	x 0.63	= 0.7	(76)
East	0.9x	0.77	x 3.9	x 113.09	x 0.63	= 0.7	(76)

TER WorkSheet: New dwelling design stage

East	0.9x	0.77	x	3.9	x	115.77	x	0.63	x	0.7	=	137.99	(76)
East	0.9x	0.77	x	3.9	x	110.22	x	0.63	x	0.7	=	131.37	(76)
East	0.9x	0.77	x	3.9	x	94.68	x	0.63	x	0.7	=	112.84	(76)
East	0.9x	0.77	x	3.9	x	73.59	x	0.63	x	0.7	=	87.71	(76)
East	0.9x	0.77	x	3.9	x	45.59	x	0.63	x	0.7	=	54.34	(76)
East	0.9x	0.77	x	3.9	x	24.49	x	0.63	x	0.7	=	29.19	(76)
East	0.9x	0.77	x	3.9	x	16.15	x	0.63	x	0.7	=	19.25	(76)
West	0.9x	0.77	x	5.6	x	19.64	x	0.63	x	0.7	=	33.61	(80)
West	0.9x	0.77	x	1.43	x	19.64	x	0.63	x	0.7	=	8.58	(80)
West	0.9x	0.77	x	5.6	x	38.42	x	0.63	x	0.7	=	65.75	(80)
West	0.9x	0.77	x	1.43	x	38.42	x	0.63	x	0.7	=	16.79	(80)
West	0.9x	0.77	x	5.6	x	63.27	x	0.63	x	0.7	=	108.29	(80)
West	0.9x	0.77	x	1.43	x	63.27	x	0.63	x	0.7	=	27.65	(80)
West	0.9x	0.77	x	5.6	x	92.28	x	0.63	x	0.7	=	157.93	(80)
West	0.9x	0.77	x	1.43	x	92.28	x	0.63	x	0.7	=	40.33	(80)
West	0.9x	0.77	x	5.6	x	113.09	x	0.63	x	0.7	=	193.55	(80)
West	0.9x	0.77	x	1.43	x	113.09	x	0.63	x	0.7	=	49.42	(80)
West	0.9x	0.77	x	5.6	x	115.77	x	0.63	x	0.7	=	198.13	(80)
West	0.9x	0.77	x	1.43	x	115.77	x	0.63	x	0.7	=	50.59	(80)
West	0.9x	0.77	x	5.6	x	110.22	x	0.63	x	0.7	=	188.63	(80)
West	0.9x	0.77	x	1.43	x	110.22	x	0.63	x	0.7	=	48.17	(80)
West	0.9x	0.77	x	5.6	x	94.68	x	0.63	x	0.7	=	162.03	(80)
West	0.9x	0.77	x	1.43	x	94.68	x	0.63	x	0.7	=	41.38	(80)
West	0.9x	0.77	x	5.6	x	73.59	x	0.63	x	0.7	=	125.94	(80)
West	0.9x	0.77	x	1.43	x	73.59	x	0.63	x	0.7	=	32.16	(80)
West	0.9x	0.77	x	5.6	x	45.59	x	0.63	x	0.7	=	78.02	(80)
West	0.9x	0.77	x	1.43	x	45.59	x	0.63	x	0.7	=	19.92	(80)
West	0.9x	0.77	x	5.6	x	24.49	x	0.63	x	0.7	=	41.91	(80)
West	0.9x	0.77	x	1.43	x	24.49	x	0.63	x	0.7	=	10.7	(80)
West	0.9x	0.77	x	5.6	x	16.15	x	0.63	x	0.7	=	27.64	(80)
West	0.9x	0.77	x	1.43	x	16.15	x	0.63	x	0.7	=	7.06	(80)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m=

65.61	128.34	211.35	308.25	377.77	386.71	368.17	316.25	245.81	152.28	81.8	53.95
-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------	-------

 (83)

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=

399.73	460.73	533.48	613.92	666.97	659.83	630.7	583.76	521.65	444.75	393.38	379.64
--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------

 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		(86)m=
1	0.99	0.97	0.92	0.79	0.6	0.44	0.5	0.76	0.95	0.99	1		

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=

19.8	19.97	20.26	20.62	20.87	20.97	20.99	20.99	20.92	20.57	20.12	19.77
------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (87)

TER WorkSheet: New dwelling design stage

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	19.91	19.92	19.92	19.93	19.93	19.94	19.94	19.94	19.94	19.93	19.93	19.92	(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.99	0.99	0.96	0.89	0.73	0.51	0.34	0.39	0.67	0.93	0.99	1	(89)
--------	------	------	------	------	------	------	------	------	------	------	------	---	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.34	18.58	19	19.5	19.81	19.93	19.94	19.94	19.88	19.45	18.81	18.3	(90)
--------	-------	-------	----	------	-------	-------	-------	-------	-------	-------	-------	------	------

$$fLA = \text{Living area} \div (4) = 0.48 \quad (91)$$

Mean internal temperature (for the whole dwelling) = $fLA \times T1 + (1 - fLA) \times T2$

(92)m=	19.04	19.25	19.61	20.04	20.32	20.43	20.45	20.45	20.38	19.99	19.44	19.01	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.04	19.25	19.61	20.04	20.32	20.43	20.45	20.45	20.38	19.99	19.44	19.01	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set T_i to the mean internal temperature obtained at step 11 of Table 9b, so that $T_{i,m} = (76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	0.99	0.98	0.96	0.89	0.75	0.55	0.39	0.44	0.71	0.93	0.98	0.99	(94)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	396.55	453.41	512.47	547.14	500.39	364.13	245.55	256.65	371.36	414.43	387.21	377.24	(95)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W = [(39)m x [(93)m - (96)m]

(97)m=	974.91	946.76	862.52	724.26	559.14	374.25	247	259.24	404.64	609.33	804.36	969.72	(97)
--------	--------	--------	--------	--------	--------	--------	-----	--------	--------	--------	--------	--------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m - (95)m] x (41)m

(98)m=	430.3	331.53	260.44	127.53	43.71	0	0	0	0	145	300.34	440.81
--------	-------	--------	--------	--------	-------	---	---	---	---	-----	--------	--------

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1...5,9...12} = 2079.66 \quad (98)$$

Space heating requirement in kWh/m²/year

$$37.95 \quad (99)$$

9a. Energy requirements – Individual heating systems including micro-CHP)

Space heating:

Fraction of space heat from secondary/supplementary system

$$0 \quad (201)$$

Fraction of space heat from main system(s)

$$(202) = 1 - (201) = 1 \quad (202)$$

Fraction of total heating from main system 1

$$(204) = (202) \times [1 - (203)] = 1 \quad (204)$$

Efficiency of main space heating system 1

$$93.5 \quad (206)$$

Efficiency of secondary/supplementary heating system, %

$$0 \quad (208)$$

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

	430.3	331.53	260.44	127.53	43.71	0	0	0	0	145	300.34	440.81
--	-------	--------	--------	--------	-------	---	---	---	---	-----	--------	--------

$$(211)m = \{((98)m \times (204)) \} \times 100 \div (206) \quad (211)$$

	460.21	354.58	278.54	136.4	46.75	0	0	0	0	155.08	321.22	471.45
--	--------	--------	--------	-------	-------	---	---	---	---	--------	--------	--------

$$\text{Total (kWh/year)} = \text{Sum}(211)_{1...5,10...12} = 2224.24 \quad (211)$$

Space heating fuel (secondary), kWh/month

$$= \{((98)m \times (201)) \} \times 100 \div (208)$$

(215)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

$$\text{Total (kWh/year)} = \text{Sum}(215)_{1...5,10...12} = 0 \quad (215)$$

TER WorkSheet: New dwelling design stage

Water heating

Output from water heater (calculated above)

173.34	152.94	160.99	144.82	142.29	127.67	123.11	134.4	133.95	150.15	158.13	169.34
--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------

Efficiency of water heater

79.8

(216)

(217)m=

87.14	86.82	86.09	84.48	82.08	79.8	79.8	79.8	84.72	86.5	87.25
-------	-------	-------	-------	-------	------	------	------	-------	------	-------

(217)

Fuel for water heating, kWh/month

(219)m = $(64)m \times 100 \div (217)m$

198.91	176.15	187	171.43	173.35	159.98	154.28	168.42	167.85	177.22	182.8	194.08
--------	--------	-----	--------	--------	--------	--------	--------	--------	--------	-------	--------

Total = Sum(219a)_{1...12} =

2111.48

(219)

Annual totals

Space heating fuel used, main system 1

kWh/year

kWh/year

2224.24

Water heating fuel used

2111.48

Electricity for pumps, fans and electric keep-hot

central heating pump:

30

(230c)

boiler with a fan-assisted flue

45

(230e)

Total electricity for the above, kWh/year

sum of (230a)...(230g) =

75

(231)

Electricity for lighting

251.39

(232)

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating (main system 1)	(211) x	0.216	= 480.44
Space heating (secondary)	(215) x	0.519	= 0
Water heating	(219) x	0.216	= 456.08
Space and water heating	(261) + (262) + (263) + (264) =		936.51
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	= 38.93
Electricity for lighting	(232) x	0.519	= 130.47
Total CO2, kg/year		sum of (265)...(271) =	1105.91
TER =			20.18

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 007 - Be Lean			
Address :	AC 007, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	52.3 (1a)	x (2a)	= 151.67 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	52.3 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	151.67 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					0 = 0 x 10 = 0 (7a)
Number of passive vents					0 = 0 x 10 = 0 (7b)
Number of flueless gas fires					0 = 0 x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 0 ÷ (5) = 0
(8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] =

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) =

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] =

Infiltration rate incorporating shelter factor (21) = (18) x (20) =

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

DER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.11	0.11	0.1	0.09	0.09	0.08	0.08	0.08	0.08	0.09	0.1	0.1
------	------	-----	------	------	------	------	------	------	------	-----	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5

(23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5

(23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5

(23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.21	0.21	0.22
---------	------	------	------	------	------	-----	-----	-----	------	------	------

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.21	0.21	0.22
--------	------	------	------	------	------	-----	-----	-----	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Doors			2.93	x 1.4 =	4.102		
Windows Type 1			4.91	x1/[1/(1.4)+ 0.04] =	6.51		
Windows Type 2			7.06	x1/[1/(1.4)+ 0.04] =	9.36		
Windows Type 3			2.69	x1/[1/(1.4)+ 0.04] =	3.57		
Floor			52.3	x 0.12 =	6.276		
Walls	34.63	17.59	17.04	x 0.12 =	2.04		
Total area of elements, m ²			86.93				
Party wall			49.76	x 0 =	0		

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U)

(26)...(30) + (32) =

31.86

(33)

Heat capacity Cm = S(A x k)

((28)...(30) + (32) + (32a)...(32e) =

0

(34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K

Indicative Value: Medium

250

(35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K

9.61

(36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss

(33) + (36) =

41.47

(37)

Ventilation heat loss calculated monthly

(38)m = 0.33 x (25)m x (5)

(38)m=	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
	11.31	11.2	11.09	10.56	10.45	9.92	9.92	9.82	10.14	10.45	10.67	10.88

(38)

Heat transfer coefficient, W/K

(39)m = (37) + (38)m

(39)m=	52.78	52.67	52.56	52.03	51.92	51.39	51.39	51.29	51.61	51.92	52.14	52.35
	Average = Sum(39) _{1...12} /12=											

52

(39)

DER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	1.01	1.01	1.01	0.99	0.99	0.98	0.98	0.98	0.99	0.99	1	1	(40)
											Average = Sum(40) _{1...12} /12=	0.99	

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(41)
31	28	31	30	31	30	31	31	30	31	30	31	

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

1.76

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

75.95

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	83.55	80.51	77.47	74.43	71.39	68.36	68.36	71.39	74.43	77.47	80.51	83.55	Total = Sum(44) _{1...12} =	911.41	(44)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------------------------------------	--------	------

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	123.9	108.36	111.82	97.49	93.54	80.72	74.8	85.83	86.86	101.22	110.49	119.99	Total = Sum(45) _{1...12} =	1195	(45)
--------	-------	--------	--------	-------	-------	-------	------	-------	-------	--------	--------	--------	-------------------------------------	------	------

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	18.58	16.25	16.77	14.62	14.03	12.11	11.22	12.87	13.03	15.18	16.57	18	(46)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	----	------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0

(48)

Temperature factor from Table 2b

0

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

110

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0.02

(51)

If community heating see section 4.3

Volume factor from Table 2a

1.03

(52)

Temperature factor from Table 2b

0.6

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

1.03

(54)

Enter (50) or (54) in (55)

1.03

(55)

Water storage loss calculated for each month

((56)m = (55) x (41)m)

(56)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01	(56)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01	(57)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26	(59)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

DER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	179.17	158.29	167.09	150.98	148.82	134.21	130.07	141.11	140.35	156.5	163.99	175.26	(62)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	179.17	158.29	167.09	150.98	148.82	134.21	130.07	141.11	140.35	156.5	163.99	175.26	Output from water heater (annual) 1...12	1845.84	(64)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--	---------	------

Heat gains from water heating, kWh/month 0.25 $[0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	85.42	75.97	81.4	75.21	75.32	69.63	69.09	72.76	71.67	77.88	79.53	84.12	(65)
--------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m=	87.9	87.9	87.9	87.9	87.9	87.9	87.9	87.9	87.9	87.9	87.9	87.9	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	13.66	12.13	9.87	7.47	5.58	4.71	5.09	6.62	8.89	11.28	13.17	14.04	(67)
--------	-------	-------	------	------	------	------	------	------	------	-------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	153.2	154.79	150.79	142.26	131.49	121.37	114.61	113.02	117.03	125.56	136.33	146.44	(68)
--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	31.79	31.79	31.79	31.79	31.79	31.79	31.79	31.79	31.79	31.79	31.79	31.79	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	0	0	0	0	0	0	0	0	0	0	0	0	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-70.32	-70.32	-70.32	-70.32	-70.32	-70.32	-70.32	-70.32	-70.32	-70.32	-70.32	-70.32	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	114.81	113.05	109.41	104.46	101.24	96.71	92.86	97.8	99.55	104.67	110.46	113.06	(72)
--------	--------	--------	--------	--------	--------	-------	-------	------	-------	--------	--------	--------	------

Total internal gains =

$$(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$$

(73)m=	331.04	329.35	319.43	303.55	287.69	272.17	261.94	266.81	274.83	290.89	309.33	322.91	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)	
East	0.9x	0.77	x 4.91	x 19.64	x 0.4	x 0.8 = 21.39	(76)
East	0.9x	0.77	x 4.91	x 38.42	x 0.4	x 0.8 = 41.83	(76)
East	0.9x	0.77	x 4.91	x 63.27	x 0.4	x 0.8 = 68.89	(76)
East	0.9x	0.77	x 4.91	x 92.28	x 0.4	x 0.8 = 100.48	(76)
East	0.9x	0.77	x 4.91	x 113.09	x 0.4	x 0.8 = 123.14	(76)

DER WorkSheet: New dwelling design stage

East	0.9x	0.77	x	4.91	x	115.77	x	0.4	x	0.8	=	126.06	(76)
East	0.9x	0.77	x	4.91	x	110.22	x	0.4	x	0.8	=	120.01	(76)
East	0.9x	0.77	x	4.91	x	94.68	x	0.4	x	0.8	=	103.09	(76)
East	0.9x	0.77	x	4.91	x	73.59	x	0.4	x	0.8	=	80.13	(76)
East	0.9x	0.77	x	4.91	x	45.59	x	0.4	x	0.8	=	49.64	(76)
East	0.9x	0.77	x	4.91	x	24.49	x	0.4	x	0.8	=	26.66	(76)
East	0.9x	0.77	x	4.91	x	16.15	x	0.4	x	0.8	=	17.59	(76)
West	0.9x	0.77	x	7.06	x	19.64	x	0.4	x	0.8	=	30.75	(80)
West	0.9x	0.77	x	2.69	x	19.64	x	0.4	x	0.8	=	11.72	(80)
West	0.9x	0.77	x	7.06	x	38.42	x	0.4	x	0.8	=	60.15	(80)
West	0.9x	0.77	x	2.69	x	38.42	x	0.4	x	0.8	=	22.92	(80)
West	0.9x	0.77	x	7.06	x	63.27	x	0.4	x	0.8	=	99.06	(80)
West	0.9x	0.77	x	2.69	x	63.27	x	0.4	x	0.8	=	37.74	(80)
West	0.9x	0.77	x	7.06	x	92.28	x	0.4	x	0.8	=	144.48	(80)
West	0.9x	0.77	x	2.69	x	92.28	x	0.4	x	0.8	=	55.05	(80)
West	0.9x	0.77	x	7.06	x	113.09	x	0.4	x	0.8	=	177.06	(80)
West	0.9x	0.77	x	2.69	x	113.09	x	0.4	x	0.8	=	67.46	(80)
West	0.9x	0.77	x	7.06	x	115.77	x	0.4	x	0.8	=	181.25	(80)
West	0.9x	0.77	x	2.69	x	115.77	x	0.4	x	0.8	=	69.06	(80)
West	0.9x	0.77	x	7.06	x	110.22	x	0.4	x	0.8	=	172.56	(80)
West	0.9x	0.77	x	2.69	x	110.22	x	0.4	x	0.8	=	65.75	(80)
West	0.9x	0.77	x	7.06	x	94.68	x	0.4	x	0.8	=	148.23	(80)
West	0.9x	0.77	x	2.69	x	94.68	x	0.4	x	0.8	=	56.48	(80)
West	0.9x	0.77	x	7.06	x	73.59	x	0.4	x	0.8	=	115.21	(80)
West	0.9x	0.77	x	2.69	x	73.59	x	0.4	x	0.8	=	43.9	(80)
West	0.9x	0.77	x	7.06	x	45.59	x	0.4	x	0.8	=	71.38	(80)
West	0.9x	0.77	x	2.69	x	45.59	x	0.4	x	0.8	=	27.2	(80)
West	0.9x	0.77	x	7.06	x	24.49	x	0.4	x	0.8	=	38.34	(80)
West	0.9x	0.77	x	2.69	x	24.49	x	0.4	x	0.8	=	14.61	(80)
West	0.9x	0.77	x	7.06	x	16.15	x	0.4	x	0.8	=	25.29	(80)
West	0.9x	0.77	x	2.69	x	16.15	x	0.4	x	0.8	=	9.63	(80)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m=

63.85	124.91	205.7	300	367.66	376.37	358.32	307.79	239.24	148.21	79.61	52.51
-------	--------	-------	-----	--------	--------	--------	--------	--------	--------	-------	-------

 (83)

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=

394.89	454.25	525.13	603.56	655.35	648.54	620.26	574.6	514.07	439.1	388.94	375.42
--------	--------	--------	--------	--------	--------	--------	-------	--------	-------	--------	--------

 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		(86)m=
0.99	0.99	0.96	0.87	0.7	0.5	0.36	0.41	0.66	0.92	0.99	1		

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=

20.1	20.26	20.52	20.8	20.95	20.99	21	21	20.97	20.75	20.37	20.07
------	-------	-------	------	-------	-------	----	----	-------	-------	-------	-------

 (87)

DER WorkSheet: New dwelling design stage

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	20.08	20.08	20.08	20.09	20.09	20.1	20.1	20.1	20.09	20.09	20.09	20.08	(88)
--------	-------	-------	-------	-------	-------	------	------	------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.99	0.98	0.95	0.83	0.64	0.43	0.29	0.33	0.59	0.89	0.98	0.99	(89)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.89	19.12	19.49	19.87	20.05	20.09	20.1	20.1	20.08	19.82	19.29	18.84	(90)
--------	-------	-------	-------	-------	-------	-------	------	------	-------	-------	-------	-------	------

$$fLA = \text{Living area} \div (4) = 0.47 \quad (91)$$

Mean internal temperature (for the whole dwelling) = $fLA \times T1 + (1 - fLA) \times T2$

(92)m=	19.45	19.66	19.97	20.31	20.47	20.52	20.52	20.52	20.5	20.26	19.79	19.42	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.45	19.66	19.97	20.31	20.47	20.52	20.52	20.52	20.5	20.26	19.79	19.42	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that $Ti,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	0.99	0.98	0.94	0.84	0.67	0.47	0.32	0.37	0.62	0.9	0.98	0.99	(94)
--------	------	------	------	------	------	------	------	------	------	-----	------	------	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	390.98	444.63	495.68	508.55	436.03	301.87	201.23	210.88	320.05	395.23	380.72	372.52	(95)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W = [(39)m x [(93)m – (96)m]

(97)m=	799.76	777.21	708.27	593.66	455.44	304.02	201.46	211.32	330.05	501.34	661.82	796.57	(97)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m – (95)m] x (41)m

(98)m=	304.13	223.49	158.17	61.28	14.44	0	0	0	0	78.95	202.4	315.5	
--------	--------	--------	--------	-------	-------	---	---	---	---	-------	-------	-------	--

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1...5,9...12} = 1358.36 \quad (98)$$

Space heating requirement in kWh/m²/year

$$25.97 \quad (99)$$

9b. Energy requirements – Community heating scheme

This part is used for space heating, space cooling or water heating provided by a community scheme.

Fraction of space heat from secondary/supplementary heating (Table 11) '0' if none

$$0 \quad (301)$$

Fraction of space heat from community system 1 – (301) =

$$1 \quad (302)$$

The community scheme may obtain heat from several sources. The procedure allows for CHP and up to four other heat sources; the latter includes boilers, heat pumps, geothermal and waste heat from power stations. See Appendix C.

Fraction of heat from Community boilers

$$1 \quad (303a)$$

Fraction of total space heat from Community boilers

$$(302) \times (303a) = 1 \quad (304a)$$

Factor for control and charging method (Table 4c(3)) for community heating system

$$1 \quad (305)$$

Distribution loss factor (Table 12c) for community heating system

$$1.1 \quad (306)$$

Space heating

Annual space heating requirement

$$1358.36$$

Space heat from Community boilers

$$(98) \times (304a) \times (305) \times (306) = 1494.19 \quad (307a)$$

Efficiency of secondary/supplementary heating system in % (from Table 4a or Appendix E)

$$0 \quad (308)$$

DER WorkSheet: New dwelling design stage

Space heating requirement from secondary/supplementary system	$(98) \times (301) \times 100 \div (308) =$	0	(309)
Water heating			
Annual water heating requirement		1845.84	
If DHW from community scheme:			
Water heat from Community boilers	$(64) \times (303a) \times (305) \times (306) =$	2030.42	(310a)
Electricity used for heat distribution	$0.01 \times [(307a) \dots (307e) + (310a) \dots (310e)] =$	35.25	(313)
Cooling System Energy Efficiency Ratio		0	(314)
Space cooling (if there is a fixed cooling system, if not enter 0)	$= (107) \div (314) =$	0	(315)
Electricity for pumps and fans within dwelling (Table 4f):			
mechanical ventilation - balanced, extract or positive input from outside		115.65	(330a)
warm air heating system fans		0	(330b)
pump for solar water heating		0	(330g)
Total electricity for the above, kWh/year	$= (330a) + (330b) + (330g) =$	115.65	(331)
Energy for lighting (calculated in Appendix L)		241.21	(332)

12b. CO2 Emissions – Community heating scheme

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
CO2 from other sources of space and water heating (not CHP)			
Efficiency of heat source 1 (%)	If there is CHP using two fuels repeat (363) to (366) for the second fuel	95	(367a)
CO2 associated with heat source 1	$[(307b)+(310b)] \times 100 \div (367b) \times$	0.22	= 801.39 (367)
Electrical energy for heat distribution	$[(313) \times$	0.52	= 18.29 (372)
Total CO2 associated with community systems	$(363) \dots (366) + (368) \dots (372)$		= 819.68 (373)
CO2 associated with space heating (secondary)	$(309) \times$	0	= 0 (374)
CO2 associated with water from immersion heater or instantaneous heater	$(312) \times$	0.22	= 0 (375)
Total CO2 associated with space and water heating	$(373) + (374) + (375) =$		819.68 (376)
CO2 associated with electricity for pumps and fans within dwelling	$(331)) \times$	0.52	= 60.02 (378)
CO2 associated with electricity for lighting	$(332)) \times$	0.52	= 125.19 (379)
Total CO2, kg/year	sum of (376)...(382) =		1004.89 (383)
Dwelling CO2 Emission Rate	$(383) \div (4) =$		19.21 (384)
EI rating (section 14)			86.16 (385)

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 007 - Be Lean			
Address :	AC 007, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	52.3 (1a)	x (2a)	= 151.67 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	52.3 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	151.67 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					2 x 10 = 20 (7a)
Number of passive vents					0 x 10 = 0 (7b)
Number of flueless gas fires					0 x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =	20	÷ (5) = 0.13 (8)
If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)		
Number of storeys in the dwelling (ns)	0	(9)
Additional infiltration	[(9)-1]x0.1 = 0	(10)
Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction	0	(11)

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0	0 (12)
If no draught lobby, enter 0.05, else enter 0	0 (13)
Percentage of windows and doors draught stripped	0 (14)
Window infiltration	0.25 - [0.2 x (14) ÷ 100] = 0 (15)
Infiltration rate	(8) + (10) + (11) + (12) + (13) + (15) = 0 (16)
Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area	5 (17)
If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)	0.38 (18)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered	2 (19)
Shelter factor	(20) = 1 - [0.075 x (19)] = 0.85 (20)
Infiltration rate incorporating shelter factor	(21) = (18) x (20) = 0.32 (21)

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

TER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.41	0.41	0.4	0.36	0.35	0.31	0.31	0.3	0.32	0.35	0.37	0.38
------	------	-----	------	------	------	------	-----	------	------	------	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0.59	0.58	0.58	0.56	0.56	0.55	0.55	0.55	0.56	0.57	0.57
---------	------	------	------	------	------	------	------	------	------	------	------

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.59	0.58	0.58	0.56	0.56	0.55	0.55	0.55	0.56	0.57	0.57
--------	------	------	------	------	------	------	------	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Doors			2.93	x 1.2 =	3.516		
Windows Type 1			3.4	x1/[1/(1.4)+ 0.04] =	4.51		
Windows Type 2			4.89	x1/[1/(1.4)+ 0.04] =	6.48		
Windows Type 3			1.86	x1/[1/(1.4)+ 0.04] =	2.47		
Floor			52.3	x 0.13 =	6.799		
Walls	34.63	13.08	21.55	x 0.18 =	3.88		
Total area of elements, m ²			86.93				
Party wall			49.76	x 0 =	0		

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U)

(26)...(30) + (32) = 27.65 (33)

Heat capacity Cm = S(A x k)

((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K

Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K

6.46 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss

(33) + (36) = 34.11 (37)

Ventilation heat loss calculated monthly

(38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	29.31	29.15	28.98	28.22	28.07	27.41	27.41	27.28	27.66	28.07	28.36	28.67

(38)

Heat transfer coefficient, W/K

(39)m = (37) + (38)m

(39)m=	63.43	63.26	63.1	62.33	62.19	61.52	61.52	61.4	61.78	62.19	62.48	62.78
Average = Sum(39) _{1...12} /12=												62.33 (39)

TER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	1.21	1.21	1.21	1.19	1.19	1.18	1.18	1.17	1.18	1.19	1.19	1.2	Average = Sum(40) _{1...12} /12=	1.19	(40)
--------	------	------	------	------	------	------	------	------	------	------	------	-----	--	------	------

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(41)m=	31	28	31	30	31	30	31	30	31	30	31	(41)
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	--------	----	----	----	----	----	----	----	----	----	----	----	------

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

1.76

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)^2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

75.95

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	83.55	80.51	77.47	74.43	71.39	68.36	68.36	71.39	74.43	77.47	80.51	83.55	Total = Sum(44) _{1...12} =	911.41	(44)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------------------------------------	--------	------

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	123.9	108.36	111.82	97.49	93.54	80.72	74.8	85.83	86.86	101.22	110.49	119.99	Total = Sum(45) _{1...12} =	1195	(45)
--------	-------	--------	--------	-------	-------	-------	------	-------	-------	--------	--------	--------	-------------------------------------	------	------

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	18.58	16.25	16.77	14.62	14.03	12.11	11.22	12.87	13.03	15.18	16.57	18	(46)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	----	------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

150

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

1.39

(48)

Temperature factor from Table 2b

0.54

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

0.75

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0

(51)

If community heating see section 4.3

Volume factor from Table 2a

0

(52)

Temperature factor from Table 2b

0

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

0

(54)

Enter (50) or (54) in (55)

0.75

(55)

Water storage loss calculated for each month

((56)m = (55) x (41)m)

(56)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	(56)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	(57)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26	(59)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

TER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	170.49	150.45	158.41	142.58	140.13	125.81	121.39	132.43	131.95	147.82	155.58	166.58	(62)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	170.49	150.45	158.41	142.58	140.13	125.81	121.39	132.43	131.95	147.82	155.58	166.58	Output from water heater (annual) 1...12	1743.62	(64)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--	---------	------

Heat gains from water heating, kWh/month 0.25 $[0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	78.47	69.7	74.46	68.49	68.38	62.91	62.15	65.81	64.95	70.93	72.81	77.17	(65)
--------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m=	87.9	87.9	87.9	87.9	87.9	87.9	87.9	87.9	87.9	87.9	87.9	87.9	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	13.66	12.13	9.87	7.47	5.58	4.71	5.09	6.62	8.89	11.28	13.17	14.04	(67)
--------	-------	-------	------	------	------	------	------	------	------	-------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	153.2	154.79	150.79	142.26	131.49	121.37	114.61	113.02	117.03	125.56	136.33	146.44	(68)
--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	31.79	31.79	31.79	31.79	31.79	31.79	31.79	31.79	31.79	31.79	31.79	31.79	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	3	3	3	3	3	3	3	3	3	3	3	3	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-70.32	-70.32	-70.32	-70.32	-70.32	-70.32	-70.32	-70.32	-70.32	-70.32	-70.32	-70.32	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	105.47	103.72	100.07	95.12	91.91	87.38	83.53	88.46	90.21	95.34	101.13	103.73	(72)
--------	--------	--------	--------	-------	-------	-------	-------	-------	-------	-------	--------	--------	------

Total internal gains =

$$(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$$

(73)m=	324.7	323.01	313.1	297.22	281.35	265.83	255.61	260.47	268.5	284.55	302.99	316.58	(73)
--------	-------	--------	-------	--------	--------	--------	--------	--------	-------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)
East	0.9x	0.77	x 3.4	x 19.64	x 0.63	x 0.7 = 20.41
East	0.9x	0.77	x 3.4	x 38.42	x 0.63	x 0.7 = 39.92
East	0.9x	0.77	x 3.4	x 63.27	x 0.63	x 0.7 = 65.75
East	0.9x	0.77	x 3.4	x 92.28	x 0.63	x 0.7 = 95.89
East	0.9x	0.77	x 3.4	x 113.09	x 0.63	x 0.7 = 117.51

TER WorkSheet: New dwelling design stage

East	0.9x	0.77	x	3.4	x	115.77	x	0.63	x	0.7	=	120.3	(76)
East	0.9x	0.77	x	3.4	x	110.22	x	0.63	x	0.7	=	114.53	(76)
East	0.9x	0.77	x	3.4	x	94.68	x	0.63	x	0.7	=	98.38	(76)
East	0.9x	0.77	x	3.4	x	73.59	x	0.63	x	0.7	=	76.47	(76)
East	0.9x	0.77	x	3.4	x	45.59	x	0.63	x	0.7	=	47.37	(76)
East	0.9x	0.77	x	3.4	x	24.49	x	0.63	x	0.7	=	25.45	(76)
East	0.9x	0.77	x	3.4	x	16.15	x	0.63	x	0.7	=	16.78	(76)
West	0.9x	0.77	x	4.89	x	19.64	x	0.63	x	0.7	=	29.35	(80)
West	0.9x	0.77	x	1.86	x	19.64	x	0.63	x	0.7	=	11.16	(80)
West	0.9x	0.77	x	4.89	x	38.42	x	0.63	x	0.7	=	57.42	(80)
West	0.9x	0.77	x	1.86	x	38.42	x	0.63	x	0.7	=	21.84	(80)
West	0.9x	0.77	x	4.89	x	63.27	x	0.63	x	0.7	=	94.56	(80)
West	0.9x	0.77	x	1.86	x	63.27	x	0.63	x	0.7	=	35.97	(80)
West	0.9x	0.77	x	4.89	x	92.28	x	0.63	x	0.7	=	137.91	(80)
West	0.9x	0.77	x	1.86	x	92.28	x	0.63	x	0.7	=	52.46	(80)
West	0.9x	0.77	x	4.89	x	113.09	x	0.63	x	0.7	=	169.01	(80)
West	0.9x	0.77	x	1.86	x	113.09	x	0.63	x	0.7	=	64.29	(80)
West	0.9x	0.77	x	4.89	x	115.77	x	0.63	x	0.7	=	173.01	(80)
West	0.9x	0.77	x	1.86	x	115.77	x	0.63	x	0.7	=	65.81	(80)
West	0.9x	0.77	x	4.89	x	110.22	x	0.63	x	0.7	=	164.72	(80)
West	0.9x	0.77	x	1.86	x	110.22	x	0.63	x	0.7	=	62.65	(80)
West	0.9x	0.77	x	4.89	x	94.68	x	0.63	x	0.7	=	141.49	(80)
West	0.9x	0.77	x	1.86	x	94.68	x	0.63	x	0.7	=	53.82	(80)
West	0.9x	0.77	x	4.89	x	73.59	x	0.63	x	0.7	=	109.98	(80)
West	0.9x	0.77	x	1.86	x	73.59	x	0.63	x	0.7	=	41.83	(80)
West	0.9x	0.77	x	4.89	x	45.59	x	0.63	x	0.7	=	68.13	(80)
West	0.9x	0.77	x	1.86	x	45.59	x	0.63	x	0.7	=	25.91	(80)
West	0.9x	0.77	x	4.89	x	24.49	x	0.63	x	0.7	=	36.6	(80)
West	0.9x	0.77	x	1.86	x	24.49	x	0.63	x	0.7	=	13.92	(80)
West	0.9x	0.77	x	4.89	x	16.15	x	0.63	x	0.7	=	24.14	(80)
West	0.9x	0.77	x	1.86	x	16.15	x	0.63	x	0.7	=	9.18	(80)

Solar gains in watts, calculated for each month

(83)m = Sum(74)m ... (82)m

(83)m=

60.92	119.18	196.27	286.25	350.81	359.12	341.89	293.68	228.27	141.42	75.96	50.1
-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	------

 (83)

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=

385.63	442.19	509.37	583.47	632.16	624.95	597.5	554.16	496.77	425.97	378.95	366.68
--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------

 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		(86)m
1	0.99	0.97	0.92	0.79	0.6	0.45	0.5	0.76	0.95	0.99	1		(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=

19.8	19.97	20.25	20.61	20.86	20.97	20.99	20.99	20.91	20.57	20.12	19.77
------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (87)

TER WorkSheet: New dwelling design stage

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	19.91	19.91	19.91	19.93	19.93	19.94	19.94	19.94	19.94	19.93	19.92	19.92	(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.99	0.99	0.96	0.89	0.73	0.51	0.34	0.39	0.68	0.93	0.99	0.99	(89)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.33	18.58	18.99	19.49	19.8	19.92	19.94	19.94	19.87	19.45	18.81	18.3	(90)
--------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	------	------

$$fLA = \text{Living area} \div (4) = 0.47 \quad (91)$$

Mean internal temperature (for the whole dwelling) = $fLA \times T1 + (1 - fLA) \times T2$

(92)m=	19.02	19.23	19.58	20.01	20.3	20.41	20.43	20.43	20.36	19.97	19.42	18.99	(92)
--------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.02	19.23	19.58	20.01	20.3	20.41	20.43	20.43	20.36	19.97	19.42	18.99	(93)
--------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set T_i to the mean internal temperature obtained at step 11 of Table 9b, so that $T_{i,m} = (76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	0.99	0.98	0.96	0.89	0.75	0.56	0.39	0.44	0.71	0.93	0.98	0.99	(94)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	382.41	435	489.29	520.88	476.76	347.54	234.32	244.92	354.41	396.64	372.79	364.23	(95)
--------	--------	-----	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W = [(39)m x [(93)m - (96)m]

(97)m=	933.61	906.41	825.44	692.71	534.67	357.64	235.78	247.49	386.75	582.91	769.95	928.47	(97)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m - (95)m] x (41)m

(98)m=	410.09	316.79	250.1	123.72	43.08	0	0	0	0	138.59	285.95	419.79	
--------	--------	--------	-------	--------	-------	---	---	---	---	--------	--------	--------	--

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1...5,9...12} = 1988.11 \quad (98)$$

Space heating requirement in kWh/m²/year

$$38.01 \quad (99)$$

9a. Energy requirements – Individual heating systems including micro-CHP)

Space heating:

Fraction of space heat from secondary/supplementary system

$$0 \quad (201)$$

Fraction of space heat from main system(s)

$$(202) = 1 - (201) = 1 \quad (202)$$

Fraction of total heating from main system 1

$$(204) = (202) \times [1 - (203)] = 1 \quad (204)$$

Efficiency of main space heating system 1

$$93.5 \quad (206)$$

Efficiency of secondary/supplementary heating system, %

$$0 \quad (208)$$

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

410.09	316.79	250.1	123.72	43.08	0	0	0	0	138.59	285.95	419.79
--------	--------	-------	--------	-------	---	---	---	---	--------	--------	--------

$$(211)m = \{(98)m \times (204)\} \times 100 \div (206) \quad (211)$$

438.6	338.81	267.48	132.32	46.08	0	0	0	0	148.22	305.83	448.97
-------	--------	--------	--------	-------	---	---	---	---	--------	--------	--------

$$\text{Total (kWh/year)} = \text{Sum}(211)_{1...5,10...12} = 2126.32 \quad (211)$$

Space heating fuel (secondary), kWh/month

$$= \{(98)m \times (201)\} \times 100 \div (208)$$

(215)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

$$\text{Total (kWh/year)} = \text{Sum}(215)_{1...5,10...12} = 0 \quad (215)$$

TER WorkSheet: New dwelling design stage

Water heating

Output from water heater (calculated above)

170.49	150.45	158.41	142.58	140.13	125.81	121.39	132.43	131.95	147.82	155.58	166.58
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

Efficiency of water heater

79.8

(216)

(217)m=	87.07	86.75	86.03	84.44	82.08	79.8	79.8	79.8	84.64	86.42	87.18		(217)
---------	-------	-------	-------	-------	-------	------	------	------	-------	-------	-------	--	-------

Fuel for water heating, kWh/month

$$(219)m = (64)m \times 100 \div (217)m$$

(219)m=	195.81	173.42	184.14	168.85	170.73	157.66	152.12	165.95	165.35	174.64	180.04	191.08
---------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

$$\text{Total} = \text{Sum}(219a)_{1\dots 12} =$$

2079.77

(219)

Annual totals

Space heating fuel used, main system 1

kWh/year

kWh/year

2126.32

Water heating fuel used

2079.77

Electricity for pumps, fans and electric keep-hot

central heating pump:

30

(230c)

boiler with a fan-assisted flue

45

(230e)

Total electricity for the above, kWh/year

$$\text{sum of (230a)\dots(230g)} =$$

75

(231)

Electricity for lighting

241.21

(232)

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating (main system 1)	(211) x	0.216	= 459.29
Space heating (secondary)	(215) x	0.519	= 0
Water heating	(219) x	0.216	= 449.23
Space and water heating	(261) + (262) + (263) + (264) =		908.51
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	= 38.93
Electricity for lighting	(232) x	0.519	= 125.19
Total CO2, kg/year		sum of (265)\dots(271) =	1072.63

TER =

20.51

(273)

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 008 - Be Lean			
Address :	AC 008, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	89.3 (1a)	x (2a)	= 258.97 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	89.3 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	258.97 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					0 = 0 x 10 = 0 (7a)
Number of passive vents					0 = 0 x 10 = 0 (7b)
Number of flueless gas fires					0 = 0 x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 0 ÷ (5) = 0
(8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] = 0

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) =

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area 2

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] = 0.85

Infiltration rate incorporating shelter factor (21) = (18) x (20) = 0.08

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

DER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.11	0.11	0.1	0.09	0.09	0.08	0.08	0.08	0.08	0.09	0.1	0.1
------	------	-----	------	------	------	------	------	------	------	-----	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.21	0.21	0.22
---------	------	------	------	------	------	-----	-----	-----	------	------	------

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.2	0.21	0.21	0.22
--------	------	------	------	------	------	-----	-----	-----	-----	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Windows Type 1			2.24	x1/[1/(1.4)+ 0.04] =	2.97		(27)
Windows Type 2			11.21	x1/[1/(1.4)+ 0.04] =	14.86		(27)
Windows Type 3			1.8	x1/[1/(1.4)+ 0.04] =	2.39		(27)
Windows Type 4			1.8	x1/[1/(1.4)+ 0.04] =	2.39		(27)
Windows Type 5			2.69	x1/[1/(1.4)+ 0.04] =	3.57		(27)
Windows Type 6			3.44	x1/[1/(1.4)+ 0.04] =	4.56		(27)
Floor			89.3	x 0.12 =	10.716		(28)
Walls	59.25	23.18	36.07	x 0.12 =	4.33		(29)
Total area of elements, m ²			148.55				(31)
Party wall			49.76	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 45.78 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34))

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 13.25 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 59.02 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

DER WorkSheet: New dwelling design stage

(38)m=	19.3	19.12	18.94	18.03	17.85	16.94	16.94	16.76	17.31	17.85	18.21	18.58	(38)
--------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Heat transfer coefficient, W/K	(39)m = (37) + (38)m
--------------------------------	----------------------

(39)m=	78.33	78.15	77.96	77.06	76.87	75.97	75.97	75.79	76.33	76.87	77.24	77.6	Average = Sum(39) _{1...12} /12=	77.01	(39)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------	--	-------	------

Heat loss parameter (HLP), W/m ² K	(40)m = (39)m ÷ (4)
---	---------------------

(40)m=	0.88	0.88	0.87	0.86	0.86	0.85	0.85	0.85	0.85	0.86	0.86	0.87	Average = Sum(40) _{1...12} /12=	0.86	(40)
--------	------	------	------	------	------	------	------	------	------	------	------	------	--	------	------

Number of days in month (Table 1a)	(41)m=	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(41)
		31	28	31	30	31	30	31	31	30	31	30	31	

4. Water heating energy requirement:	kWh/year:
--------------------------------------	-----------

Assumed occupancy, N	(42)
----------------------	------

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)^2)] + 0.0013 \times (\text{TFA} - 13.9)$
if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day Vd,average = (25 x N) + 36	(43)
---	------

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month Vd,m = factor from Table 1c x (43)

(44)m=	105.96	102.11	98.26	94.4	90.55	86.7	86.7	90.55	94.4	98.26	102.11	105.96	Total = Sum(44) _{1...12} =	1155.96	(44)
--------	--------	--------	-------	------	-------	------	------	-------	------	-------	--------	--------	-------------------------------------	---------	------

Energy content of hot water used - calculated monthly = 4.190 x Vd,m x nm x DTm / 3600 kWh/month (see Tables 1b, 1c, 1d)	(44)														
(45)m=	157.14	137.44	141.82	123.64	118.64	102.38	94.87	108.86	110.16	128.38	140.14	152.18	Total = Sum(45) _{1...12} =	1515.65	(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	23.57	20.62	21.27	18.55	17.8	15.36	14.23	16.33	16.52	19.26	21.02	22.83
--------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel	(47)
---	------

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

(48)	0	(48)
	0	(49)

Energy lost from water storage, kWh/year

(48) x (49) =

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

(51)	0.02
------	------

If community heating see section 4.3

Volume factor from Table 2a

Temperature factor from Table 2b

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

Enter (50) or (54) in (55)

Water storage loss calculated for each month

((56)m = (55) x (41)m)

(56)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

If cylinder contains dedicated solar storage, (57)m = (56)m x [(50) - (H11)] ÷ (50), else (57)m = (56)m where (H11) is from Appendix H

(57)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

DER WorkSheet: New dwelling design stage

Primary circuit loss (annual) from Table 3 (58)

0

Primary circuit loss calculated for each month (59)m = (58) ÷ 365 × (41)m

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m= (59)

23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Combi loss calculated for each month (61)m = (60) ÷ 365 × (41)m

(61)m= (61)

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

Total heat required for water heating calculated for each month (62)m = 0.85 × (45)m + (46)m + (57)m + (59)m + (61)m

(62)m= (62)

212.42	187.36	197.1	177.14	173.92	155.87	150.14	164.14	163.66	183.66	193.63	207.46
--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRS applies, see Appendix G)

(63)m= (63)

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

Output from water heater

(64)m= (64)

212.42	187.36	197.1	177.14	173.92	155.87	150.14	164.14	163.66	183.66	193.63	207.46
--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------

Output from water heater (annual)_{1...12} 2166.49 (64)

Heat gains from water heating, kWh/month 0.25 [0.85 × (45)m + (61)m] + 0.8 × [(46)m + (57)m + (59)m]

(65)m= (65)

96.47	85.64	91.38	83.91	83.67	76.84	75.76	80.42	79.42	86.91	89.39	94.82
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

(66)m= (66)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
130.8	130.8	130.8	130.8	130.8	130.8	130.8	130.8	130.8	130.8	130.8	130.8

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m= (67)

21.2	18.83	15.31	11.59	8.67	7.32	7.9	10.28	13.79	17.51	20.44	21.79
------	-------	-------	-------	------	------	-----	-------	-------	-------	-------	-------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m= (68)

237.78	240.25	234.03	220.8	204.09	188.38	177.89	175.42	181.64	194.88	211.59	227.29
--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m= (69)

36.08	36.08	36.08	36.08	36.08	36.08	36.08	36.08	36.08	36.08	36.08	36.08
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Pumps and fans gains (Table 5a)

(70)m= (70)

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

Losses e.g. evaporation (negative values) (Table 5)

(71)m= (71)

-104.64	-104.64	-104.64	-104.64	-104.64	-104.64	-104.64	-104.64	-104.64	-104.64	-104.64	-104.64
---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------

Water heating gains (Table 5)

(72)m= (72)

129.66	127.44	122.82	116.54	112.46	106.72	101.83	108.09	110.31	116.81	124.15	127.45
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

Total internal gains = (66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m

(73)m= (73)

450.89	448.76	434.41	411.17	387.45	364.65	349.87	356.03	367.98	391.44	418.42	438.77
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)
North	0.9x	0.77	x 11.21	x 10.63	x 0.4	x 0.8 = 26.43 (74)
North	0.9x	0.77	x 2.69	x 10.63	x 0.4	x 0.8 = 6.34 (74)

DER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	11.21	x	20.32	x	0.4	x	0.8	=	50.52	(74)
North	0.9x	0.77	x	2.69	x	20.32	x	0.4	x	0.8	=	12.12	(74)
North	0.9x	0.77	x	11.21	x	34.53	x	0.4	x	0.8	=	85.84	(74)
North	0.9x	0.77	x	2.69	x	34.53	x	0.4	x	0.8	=	20.6	(74)
North	0.9x	0.77	x	11.21	x	55.46	x	0.4	x	0.8	=	137.88	(74)
North	0.9x	0.77	x	2.69	x	55.46	x	0.4	x	0.8	=	33.09	(74)
North	0.9x	0.77	x	11.21	x	74.72	x	0.4	x	0.8	=	185.74	(74)
North	0.9x	0.77	x	2.69	x	74.72	x	0.4	x	0.8	=	44.57	(74)
North	0.9x	0.77	x	11.21	x	79.99	x	0.4	x	0.8	=	198.84	(74)
North	0.9x	0.77	x	2.69	x	79.99	x	0.4	x	0.8	=	47.71	(74)
North	0.9x	0.77	x	11.21	x	74.68	x	0.4	x	0.8	=	185.64	(74)
North	0.9x	0.77	x	2.69	x	74.68	x	0.4	x	0.8	=	44.55	(74)
North	0.9x	0.77	x	11.21	x	59.25	x	0.4	x	0.8	=	147.28	(74)
North	0.9x	0.77	x	2.69	x	59.25	x	0.4	x	0.8	=	35.34	(74)
North	0.9x	0.77	x	11.21	x	41.52	x	0.4	x	0.8	=	103.21	(74)
North	0.9x	0.77	x	2.69	x	41.52	x	0.4	x	0.8	=	24.77	(74)
North	0.9x	0.77	x	11.21	x	24.19	x	0.4	x	0.8	=	60.13	(74)
North	0.9x	0.77	x	2.69	x	24.19	x	0.4	x	0.8	=	14.43	(74)
North	0.9x	0.77	x	11.21	x	13.12	x	0.4	x	0.8	=	32.61	(74)
North	0.9x	0.77	x	2.69	x	13.12	x	0.4	x	0.8	=	7.83	(74)
North	0.9x	0.77	x	11.21	x	8.86	x	0.4	x	0.8	=	22.04	(74)
North	0.9x	0.77	x	2.69	x	8.86	x	0.4	x	0.8	=	5.29	(74)
West	0.9x	0.77	x	2.24	x	19.64	x	0.4	x	0.8	=	9.76	(80)
West	0.9x	0.77	x	1.8	x	19.64	x	0.4	x	0.8	=	7.84	(80)
West	0.9x	0.77	x	1.8	x	19.64	x	0.4	x	0.8	=	7.84	(80)
West	0.9x	0.77	x	3.44	x	19.64	x	0.4	x	0.8	=	14.98	(80)
West	0.9x	0.77	x	2.24	x	38.42	x	0.4	x	0.8	=	19.09	(80)
West	0.9x	0.77	x	1.8	x	38.42	x	0.4	x	0.8	=	15.34	(80)
West	0.9x	0.77	x	1.8	x	38.42	x	0.4	x	0.8	=	15.34	(80)
West	0.9x	0.77	x	3.44	x	38.42	x	0.4	x	0.8	=	29.31	(80)
West	0.9x	0.77	x	2.24	x	63.27	x	0.4	x	0.8	=	31.43	(80)
West	0.9x	0.77	x	1.8	x	63.27	x	0.4	x	0.8	=	25.26	(80)
West	0.9x	0.77	x	1.8	x	63.27	x	0.4	x	0.8	=	25.26	(80)
West	0.9x	0.77	x	3.44	x	63.27	x	0.4	x	0.8	=	48.27	(80)
West	0.9x	0.77	x	2.24	x	92.28	x	0.4	x	0.8	=	45.84	(80)
West	0.9x	0.77	x	1.8	x	92.28	x	0.4	x	0.8	=	36.84	(80)
West	0.9x	0.77	x	1.8	x	92.28	x	0.4	x	0.8	=	36.84	(80)
West	0.9x	0.77	x	3.44	x	92.28	x	0.4	x	0.8	=	70.4	(80)
West	0.9x	0.77	x	2.24	x	113.09	x	0.4	x	0.8	=	56.18	(80)
West	0.9x	0.77	x	1.8	x	113.09	x	0.4	x	0.8	=	45.14	(80)
West	0.9x	0.77	x	1.8	x	113.09	x	0.4	x	0.8	=	45.14	(80)

DER WorkSheet: New dwelling design stage

West	0.9x	0.77	x	3.44	x	113.09	x	0.4	x	0.8	=	86.27	(80)
West	0.9x	0.77	x	2.24	x	115.77	x	0.4	x	0.8	=	57.51	(80)
West	0.9x	0.77	x	1.8	x	115.77	x	0.4	x	0.8	=	46.21	(80)
West	0.9x	0.77	x	1.8	x	115.77	x	0.4	x	0.8	=	46.21	(80)
West	0.9x	0.77	x	3.44	x	115.77	x	0.4	x	0.8	=	88.32	(80)
West	0.9x	0.77	x	2.24	x	110.22	x	0.4	x	0.8	=	54.75	(80)
West	0.9x	0.77	x	1.8	x	110.22	x	0.4	x	0.8	=	44	(80)
West	0.9x	0.77	x	1.8	x	110.22	x	0.4	x	0.8	=	44	(80)
West	0.9x	0.77	x	3.44	x	110.22	x	0.4	x	0.8	=	84.08	(80)
West	0.9x	0.77	x	2.24	x	94.68	x	0.4	x	0.8	=	47.03	(80)
West	0.9x	0.77	x	1.8	x	94.68	x	0.4	x	0.8	=	37.79	(80)
West	0.9x	0.77	x	1.8	x	94.68	x	0.4	x	0.8	=	37.79	(80)
West	0.9x	0.77	x	3.44	x	94.68	x	0.4	x	0.8	=	72.22	(80)
West	0.9x	0.77	x	2.24	x	73.59	x	0.4	x	0.8	=	36.55	(80)
West	0.9x	0.77	x	1.8	x	73.59	x	0.4	x	0.8	=	29.37	(80)
West	0.9x	0.77	x	1.8	x	73.59	x	0.4	x	0.8	=	29.37	(80)
West	0.9x	0.77	x	3.44	x	73.59	x	0.4	x	0.8	=	56.14	(80)
West	0.9x	0.77	x	2.24	x	45.59	x	0.4	x	0.8	=	22.65	(80)
West	0.9x	0.77	x	1.8	x	45.59	x	0.4	x	0.8	=	18.2	(80)
West	0.9x	0.77	x	1.8	x	45.59	x	0.4	x	0.8	=	18.2	(80)
West	0.9x	0.77	x	3.44	x	45.59	x	0.4	x	0.8	=	34.78	(80)
West	0.9x	0.77	x	2.24	x	24.49	x	0.4	x	0.8	=	12.16	(80)
West	0.9x	0.77	x	1.8	x	24.49	x	0.4	x	0.8	=	9.78	(80)
West	0.9x	0.77	x	1.8	x	24.49	x	0.4	x	0.8	=	9.78	(80)
West	0.9x	0.77	x	3.44	x	24.49	x	0.4	x	0.8	=	18.68	(80)
West	0.9x	0.77	x	2.24	x	16.15	x	0.4	x	0.8	=	8.02	(80)
West	0.9x	0.77	x	1.8	x	16.15	x	0.4	x	0.8	=	6.45	(80)
West	0.9x	0.77	x	1.8	x	16.15	x	0.4	x	0.8	=	6.45	(80)
West	0.9x	0.77	x	3.44	x	16.15	x	0.4	x	0.8	=	12.32	(80)

Solar gains in watts, calculated for each month

(83)m = Sum(74)m ... (82)m

$$(83)m = \boxed{73.2 \quad 141.71 \quad 236.65 \quad 360.87 \quad 463.05 \quad 484.8 \quad 457.01 \quad 377.46 \quad 279.42 \quad 168.38 \quad 90.83 \quad 60.56} \quad (83)$$

Total gains – internal and solar (84)m = (73)m + (83)m , watts

$$(84)m = \boxed{524.08 \quad 590.47 \quad 671.06 \quad 772.04 \quad 850.5 \quad 849.45 \quad 806.88 \quad 733.49 \quad 647.4 \quad 559.82 \quad 509.25 \quad 499.33} \quad (84)$$

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m=	1	1	0.98	0.93	0.78	0.57	0.41	0.47	0.76	0.97	1	1	(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

$$(87)m = \boxed{20.13 \quad 20.26 \quad 20.48 \quad 20.76 \quad 20.94 \quad 20.99 \quad 21 \quad 21 \quad 20.96 \quad 20.71 \quad 20.37 \quad 20.11} \quad (87)$$

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

$$(88)m = \boxed{20.19 \quad 20.19 \quad 20.19 \quad 20.2 \quad 20.2 \quad 20.21 \quad 20.21 \quad 20.21 \quad 20.21 \quad 20.2 \quad 20.2 \quad 20.19} \quad (88)$$

DER WorkSheet: New dwelling design stage

Utilisation factor for gains for rest of dwelling, h_{2,m} (see Table 9a)

(89)m=	1	0.99	0.98	0.91	0.73	0.5	0.34	0.39	0.69	0.95	0.99	1		(89)
--------	---	------	------	------	------	-----	------	------	------	------	------	---	--	------

Mean internal temperature in the rest of dwelling T₂ (follow steps 3 to 7 in Table 9c)

(90)m=	19.02	19.2	19.53	19.93	20.15	20.21	20.21	20.21	20.18	19.87	19.38	18.99		(90)
									fLA = Living area ÷ (4) =				0.39	(91)

Mean internal temperature (for the whole dwelling) = f_{LA} × T₁ + (1 – f_{LA}) × T₂

(92)m=	19.45	19.61	19.89	20.25	20.45	20.51	20.51	20.51	20.48	20.19	19.76	19.42		(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.45	19.61	19.89	20.25	20.45	20.51	20.51	20.51	20.48	20.19	19.76	19.42		(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--	------

8. Space heating requirement

Set T_i to the mean internal temperature obtained at step 11 of Table 9b, so that T_{i,m}=(76)m and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, h_m:

(94)m=	1	0.99	0.98	0.91	0.75	0.52	0.37	0.42	0.72	0.95	0.99	1		(94)
--------	---	------	------	------	------	------	------	------	------	------	------	---	--	------

Useful gains, h_mG_m, W = (94)m × (84)m

(95)m=	522.35	586.09	655.67	703.92	634.61	445.45	297.07	311.13	464.96	533.08	505.35	498.09		(95)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2		(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	--	------

Heat loss rate for mean internal temperature, L_m, W = [(39)m × [(93)m – (96)m]]

(97)m=	1186.48	1149.57	1044.24	874.55	672.99	448.96	297.37	311.85	487.07	737.56	977.87	1181.14		(97)
--------	---------	---------	---------	--------	--------	--------	--------	--------	--------	--------	--------	---------	--	------

Space heating requirement for each month, kWh/month = 0.024 × [(97)m – (95)m] × (41)m

(98)m=	494.11	378.66	289.1	122.85	28.56	0	0	0	0	152.13	340.21	508.19	
--------	--------	--------	-------	--------	-------	---	---	---	---	--------	--------	--------	--

Total per year (kWh/year) = Sum(98)_{1...5,9...12} = 2313.82 (98)

Space heating requirement in kWh/m²/year

25.91 (99)

9b. Energy requirements – Community heating scheme

This part is used for space heating, space cooling or water heating provided by a community scheme.

Fraction of space heat from secondary/supplementary heating (Table 11) '0' if none

0 (301)

Fraction of space heat from community system 1 – (301) =

1 (302)

The community scheme may obtain heat from several sources. The procedure allows for CHP and up to four other heat sources; the latter includes boilers, heat pumps, geothermal and waste heat from power stations. See Appendix C.

Fraction of heat from Community boilers

1 (303a)

Fraction of total space heat from Community boilers (302) × (303a) =

1 (304a)

Factor for control and charging method (Table 4c(3)) for community heating system

1 (305)

Distribution loss factor (Table 12c) for community heating system

1.1 (306)

Space heating

Annual space heating requirement

2313.82

Space heat from Community boilers (98) × (304a) × (305) × (306) =

2545.2 (307a)

Efficiency of secondary/supplementary heating system in % (from Table 4a or Appendix E)

0 (308)

Space heating requirement from secondary/supplementary system (98) × (301) × 100 ÷ (308) =

0 (309)

DER WorkSheet: New dwelling design stage

Water heating

Annual water heating requirement

2166.49

If DHW from community scheme:

Water heat from Community boilers

$(64) \times (303a) \times (305) \times (306) =$

2383.14

(310a)

Electricity used for heat distribution

$0.01 \times [(307a) \dots (307e) + (310a) \dots (310e)] =$

49.28

(313)

Cooling System Energy Efficiency Ratio

0

(314)

Space cooling (if there is a fixed cooling system, if not enter 0)

$= (107) \div (314) =$

0

(315)

Electricity for pumps and fans within dwelling (Table 4f):

mechanical ventilation - balanced, extract or positive input from outside

197.46

(330a)

warm air heating system fans

0

(330b)

pump for solar water heating

0

(330g)

Total electricity for the above, kWh/year

$=(330a) + (330b) + (330g) =$

197.46

(331)

Energy for lighting (calculated in Appendix L)

374.37

(332)

12b. CO2 Emissions – Community heating scheme

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
CO2 from other sources of space and water heating (not CHP)			
Efficiency of heat source 1 (%)	If there is CHP using two fuels repeat (363) to (366) for the second fuel	95	(367a)
CO2 associated with heat source 1	$[(307b)+(310b)] \times 100 \div (367b) \times$	0.22	= 1120.55 (367)
Electrical energy for heat distribution	$(313) \times$	0.52	= 25.58 (372)
Total CO2 associated with community systems	$(363) \dots (366) + (368) \dots (372)$		= 1146.13 (373)
CO2 associated with space heating (secondary)	$(309) \times$	0	= 0 (374)
CO2 associated with water from immersion heater or instantaneous heater	$(312) \times$	0.22	= 0 (375)
Total CO2 associated with space and water heating	$(373) + (374) + (375) =$		= 1146.13 (376)
CO2 associated with electricity for pumps and fans within dwelling	$(331) \times$	0.52	= 102.48 (378)
CO2 associated with electricity for lighting	$(332) \times$	0.52	= 194.3 (379)
Total CO2, kg/year	sum of (376)...(382) =		1442.91 (383)
Dwelling CO2 Emission Rate	$(383) \div (4) =$		16.16 (384)
EI rating (section 14)			85.6 (385)

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 008 - Be Lean			
Address :	AC 008, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	89.3 (1a)	x (2a)	= 258.97 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	89.3 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	258.97 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					3 x 10 = 30 (7a)
Number of passive vents					0 x 10 = 0 (7b)
Number of flueless gas fires					0 x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 30 ÷ (5) = 0.12 (8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] =

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) =

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area 5 (17)

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] =

Infiltration rate incorporating shelter factor (21) = (18) x (20) =

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

TER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.4	0.39	0.38	0.34	0.33	0.3	0.3	0.29	0.31	0.33	0.35	0.37
-----	------	------	------	------	-----	-----	------	------	------	------	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0.58	0.58	0.57	0.56	0.56	0.54	0.54	0.54	0.55	0.56	0.56
---------	------	------	------	------	------	------	------	------	------	------	------

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.58	0.58	0.57	0.56	0.56	0.54	0.54	0.54	0.55	0.56	0.56
--------	------	------	------	------	------	------	------	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Windows Type 1			2.16	x1/[1/(1.4)+ 0.04] =	2.86		(27)
Windows Type 2			10.8	x1/[1/(1.4)+ 0.04] =	14.32		(27)
Windows Type 3			1.73	x1/[1/(1.4)+ 0.04] =	2.29		(27)
Windows Type 4			1.73	x1/[1/(1.4)+ 0.04] =	2.29		(27)
Windows Type 5			2.59	x1/[1/(1.4)+ 0.04] =	3.43		(27)
Windows Type 6			3.31	x1/[1/(1.4)+ 0.04] =	4.39		(27)
Floor			89.3	x 0.13 =	11.609		(28)
Walls	59.25	22.32	36.93	x 0.18 =	6.65		(29)
Total area of elements, m ²			148.55				(31)
Party wall			49.76	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 47.85 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34))

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 9.3 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 57.15 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

TER WorkSheet: New dwelling design stage

(38)m=	49.45	49.19	48.93	47.73	47.51	46.46	46.46	46.27	46.86	47.51	47.96	48.43	(38)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Heat transfer coefficient, W/K $(39)m = (37) + (38)m$

(39)m=	106.59	106.33	106.08	104.88	104.65	103.61	103.61	103.41	104.01	104.65	105.11	105.58	Average = Sum(39) _{1...12} /12=	104.88	(39)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--	--------	------

Heat loss parameter (HLP), W/m²K $(40)m = (39)m \div (4)$

(40)m=	1.19	1.19	1.19	1.17	1.17	1.16	1.16	1.16	1.16	1.17	1.18	1.18	Average = Sum(40) _{1...12} /12=	1.17	(40)
--------	------	------	------	------	------	------	------	------	------	------	------	------	--	------	------

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		(41)
31	28	31	30	31	30	31	31	30	31	30	31		

4. Water heating energy requirement: kWh/year:

Assumed occupancy, N 2.62 (42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)^2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$ 96.33 (43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	105.96	102.11	98.26	94.4	90.55	86.7	86.7	90.55	94.4	98.26	102.11	105.96	Total = Sum(44) _{1...12} =	1155.96	(44)
--------	--------	--------	-------	------	-------	------	------	-------	------	-------	--------	--------	-------------------------------------	---------	------

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	157.14	137.44	141.82	123.64	118.64	102.38	94.87	108.86	110.16	128.38	140.14	152.18	Total = Sum(45) _{1...12} =	1515.65	(45)
--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	-------------------------------------	---------	------

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	23.57	20.62	21.27	18.55	17.8	15.36	14.23	16.33	16.52	19.26	21.02	22.83		(46)
--------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	--	------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel 150 (47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day): 1.39 (48)

Temperature factor from Table 2b 0.54 (49)

Energy lost from water storage, kWh/year (48) x (49) = 0.75 (50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day) 0 (51)

If community heating see section 4.3

Volume factor from Table 2a 0 (52)

Temperature factor from Table 2b 0 (53)

Energy lost from water storage, kWh/year (47) x (51) x (52) x (53) = 0 (54)

Enter (50) or (54) in (55)

Water storage loss calculated for each month ((56)m = (55) x (41)m) 0.75 (55)

(56)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33		(56)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--	------

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33		(57)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--	------

TER WorkSheet: New dwelling design stage

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month (59)m = (58) ÷ 365 × (41)m

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(59)

Combi loss calculated for each month (61)m = (60) ÷ 365 × (41)m

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0
--------	---	---	---	---	---	---	---	---	---	---	---	---

(61)

Total heat required for water heating calculated for each month (62)m = 0.85 × (45)m + (46)m + (57)m + (59)m + (61)m

(62)m=	203.74	179.52	188.42	168.74	165.23	147.47	141.46	155.46	155.25	174.98	185.23	198.78
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

(62)

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRS and/or WWHRS applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0
--------	---	---	---	---	---	---	---	---	---	---	---	---

(63)

Output from water heater

(64)m=	203.74	179.52	188.42	168.74	165.23	147.47	141.46	155.46	155.25	174.98	185.23	198.78
Output from water heater (annual) _{1...12}											2064.27	(64)

Heat gains from water heating, kWh/month 0.25 [0.85 × (45)m + (61)m] + 0.8 × [(46)m + (57)m + (59)m]

(65)m=	89.53	79.37	84.43	77.19	76.72	70.11	68.82	73.47	72.7	79.96	82.67	87.88
--------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------

(65)

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(66)m=	130.8	130.8	130.8	130.8	130.8	130.8	130.8	130.8	130.8	130.8	130.8

(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	21.2	18.83	15.31	11.59	8.67	7.32	7.9	10.28	13.79	17.51	20.44	21.79
--------	------	-------	-------	-------	------	------	-----	-------	-------	-------	-------	-------

(67)

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	237.78	240.25	234.03	220.8	204.09	188.38	177.89	175.42	181.64	194.88	211.59	227.29
--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------

(68)

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	36.08	36.08	36.08	36.08	36.08	36.08	36.08	36.08	36.08	36.08	36.08	36.08
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(69)

Pumps and fans gains (Table 5a)

(70)m=	3	3	3	3	3	3	3	3	3	3	3	3
--------	---	---	---	---	---	---	---	---	---	---	---	---

(70)

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-104.64	-104.64	-104.64	-104.64	-104.64	-104.64	-104.64	-104.64	-104.64	-104.64	-104.64	-104.64
--------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------

(71)

Water heating gains (Table 5)

(72)m=	120.33	118.1	113.48	107.2	103.12	97.38	92.5	98.75	100.98	107.48	114.82	118.11
--------	--------	-------	--------	-------	--------	-------	------	-------	--------	--------	--------	--------

(72)

Total internal gains =

$$(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$$

(73)m=	444.55	442.42	428.07	404.83	381.12	358.32	343.53	349.69	361.65	385.11	412.09	432.43
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

(73)

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)
North	0.9x	0.77	x 10.8	x 10.63	x 0.63	x 0.7 = 35.1
North	0.9x	0.77	x 2.59	x 10.63	x 0.63	x 0.7 = 8.42

TER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	10.8	x	20.32	x	0.63	x	0.7	=	67.07	(74)
North	0.9x	0.77	x	2.59	x	20.32	x	0.63	x	0.7	=	16.08	(74)
North	0.9x	0.77	x	10.8	x	34.53	x	0.63	x	0.7	=	113.97	(74)
North	0.9x	0.77	x	2.59	x	34.53	x	0.63	x	0.7	=	27.33	(74)
North	0.9x	0.77	x	10.8	x	55.46	x	0.63	x	0.7	=	183.07	(74)
North	0.9x	0.77	x	2.59	x	55.46	x	0.63	x	0.7	=	43.9	(74)
North	0.9x	0.77	x	10.8	x	74.72	x	0.63	x	0.7	=	246.61	(74)
North	0.9x	0.77	x	2.59	x	74.72	x	0.63	x	0.7	=	59.14	(74)
North	0.9x	0.77	x	10.8	x	79.99	x	0.63	x	0.7	=	264	(74)
North	0.9x	0.77	x	2.59	x	79.99	x	0.63	x	0.7	=	63.31	(74)
North	0.9x	0.77	x	10.8	x	74.68	x	0.63	x	0.7	=	246.48	(74)
North	0.9x	0.77	x	2.59	x	74.68	x	0.63	x	0.7	=	59.11	(74)
North	0.9x	0.77	x	10.8	x	59.25	x	0.63	x	0.7	=	195.55	(74)
North	0.9x	0.77	x	2.59	x	59.25	x	0.63	x	0.7	=	46.9	(74)
North	0.9x	0.77	x	10.8	x	41.52	x	0.63	x	0.7	=	137.03	(74)
North	0.9x	0.77	x	2.59	x	41.52	x	0.63	x	0.7	=	32.86	(74)
North	0.9x	0.77	x	10.8	x	24.19	x	0.63	x	0.7	=	79.84	(74)
North	0.9x	0.77	x	2.59	x	24.19	x	0.63	x	0.7	=	19.15	(74)
North	0.9x	0.77	x	10.8	x	13.12	x	0.63	x	0.7	=	43.3	(74)
North	0.9x	0.77	x	2.59	x	13.12	x	0.63	x	0.7	=	10.38	(74)
North	0.9x	0.77	x	10.8	x	8.86	x	0.63	x	0.7	=	29.26	(74)
North	0.9x	0.77	x	2.59	x	8.86	x	0.63	x	0.7	=	7.02	(74)
West	0.9x	0.77	x	2.16	x	19.64	x	0.63	x	0.7	=	12.97	(80)
West	0.9x	0.77	x	1.73	x	19.64	x	0.63	x	0.7	=	10.38	(80)
West	0.9x	0.77	x	1.73	x	19.64	x	0.63	x	0.7	=	10.38	(80)
West	0.9x	0.77	x	3.31	x	19.64	x	0.63	x	0.7	=	19.87	(80)
West	0.9x	0.77	x	2.16	x	38.42	x	0.63	x	0.7	=	25.36	(80)
West	0.9x	0.77	x	1.73	x	38.42	x	0.63	x	0.7	=	20.31	(80)
West	0.9x	0.77	x	1.73	x	38.42	x	0.63	x	0.7	=	20.31	(80)
West	0.9x	0.77	x	3.31	x	38.42	x	0.63	x	0.7	=	38.87	(80)
West	0.9x	0.77	x	2.16	x	63.27	x	0.63	x	0.7	=	41.77	(80)
West	0.9x	0.77	x	1.73	x	63.27	x	0.63	x	0.7	=	33.45	(80)
West	0.9x	0.77	x	1.73	x	63.27	x	0.63	x	0.7	=	33.45	(80)
West	0.9x	0.77	x	3.31	x	63.27	x	0.63	x	0.7	=	64.01	(80)
West	0.9x	0.77	x	2.16	x	92.28	x	0.63	x	0.7	=	60.92	(80)
West	0.9x	0.77	x	1.73	x	92.28	x	0.63	x	0.7	=	48.79	(80)
West	0.9x	0.77	x	1.73	x	92.28	x	0.63	x	0.7	=	48.79	(80)
West	0.9x	0.77	x	3.31	x	92.28	x	0.63	x	0.7	=	93.35	(80)
West	0.9x	0.77	x	2.16	x	113.09	x	0.63	x	0.7	=	74.66	(80)
West	0.9x	0.77	x	1.73	x	113.09	x	0.63	x	0.7	=	59.79	(80)
West	0.9x	0.77	x	1.73	x	113.09	x	0.63	x	0.7	=	59.79	(80)

TER WorkSheet: New dwelling design stage

West	0.9x	0.77	x	3.31	x	113.09	x	0.63	x	0.7	=	114.4	(80)
West	0.9x	0.77	x	2.16	x	115.77	x	0.63	x	0.7	=	76.42	(80)
West	0.9x	0.77	x	1.73	x	115.77	x	0.63	x	0.7	=	61.21	(80)
West	0.9x	0.77	x	1.73	x	115.77	x	0.63	x	0.7	=	61.21	(80)
West	0.9x	0.77	x	3.31	x	115.77	x	0.63	x	0.7	=	117.11	(80)
West	0.9x	0.77	x	2.16	x	110.22	x	0.63	x	0.7	=	72.76	(80)
West	0.9x	0.77	x	1.73	x	110.22	x	0.63	x	0.7	=	58.27	(80)
West	0.9x	0.77	x	1.73	x	110.22	x	0.63	x	0.7	=	58.27	(80)
West	0.9x	0.77	x	3.31	x	110.22	x	0.63	x	0.7	=	111.49	(80)
West	0.9x	0.77	x	2.16	x	94.68	x	0.63	x	0.7	=	62.5	(80)
West	0.9x	0.77	x	1.73	x	94.68	x	0.63	x	0.7	=	50.06	(80)
West	0.9x	0.77	x	1.73	x	94.68	x	0.63	x	0.7	=	50.06	(80)
West	0.9x	0.77	x	3.31	x	94.68	x	0.63	x	0.7	=	95.77	(80)
West	0.9x	0.77	x	2.16	x	73.59	x	0.63	x	0.7	=	48.58	(80)
West	0.9x	0.77	x	1.73	x	73.59	x	0.63	x	0.7	=	38.91	(80)
West	0.9x	0.77	x	1.73	x	73.59	x	0.63	x	0.7	=	38.91	(80)
West	0.9x	0.77	x	3.31	x	73.59	x	0.63	x	0.7	=	74.44	(80)
West	0.9x	0.77	x	2.16	x	45.59	x	0.63	x	0.7	=	30.09	(80)
West	0.9x	0.77	x	1.73	x	45.59	x	0.63	x	0.7	=	24.1	(80)
West	0.9x	0.77	x	1.73	x	45.59	x	0.63	x	0.7	=	24.1	(80)
West	0.9x	0.77	x	3.31	x	45.59	x	0.63	x	0.7	=	46.12	(80)
West	0.9x	0.77	x	2.16	x	24.49	x	0.63	x	0.7	=	16.17	(80)
West	0.9x	0.77	x	1.73	x	24.49	x	0.63	x	0.7	=	12.95	(80)
West	0.9x	0.77	x	1.73	x	24.49	x	0.63	x	0.7	=	12.95	(80)
West	0.9x	0.77	x	3.31	x	24.49	x	0.63	x	0.7	=	24.77	(80)
West	0.9x	0.77	x	2.16	x	16.15	x	0.63	x	0.7	=	10.66	(80)
West	0.9x	0.77	x	1.73	x	16.15	x	0.63	x	0.7	=	8.54	(80)
West	0.9x	0.77	x	1.73	x	16.15	x	0.63	x	0.7	=	8.54	(80)
West	0.9x	0.77	x	3.31	x	16.15	x	0.63	x	0.7	=	16.34	(80)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

$$(83)m = 97.11 \quad 188.01 \quad 313.98 \quad 478.81 \quad 614.39 \quad 643.26 \quad 606.39 \quad 500.83 \quad 370.73 \quad 223.41 \quad 120.51 \quad 80.35 \quad (83)$$

Total gains – internal and solar $(84)m = (73)m + (83)m$, watts

$$(84)m = 541.67 \quad 630.44 \quad 742.05 \quad 883.64 \quad 995.51 \quad 1001.58 \quad 949.92 \quad 850.52 \quad 732.37 \quad 608.51 \quad 532.6 \quad 512.79 \quad (84)$$

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 ($^{\circ}\text{C}$)

21

(85)

Utilisation factor for gains for living area, $h1,m$ (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m=	1	1	0.99	0.94	0.82	0.63	0.47	0.55	0.82	0.97	1	1	(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

$$(87)m = 19.71 \quad 19.87 \quad 20.16 \quad 20.54 \quad 20.84 \quad 20.97 \quad 20.99 \quad 20.99 \quad 20.88 \quad 20.48 \quad 20.03 \quad 19.68 \quad (87)$$

Temperature during heating periods in rest of dwelling from Table 9, Th2 ($^{\circ}\text{C}$)

$$(88)m = 19.93 \quad 19.93 \quad 19.93 \quad 19.94 \quad 19.94 \quad 19.95 \quad 19.95 \quad 19.95 \quad 19.95 \quad 19.94 \quad 19.94 \quad 19.93 \quad (88)$$

TER WorkSheet: New dwelling design stage

Utilisation factor for gains for rest of dwelling, h_{2,m} (see Table 9a)

(89)m=	1	0.99	0.98	0.92	0.77	0.54	0.36	0.43	0.75	0.96	0.99	1		(89)
--------	---	------	------	------	------	------	------	------	------	------	------	---	--	------

Mean internal temperature in the rest of dwelling T₂ (follow steps 3 to 7 in Table 9c)

(90)m=	18.21	18.44	18.86	19.41	19.79	19.93	19.95	19.95	19.85	19.34	18.68	18.17		(90)
									fLA = Living area ÷ (4) =				0.39	(91)

Mean internal temperature (for the whole dwelling) = f_{LA} × T₁ + (1 – f_{LA}) × T₂

(92)m=	18.79	18.99	19.36	19.85	20.2	20.33	20.35	20.35	20.25	19.78	19.2	18.76		(92)
--------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	------	-------	--	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	18.79	18.99	19.36	19.85	20.2	20.33	20.35	20.35	20.25	19.78	19.2	18.76		(93)
--------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	------	-------	--	------

8. Space heating requirement

Set T_i to the mean internal temperature obtained at step 11 of Table 9b, so that T_{i,m}=(76)m and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	--

Utilisation factor for gains, h_m:

(94)m=	1	0.99	0.98	0.92	0.78	0.57	0.41	0.47	0.77	0.96	0.99	1		(94)
--------	---	------	------	------	------	------	------	------	------	------	------	---	--	------

Useful gains, h_{mGm}, W = (94)m × (84)m

(95)m=	539.54	625.1	724.43	812.97	778.18	575.22	386.16	402.99	565.24	583.61	528.35	511.24		(95)
--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2		(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	--	------

Heat loss rate for mean internal temperature, L_m, W =[(39)m × [(93)m – (96)m]

(97)m=	1544.05	1498.54	1364.46	1148.46	889.08	593.83	388.84	408.5	639.74	960.81	1271.88	1536.86		(97)
--------	---------	---------	---------	---------	--------	--------	--------	-------	--------	--------	---------	---------	--	------

Space heating requirement for each month, kWh/month = 0.024 × [(97)m – (95)m] × (41)m

(98)m=	747.36	586.95	476.19	241.55	82.51	0	0	0	0	280.64	535.34	763.06	
--------	--------	--------	--------	--------	-------	---	---	---	---	--------	--------	--------	--

Total per year (kWh/year) = Sum(98)_{1...5,9...12} = 3713.6 (98)

Space heating requirement in kWh/m²/year

41.59 (99)

9a. Energy requirements – Individual heating systems including micro-CHP

Space heating:

Fraction of space heat from secondary/supplementary system

0 (201)

Fraction of space heat from main system(s) (202) = 1 – (201) = 1 (202)

Fraction of total heating from main system 1 (204) = (202) × [1 – (203)] = 1 (204)

Efficiency of main space heating system 1 93.5 (206)

Efficiency of secondary/supplementary heating system, % 0 (208)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

747.36	586.95	476.19	241.55	82.51	0	0	0	0	280.64	535.34	763.06	
--------	--------	--------	--------	-------	---	---	---	---	--------	--------	--------	--

(211)m = {[(98)m × (204)] } × 100 ÷ (206) 3971.76 (211)

799.31	627.76	509.29	258.35	88.24	0	0	0	0	300.15	572.56	816.11	
--------	--------	--------	--------	-------	---	---	---	---	--------	--------	--------	--

Total (kWh/year) =Sum(211)_{1...5,10...12}= 3971.76 (211)

Space heating fuel (secondary), kWh/month

= {[(98)m × (201)] } × 100 ÷ (208) 0 (215)

0	0	0	0	0	0	0	0	0	0	0	0	
---	---	---	---	---	---	---	---	---	---	---	---	--

Total (kWh/year) =Sum(215)_{1...5,10...12}= 0 (215)

TER WorkSheet: New dwelling design stage

Water heating

Output from water heater (calculated above)

203.74	179.52	188.42	168.74	165.23	147.47	141.46	155.46	155.25	174.98	185.23	198.78
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

Efficiency of water heater

79.8

(216)

(217)m=	87.97	87.74	87.19	85.77	83.07	79.8	79.8	79.8	86.07	87.48	88.06		(217)
---------	-------	-------	-------	-------	-------	------	------	------	-------	-------	-------	--	-------

Fuel for water heating, kWh/month

$$(219)m = (64)m \times 100 \div (217)m$$

(219)m=	231.59	204.6	216.11	196.73	198.91	184.8	177.27	194.81	194.55	203.3	211.73	225.73
---------	--------	-------	--------	--------	--------	-------	--------	--------	--------	-------	--------	--------

$$\text{Total} = \text{Sum}(219a)_{1\dots 12} =$$

2440.12

(219)

Annual totals

Space heating fuel used, main system 1

kWh/year

3971.76

Water heating fuel used

kWh/year

2440.12

Electricity for pumps, fans and electric keep-hot

central heating pump:

30

(230c)

boiler with a fan-assisted flue

45

(230e)

Total electricity for the above, kWh/year

$$\text{sum of } (230a)\dots(230g) =$$

75

(231)

Electricity for lighting

374.37

(232)

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating (main system 1)	(211) x	0.216	= 857.9
Space heating (secondary)	(215) x	0.519	= 0
Water heating	(219) x	0.216	= 527.07
Space and water heating	(261) + (262) + (263) + (264) =		1384.97
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	= 38.93
Electricity for lighting	(232) x	0.519	= 194.3
Total CO2, kg/year		sum of (265)...(271) =	1618.19
TER =			18.12

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 009 - Be Lean			
Address :	AC 009, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	52.4 (1a)	x (2a)	= 151.96 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	52.4 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	151.96 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					0 = 0 x 10 = 0 (7a)
Number of passive vents					0 = 0 x 10 = 0 (7b)
Number of flueless gas fires					0 = 0 x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 0 ÷ (5) = 0
(8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] =

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) =

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] =

Infiltration rate incorporating shelter factor (21) = (18) x (20) =

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

DER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.11	0.11	0.1	0.09	0.09	0.08	0.08	0.08	0.08	0.09	0.1	0.1
------	------	-----	------	------	------	------	------	------	------	-----	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.21	0.21	0.22
---------	------	------	------	------	------	-----	-----	-----	------	------	------

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.21	0.21	0.22
--------	------	------	------	------	------	-----	-----	-----	------	------	------

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Doors			2.93	x 1.4 =	4.102		(26)
Windows Type 1			4.91	x1/[1/(1.4)+ 0.04] =	6.51		(27)
Windows Type 2			7.06	x1/[1/(1.4)+ 0.04] =	9.36		(27)
Windows Type 3			1.97	x1/[1/(1.4)+ 0.04] =	2.61		(27)
Floor			52.4	x 0.12 =	6.288		(28)
Walls	34.68	16.87	17.81	x 0.12 =	2.14		(29)
Total area of elements, m ²			87.08				(31)
Party wall			49.76	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[1/(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U)

(26)...(30) + (32) = 31.01 (33)

Heat capacity Cm = S(A x k)

((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K

Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K

9.49 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss

(33) + (36) = 40.5 (37)

Ventilation heat loss calculated monthly

(38)m = 0.33 x (25)m x (5)

(38)m=	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
	11.33	11.22	11.11	10.58	10.47	9.94	9.94	9.84	10.15	10.47	10.69	10.9

Heat transfer coefficient, W/K

(39)m = (37) + (38)m

(39)m=	51.83	51.72	51.62	51.08	50.98	50.44	50.44	50.34	50.66	50.98	51.19	51.4
	Average = Sum(39) _{1...12} /12=											

51.06 (39)

DER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	0.99	0.99	0.99	0.97	0.97	0.96	0.96	0.96	0.97	0.97	0.98	0.98		(40)
													Average = Sum(40) _{1...12} /12=	0.97

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		(41)	
(41)m=	31	28	31	30	31	30	31	31	30	31	30	31		

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

1.76

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)^2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd,\text{average} = (25 \times N) + 36$

76.02

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	83.62	80.58	77.54	74.5	71.46	68.42	68.42	71.46	74.5	77.54	80.58	83.62	
--------	-------	-------	-------	------	-------	-------	-------	-------	------	-------	-------	-------	--

Total = Sum(44)_{1...12} =

912.25

(44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	124.01	108.46	111.92	97.58	93.63	80.79	74.87	85.91	86.94	101.32	110.59	120.1	
--------	--------	--------	--------	-------	-------	-------	-------	-------	-------	--------	--------	-------	--

Total = Sum(45)_{1...12} =

1196.1

(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	18.6	16.27	16.79	14.64	14.04	12.12	11.23	12.89	13.04	15.2	16.59	18.01	
--------	------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	--

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0

(48)

Temperature factor from Table 2b

0

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

110

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0.02

(51)

If community heating see section 4.3

Volume factor from Table 2a

1.03

(52)

Temperature factor from Table 2b

0.6

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

1.03

(54)

Enter (50) or (54) in (55)

1.03

(55)

Water storage loss calculated for each month

((56)m = (55) x (41)m

(56)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01	
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01	
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26	
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--

DER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	179.29	158.39	167.2	151.07	148.9	134.29	130.14	141.19	140.43	156.59	164.09	175.37	(62)
--------	--------	--------	-------	--------	-------	--------	--------	--------	--------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	179.29	158.39	167.2	151.07	148.9	134.29	130.14	141.19	140.43	156.59	164.09	175.37	Output from water heater (annual) 1...12	1846.94	(64)
--------	--------	--------	-------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--	---------	------

Heat gains from water heating, kWh/month 0.25 $[0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	85.45	76	81.44	75.24	75.35	69.66	69.11	72.79	71.7	77.91	79.57	84.15	(65)
--------	-------	----	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m=	88.04	88.04	88.04	88.04	88.04	88.04	88.04	88.04	88.04	88.04	88.04	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	13.68	12.15	9.88	7.48	5.59	4.72	5.1	6.63	8.9	11.3	13.19	14.06	(67)
--------	-------	-------	------	------	------	------	-----	------	-----	------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	153.46	155.06	151.04	142.5	131.72	121.58	114.81	113.22	117.23	125.77	136.56	146.69	(68)
--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	31.8	31.8	31.8	31.8	31.8	31.8	31.8	31.8	31.8	31.8	31.8	31.8	(69)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Pumps and fans gains (Table 5a)

(70)m=	0	0	0	0	0	0	0	0	0	0	0	0	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-70.43	-70.43	-70.43	-70.43	-70.43	-70.43	-70.43	-70.43	-70.43	-70.43	-70.43	-70.43	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	114.86	113.1	109.46	104.5	101.28	96.75	92.9	97.83	99.58	104.72	110.51	113.11	(72)
--------	--------	-------	--------	-------	--------	-------	------	-------	-------	--------	--------	--------	------

Total internal gains =

$$(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$$

(73)m=	331.42	329.72	319.79	303.89	288	272.46	262.22	267.09	275.13	291.2	309.67	323.28	(73)
--------	--------	--------	--------	--------	-----	--------	--------	--------	--------	-------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)
North	0.9x	0.77	x 7.06	x 10.63	x 0.4	x 0.8 = 16.65
North	0.9x	0.77	x 1.97	x 10.63	x 0.4	x 0.8 = 4.65
North	0.9x	0.77	x 7.06	x 20.32	x 0.4	x 0.8 = 31.82
North	0.9x	0.77	x 1.97	x 20.32	x 0.4	x 0.8 = 8.88
North	0.9x	0.77	x 7.06	x 34.53	x 0.4	x 0.8 = 54.06

DER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	1.97	x	34.53	x	0.4	x	0.8	=	15.09	(74)
North	0.9x	0.77	x	7.06	x	55.46	x	0.4	x	0.8	=	86.84	(74)
North	0.9x	0.77	x	1.97	x	55.46	x	0.4	x	0.8	=	24.23	(74)
North	0.9x	0.77	x	7.06	x	74.72	x	0.4	x	0.8	=	116.98	(74)
North	0.9x	0.77	x	1.97	x	74.72	x	0.4	x	0.8	=	32.64	(74)
North	0.9x	0.77	x	7.06	x	79.99	x	0.4	x	0.8	=	125.23	(74)
North	0.9x	0.77	x	1.97	x	79.99	x	0.4	x	0.8	=	34.94	(74)
North	0.9x	0.77	x	7.06	x	74.68	x	0.4	x	0.8	=	116.92	(74)
North	0.9x	0.77	x	1.97	x	74.68	x	0.4	x	0.8	=	32.62	(74)
North	0.9x	0.77	x	7.06	x	59.25	x	0.4	x	0.8	=	92.76	(74)
North	0.9x	0.77	x	1.97	x	59.25	x	0.4	x	0.8	=	25.88	(74)
North	0.9x	0.77	x	7.06	x	41.52	x	0.4	x	0.8	=	65	(74)
North	0.9x	0.77	x	1.97	x	41.52	x	0.4	x	0.8	=	18.14	(74)
North	0.9x	0.77	x	7.06	x	24.19	x	0.4	x	0.8	=	37.87	(74)
North	0.9x	0.77	x	1.97	x	24.19	x	0.4	x	0.8	=	10.57	(74)
North	0.9x	0.77	x	7.06	x	13.12	x	0.4	x	0.8	=	20.54	(74)
North	0.9x	0.77	x	1.97	x	13.12	x	0.4	x	0.8	=	5.73	(74)
North	0.9x	0.77	x	7.06	x	8.86	x	0.4	x	0.8	=	13.88	(74)
North	0.9x	0.77	x	1.97	x	8.86	x	0.4	x	0.8	=	3.87	(74)
South	0.9x	0.77	x	4.91	x	46.75	x	0.4	x	0.8	=	50.91	(78)
South	0.9x	0.77	x	4.91	x	76.57	x	0.4	x	0.8	=	83.37	(78)
South	0.9x	0.77	x	4.91	x	97.53	x	0.4	x	0.8	=	106.2	(78)
South	0.9x	0.77	x	4.91	x	110.23	x	0.4	x	0.8	=	120.03	(78)
South	0.9x	0.77	x	4.91	x	114.87	x	0.4	x	0.8	=	125.08	(78)
South	0.9x	0.77	x	4.91	x	110.55	x	0.4	x	0.8	=	120.37	(78)
South	0.9x	0.77	x	4.91	x	108.01	x	0.4	x	0.8	=	117.61	(78)
South	0.9x	0.77	x	4.91	x	104.89	x	0.4	x	0.8	=	114.21	(78)
South	0.9x	0.77	x	4.91	x	101.89	x	0.4	x	0.8	=	110.94	(78)
South	0.9x	0.77	x	4.91	x	82.59	x	0.4	x	0.8	=	89.92	(78)
South	0.9x	0.77	x	4.91	x	55.42	x	0.4	x	0.8	=	60.34	(78)
South	0.9x	0.77	x	4.91	x	40.4	x	0.4	x	0.8	=	43.99	(78)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m=	72.2	124.06	175.35	231.09	274.69	280.54	267.15	232.85	194.07	138.36	86.61	61.74	(83)
--------	------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	-------	------

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=	403.62	453.79	495.14	534.99	562.69	553	529.37	499.95	469.2	429.56	396.28	385.01	(84)
--------	--------	--------	--------	--------	--------	-----	--------	--------	-------	--------	--------	--------	------

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m=	0.99	0.99	0.97	0.91	0.77	0.57	0.42	0.46	0.7	0.93	0.98	0.99	(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	20.14	20.29	20.5	20.75	20.92	20.99	21	21	20.97	20.75	20.41	20.11	(87)
--------	-------	-------	------	-------	-------	-------	----	----	-------	-------	-------	-------	------

DER WorkSheet: New dwelling design stage

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	20.09	20.09	20.1	20.1	20.11	20.11	20.11	20.12	20.11	20.11	20.1	20.1	(88)
--------	-------	-------	------	------	-------	-------	-------	-------	-------	-------	------	------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.99	0.98	0.96	0.88	0.72	0.5	0.33	0.37	0.63	0.9	0.98	0.99	(89)
--------	------	------	------	------	------	-----	------	------	------	-----	------	------	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.96	19.17	19.48	19.83	20.04	20.11	20.11	20.12	20.09	19.84	19.35	18.92	(90)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

$$fLA = \text{Living area} \div (4) = 0.47 \quad (91)$$

Mean internal temperature (for the whole dwelling) = $fLA \times T1 + (1 - fLA) \times T2$

(92)m=	19.52	19.7	19.96	20.26	20.46	20.52	20.53	20.53	20.5	20.27	19.85	19.48	(92)
--------	-------	------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.52	19.7	19.96	20.26	20.46	20.52	20.53	20.53	20.5	20.27	19.85	19.48	(93)
--------	-------	------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that $Ti,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	0.99	0.98	0.95	0.88	0.74	0.53	0.37	0.41	0.66	0.9	0.98	0.99	(94)
--------	------	------	------	------	------	------	------	------	------	-----	------	------	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	399.18	444.06	472.12	473.07	415.61	294.87	197.87	207.2	311.39	388.27	387.07	381.66	(95)
--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W = [(39)m x [(93)m – (96)m]

(97)m=	788.69	765.39	694.71	580.49	446.33	298.77	198.29	207.94	324.23	492.94	652.52	785.53	(97)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m – (95)m] x (41)m

(98)m=	289.8	215.94	165.61	77.34	22.86	0	0	0	77.87	191.13	300.48	
--------	-------	--------	--------	-------	-------	---	---	---	-------	--------	--------	--

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1...5,9...12} = 1341.03 \quad (98)$$

Space heating requirement in kWh/m²/year

$$25.59 \quad (99)$$

9b. Energy requirements – Community heating scheme

This part is used for space heating, space cooling or water heating provided by a community scheme.

Fraction of space heat from secondary/supplementary heating (Table 11) '0' if none

$$0 \quad (301)$$

Fraction of space heat from community system 1 – (301) =

$$1 \quad (302)$$

The community scheme may obtain heat from several sources. The procedure allows for CHP and up to four other heat sources; the latter includes boilers, heat pumps, geothermal and waste heat from power stations. See Appendix C.

Fraction of heat from Community boilers

$$1 \quad (303a)$$

Fraction of total space heat from Community boilers

$$(302) \times (303a) = 1 \quad (304a)$$

Factor for control and charging method (Table 4c(3)) for community heating system

$$1 \quad (305)$$

Distribution loss factor (Table 12c) for community heating system

$$1.1 \quad (306)$$

Space heating

Annual space heating requirement

$$1341.03$$

Space heat from Community boilers

$$(98) \times (304a) \times (305) \times (306) = 1475.13 \quad (307a)$$

Efficiency of secondary/supplementary heating system in % (from Table 4a or Appendix E)

$$0 \quad (308)$$

DER WorkSheet: New dwelling design stage

Space heating requirement from secondary/supplementary system	$(98) \times (301) \times 100 \div (308) =$	0	(309)
Water heating			
Annual water heating requirement		1846.94	
If DHW from community scheme:			
Water heat from Community boilers	$(64) \times (303a) \times (305) \times (306) =$	2031.64	(310a)
Electricity used for heat distribution	$0.01 \times [(307a) \dots (307e) + (310a) \dots (310e)] =$	35.07	(313)
Cooling System Energy Efficiency Ratio		0	(314)
Space cooling (if there is a fixed cooling system, if not enter 0)	$= (107) \div (314) =$	0	(315)
Electricity for pumps and fans within dwelling (Table 4f):			
mechanical ventilation - balanced, extract or positive input from outside		115.87	(330a)
warm air heating system fans		0	(330b)
pump for solar water heating		0	(330g)
Total electricity for the above, kWh/year	$= (330a) + (330b) + (330g) =$	115.87	(331)
Energy for lighting (calculated in Appendix L)		241.62	(332)

12b. CO2 Emissions – Community heating scheme

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
CO2 from other sources of space and water heating (not CHP)			
Efficiency of heat source 1 (%)	If there is CHP using two fuels repeat (363) to (366) for the second fuel	95	(367a)
CO2 associated with heat source 1	$[(307b)+(310b)] \times 100 \div (367b) \times$	0.22	= 797.33 (367)
Electrical energy for heat distribution	$[(313) \times$	0.52	= 18.2 (372)
Total CO2 associated with community systems	$(363) \dots (366) + (368) \dots (372)$		= 815.53 (373)
CO2 associated with space heating (secondary)	$(309) \times$	0	= 0 (374)
CO2 associated with water from immersion heater or instantaneous heater	$(312) \times$	0.22	= 0 (375)
Total CO2 associated with space and water heating	$(373) + (374) + (375) =$		815.53 (376)
CO2 associated with electricity for pumps and fans within dwelling	$(331)) \times$	0.52	= 60.14 (378)
CO2 associated with electricity for lighting	$(332)) \times$	0.52	= 125.4 (379)
Total CO2, kg/year	sum of (376)...(382) =		1001.06 (383)
Dwelling CO2 Emission Rate	$(383) \div (4) =$		19.1 (384)
EI rating (section 14)			86.23 (385)

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 009 - Be Lean			
Address :	AC 009, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	52.4 (1a)	x (2a)	= 151.96 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	52.4 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	151.96 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					2 x 10 = 20 (7a)
Number of passive vents					0 x 10 = 0 (7b)
Number of flueless gas fires					0 x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 20 ÷ (5) = 0.13 (8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] = 0

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) = 0

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] = 0.85

Infiltration rate incorporating shelter factor (21) = (18) x (20) = 0.32

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

TER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.41	0.41	0.4	0.36	0.35	0.31	0.31	0.3	0.32	0.35	0.36	0.38
------	------	-----	------	------	------	------	-----	------	------	------	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0.59	0.58	0.58	0.56	0.56	0.55	0.55	0.55	0.56	0.57	0.57
---------	------	------	------	------	------	------	------	------	------	------	------

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.59	0.58	0.58	0.56	0.56	0.55	0.55	0.55	0.56	0.57	0.57
--------	------	------	------	------	------	------	------	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Doors			2.93	x 1.2 =	3.516		
Windows Type 1			3.58	x1/[1/(1.4)+ 0.04] =	4.75		
Windows Type 2			5.15	x1/[1/(1.4)+ 0.04] =	6.83		
Windows Type 3			1.44	x1/[1/(1.4)+ 0.04] =	1.91		
Floor			52.4	x 0.13 =	6.812		
Walls	34.68	13.1	21.58	x 0.18 =	3.89		
Total area of elements, m ²			87.08				
Party wall			49.76	x 0 =	0		

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U)

(26)...(30) + (32) = 27.7 (33)

Heat capacity Cm = S(A x k)

((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K

Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K

6.43 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss

(33) + (36) = 34.13 (37)

Ventilation heat loss calculated monthly

(38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	29.36	29.2	29.03	28.27	28.12	27.45	27.45	27.33	27.71	28.12	28.41	28.72

(38)

Heat transfer coefficient, W/K

(39)m = (37) + (38)m

(39)m=	63.49	63.32	63.16	62.39	62.25	61.58	61.58	61.46	61.84	62.25	62.54	62.84
Average = Sum(39) _{1...12} /12=												62.39 (39)

TER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	1.21	1.21	1.21	1.19	1.19	1.18	1.18	1.17	1.18	1.19	1.19	1.2	Average = Sum(40) _{1...12} /12=	1.19	(40)
--------	------	------	------	------	------	------	------	------	------	------	------	-----	--	------	------

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(41)m=	31	28	31	30	31	30	31	30	31	30	31	(41)
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	--------	----	----	----	----	----	----	----	----	----	----	----	------

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

1.76

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

76.02

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	83.62	80.58	77.54	74.5	71.46	68.42	68.42	71.46	74.5	77.54	80.58	83.62	Total = Sum(44) _{1...12} =	912.25	(44)
--------	-------	-------	-------	------	-------	-------	-------	-------	------	-------	-------	-------	-------------------------------------	--------	------

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	124.01	108.46	111.92	97.58	93.63	80.79	74.87	85.91	86.94	101.32	110.59	120.1	Total = Sum(45) _{1...12} =	1196.1	(45)
--------	--------	--------	--------	-------	-------	-------	-------	-------	-------	--------	--------	-------	-------------------------------------	--------	------

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	18.6	16.27	16.79	14.64	14.04	12.12	11.23	12.89	13.04	15.2	16.59	18.01	(46)
--------	------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

150

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

1.39

(48)

Temperature factor from Table 2b

0.54

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

0.75

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0

(51)

If community heating see section 4.3

Volume factor from Table 2a

0

(52)

Temperature factor from Table 2b

0

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

0

(54)

Enter (50) or (54) in (55)

0.75

(55)

Water storage loss calculated for each month

((56)m = (55) x (41)m)

(56)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	(56)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	(57)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26	(59)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

TER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	170.61	150.55	158.52	142.67	140.22	125.88	121.46	132.5	132.03	147.91	155.69	166.69	(62)
--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	170.61	150.55	158.52	142.67	140.22	125.88	121.46	132.5	132.03	147.91	155.69	166.69	Output from water heater (annual) 1...12	1744.72	(64)
--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--	---------	------

Heat gains from water heating, kWh/month 0.25 $[0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	78.51	69.73	74.49	68.52	68.41	62.94	62.17	65.84	64.98	70.96	72.85	77.21	(65)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(66)m=	88.04	88.04	88.04	88.04	88.04	88.04	88.04	88.04	88.04	88.04	88.04	88.04

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	13.68	12.15	9.88	7.48	5.59	4.72	5.1	6.63	8.9	11.3	13.19	14.06	(67)
--------	-------	-------	------	------	------	------	-----	------	-----	------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	153.46	155.06	151.04	142.5	131.72	121.58	114.81	113.22	117.23	125.77	136.56	146.69	(68)
--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	31.8	31.8	31.8	31.8	31.8	31.8	31.8	31.8	31.8	31.8	31.8	31.8	(69)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Pumps and fans gains (Table 5a)

(70)m=	3	3	3	3	3	3	3	3	3	3	3	3	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-70.43	-70.43	-70.43	-70.43	-70.43	-70.43	-70.43	-70.43	-70.43	-70.43	-70.43	-70.43	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	105.52	103.77	100.12	95.16	91.94	87.41	83.56	88.5	90.25	95.38	101.17	103.77	(72)
--------	--------	--------	--------	-------	-------	-------	-------	------	-------	-------	--------	--------	------

Total internal gains = $(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$

(73)m=	325.08	323.39	313.46	297.56	281.67	266.13	255.88	260.76	268.79	284.87	303.33	316.94	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)
North	0.9x	0.77	x 5.15	x 10.63	x 0.63	= 16.74
North	0.9x	0.77	x 1.44	x 10.63	x 0.63	= 4.68
North	0.9x	0.77	x 5.15	x 20.32	x 0.63	= 31.98
North	0.9x	0.77	x 1.44	x 20.32	x 0.63	= 8.94
North	0.9x	0.77	x 5.15	x 34.53	x 0.63	= 54.35

TER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	1.44	x	34.53	x	0.63	x	0.7	=	15.2	(74)
North	0.9x	0.77	x	5.15	x	55.46	x	0.63	x	0.7	=	87.3	(74)
North	0.9x	0.77	x	1.44	x	55.46	x	0.63	x	0.7	=	24.41	(74)
North	0.9x	0.77	x	5.15	x	74.72	x	0.63	x	0.7	=	117.6	(74)
North	0.9x	0.77	x	1.44	x	74.72	x	0.63	x	0.7	=	32.88	(74)
North	0.9x	0.77	x	5.15	x	79.99	x	0.63	x	0.7	=	125.89	(74)
North	0.9x	0.77	x	1.44	x	79.99	x	0.63	x	0.7	=	35.2	(74)
North	0.9x	0.77	x	5.15	x	74.68	x	0.63	x	0.7	=	117.53	(74)
North	0.9x	0.77	x	1.44	x	74.68	x	0.63	x	0.7	=	32.86	(74)
North	0.9x	0.77	x	5.15	x	59.25	x	0.63	x	0.7	=	93.25	(74)
North	0.9x	0.77	x	1.44	x	59.25	x	0.63	x	0.7	=	26.07	(74)
North	0.9x	0.77	x	5.15	x	41.52	x	0.63	x	0.7	=	65.34	(74)
North	0.9x	0.77	x	1.44	x	41.52	x	0.63	x	0.7	=	18.27	(74)
North	0.9x	0.77	x	5.15	x	24.19	x	0.63	x	0.7	=	38.07	(74)
North	0.9x	0.77	x	1.44	x	24.19	x	0.63	x	0.7	=	10.65	(74)
North	0.9x	0.77	x	5.15	x	13.12	x	0.63	x	0.7	=	20.65	(74)
North	0.9x	0.77	x	1.44	x	13.12	x	0.63	x	0.7	=	5.77	(74)
North	0.9x	0.77	x	5.15	x	8.86	x	0.63	x	0.7	=	13.95	(74)
North	0.9x	0.77	x	1.44	x	8.86	x	0.63	x	0.7	=	3.9	(74)
South	0.9x	0.77	x	3.58	x	46.75	x	0.63	x	0.7	=	51.15	(78)
South	0.9x	0.77	x	3.58	x	76.57	x	0.63	x	0.7	=	83.77	(78)
South	0.9x	0.77	x	3.58	x	97.53	x	0.63	x	0.7	=	106.71	(78)
South	0.9x	0.77	x	3.58	x	110.23	x	0.63	x	0.7	=	120.61	(78)
South	0.9x	0.77	x	3.58	x	114.87	x	0.63	x	0.7	=	125.68	(78)
South	0.9x	0.77	x	3.58	x	110.55	x	0.63	x	0.7	=	120.95	(78)
South	0.9x	0.77	x	3.58	x	108.01	x	0.63	x	0.7	=	118.18	(78)
South	0.9x	0.77	x	3.58	x	104.89	x	0.63	x	0.7	=	114.76	(78)
South	0.9x	0.77	x	3.58	x	101.89	x	0.63	x	0.7	=	111.47	(78)
South	0.9x	0.77	x	3.58	x	82.59	x	0.63	x	0.7	=	90.36	(78)
South	0.9x	0.77	x	3.58	x	55.42	x	0.63	x	0.7	=	60.63	(78)
South	0.9x	0.77	x	3.58	x	40.4	x	0.63	x	0.7	=	44.2	(78)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m=

72.57	124.7	176.25	232.31	276.16	282.04	268.57	234.09	195.09	139.07	87.05	62.05
-------	-------	--------	--------	--------	--------	--------	--------	--------	--------	-------	-------

 (83)

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=

397.65	448.09	489.71	529.87	557.82	548.17	524.46	494.84	463.88	423.94	390.38	378.99
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		(86)m=
0.99	0.99	0.98	0.94	0.85	0.67	0.51	0.56	0.79	0.95	0.99	1		

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=

19.82	19.98	20.22	20.54	20.81	20.95	20.99	20.99	20.9	20.57	20.14	19.79
-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------

 (87)

TER WorkSheet: New dwelling design stage

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	19.91	19.91	19.92	19.93	19.93	19.94	19.94	19.94	19.94	19.93	19.93	19.92	(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.99	0.99	0.97	0.92	0.79	0.58	0.39	0.44	0.71	0.93	0.98	0.99	(89)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.36	18.59	18.95	19.4	19.75	19.91	19.94	19.94	19.86	19.45	18.84	18.33	(90)
--------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	------

$$fLA = \text{Living area} \div (4) = 0.47 \quad (91)$$

Mean internal temperature (for the whole dwelling) = $fLA \times T1 + (1 - fLA) \times T2$

(92)m=	19.05	19.25	19.55	19.94	20.25	20.4	20.43	20.43	20.35	19.97	19.45	19.02	(92)
--------	-------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.05	19.25	19.55	19.94	20.25	20.4	20.43	20.43	20.35	19.97	19.45	19.02	(93)
--------	-------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set T_i to the mean internal temperature obtained at step 11 of Table 9b, so that $T_{i,m} = (76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	0.99	0.98	0.97	0.92	0.81	0.62	0.45	0.49	0.75	0.93	0.98	0.99	(94)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	393.94	440.49	472.92	486.76	451.98	341.05	233.54	243.64	346.66	395.34	383.34	376.14	(95)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W = [(39)m x [(93)m - (96)m]

(97)m=	936.5	908.38	824.17	688.83	532.11	357.37	236.08	247.74	386.33	583.52	772.48	931.39	(97)
--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m - (95)m] x (41)m

(98)m=	403.67	314.42	261.33	145.49	59.62	0	0	0	0	140	280.17	413.11	(98)
--------	--------	--------	--------	--------	-------	---	---	---	---	-----	--------	--------	------

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1...5,9...12} = 2017.82 \quad (98)$$

Space heating requirement in kWh/m²/year

$$38.51 \quad (99)$$

9a. Energy requirements – Individual heating systems including micro-CHP)

Space heating:

Fraction of space heat from secondary/supplementary system

$$0 \quad (201)$$

Fraction of space heat from main system(s)

$$(202) = 1 - (201) = 1 \quad (202)$$

Fraction of total heating from main system 1

$$(204) = (202) \times [1 - (203)] = 1 \quad (204)$$

Efficiency of main space heating system 1

$$93.5 \quad (206)$$

Efficiency of secondary/supplementary heating system, %

$$0 \quad (208)$$

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

403.67	314.42	261.33	145.49	59.62	0	0	0	0	140	280.17	413.11
--------	--------	--------	--------	-------	---	---	---	---	-----	--------	--------

$$(211)m = \{(98)m \times (204)\} \times 100 \div (206) \quad (211)$$

431.73	336.28	279.5	155.61	63.77	0	0	0	0	149.74	299.65	441.83
--------	--------	-------	--------	-------	---	---	---	---	--------	--------	--------

$$\text{Total (kWh/year)} = \text{Sum}(211)_{1...5,10...12} = 2158.1 \quad (211)$$

Space heating fuel (secondary), kWh/month

$$= \{(98)m \times (201)\} \times 100 \div (208) \quad (215)$$

(215)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

$$\text{Total (kWh/year)} = \text{Sum}(215)_{1...5,10...12} = 0 \quad (215)$$

TER WorkSheet: New dwelling design stage

Water heating

Output from water heater (calculated above)

170.61	150.55	158.52	142.67	140.22	125.88	121.46	132.5	132.03	147.91	155.69	166.69
--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------

Efficiency of water heater

79.8

(216)

(217)m=

87.03	86.73	86.14	84.87	82.72	79.8	79.8	79.8	84.67	86.36	87.14
-------	-------	-------	-------	-------	------	------	------	-------	-------	-------

(217)

Fuel for water heating, kWh/month

(219)m = $(64)m \times 100 \div (217)m$

(219)m=

196.02	173.57	184.02	168.11	169.52	157.75	152.21	166.05	165.45	174.69	180.27	191.29
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

Total = Sum(219a)_{1...12} =

2078.94

(219)

Annual totals

Space heating fuel used, main system 1

kWh/year

2158.1

Water heating fuel used

kWh/year

2078.94

Electricity for pumps, fans and electric keep-hot

central heating pump:

30

(230c)

boiler with a fan-assisted flue

45

(230e)

Total electricity for the above, kWh/year

sum of (230a)...(230g) =

75

(231)

Electricity for lighting

241.62

(232)

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating (main system 1)	(211) x	0.216	= 466.15
Space heating (secondary)	(215) x	0.519	= 0
Water heating	(219) x	0.216	= 449.05
Space and water heating	(261) + (262) + (263) + (264) =		915.2
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	= 38.93
Electricity for lighting	(232) x	0.519	= 125.4
Total CO2, kg/year		sum of (265)...(271) =	1079.53

TER =

20.6

(273)

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 010 - Be Lean			
Address :	AC 010, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	78.1 (1a)	x (2a)	= 226.49 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	78.1 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	226.49 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					0 = 0 x 10 = 0 (7a)
Number of passive vents					0 = 0 x 10 = 0 (7b)
Number of flueless gas fires					0 = 0 x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 0 ÷ (5) = 0
(8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] =

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) =

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] =

Infiltration rate incorporating shelter factor (21) = (18) x (20) =

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

DER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.11	0.11	0.1	0.09	0.09	0.08	0.08	0.08	0.08	0.09	0.1	0.1
------	------	-----	------	------	------	------	------	------	------	-----	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5

(23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5

(23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5

(23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.21	0.21	0.22
---------	------	------	------	------	------	-----	-----	-----	------	------	------

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.21	0.21	0.22
--------	------	------	------	------	------	-----	-----	-----	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Doors			2.93	x 1.4 =	4.102		
Windows Type 1			2.69	x1/[1/(1.4)+ 0.04] =	3.57		
Windows Type 2			4.91	x1/[1/(1.4)+ 0.04] =	6.51		
Windows Type 3			7.06	x1/[1/(1.4)+ 0.04] =	9.36		
Windows Type 4			2.69	x1/[1/(1.4)+ 0.04] =	3.57		
Windows Type 5			2.01	x1/[1/(1.4)+ 0.04] =	2.66		
Floor			78.1	x 0.12 =	9.372		
Walls	51.79	22.29	29.5	x 0.12 =	3.54		
Total area of elements, m ²			129.89				
Party wall			49.76	x 0 =	0		

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 42.68 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34))

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 12.18 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 54.86 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

DER WorkSheet: New dwelling design stage

(38)m=	16.88	16.72	16.56	15.77	15.61	14.82	14.82	14.66	15.14	15.61	15.93	16.25	(38)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Heat transfer coefficient, W/K $(39)m = (37) + (38)m$

(39)m=	71.74	71.58	71.42	70.63	70.47	69.68	69.68	69.52	69.99	70.47	70.79	71.11	Average = Sum(39) _{1...12} / 12 = 70.59 (39)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	---

Heat loss parameter (HLP), W/m²K $(40)m = (39)m \div (4)$

(40)m=	0.92	0.92	0.91	0.9	0.9	0.89	0.89	0.89	0.9	0.9	0.91	0.91	Average = Sum(40) _{1...12} / 12 = 0.9 (40)
--------	------	------	------	-----	-----	------	------	------	-----	-----	------	------	---

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(41)
31	28	31	30	31	30	31	31	30	31	30	31	

4. Water heating energy requirement: kWh/year:

Assumed occupancy, N 2.43 (42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)^2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$ 91.81 (43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	--

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	100.99	97.32	93.65	89.98	86.3	82.63	82.63	86.3	89.98	93.65	97.32	100.99	Total = Sum(44) _{1...12} = 1101.76 (44)
--------	--------	-------	-------	-------	------	-------	-------	------	-------	-------	-------	--------	--

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	149.77	130.99	135.17	117.85	113.08	97.58	90.42	103.76	105	122.36	133.57	145.05	Total = Sum(45) _{1...12} = 1444.58 (45)
--------	--------	--------	--------	--------	--------	-------	-------	--------	-----	--------	--------	--------	--

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	22.47	19.65	20.28	17.68	16.96	14.64	13.56	15.56	15.75	18.35	20.04	21.76	(46)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel 0 (47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day): 0 (48)

Temperature factor from Table 2b 0 (49)

Energy lost from water storage, kWh/year (48) x (49) = 110 (50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day) 0.02 (51)

If community heating see section 4.3

Volume factor from Table 2a 1.03 (52)

Temperature factor from Table 2b 0.6 (53)

Energy lost from water storage, kWh/year (47) x (51) x (52) x (53) = 1.03 (54)

Enter (50) or (54) in (55)

Water storage loss calculated for each month ((56)m = (55) x (41)m)

(56)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01	(56)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01	(57)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

DER WorkSheet: New dwelling design stage

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month (59)m = (58) ÷ 365 × (41)m

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(59)

Combi loss calculated for each month (61)m = (60) ÷ 365 × (41)m

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0
--------	---	---	---	---	---	---	---	---	---	---	---	---

(61)

Total heat required for water heating calculated for each month (62)m = 0.85 × (45)m + (46)m + (57)m + (59)m + (61)m

(62)m=	205.05	180.92	190.45	171.34	168.35	151.07	145.7	159.03	158.49	177.64	187.06	200.32
--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------

(62)

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRS applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0
--------	---	---	---	---	---	---	---	---	---	---	---	---

(63)

Output from water heater

(64)m=	205.05	180.92	190.45	171.34	168.35	151.07	145.7	159.03	158.49	177.64	187.06	200.32
Output from water heater (annual) _{1...12}											2095.42	(64)

Heat gains from water heating, kWh/month 0.25 [0.85 × (45)m + (61)m] + 0.8 × [(46)m + (57)m + (59)m]

(65)m=	94.02	83.5	89.17	81.98	81.82	75.24	74.29	78.72	77.71	84.91	87.21	92.45
--------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(65)

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(66)m=	121.29	121.29	121.29	121.29	121.29	121.29	121.29	121.29	121.29	121.29	121.29

(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	19.21	17.06	13.87	10.5	7.85	6.63	7.16	9.31	12.49	15.86	18.52	19.74
--------	-------	-------	-------	------	------	------	------	------	-------	-------	-------	-------

(67)

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	215.42	217.66	212.03	200.03	184.9	170.67	161.16	158.93	164.56	176.55	191.69	205.92
--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------

(68)

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	35.13	35.13	35.13	35.13	35.13	35.13	35.13	35.13	35.13	35.13	35.13	35.13
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(69)

Pumps and fans gains (Table 5a)

(70)m=	0	0	0	0	0	0	0	0	0	0	0	0
--------	---	---	---	---	---	---	---	---	---	---	---	---

(70)

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-97.03	-97.03	-97.03	-97.03	-97.03	-97.03	-97.03	-97.03	-97.03	-97.03	-97.03	-97.03
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

(71)

Water heating gains (Table 5)

(72)m=	126.37	124.25	119.85	113.86	109.97	104.5	99.85	105.81	107.92	114.12	121.12	124.26
--------	--------	--------	--------	--------	--------	-------	-------	--------	--------	--------	--------	--------

(72)

Total internal gains = (66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m

(73)m=	420.39	418.36	405.13	383.78	362.11	341.18	327.56	333.43	344.37	365.93	390.71	409.3
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------

(73)

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)
North	0.9x	0.77	x 7.06	x 10.63	x 0.4	x 0.8 = 16.65
North	0.9x	0.77	x 2.69	x 10.63	x 0.4	x 0.8 = 6.34

DER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	2.01	x	10.63	x	0.4	x	0.8	=	4.74	(74)
North	0.9x	0.77	x	7.06	x	20.32	x	0.4	x	0.8	=	31.82	(74)
North	0.9x	0.77	x	2.69	x	20.32	x	0.4	x	0.8	=	12.12	(74)
North	0.9x	0.77	x	2.01	x	20.32	x	0.4	x	0.8	=	9.06	(74)
North	0.9x	0.77	x	7.06	x	34.53	x	0.4	x	0.8	=	54.06	(74)
North	0.9x	0.77	x	2.69	x	34.53	x	0.4	x	0.8	=	20.6	(74)
North	0.9x	0.77	x	2.01	x	34.53	x	0.4	x	0.8	=	15.39	(74)
North	0.9x	0.77	x	7.06	x	55.46	x	0.4	x	0.8	=	86.84	(74)
North	0.9x	0.77	x	2.69	x	55.46	x	0.4	x	0.8	=	33.09	(74)
North	0.9x	0.77	x	2.01	x	55.46	x	0.4	x	0.8	=	24.72	(74)
North	0.9x	0.77	x	7.06	x	74.72	x	0.4	x	0.8	=	116.98	(74)
North	0.9x	0.77	x	2.69	x	74.72	x	0.4	x	0.8	=	44.57	(74)
North	0.9x	0.77	x	2.01	x	74.72	x	0.4	x	0.8	=	33.3	(74)
North	0.9x	0.77	x	7.06	x	79.99	x	0.4	x	0.8	=	125.23	(74)
North	0.9x	0.77	x	2.69	x	79.99	x	0.4	x	0.8	=	47.71	(74)
North	0.9x	0.77	x	2.01	x	79.99	x	0.4	x	0.8	=	35.65	(74)
North	0.9x	0.77	x	7.06	x	74.68	x	0.4	x	0.8	=	116.92	(74)
North	0.9x	0.77	x	2.69	x	74.68	x	0.4	x	0.8	=	44.55	(74)
North	0.9x	0.77	x	2.01	x	74.68	x	0.4	x	0.8	=	33.29	(74)
North	0.9x	0.77	x	7.06	x	59.25	x	0.4	x	0.8	=	92.76	(74)
North	0.9x	0.77	x	2.69	x	59.25	x	0.4	x	0.8	=	35.34	(74)
North	0.9x	0.77	x	2.01	x	59.25	x	0.4	x	0.8	=	26.41	(74)
North	0.9x	0.77	x	7.06	x	41.52	x	0.4	x	0.8	=	65	(74)
North	0.9x	0.77	x	2.69	x	41.52	x	0.4	x	0.8	=	24.77	(74)
North	0.9x	0.77	x	2.01	x	41.52	x	0.4	x	0.8	=	18.51	(74)
North	0.9x	0.77	x	7.06	x	24.19	x	0.4	x	0.8	=	37.87	(74)
North	0.9x	0.77	x	2.69	x	24.19	x	0.4	x	0.8	=	14.43	(74)
North	0.9x	0.77	x	2.01	x	24.19	x	0.4	x	0.8	=	10.78	(74)
North	0.9x	0.77	x	7.06	x	13.12	x	0.4	x	0.8	=	20.54	(74)
North	0.9x	0.77	x	2.69	x	13.12	x	0.4	x	0.8	=	7.83	(74)
North	0.9x	0.77	x	2.01	x	13.12	x	0.4	x	0.8	=	5.85	(74)
North	0.9x	0.77	x	7.06	x	8.86	x	0.4	x	0.8	=	13.88	(74)
North	0.9x	0.77	x	2.69	x	8.86	x	0.4	x	0.8	=	5.29	(74)
North	0.9x	0.77	x	2.01	x	8.86	x	0.4	x	0.8	=	3.95	(74)
South	0.9x	0.77	x	2.69	x	46.75	x	0.4	x	0.8	=	27.89	(78)
South	0.9x	0.77	x	4.91	x	46.75	x	0.4	x	0.8	=	50.91	(78)
South	0.9x	0.77	x	2.69	x	76.57	x	0.4	x	0.8	=	45.68	(78)
South	0.9x	0.77	x	4.91	x	76.57	x	0.4	x	0.8	=	83.37	(78)
South	0.9x	0.77	x	2.69	x	97.53	x	0.4	x	0.8	=	58.18	(78)
South	0.9x	0.77	x	4.91	x	97.53	x	0.4	x	0.8	=	106.2	(78)
South	0.9x	0.77	x	2.69	x	110.23	x	0.4	x	0.8	=	65.76	(78)

DER WorkSheet: New dwelling design stage

South	0.9x	0.77	x	4.91	x	110.23	x	0.4	x	0.8	=	120.03	(78)
South	0.9x	0.77	x	2.69	x	114.87	x	0.4	x	0.8	=	68.52	(78)
South	0.9x	0.77	x	4.91	x	114.87	x	0.4	x	0.8	=	125.08	(78)
South	0.9x	0.77	x	2.69	x	110.55	x	0.4	x	0.8	=	65.95	(78)
South	0.9x	0.77	x	4.91	x	110.55	x	0.4	x	0.8	=	120.37	(78)
South	0.9x	0.77	x	2.69	x	108.01	x	0.4	x	0.8	=	64.43	(78)
South	0.9x	0.77	x	4.91	x	108.01	x	0.4	x	0.8	=	117.61	(78)
South	0.9x	0.77	x	2.69	x	104.89	x	0.4	x	0.8	=	62.57	(78)
South	0.9x	0.77	x	4.91	x	104.89	x	0.4	x	0.8	=	114.21	(78)
South	0.9x	0.77	x	2.69	x	101.89	x	0.4	x	0.8	=	60.78	(78)
South	0.9x	0.77	x	4.91	x	101.89	x	0.4	x	0.8	=	110.94	(78)
South	0.9x	0.77	x	2.69	x	82.59	x	0.4	x	0.8	=	49.27	(78)
South	0.9x	0.77	x	4.91	x	82.59	x	0.4	x	0.8	=	89.92	(78)
South	0.9x	0.77	x	2.69	x	55.42	x	0.4	x	0.8	=	33.06	(78)
South	0.9x	0.77	x	4.91	x	55.42	x	0.4	x	0.8	=	60.34	(78)
South	0.9x	0.77	x	2.69	x	40.4	x	0.4	x	0.8	=	24.1	(78)
South	0.9x	0.77	x	4.91	x	40.4	x	0.4	x	0.8	=	43.99	(78)

Solar gains in watts, calculated for each month

(83)m = Sum(74)m ... (82)m

(83)m=	106.53	182.04	254.43	330.43	388.45	394.91	376.79	331.3	279.99	202.27	127.61	91.2	(83)
--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	------	------

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=	526.91	600.4	659.57	714.21	750.56	736.09	704.35	664.73	624.35	568.2	518.32	500.51	(84)
--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	------

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m=	1	0.99	0.98	0.92	0.8	0.59	0.43	0.48	0.73	0.94	0.99	1	(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	20.15	20.3	20.51	20.75	20.93	20.99	21	21	20.97	20.75	20.41	20.13	(87)
--------	-------	------	-------	-------	-------	-------	----	----	-------	-------	-------	-------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	20.15	20.15	20.16	20.16	20.17	20.17	20.17	20.18	20.17	20.17	20.16	20.16	(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.99	0.99	0.97	0.9	0.75	0.52	0.35	0.39	0.66	0.92	0.99	1	(89)
--------	------	------	------	-----	------	------	------	------	------	------	------	---	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	19.02	19.24	19.54	19.88	20.1	20.17	20.17	20.17	20.15	19.89	19.4	18.99	(90)
--------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	------	-------	------

fLA = Living area ÷ (4) =

0.35

(91)

Mean internal temperature (for the whole dwelling) = fLA × T1 + (1 – fLA) × T2

(92)m=	19.43	19.61	19.88	20.19	20.39	20.46	20.47	20.47	20.44	20.19	19.76	19.39	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.43	19.61	19.88	20.19	20.39	20.46	20.47	20.47	20.44	20.19	19.76	19.39	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that $Ti,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

DER WorkSheet: New dwelling design stage

Utilisation factor for gains, hm:

(94)m=	0.99	0.99	0.96	0.9	0.76	0.55	0.38	0.42	0.68	0.92	0.98	1	(94)
--------	------	------	------	-----	------	------	------	------	------	------	------	---	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	523.44	591.62	636.28	644.43	570.14	403.44	268.96	281.9	426.46	524.26	510.44	498.01	(95)
--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W =[(39)m x [(93)m– (96)m]

(97)m=	1085.11	1053.19	955.63	797.61	612.47	408.25	269.39	282.71	443.54	676.14	896.03	1080.15	(97)
--------	---------	---------	--------	--------	--------	--------	--------	--------	--------	--------	--------	---------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m – (95)m] x (41)m

(98)m=	417.88	310.18	237.59	110.29	31.49	0	0	0	0	113	277.62	433.11	
--------	--------	--------	--------	--------	-------	---	---	---	---	-----	--------	--------	--

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1..5,9..12} = 1931.16 \quad (98)$$

Space heating requirement in kWh/m²/year

$$24.73 \quad (99)$$

9b. Energy requirements – Community heating scheme

This part is used for space heating, space cooling or water heating provided by a community scheme.

Fraction of space heat from secondary/supplementary heating (Table 11) '0' if none

$$0 \quad (301)$$

Fraction of space heat from community system 1 – (301) =

$$1 \quad (302)$$

The community scheme may obtain heat from several sources. The procedure allows for CHP and up to four other heat sources; the latter includes boilers, heat pumps, geothermal and waste heat from power stations. See Appendix C.

Fraction of heat from Community boilers

$$1 \quad (303a)$$

Fraction of total space heat from Community boilers

$$(302) \times (303a) = 1 \quad (304a)$$

Factor for control and charging method (Table 4c(3)) for community heating system

$$1 \quad (305)$$

Distribution loss factor (Table 12c) for community heating system

$$1.1 \quad (306)$$

Space heating

Annual space heating requirement

$$1931.16$$

Space heat from Community boilers

$$(98) \times (304a) \times (305) \times (306) = 2124.28 \quad (307a)$$

Efficiency of secondary/supplementary heating system in % (from Table 4a or Appendix E)

$$0 \quad (308)$$

Space heating requirement from secondary/supplementary system

$$(98) \times (301) \times 100 \div (308) = 0 \quad (309)$$

Water heating

Annual water heating requirement

$$2095.42$$

If DHW from community scheme:

Water heat from Community boilers

$$(64) \times (303a) \times (305) \times (306) = 2304.96 \quad (310a)$$

Electricity used for heat distribution

$$0.01 \times [(307a) \dots (307e) + (310a) \dots (310e)] = 44.29 \quad (313)$$

Cooling System Energy Efficiency Ratio

$$0 \quad (314)$$

Space cooling (if there is a fixed cooling system, if not enter 0)

$$= (107) \div (314) = 0 \quad (315)$$

Electricity for pumps and fans within dwelling (Table 4f):

mechanical ventilation - balanced, extract or positive input from outside

$$172.7 \quad (330a)$$

warm air heating system fans

$$0 \quad (330b)$$

pump for solar water heating

$$0 \quad (330g)$$

Total electricity for the above, kWh/year

$$=(330a) + (330b) + (330g) = 172.7 \quad (331)$$

DER WorkSheet: New dwelling design stage

Energy for lighting (calculated in Appendix L)

339.17

(332)

12b. CO2 Emissions – Community heating scheme

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
CO2 from other sources of space and water heating (not CHP) Efficiency of heat source 1 (%)	If there is CHP using two fuels repeat (363) to (366) for the second fuel	95	(367a)
CO2 associated with heat source 1	$[(307b)+(310b)] \times 100 \div (367b) \times$	0.22	= 1007.07 (367)
Electrical energy for heat distribution	$[(313) \times$	0.52	= 22.99 (372)
Total CO2 associated with community systems	$(363)\dots(366) + (368)\dots(372)$		= 1030.06 (373)
CO2 associated with space heating (secondary)	$(309) \times$	0	= 0 (374)
CO2 associated with water from immersion heater or instantaneous heater	$(312) \times$	0.22	= 0 (375)
Total CO2 associated with space and water heating	$(373) + (374) + (375) =$		1030.06 (376)
CO2 associated with electricity for pumps and fans within dwelling	$(331) \times$	0.52	= 89.63 (378)
CO2 associated with electricity for lighting	$(332)) \times$	0.52	= 176.03 (379)
Total CO2, kg/year	sum of (376)...(382) =		1295.72 (383)
Dwelling CO2 Emission Rate	$(383) \div (4) =$		16.59 (384)
EI rating (section 14)			85.9 (385)

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 010 - Be Lean			
Address :	AC 010, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	78.1 (1a)	x (2a)	= 226.49 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	78.1 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	226.49 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					3 x 10 = 30 (7a)
Number of passive vents					0 x 10 = 0 (7b)
Number of flueless gas fires					0 x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =	30	÷ (5) = 0.13 (8)
If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)		
Number of storeys in the dwelling (ns)	0	(9)
Additional infiltration	0	[(9)-1]x0.1 = 0 (10)
Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction	0	0 (11)

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0	0 (12)
If no draught lobby, enter 0.05, else enter 0	0 (13)
Percentage of windows and doors draught stripped	0 (14)
Window infiltration	0.25 - [0.2 x (14) ÷ 100] = 0 (15)
Infiltration rate	(8) + (10) + (11) + (12) + (13) + (15) = 0 (16)
Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area	5 (17)
If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)	0.38 (18)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered	2 (19)
Shelter factor	(20) = 1 - [0.075 x (19)] = 0.85 (20)
Infiltration rate incorporating shelter factor	(21) = (18) x (20) = 0.33 (21)

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

TER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.41	0.41	0.4	0.36	0.35	0.31	0.31	0.3	0.33	0.35	0.37	0.38
------	------	-----	------	------	------	------	-----	------	------	------	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0.59	0.58	0.58	0.56	0.56	0.55	0.55	0.55	0.56	0.57	0.57
---------	------	------	------	------	------	------	------	------	------	------	------

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.59	0.58	0.58	0.56	0.56	0.55	0.55	0.55	0.56	0.57	0.57
--------	------	------	------	------	------	------	------	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K	
Doors			2.93	x 1.2 =	3.516			(26)
Windows Type 1			2.31	x1/[1/(1.4)+ 0.04] =	3.06			(27)
Windows Type 2			4.21	x1/[1/(1.4)+ 0.04] =	5.58			(27)
Windows Type 3			6.05	x1/[1/(1.4)+ 0.04] =	8.02			(27)
Windows Type 4			2.31	x1/[1/(1.4)+ 0.04] =	3.06			(27)
Windows Type 5			1.72	x1/[1/(1.4)+ 0.04] =	2.28			(27)
Floor			78.1	x 0.13 =	10.153			(28)
Walls	51.79	19.53	32.26	x 0.18 =	5.81			(29)
Total area of elements, m ²			129.89					(31)
Party wall			49.76	x 0 =	0			(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 41.48 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34))

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 8.46 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 49.94 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

TER WorkSheet: New dwelling design stage

(38)m=	43.79	43.54	43.3	42.15	41.93	40.94	40.94	40.75	41.32	41.93	42.37	42.82	(38)
--------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Heat transfer coefficient, W/K $(39)m = (37) + (38)m$

(39)m=	93.73	93.48	93.24	92.09	91.88	90.88	90.88	90.69	91.26	91.88	92.31	92.77	Average = Sum(39) _{1...12} / 12 = 92.09 (39)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	---

Heat loss parameter (HLP), W/m²K $(40)m = (39)m \div (4)$

(40)m=	1.2	1.2	1.19	1.18	1.18	1.16	1.16	1.16	1.17	1.18	1.18	1.19	Average = Sum(40) _{1...12} / 12 = 1.18 (40)
--------	-----	-----	------	------	------	------	------	------	------	------	------	------	--

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(41)
31	28	31	30	31	30	31	31	30	31	30	31	

4. Water heating energy requirement: kWh/year:

Assumed occupancy, N 2.43 (42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)^2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$ 91.81 (43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	100.99	97.32	93.65	89.98	86.3	82.63	82.63	86.3	89.98	93.65	97.32	100.99	Total = Sum(44) _{1...12} = 1101.76 (44)
--------	--------	-------	-------	-------	------	-------	-------	------	-------	-------	-------	--------	--

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	149.77	130.99	135.17	117.85	113.08	97.58	90.42	103.76	105	122.36	133.57	145.05	Total = Sum(45) _{1...12} = 1444.58 (45)
--------	--------	--------	--------	--------	--------	-------	-------	--------	-----	--------	--------	--------	--

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	22.47	19.65	20.28	17.68	16.96	14.64	13.56	15.56	15.75	18.35	20.04	21.76
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel 150 (47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day): 1.39 (48)

Temperature factor from Table 2b 0.54 (49)

Energy lost from water storage, kWh/year (48) x (49) = 0.75 (50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day) 0 (51)

If community heating see section 4.3

Volume factor from Table 2a 0 (52)

Temperature factor from Table 2b 0 (53)

Energy lost from water storage, kWh/year (47) x (51) x (52) x (53) = 0 (54)

Enter (50) or (54) in (55)

Water storage loss calculated for each month ((56)m = (55) x (41)m)

(56)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	(56)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	(57)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

TER WorkSheet: New dwelling design stage

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month (59)m = (58) ÷ 365 × (41)m

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(59)

Combi loss calculated for each month (61)m = (60) ÷ 365 × (41)m

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0
--------	---	---	---	---	---	---	---	---	---	---	---	---

(61)

Total heat required for water heating calculated for each month (62)m = 0.85 × (45)m + (46)m + (57)m + (59)m + (61)m

(62)m=	196.37	173.08	181.77	162.94	159.67	142.67	137.01	150.35	150.09	168.96	178.66	191.64
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

(62)

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRS applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0
--------	---	---	---	---	---	---	---	---	---	---	---	---

(63)

Output from water heater

(64)m=	196.37	173.08	181.77	162.94	159.67	142.67	137.01	150.35	150.09	168.96	178.66	191.64
Output from water heater (annual) _{1...12}	1993.2											

(64)

Heat gains from water heating, kWh/month 0.25 [0.85 × (45)m + (61)m] + 0.8 × [(46)m + (57)m + (59)m]

(65)m=	87.08	77.22	82.22	75.26	74.87	68.52	67.34	71.77	70.98	77.96	80.48	85.5
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

(65)

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(66)m=	121.29	121.29	121.29	121.29	121.29	121.29	121.29	121.29	121.29	121.29	121.29	121.29

(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	19.21	17.06	13.87	10.5	7.85	6.63	7.16	9.31	12.49	15.86	18.52	19.74
--------	-------	-------	-------	------	------	------	------	------	-------	-------	-------	-------

(67)

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	215.42	217.66	212.03	200.03	184.9	170.67	161.16	158.93	164.56	176.55	191.69	205.92
--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------

(68)

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	35.13	35.13	35.13	35.13	35.13	35.13	35.13	35.13	35.13	35.13	35.13	35.13
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(69)

Pumps and fans gains (Table 5a)

(70)m=	3	3	3	3	3	3	3	3	3	3	3	3
--------	---	---	---	---	---	---	---	---	---	---	---	---

(70)

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-97.03	-97.03	-97.03	-97.03	-97.03	-97.03	-97.03	-97.03	-97.03	-97.03	-97.03	-97.03
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

(71)

Water heating gains (Table 5)

(72)m=	117.04	114.92	110.51	104.52	100.64	95.16	90.51	96.47	98.59	104.79	111.78	114.92
--------	--------	--------	--------	--------	--------	-------	-------	-------	-------	--------	--------	--------

(72)

Total internal gains = (66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m

(73)m=	414.05	412.02	398.8	377.45	355.77	334.85	321.22	327.09	338.03	359.59	384.38	402.97
--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------

(73)

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)
North	0.9x	0.77	x 6.05	x 10.63	x 0.63	x 0.7 = 19.66
North	0.9x	0.77	x 2.31	x 10.63	x 0.63	x 0.7 = 7.51

TER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	1.72	x	10.63	x	0.63	x	0.7	=	5.59	(74)
North	0.9x	0.77	x	6.05	x	20.32	x	0.63	x	0.7	=	37.57	(74)
North	0.9x	0.77	x	2.31	x	20.32	x	0.63	x	0.7	=	14.35	(74)
North	0.9x	0.77	x	1.72	x	20.32	x	0.63	x	0.7	=	10.68	(74)
North	0.9x	0.77	x	6.05	x	34.53	x	0.63	x	0.7	=	63.85	(74)
North	0.9x	0.77	x	2.31	x	34.53	x	0.63	x	0.7	=	24.38	(74)
North	0.9x	0.77	x	1.72	x	34.53	x	0.63	x	0.7	=	18.15	(74)
North	0.9x	0.77	x	6.05	x	55.46	x	0.63	x	0.7	=	102.55	(74)
North	0.9x	0.77	x	2.31	x	55.46	x	0.63	x	0.7	=	39.16	(74)
North	0.9x	0.77	x	1.72	x	55.46	x	0.63	x	0.7	=	29.16	(74)
North	0.9x	0.77	x	6.05	x	74.72	x	0.63	x	0.7	=	138.15	(74)
North	0.9x	0.77	x	2.31	x	74.72	x	0.63	x	0.7	=	52.75	(74)
North	0.9x	0.77	x	1.72	x	74.72	x	0.63	x	0.7	=	39.27	(74)
North	0.9x	0.77	x	6.05	x	79.99	x	0.63	x	0.7	=	147.89	(74)
North	0.9x	0.77	x	2.31	x	79.99	x	0.63	x	0.7	=	56.47	(74)
North	0.9x	0.77	x	1.72	x	79.99	x	0.63	x	0.7	=	42.04	(74)
North	0.9x	0.77	x	6.05	x	74.68	x	0.63	x	0.7	=	138.07	(74)
North	0.9x	0.77	x	2.31	x	74.68	x	0.63	x	0.7	=	52.72	(74)
North	0.9x	0.77	x	1.72	x	74.68	x	0.63	x	0.7	=	39.25	(74)
North	0.9x	0.77	x	6.05	x	59.25	x	0.63	x	0.7	=	109.54	(74)
North	0.9x	0.77	x	2.31	x	59.25	x	0.63	x	0.7	=	41.83	(74)
North	0.9x	0.77	x	1.72	x	59.25	x	0.63	x	0.7	=	31.14	(74)
North	0.9x	0.77	x	6.05	x	41.52	x	0.63	x	0.7	=	76.76	(74)
North	0.9x	0.77	x	2.31	x	41.52	x	0.63	x	0.7	=	29.31	(74)
North	0.9x	0.77	x	1.72	x	41.52	x	0.63	x	0.7	=	21.82	(74)
North	0.9x	0.77	x	6.05	x	24.19	x	0.63	x	0.7	=	44.73	(74)
North	0.9x	0.77	x	2.31	x	24.19	x	0.63	x	0.7	=	17.08	(74)
North	0.9x	0.77	x	1.72	x	24.19	x	0.63	x	0.7	=	12.72	(74)
North	0.9x	0.77	x	6.05	x	13.12	x	0.63	x	0.7	=	24.25	(74)
North	0.9x	0.77	x	2.31	x	13.12	x	0.63	x	0.7	=	9.26	(74)
North	0.9x	0.77	x	1.72	x	13.12	x	0.63	x	0.7	=	6.9	(74)
North	0.9x	0.77	x	6.05	x	8.86	x	0.63	x	0.7	=	16.39	(74)
North	0.9x	0.77	x	2.31	x	8.86	x	0.63	x	0.7	=	6.26	(74)
North	0.9x	0.77	x	1.72	x	8.86	x	0.63	x	0.7	=	4.66	(74)
South	0.9x	0.77	x	2.31	x	46.75	x	0.63	x	0.7	=	33.01	(78)
South	0.9x	0.77	x	4.21	x	46.75	x	0.63	x	0.7	=	60.15	(78)
South	0.9x	0.77	x	2.31	x	76.57	x	0.63	x	0.7	=	54.05	(78)
South	0.9x	0.77	x	4.21	x	76.57	x	0.63	x	0.7	=	98.51	(78)
South	0.9x	0.77	x	2.31	x	97.53	x	0.63	x	0.7	=	68.86	(78)
South	0.9x	0.77	x	4.21	x	97.53	x	0.63	x	0.7	=	125.49	(78)
South	0.9x	0.77	x	2.31	x	110.23	x	0.63	x	0.7	=	77.82	(78)

TER WorkSheet: New dwelling design stage

South	0.9x	0.77	x	4.21	x	110.23	x	0.63	x	0.7	=	141.83	(78)
South	0.9x	0.77	x	2.31	x	114.87	x	0.63	x	0.7	=	81.1	(78)
South	0.9x	0.77	x	4.21	x	114.87	x	0.63	x	0.7	=	147.8	(78)
South	0.9x	0.77	x	2.31	x	110.55	x	0.63	x	0.7	=	78.04	(78)
South	0.9x	0.77	x	4.21	x	110.55	x	0.63	x	0.7	=	142.23	(78)
South	0.9x	0.77	x	2.31	x	108.01	x	0.63	x	0.7	=	76.25	(78)
South	0.9x	0.77	x	4.21	x	108.01	x	0.63	x	0.7	=	138.97	(78)
South	0.9x	0.77	x	2.31	x	104.89	x	0.63	x	0.7	=	74.05	(78)
South	0.9x	0.77	x	4.21	x	104.89	x	0.63	x	0.7	=	134.96	(78)
South	0.9x	0.77	x	2.31	x	101.89	x	0.63	x	0.7	=	71.93	(78)
South	0.9x	0.77	x	4.21	x	101.89	x	0.63	x	0.7	=	131.09	(78)
South	0.9x	0.77	x	2.31	x	82.59	x	0.63	x	0.7	=	58.3	(78)
South	0.9x	0.77	x	4.21	x	82.59	x	0.63	x	0.7	=	106.26	(78)
South	0.9x	0.77	x	2.31	x	55.42	x	0.63	x	0.7	=	39.12	(78)
South	0.9x	0.77	x	4.21	x	55.42	x	0.63	x	0.7	=	71.3	(78)
South	0.9x	0.77	x	2.31	x	40.4	x	0.63	x	0.7	=	28.52	(78)
South	0.9x	0.77	x	4.21	x	40.4	x	0.63	x	0.7	=	51.98	(78)

Solar gains in watts, calculated for each month

(83)m = Sum(74)m ... (82)m

(83)m=	125.92	215.17	300.72	390.52	459.06	466.68	445.27	391.53	330.91	239.08	150.83	107.8	(83)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	------

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=	539.97	627.19	699.52	767.96	814.83	801.52	766.49	718.62	668.94	598.67	535.21	510.77	(84)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m=	1	0.99	0.98	0.94	0.85	0.68	0.51	0.56	0.81	0.96	0.99	1	(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	19.78	19.95	20.21	20.53	20.81	20.95	20.99	20.99	20.89	20.54	20.1	19.75	(87)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	19.92	19.92	19.92	19.94	19.94	19.95	19.95	19.95	19.94	19.93	19.93		(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	1	0.99	0.97	0.92	0.8	0.59	0.39	0.44	0.73	0.94	0.99	1	(89)
--------	---	------	------	------	-----	------	------	------	------	------	------	---	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.3	18.55	18.93	19.4	19.75	19.92	19.95	19.95	19.86	19.42	18.79	18.27	(90)
--------	------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	------

fLA = Living area ÷ (4) =

0.35

(91)

Mean internal temperature (for the whole dwelling) = fLA × T1 + (1 – fLA) × T2

(92)m=	18.82	19.05	19.38	19.8	20.13	20.29	20.32	20.31	20.23	19.82	19.25	18.79	(92)
--------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	18.82	19.05	19.38	19.8	20.13	20.29	20.32	20.31	20.23	19.82	19.25	18.79	(93)
--------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that $Ti,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

TER WorkSheet: New dwelling design stage

Utilisation factor for gains, hm:

(94)m=	0.99	0.99	0.97	0.92	0.81	0.62	0.44	0.49	0.75	0.94	0.99	0.99	(94)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	536.3	618.35	677.69	707.36	659.7	494.54	334.53	349.58	501.75	562.41	527.76	508.08	(95)
--------	-------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W =[(39)m x [(93)m – (96)m]

(97)m=	1361.47	1322.57	1200.99	1003.99	774.29	516.81	337.75	355	559.18	847.21	1121.84	1353.66	(97)
--------	---------	---------	---------	---------	--------	--------	--------	-----	--------	--------	---------	---------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m – (95)m] x (41)m

(98)m=	613.92	473.24	389.33	213.57	85.26	0	0	0	0	211.89	427.73	629.11	
--------	--------	--------	--------	--------	-------	---	---	---	---	--------	--------	--------	--

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1...5,9...12} = 3044.06 \quad (98)$$

Space heating requirement in kWh/m²/year

$$38.98 \quad (99)$$

9a. Energy requirements – Individual heating systems including micro-CHP)

Space heating:

Fraction of space heat from secondary/supplementary system

$$0 \quad (201)$$

Fraction of space heat from main system(s)

$$(202) = 1 - (201) = 1 \quad (202)$$

Fraction of total heating from main system 1

$$(204) = (202) \times [1 - (203)] = 1 \quad (204)$$

Efficiency of main space heating system 1

$$93.5 \quad (206)$$

Efficiency of secondary/supplementary heating system, %

$$0 \quad (208)$$

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

613.92	473.24	389.33	213.57	85.26	0	0	0	0	211.89	427.73	629.11
--------	--------	--------	--------	-------	---	---	---	---	--------	--------	--------

$$(211)m = \{[(98)m \times (204)]\} \times 100 \div (206) \quad (211)$$

656.6	506.14	416.4	228.42	91.18	0	0	0	0	226.62	457.47	672.85
-------	--------	-------	--------	-------	---	---	---	---	--------	--------	--------

$$\text{Total (kWh/year)} = \text{Sum}(211)_{1...5,10...12} = 3255.68 \quad (211)$$

Space heating fuel (secondary), kWh/month

$$= \{[(98)m \times (201)]\} \times 100 \div (208)$$

(215)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

$$\text{Total (kWh/year)} = \text{Sum}(215)_{1...5,10...12} = 0 \quad (215)$$

Water heating

Output from water heater (calculated above)

196.37	173.08	181.77	162.94	159.67	142.67	137.01	150.35	150.09	168.96	178.66	191.64
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

$$79.8 \quad (216)$$

Efficiency of water heater

(217)m=	87.65	87.36	86.8	85.54	83.23	79.8	79.8	79.8	85.42	87.06	87.75
---------	-------	-------	------	-------	-------	------	------	------	-------	-------	-------

$$217 \quad (217)$$

Fuel for water heating, kWh/month

$$(219)m = (64)m \times 100 \div (217)m$$

(219)m=	224.03	198.11	209.42	190.49	191.85	178.78	171.7	188.41	188.08	197.8	205.21	218.39
---------	--------	--------	--------	--------	--------	--------	-------	--------	--------	-------	--------	--------

$$\text{Total} = \text{Sum}(219a)_{1...12} = 2362.27 \quad (219)$$

Annual totals

Space heating fuel used, main system 1

$$\text{kWh/year} \quad 3255.68$$

Water heating fuel used

$$2362.27$$

Electricity for pumps, fans and electric keep-hot

TER WorkSheet: New dwelling design stage

central heating pump:	30	(230c)
boiler with a fan-assisted flue	45	(230e)
Total electricity for the above, kWh/year	sum of (230a)...(230g) =	75 (231)
Electricity for lighting	339.17 (232)	

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating (main system 1)	(211) x	0.216	= 703.23 (261)
Space heating (secondary)	(215) x	0.519	= 0 (263)
Water heating	(219) x	0.216	= 510.25 (264)
Space and water heating	(261) + (262) + (263) + (264) =		1213.48 (265)
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	= 38.93 (267)
Electricity for lighting	(232) x	0.519	= 176.03 (268)
Total CO2, kg/year		sum of (265)...(271) =	1428.43 (272)

TER = 18.29 (273)

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 011 - Be Lean			
Address :	AC 011, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	95.2 (1a)	x (2a)	= 276.08 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	95.2 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	276.08 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					x 10 = 0 (7a)
Number of passive vents					x 10 = 0 (7b)
Number of flueless gas fires					x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 0 ÷ (5) = 0
(8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] =

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) =

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] =

Infiltration rate incorporating shelter factor (21) = (18) x (20) =

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

DER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.12	0.12	0.11	0.1	0.1	0.09	0.09	0.09	0.09	0.1	0.1	0.11
------	------	------	-----	-----	------	------	------	------	-----	-----	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5

(23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5

(23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5

(23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0.24	0.23	0.23	0.22	0.22	0.21	0.21	0.2	0.21	0.22	0.22	0.23
---------	------	------	------	------	------	------	------	-----	------	------	------	------

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.24	0.23	0.23	0.22	0.22	0.21	0.21	0.2	0.21	0.22	0.22	0.23
--------	------	------	------	------	------	------	------	-----	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Doors			3.89	x 1.4 =	5.446		
Windows Type 1			3.44	x1/[1/(1.4)+ 0.04] =	4.56		
Windows Type 2			3.44	x1/[1/(1.4)+ 0.04] =	4.56		
Windows Type 3			5.36	x1/[1/(1.4)+ 0.04] =	7.11		
Windows Type 4			3.44	x1/[1/(1.4)+ 0.04] =	4.56		
Windows Type 5			3.44	x1/[1/(1.4)+ 0.04] =	4.56		
Windows Type 6			2.83	x1/[1/(1.4)+ 0.04] =	3.75		
Windows Type 7			2.75	x1/[1/(1.4)+ 0.04] =	3.65		
Windows Type 8			2.69	x1/[1/(1.4)+ 0.04] =	3.57		
Windows Type 9			1.8	x1/[1/(1.4)+ 0.04] =	2.39		
Windows Type 10			1.8	x1/[1/(1.4)+ 0.04] =	2.39		
Windows Type 11			4.91	x1/[1/(1.4)+ 0.04] =	6.51		
Floor			95.2	x 0.12 =	11.424		
Walls	88.28	39.79	48.49	x 0.12 =	5.82		
Total area of elements, m ²			183.48				
Party wall			24.88	x 0 =	0		

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U)	(26)...(30) + (32) =	70.28	(33)
Heat capacity Cm = S(A x k)	((28)...(30) + (32) + (32a)...(32e) =	0	(34)
Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m ² K	Indicative Value: Medium	250	(35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f

DER WorkSheet: New dwelling design stage

can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K

18.17 (36)

if details of thermal bridging are not known (36) = $0.05 \times (31)$

Total fabric heat loss

(33) + (36) =

88.45 (37)

Ventilation heat loss calculated monthly

(38)m = $0.33 \times (25)m \times (5)$

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m= 21.45	21.24	21.03	19.98	19.76	18.71	18.71	18.5	19.13	19.76	20.19	20.61

(38)

Heat transfer coefficient, W/K

(39)m = (37) + (38)m

(39)m= 109.9	109.69	109.48	108.43	108.22	107.16	107.16	106.95	107.59	108.22	108.64	109.06
Average = Sum(39) _{1...12} /12=											108.38 (39)

Heat loss parameter (HLP), W/m²K

(40)m = (39)m ÷ (4)

(40)m= 1.15	1.15	1.15	1.14	1.14	1.13	1.13	1.12	1.13	1.14	1.14	1.15
Average = Sum(40) _{1...12} /12=											1.14 (40)

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(41)m= 31	28	31	30	31	30	31	31	30	31	30	31

(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

2.69 (42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (TFA - 13.9)2)] + 0.0013 \times (TFA - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd,average = (25 \times N) + 36$

98.1 (43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m= 107.91	103.98	100.06	96.14	92.21	88.29	88.29	92.21	96.14	100.06	103.98	107.91
Total = Sum(44) _{1...12} =											1177.17 (44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m= 160.02	139.96	144.42	125.91	120.82	104.25	96.61	110.86	112.18	130.74	142.71	154.97
Total = Sum(45) _{1...12} =											1543.46 (45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m= 24	20.99	21.66	18.89	18.12	15.64	14.49	16.63	16.83	19.61	21.41	23.25
-----------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(46)

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0 (47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0 (48)

Temperature factor from Table 2b

0 (49)

Energy lost from water storage, kWh/year

(48) x (49) =

110 (50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0.02 (51)

If community heating see section 4.3

Volume factor from Table 2a

1.03 (52)

Temperature factor from Table 2b

0.6 (53)

DER WorkSheet: New dwelling design stage

Energy lost from water storage, kWh/year $(47) \times (51) \times (52) \times (53) =$
 Enter (50) or (54) in (55)

(54)	1.03
1.03	(55)

Water storage loss calculated for each month $((56)m = (55) \times (41)m$

(56)m=

32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (56)

If cylinder contains dedicated solar storage, (57)m = (56)m x [(50) – (H11)] ÷ (50), else (57)m = (56)m where (H11) is from Appendix H

(57)m=

32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (57)

Primary circuit loss (annual) from Table 3 0 (58)

Primary circuit loss calculated for each month (59)m = (58) ÷ 365 × (41)m

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)
 (59)m=

23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (59)

Combi loss calculated for each month (61)m = (60) ÷ 365 × (41)m

(61)m=

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

 (61)

Total heat required for water heating calculated for each month (62)m = 0.85 × (45)m + (46)m + (57)m + (59)m + (61)m

(62)m=

215.3	189.89	199.7	179.41	176.09	157.75	151.88	166.14	165.68	186.01	196.2	210.25
-------	--------	-------	--------	--------	--------	--------	--------	--------	--------	-------	--------

 (62)

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

 (63)

Output from water heater

(64)m=

215.3	189.89	199.7	179.41	176.09	157.75	151.88	166.14	165.68	186.01	196.2	210.25
-------	--------	-------	--------	--------	--------	--------	--------	--------	--------	-------	--------

 Output from water heater (annual) 2194.3 (64)

Heat gains from water heating, kWh/month 0.25 [0.85 × (45)m + (61)m] + 0.8 × [(46)m + (57)m + (59)m]

(65)m=

97.43	86.48	92.24	84.66	84.39	77.46	76.34	81.08	80.1	87.69	90.25	95.75
-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------

 (65)

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(66)m= 134.52	134.52	134.52	134.52	134.52	134.52	134.52	134.52	134.52	134.52	134.52	134.52

 (66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=

22.14	19.66	15.99	12.11	9.05	7.64	8.26	10.73	14.4	18.29	21.34	22.75
-------	-------	-------	-------	------	------	------	-------	------	-------	-------	-------

 (67)

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=

248.33	250.9	244.41	230.59	213.14	196.73	185.78	183.2	189.69	203.52	220.97	237.37
--------	-------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------

 (68)

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=

36.45	36.45	36.45	36.45	36.45	36.45	36.45	36.45	36.45	36.45	36.45	36.45
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (69)

Pumps and fans gains (Table 5a)

(70)m=

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

 (70)

Losses e.g. evaporation (negative values) (Table 5)

(71)m=

-107.62	-107.62	-107.62	-107.62	-107.62	-107.62	-107.62	-107.62	-107.62	-107.62	-107.62	-107.62
---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------

 (71)

Water heating gains (Table 5)

(72)m=

130.95	128.69	123.98	117.58	113.43	107.58	102.61	108.98	111.24	117.87	125.34	128.7
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------

 (72)

Total internal gains = (66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m

(73)m=

464.77	462.61	447.74	423.63	398.97	375.31	360	366.27	378.7	403.03	431.01	452.18
--------	--------	--------	--------	--------	--------	-----	--------	-------	--------	--------	--------

 (73)

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

DER WorkSheet: New dwelling design stage

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g Table 6b	FF Table 6c	Gains (W)
North	0.9x 0.77	x 3.44	x 10.63	x 0.4	x 0.8	= 8.11 (74)
North	0.9x 0.77	x 2.83	x 10.63	x 0.4	x 0.8	= 6.67 (74)
North	0.9x 0.77	x 2.75	x 10.63	x 0.4	x 0.8	= 6.48 (74)
North	0.9x 0.77	x 2.69	x 10.63	x 0.4	x 0.8	= 6.34 (74)
North	0.9x 0.77	x 1.8	x 10.63	x 0.4	x 0.8	= 4.24 (74)
North	0.9x 0.77	x 3.44	x 20.32	x 0.4	x 0.8	= 15.5 (74)
North	0.9x 0.77	x 2.83	x 20.32	x 0.4	x 0.8	= 12.75 (74)
North	0.9x 0.77	x 2.75	x 20.32	x 0.4	x 0.8	= 12.39 (74)
North	0.9x 0.77	x 2.69	x 20.32	x 0.4	x 0.8	= 12.12 (74)
North	0.9x 0.77	x 1.8	x 20.32	x 0.4	x 0.8	= 8.11 (74)
North	0.9x 0.77	x 3.44	x 34.53	x 0.4	x 0.8	= 26.34 (74)
North	0.9x 0.77	x 2.83	x 34.53	x 0.4	x 0.8	= 21.67 (74)
North	0.9x 0.77	x 2.75	x 34.53	x 0.4	x 0.8	= 21.06 (74)
North	0.9x 0.77	x 2.69	x 34.53	x 0.4	x 0.8	= 20.6 (74)
North	0.9x 0.77	x 1.8	x 34.53	x 0.4	x 0.8	= 13.78 (74)
North	0.9x 0.77	x 3.44	x 55.46	x 0.4	x 0.8	= 42.31 (74)
North	0.9x 0.77	x 2.83	x 55.46	x 0.4	x 0.8	= 34.81 (74)
North	0.9x 0.77	x 2.75	x 55.46	x 0.4	x 0.8	= 33.82 (74)
North	0.9x 0.77	x 2.69	x 55.46	x 0.4	x 0.8	= 33.09 (74)
North	0.9x 0.77	x 1.8	x 55.46	x 0.4	x 0.8	= 22.14 (74)
North	0.9x 0.77	x 3.44	x 74.72	x 0.4	x 0.8	= 57 (74)
North	0.9x 0.77	x 2.83	x 74.72	x 0.4	x 0.8	= 46.89 (74)
North	0.9x 0.77	x 2.75	x 74.72	x 0.4	x 0.8	= 45.56 (74)
North	0.9x 0.77	x 2.69	x 74.72	x 0.4	x 0.8	= 44.57 (74)
North	0.9x 0.77	x 1.8	x 74.72	x 0.4	x 0.8	= 29.82 (74)
North	0.9x 0.77	x 3.44	x 79.99	x 0.4	x 0.8	= 61.02 (74)
North	0.9x 0.77	x 2.83	x 79.99	x 0.4	x 0.8	= 50.2 (74)
North	0.9x 0.77	x 2.75	x 79.99	x 0.4	x 0.8	= 48.78 (74)
North	0.9x 0.77	x 2.69	x 79.99	x 0.4	x 0.8	= 47.71 (74)
North	0.9x 0.77	x 1.8	x 79.99	x 0.4	x 0.8	= 31.93 (74)
North	0.9x 0.77	x 3.44	x 74.68	x 0.4	x 0.8	= 56.97 (74)
North	0.9x 0.77	x 2.83	x 74.68	x 0.4	x 0.8	= 46.87 (74)
North	0.9x 0.77	x 2.75	x 74.68	x 0.4	x 0.8	= 45.54 (74)
North	0.9x 0.77	x 2.69	x 74.68	x 0.4	x 0.8	= 44.55 (74)
North	0.9x 0.77	x 1.8	x 74.68	x 0.4	x 0.8	= 29.81 (74)
North	0.9x 0.77	x 3.44	x 59.25	x 0.4	x 0.8	= 45.2 (74)
North	0.9x 0.77	x 2.83	x 59.25	x 0.4	x 0.8	= 37.18 (74)
North	0.9x 0.77	x 2.75	x 59.25	x 0.4	x 0.8	= 36.13 (74)
North	0.9x 0.77	x 2.69	x 59.25	x 0.4	x 0.8	= 35.34 (74)

DER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	1.8	x	59.25	x	0.4	x	0.8	=	23.65	(74)
North	0.9x	0.77	x	3.44	x	41.52	x	0.4	x	0.8	=	31.67	(74)
North	0.9x	0.77	x	2.83	x	41.52	x	0.4	x	0.8	=	26.05	(74)
North	0.9x	0.77	x	2.75	x	41.52	x	0.4	x	0.8	=	25.32	(74)
North	0.9x	0.77	x	2.69	x	41.52	x	0.4	x	0.8	=	24.77	(74)
North	0.9x	0.77	x	1.8	x	41.52	x	0.4	x	0.8	=	16.57	(74)
North	0.9x	0.77	x	3.44	x	24.19	x	0.4	x	0.8	=	18.45	(74)
North	0.9x	0.77	x	2.83	x	24.19	x	0.4	x	0.8	=	15.18	(74)
North	0.9x	0.77	x	2.75	x	24.19	x	0.4	x	0.8	=	14.75	(74)
North	0.9x	0.77	x	2.69	x	24.19	x	0.4	x	0.8	=	14.43	(74)
North	0.9x	0.77	x	1.8	x	24.19	x	0.4	x	0.8	=	9.66	(74)
North	0.9x	0.77	x	3.44	x	13.12	x	0.4	x	0.8	=	10.01	(74)
North	0.9x	0.77	x	2.83	x	13.12	x	0.4	x	0.8	=	8.23	(74)
North	0.9x	0.77	x	2.75	x	13.12	x	0.4	x	0.8	=	8	(74)
North	0.9x	0.77	x	2.69	x	13.12	x	0.4	x	0.8	=	7.83	(74)
North	0.9x	0.77	x	1.8	x	13.12	x	0.4	x	0.8	=	5.24	(74)
North	0.9x	0.77	x	3.44	x	8.86	x	0.4	x	0.8	=	6.76	(74)
North	0.9x	0.77	x	2.83	x	8.86	x	0.4	x	0.8	=	5.56	(74)
North	0.9x	0.77	x	2.75	x	8.86	x	0.4	x	0.8	=	5.41	(74)
North	0.9x	0.77	x	2.69	x	8.86	x	0.4	x	0.8	=	5.29	(74)
North	0.9x	0.77	x	1.8	x	8.86	x	0.4	x	0.8	=	3.54	(74)
East	0.9x	0.77	x	3.44	x	19.64	x	0.4	x	0.8	=	14.98	(76)
East	0.9x	0.77	x	5.36	x	19.64	x	0.4	x	0.8	=	23.35	(76)
East	0.9x	0.77	x	3.44	x	19.64	x	0.4	x	0.8	=	14.98	(76)
East	0.9x	0.77	x	3.44	x	38.42	x	0.4	x	0.8	=	29.31	(76)
East	0.9x	0.77	x	5.36	x	38.42	x	0.4	x	0.8	=	45.67	(76)
East	0.9x	0.77	x	3.44	x	38.42	x	0.4	x	0.8	=	29.31	(76)
East	0.9x	0.77	x	3.44	x	63.27	x	0.4	x	0.8	=	48.27	(76)
East	0.9x	0.77	x	5.36	x	63.27	x	0.4	x	0.8	=	75.21	(76)
East	0.9x	0.77	x	3.44	x	63.27	x	0.4	x	0.8	=	48.27	(76)
East	0.9x	0.77	x	3.44	x	92.28	x	0.4	x	0.8	=	70.4	(76)
East	0.9x	0.77	x	5.36	x	92.28	x	0.4	x	0.8	=	109.69	(76)
East	0.9x	0.77	x	3.44	x	92.28	x	0.4	x	0.8	=	70.4	(76)
East	0.9x	0.77	x	3.44	x	113.09	x	0.4	x	0.8	=	86.27	(76)
East	0.9x	0.77	x	5.36	x	113.09	x	0.4	x	0.8	=	134.43	(76)
East	0.9x	0.77	x	3.44	x	113.09	x	0.4	x	0.8	=	86.27	(76)
East	0.9x	0.77	x	3.44	x	115.77	x	0.4	x	0.8	=	88.32	(76)
East	0.9x	0.77	x	5.36	x	115.77	x	0.4	x	0.8	=	137.61	(76)
East	0.9x	0.77	x	3.44	x	115.77	x	0.4	x	0.8	=	88.32	(76)
East	0.9x	0.77	x	3.44	x	110.22	x	0.4	x	0.8	=	84.08	(76)
East	0.9x	0.77	x	5.36	x	110.22	x	0.4	x	0.8	=	131.01	(76)

DER WorkSheet: New dwelling design stage

East	0.9x	0.77	x	3.44	x	110.22	x	0.4	x	0.8	=	84.08	(76)
East	0.9x	0.77	x	3.44	x	94.68	x	0.4	x	0.8	=	72.22	(76)
East	0.9x	0.77	x	5.36	x	94.68	x	0.4	x	0.8	=	112.53	(76)
East	0.9x	0.77	x	3.44	x	94.68	x	0.4	x	0.8	=	72.22	(76)
East	0.9x	0.77	x	3.44	x	73.59	x	0.4	x	0.8	=	56.14	(76)
East	0.9x	0.77	x	5.36	x	73.59	x	0.4	x	0.8	=	87.47	(76)
East	0.9x	0.77	x	3.44	x	73.59	x	0.4	x	0.8	=	56.14	(76)
East	0.9x	0.77	x	3.44	x	45.59	x	0.4	x	0.8	=	34.78	(76)
East	0.9x	0.77	x	5.36	x	45.59	x	0.4	x	0.8	=	54.19	(76)
East	0.9x	0.77	x	3.44	x	45.59	x	0.4	x	0.8	=	34.78	(76)
East	0.9x	0.77	x	3.44	x	24.49	x	0.4	x	0.8	=	18.68	(76)
East	0.9x	0.77	x	5.36	x	24.49	x	0.4	x	0.8	=	29.11	(76)
East	0.9x	0.77	x	3.44	x	24.49	x	0.4	x	0.8	=	18.68	(76)
East	0.9x	0.77	x	3.44	x	16.15	x	0.4	x	0.8	=	12.32	(76)
East	0.9x	0.77	x	5.36	x	16.15	x	0.4	x	0.8	=	19.2	(76)
East	0.9x	0.77	x	3.44	x	16.15	x	0.4	x	0.8	=	12.32	(76)
South	0.9x	0.77	x	3.44	x	46.75	x	0.4	x	0.8	=	35.67	(78)
South	0.9x	0.77	x	1.8	x	46.75	x	0.4	x	0.8	=	18.66	(78)
South	0.9x	0.77	x	4.91	x	46.75	x	0.4	x	0.8	=	50.91	(78)
South	0.9x	0.77	x	3.44	x	76.57	x	0.4	x	0.8	=	58.41	(78)
South	0.9x	0.77	x	1.8	x	76.57	x	0.4	x	0.8	=	30.56	(78)
South	0.9x	0.77	x	4.91	x	76.57	x	0.4	x	0.8	=	83.37	(78)
South	0.9x	0.77	x	3.44	x	97.53	x	0.4	x	0.8	=	74.4	(78)
South	0.9x	0.77	x	1.8	x	97.53	x	0.4	x	0.8	=	38.93	(78)
South	0.9x	0.77	x	4.91	x	97.53	x	0.4	x	0.8	=	106.2	(78)
South	0.9x	0.77	x	3.44	x	110.23	x	0.4	x	0.8	=	84.09	(78)
South	0.9x	0.77	x	1.8	x	110.23	x	0.4	x	0.8	=	44	(78)
South	0.9x	0.77	x	4.91	x	110.23	x	0.4	x	0.8	=	120.03	(78)
South	0.9x	0.77	x	3.44	x	114.87	x	0.4	x	0.8	=	87.63	(78)
South	0.9x	0.77	x	1.8	x	114.87	x	0.4	x	0.8	=	45.85	(78)
South	0.9x	0.77	x	4.91	x	114.87	x	0.4	x	0.8	=	125.08	(78)
South	0.9x	0.77	x	3.44	x	110.55	x	0.4	x	0.8	=	84.33	(78)
South	0.9x	0.77	x	1.8	x	110.55	x	0.4	x	0.8	=	44.13	(78)
South	0.9x	0.77	x	4.91	x	110.55	x	0.4	x	0.8	=	120.37	(78)
South	0.9x	0.77	x	3.44	x	108.01	x	0.4	x	0.8	=	82.4	(78)
South	0.9x	0.77	x	1.8	x	108.01	x	0.4	x	0.8	=	43.11	(78)
South	0.9x	0.77	x	4.91	x	108.01	x	0.4	x	0.8	=	117.61	(78)
South	0.9x	0.77	x	3.44	x	104.89	x	0.4	x	0.8	=	80.02	(78)
South	0.9x	0.77	x	1.8	x	104.89	x	0.4	x	0.8	=	41.87	(78)
South	0.9x	0.77	x	4.91	x	104.89	x	0.4	x	0.8	=	114.21	(78)
South	0.9x	0.77	x	3.44	x	101.89	x	0.4	x	0.8	=	77.72	(78)

DER WorkSheet: New dwelling design stage

South	0.9x	0.77	x	1.8	x	101.89	x	0.4	x	0.8	=	40.67	(78)
South	0.9x	0.77	x	4.91	x	101.89	x	0.4	x	0.8	=	110.94	(78)
South	0.9x	0.77	x	3.44	x	82.59	x	0.4	x	0.8	=	63	(78)
South	0.9x	0.77	x	1.8	x	82.59	x	0.4	x	0.8	=	32.97	(78)
South	0.9x	0.77	x	4.91	x	82.59	x	0.4	x	0.8	=	89.92	(78)
South	0.9x	0.77	x	3.44	x	55.42	x	0.4	x	0.8	=	42.28	(78)
South	0.9x	0.77	x	1.8	x	55.42	x	0.4	x	0.8	=	22.12	(78)
South	0.9x	0.77	x	4.91	x	55.42	x	0.4	x	0.8	=	60.34	(78)
South	0.9x	0.77	x	3.44	x	40.4	x	0.4	x	0.8	=	30.82	(78)
South	0.9x	0.77	x	1.8	x	40.4	x	0.4	x	0.8	=	16.13	(78)
South	0.9x	0.77	x	4.91	x	40.4	x	0.4	x	0.8	=	43.99	(78)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m=	190.4	337.51	494.73	664.77	789.38	802.7	766.02	670.59	553.46	382.1	230.51	161.33	(83)
--------	-------	--------	--------	--------	--------	-------	--------	--------	--------	-------	--------	--------	------

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=	655.17	800.12	942.47	1088.41	1188.35	1178.02	1126.02	1036.86	932.16	785.13	661.52	613.5	(84)
--------	--------	--------	--------	---------	---------	---------	---------	---------	--------	--------	--------	-------	------

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m=	1	0.99	0.97	0.9	0.76	0.57	0.42	0.47	0.73	0.95	0.99	1	(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	19.83	20.04	20.33	20.67	20.9	20.98	21	20.99	20.94	20.62	20.16	19.8	(87)
--------	-------	-------	-------	-------	------	-------	----	-------	-------	-------	-------	------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	19.96	19.96	19.96	19.97	19.97	19.98	19.98	19.98	19.98	19.97	19.97	19.96	(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	1	0.99	0.96	0.87	0.7	0.48	0.32	0.37	0.64	0.92	0.99	1	(89)
--------	---	------	------	------	-----	------	------	------	------	------	------	---	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.41	18.71	19.14	19.61	19.88	19.97	19.98	19.98	19.93	19.55	18.89	18.36	(90)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

$$fLA = \text{Living area} \div (4) =$$

0.36

(91)

Mean internal temperature (for the whole dwelling) = fLA × T1 + (1 – fLA) × T2

(92)m=	18.93	19.19	19.57	19.99	20.25	20.34	20.35	20.35	20.3	19.94	19.35	18.88	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	18.93	19.19	19.57	19.99	20.25	20.34	20.35	20.35	20.3	19.94	19.35	18.88	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that $Ti,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	0.99	0.98	0.95	0.87	0.72	0.51	0.36	0.4	0.67	0.92	0.99	1	(94)
--------	------	------	------	------	------	------	------	-----	------	------	------	---	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	650.83	786.49	899.58	951.19	851.48	604	400.41	419.77	627.18	723.08	651.67	610.49	(95)
--------	--------	--------	--------	--------	--------	-----	--------	--------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

DER WorkSheet: New dwelling design stage

Heat loss rate for mean internal temperature, L_m , $W = [(39)m \times [(93)m - (96)m]]$

(97)m=	1607.88	1568.02	1431.19	1203.01	925.1	614.78	401.74	422.29	666.71	1010.7	1330.84	1601.3	(97)
--------	---------	---------	---------	---------	-------	--------	--------	--------	--------	--------	---------	--------	------

Space heating requirement for each month, kWh/month = $0.024 \times [(97)m - (95)m] \times (41)m$

(98)m=	712.04	525.19	395.52	181.31	54.78	0	0	0	213.99	489	737.16	
--------	--------	--------	--------	--------	-------	---	---	---	--------	-----	--------	--

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1...5,9...12} = 3308.98 \quad (98)$$

Space heating requirement in kWh/m²/year

$$34.76 \quad (99)$$

9b. Energy requirements – Community heating scheme

This part is used for space heating, space cooling or water heating provided by a community scheme.

Fraction of space heat from secondary/supplementary heating (Table 11) '0' if none

$$0 \quad (301)$$

Fraction of space heat from community system 1 – (301) =

$$1 \quad (302)$$

The community scheme may obtain heat from several sources. The procedure allows for CHP and up to four other heat sources; the latter includes boilers, heat pumps, geothermal and waste heat from power stations. See Appendix C.

Fraction of heat from Community boilers

$$1 \quad (303a)$$

Fraction of total space heat from Community boilers

$$(302) \times (303a) = 1 \quad (304a)$$

Factor for control and charging method (Table 4c(3)) for community heating system

$$1 \quad (305)$$

Distribution loss factor (Table 12c) for community heating system

$$1.1 \quad (306)$$

Space heating

Annual space heating requirement

$$3308.98$$

Space heat from Community boilers

$$(98) \times (304a) \times (305) \times (306) = 3639.88 \quad (307a)$$

Efficiency of secondary/supplementary heating system in % (from Table 4a or Appendix E)

$$0 \quad (308)$$

Space heating requirement from secondary/supplementary system

$$(98) \times (301) \times 100 \div (308) = 0 \quad (309)$$

Water heating

Annual water heating requirement

$$2194.3$$

If DHW from community scheme:

Water heat from Community boilers

$$(64) \times (303a) \times (305) \times (306) = 2413.73 \quad (310a)$$

Electricity used for heat distribution

$$0.01 \times [(307a) \dots (307e) + (310a) \dots (310e)] = 60.54 \quad (313)$$

Cooling System Energy Efficiency Ratio

$$0 \quad (314)$$

Space cooling (if there is a fixed cooling system, if not enter 0)

$$= (107) \div (314) = 0 \quad (315)$$

Electricity for pumps and fans within dwelling (Table 4f):

mechanical ventilation - balanced, extract or positive input from outside

$$223.14 \quad (330a)$$

warm air heating system fans

$$0 \quad (330b)$$

pump for solar water heating

$$0 \quad (330g)$$

Total electricity for the above, kWh/year

$$=(330a) + (330b) + (330g) = 223.14 \quad (331)$$

Energy for lighting (calculated in Appendix L)

$$390.97 \quad (332)$$

12b. CO2 Emissions – Community heating scheme

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
--	--------------------	-------------------------------	--------------------------

CO2 from other sources of space and water heating (not CHP)

Efficiency of heat source 1 (%)

If there is CHP using two fuels repeat (363) to (366) for the second fuel

$$95 \quad (367a)$$

DER WorkSheet: New dwelling design stage

CO2 associated with heat source 1	$[(307b)+(310b)] \times 100 \div (367b) \times$	0.22	=	1376.4	(367)
Electrical energy for heat distribution	$[(313) \times$	0.52	=	31.42	(372)
Total CO2 associated with community systems	$(363)\dots(366) + (368)\dots(372)$		=	1407.82	(373)
CO2 associated with space heating (secondary)	$(309) \times$	0	=	0	(374)
CO2 associated with water from immersion heater or instantaneous heater	$(312) \times$	0.22	=	0	(375)
Total CO2 associated with space and water heating	$(373) + (374) + (375) =$			1407.82	(376)
CO2 associated with electricity for pumps and fans within dwelling	$(331)) \times$	0.52	=	115.81	(378)
CO2 associated with electricity for lighting	$(332))) \times$	0.52	=	202.91	(379)
Total CO2, kg/year	sum of (376)...(382) =			1726.54	(383)
Dwelling CO2 Emission Rate	$(383) \div (4) =$			18.14	(384)
EI rating (section 14)				83.5	(385)

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 011 - Be Lean			
Address :	AC 011, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	95.2 (1a)	x (2a)	= 276.08 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	95.2 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	276.08 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					3 x 10 = 30 (7a)
Number of passive vents					0 x 10 = 0 (7b)
Number of flueless gas fires					0 x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 30 ÷ (5) = 0.11 (8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] =

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) =

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] =

Infiltration rate incorporating shelter factor (21) = (18) x (20) =

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

TER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.42	0.41	0.41	0.36	0.36	0.32	0.32	0.31	0.33	0.36	0.37	0.39
------	------	------	------	------	------	------	------	------	------	------	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0.59	0.59	0.58	0.57	0.56	0.55	0.55	0.55	0.56	0.56	0.57	0.58
---------	------	------	------	------	------	------	------	------	------	------	------	------

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.59	0.59	0.58	0.57	0.56	0.55	0.55	0.55	0.56	0.56	0.57	0.58
--------	------	------	------	------	------	------	------	------	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Doors			3.89	x 1.2 =	4.668		(26)
Windows Type 1			1.91	x1/[1/(1.4)+ 0.04] =	2.53		(27)
Windows Type 2			1.91	x1/[1/(1.4)+ 0.04] =	2.53		(27)
Windows Type 3			2.97	x1/[1/(1.4)+ 0.04] =	3.94		(27)
Windows Type 4			1.91	x1/[1/(1.4)+ 0.04] =	2.53		(27)
Windows Type 5			1.91	x1/[1/(1.4)+ 0.04] =	2.53		(27)
Windows Type 6			1.57	x1/[1/(1.4)+ 0.04] =	2.08		(27)
Windows Type 7			1.53	x1/[1/(1.4)+ 0.04] =	2.03		(27)
Windows Type 8			1.49	x1/[1/(1.4)+ 0.04] =	1.98		(27)
Windows Type 9			1	x1/[1/(1.4)+ 0.04] =	1.33		(27)
Windows Type 10			1	x1/[1/(1.4)+ 0.04] =	1.33		(27)
Windows Type 11			2.72	x1/[1/(1.4)+ 0.04] =	3.61		(27)
Floor			95.2	x 0.13 =	12.376		(28)
Walls	88.28	23.81	64.47	x 0.18 =	11.6		(29)
Total area of elements, m ²			183.48				(31)
Party wall			24.88	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 55.06 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f

TER WorkSheet: New dwelling design stage

can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K

12.99 (36)

if details of thermal bridging are not known (36) = $0.05 \times (31)$

Total fabric heat loss

(33) + (36) =

68.05 (37)

Ventilation heat loss calculated monthly

(38)m = $0.33 \times (25)m \times (5)$

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m= 53.7	53.39	53.08	51.62	51.35	50.08	50.08	49.84	50.57	51.35	51.9	52.48

(38)

Heat transfer coefficient, W/K

(39)m = (37) + (38)m

(39)m= 121.75	121.43	121.12	119.67	119.39	118.12	118.12	117.89	118.61	119.39	119.94	120.52
Average = Sum(39) _{1...12} /12=											119.66 (39)

Heat loss parameter (HLP), W/m²K

(40)m = (39)m ÷ (4)

(40)m= 1.28	1.28	1.27	1.26	1.25	1.24	1.24	1.24	1.25	1.25	1.26	1.27
Average = Sum(40) _{1...12} /12=											1.26 (40)

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(41)m= 31	28	31	30	31	30	31	31	30	31	30	31

(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

2.69 (42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (TFA - 13.9)^2)] + 0.0013 \times (TFA - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd,average = (25 \times N) + 36$

98.1 (43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m= 107.91	103.98	100.06	96.14	92.21	88.29	88.29	92.21	96.14	100.06	103.98	107.91
Total = Sum(44) _{1...12} =											1177.17 (44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m= 160.02	139.96	144.42	125.91	120.82	104.25	96.61	110.86	112.18	130.74	142.71	154.97
Total = Sum(45) _{1...12} =											1543.46 (45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m= 24	20.99	21.66	18.89	18.12	15.64	14.49	16.63	16.83	19.61	21.41	23.25
-----------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(46)

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

150 (47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

1.39 (48)

Temperature factor from Table 2b

0.54 (49)

Energy lost from water storage, kWh/year

(48) x (49) = 0.75 (50)

b) If manufacturer's declared cylinder loss factor is not known:

0.75 (50)

Hot water storage loss factor from Table 2 (kWh/litre/day)

0 (51)

If community heating see section 4.3

Volume factor from Table 2a

0 (52)

Temperature factor from Table 2b

0 (53)

TER WorkSheet: New dwelling design stage

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g Table 6b	FF Table 6c	Gains (W)
North	0.9x 0.77	x 1.91	x 10.63	x 0.63	x 0.7	= 6.21 (74)
North	0.9x 0.77	x 1.57	x 10.63	x 0.63	x 0.7	= 5.1 (74)
North	0.9x 0.77	x 1.53	x 10.63	x 0.63	x 0.7	= 4.97 (74)
North	0.9x 0.77	x 1.49	x 10.63	x 0.63	x 0.7	= 4.84 (74)
North	0.9x 0.77	x 1	x 10.63	x 0.63	x 0.7	= 3.25 (74)
North	0.9x 0.77	x 1.91	x 20.32	x 0.63	x 0.7	= 11.86 (74)
North	0.9x 0.77	x 1.57	x 20.32	x 0.63	x 0.7	= 9.75 (74)
North	0.9x 0.77	x 1.53	x 20.32	x 0.63	x 0.7	= 9.5 (74)
North	0.9x 0.77	x 1.49	x 20.32	x 0.63	x 0.7	= 9.25 (74)
North	0.9x 0.77	x 1	x 20.32	x 0.63	x 0.7	= 6.21 (74)
North	0.9x 0.77	x 1.91	x 34.53	x 0.63	x 0.7	= 20.16 (74)
North	0.9x 0.77	x 1.57	x 34.53	x 0.63	x 0.7	= 16.57 (74)
North	0.9x 0.77	x 1.53	x 34.53	x 0.63	x 0.7	= 16.15 (74)
North	0.9x 0.77	x 1.49	x 34.53	x 0.63	x 0.7	= 15.72 (74)
North	0.9x 0.77	x 1	x 34.53	x 0.63	x 0.7	= 10.55 (74)
North	0.9x 0.77	x 1.91	x 55.46	x 0.63	x 0.7	= 32.38 (74)
North	0.9x 0.77	x 1.57	x 55.46	x 0.63	x 0.7	= 26.61 (74)
North	0.9x 0.77	x 1.53	x 55.46	x 0.63	x 0.7	= 25.93 (74)
North	0.9x 0.77	x 1.49	x 55.46	x 0.63	x 0.7	= 25.26 (74)
North	0.9x 0.77	x 1	x 55.46	x 0.63	x 0.7	= 16.95 (74)
North	0.9x 0.77	x 1.91	x 74.72	x 0.63	x 0.7	= 43.61 (74)
North	0.9x 0.77	x 1.57	x 74.72	x 0.63	x 0.7	= 35.85 (74)
North	0.9x 0.77	x 1.53	x 74.72	x 0.63	x 0.7	= 34.94 (74)
North	0.9x 0.77	x 1.49	x 74.72	x 0.63	x 0.7	= 34.02 (74)
North	0.9x 0.77	x 1	x 74.72	x 0.63	x 0.7	= 22.83 (74)
North	0.9x 0.77	x 1.91	x 79.99	x 0.63	x 0.7	= 46.69 (74)
North	0.9x 0.77	x 1.57	x 79.99	x 0.63	x 0.7	= 38.38 (74)
North	0.9x 0.77	x 1.53	x 79.99	x 0.63	x 0.7	= 37.4 (74)
North	0.9x 0.77	x 1.49	x 79.99	x 0.63	x 0.7	= 36.42 (74)
North	0.9x 0.77	x 1	x 79.99	x 0.63	x 0.7	= 24.44 (74)
North	0.9x 0.77	x 1.91	x 74.68	x 0.63	x 0.7	= 43.59 (74)
North	0.9x 0.77	x 1.57	x 74.68	x 0.63	x 0.7	= 35.83 (74)
North	0.9x 0.77	x 1.53	x 74.68	x 0.63	x 0.7	= 34.92 (74)
North	0.9x 0.77	x 1.49	x 74.68	x 0.63	x 0.7	= 34 (74)
North	0.9x 0.77	x 1	x 74.68	x 0.63	x 0.7	= 22.82 (74)
North	0.9x 0.77	x 1.91	x 59.25	x 0.63	x 0.7	= 34.58 (74)
North	0.9x 0.77	x 1.57	x 59.25	x 0.63	x 0.7	= 28.43 (74)
North	0.9x 0.77	x 1.53	x 59.25	x 0.63	x 0.7	= 27.7 (74)
North	0.9x 0.77	x 1.49	x 59.25	x 0.63	x 0.7	= 26.98 (74)

TER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	1	x	59.25	x	0.63	x	0.7	=	18.11	(74)
North	0.9x	0.77	x	1.91	x	41.52	x	0.63	x	0.7	=	24.23	(74)
North	0.9x	0.77	x	1.57	x	41.52	x	0.63	x	0.7	=	19.92	(74)
North	0.9x	0.77	x	1.53	x	41.52	x	0.63	x	0.7	=	19.41	(74)
North	0.9x	0.77	x	1.49	x	41.52	x	0.63	x	0.7	=	18.91	(74)
North	0.9x	0.77	x	1	x	41.52	x	0.63	x	0.7	=	12.69	(74)
North	0.9x	0.77	x	1.91	x	24.19	x	0.63	x	0.7	=	14.12	(74)
North	0.9x	0.77	x	1.57	x	24.19	x	0.63	x	0.7	=	11.61	(74)
North	0.9x	0.77	x	1.53	x	24.19	x	0.63	x	0.7	=	11.31	(74)
North	0.9x	0.77	x	1.49	x	24.19	x	0.63	x	0.7	=	11.01	(74)
North	0.9x	0.77	x	1	x	24.19	x	0.63	x	0.7	=	7.39	(74)
North	0.9x	0.77	x	1.91	x	13.12	x	0.63	x	0.7	=	7.66	(74)
North	0.9x	0.77	x	1.57	x	13.12	x	0.63	x	0.7	=	6.29	(74)
North	0.9x	0.77	x	1.53	x	13.12	x	0.63	x	0.7	=	6.13	(74)
North	0.9x	0.77	x	1.49	x	13.12	x	0.63	x	0.7	=	5.97	(74)
North	0.9x	0.77	x	1	x	13.12	x	0.63	x	0.7	=	4.01	(74)
North	0.9x	0.77	x	1.91	x	8.86	x	0.63	x	0.7	=	5.17	(74)
North	0.9x	0.77	x	1.57	x	8.86	x	0.63	x	0.7	=	4.25	(74)
North	0.9x	0.77	x	1.53	x	8.86	x	0.63	x	0.7	=	4.14	(74)
North	0.9x	0.77	x	1.49	x	8.86	x	0.63	x	0.7	=	4.04	(74)
North	0.9x	0.77	x	1	x	8.86	x	0.63	x	0.7	=	2.71	(74)
East	0.9x	0.77	x	1.91	x	19.64	x	0.63	x	0.7	=	11.46	(76)
East	0.9x	0.77	x	2.97	x	19.64	x	0.63	x	0.7	=	17.83	(76)
East	0.9x	0.77	x	1.91	x	19.64	x	0.63	x	0.7	=	11.46	(76)
East	0.9x	0.77	x	1.91	x	38.42	x	0.63	x	0.7	=	22.43	(76)
East	0.9x	0.77	x	2.97	x	38.42	x	0.63	x	0.7	=	34.87	(76)
East	0.9x	0.77	x	1.91	x	38.42	x	0.63	x	0.7	=	22.43	(76)
East	0.9x	0.77	x	1.91	x	63.27	x	0.63	x	0.7	=	36.93	(76)
East	0.9x	0.77	x	2.97	x	63.27	x	0.63	x	0.7	=	57.43	(76)
East	0.9x	0.77	x	1.91	x	63.27	x	0.63	x	0.7	=	36.93	(76)
East	0.9x	0.77	x	1.91	x	92.28	x	0.63	x	0.7	=	53.87	(76)
East	0.9x	0.77	x	2.97	x	92.28	x	0.63	x	0.7	=	83.76	(76)
East	0.9x	0.77	x	1.91	x	92.28	x	0.63	x	0.7	=	53.87	(76)
East	0.9x	0.77	x	1.91	x	113.09	x	0.63	x	0.7	=	66.01	(76)
East	0.9x	0.77	x	2.97	x	113.09	x	0.63	x	0.7	=	102.65	(76)
East	0.9x	0.77	x	1.91	x	113.09	x	0.63	x	0.7	=	66.01	(76)
East	0.9x	0.77	x	1.91	x	115.77	x	0.63	x	0.7	=	67.58	(76)
East	0.9x	0.77	x	2.97	x	115.77	x	0.63	x	0.7	=	105.08	(76)
East	0.9x	0.77	x	1.91	x	115.77	x	0.63	x	0.7	=	67.58	(76)
East	0.9x	0.77	x	1.91	x	110.22	x	0.63	x	0.7	=	64.34	(76)
East	0.9x	0.77	x	2.97	x	110.22	x	0.63	x	0.7	=	100.04	(76)

TER WorkSheet: New dwelling design stage

East	0.9x	0.77	x	1.91	x	110.22	x	0.63	x	0.7	=	64.34	(76)
East	0.9x	0.77	x	1.91	x	94.68	x	0.63	x	0.7	=	55.26	(76)
East	0.9x	0.77	x	2.97	x	94.68	x	0.63	x	0.7	=	85.93	(76)
East	0.9x	0.77	x	1.91	x	94.68	x	0.63	x	0.7	=	55.26	(76)
East	0.9x	0.77	x	1.91	x	73.59	x	0.63	x	0.7	=	42.96	(76)
East	0.9x	0.77	x	2.97	x	73.59	x	0.63	x	0.7	=	66.79	(76)
East	0.9x	0.77	x	1.91	x	73.59	x	0.63	x	0.7	=	42.96	(76)
East	0.9x	0.77	x	1.91	x	45.59	x	0.63	x	0.7	=	26.61	(76)
East	0.9x	0.77	x	2.97	x	45.59	x	0.63	x	0.7	=	41.38	(76)
East	0.9x	0.77	x	1.91	x	45.59	x	0.63	x	0.7	=	26.61	(76)
East	0.9x	0.77	x	1.91	x	24.49	x	0.63	x	0.7	=	14.29	(76)
East	0.9x	0.77	x	2.97	x	24.49	x	0.63	x	0.7	=	22.23	(76)
East	0.9x	0.77	x	1.91	x	24.49	x	0.63	x	0.7	=	14.29	(76)
East	0.9x	0.77	x	1.91	x	16.15	x	0.63	x	0.7	=	9.43	(76)
East	0.9x	0.77	x	2.97	x	16.15	x	0.63	x	0.7	=	14.66	(76)
East	0.9x	0.77	x	1.91	x	16.15	x	0.63	x	0.7	=	9.43	(76)
South	0.9x	0.77	x	1.91	x	46.75	x	0.63	x	0.7	=	27.29	(78)
South	0.9x	0.77	x	1	x	46.75	x	0.63	x	0.7	=	14.29	(78)
South	0.9x	0.77	x	2.72	x	46.75	x	0.63	x	0.7	=	38.86	(78)
South	0.9x	0.77	x	1.91	x	76.57	x	0.63	x	0.7	=	44.69	(78)
South	0.9x	0.77	x	1	x	76.57	x	0.63	x	0.7	=	23.4	(78)
South	0.9x	0.77	x	2.72	x	76.57	x	0.63	x	0.7	=	63.65	(78)
South	0.9x	0.77	x	1.91	x	97.53	x	0.63	x	0.7	=	56.93	(78)
South	0.9x	0.77	x	1	x	97.53	x	0.63	x	0.7	=	29.81	(78)
South	0.9x	0.77	x	2.72	x	97.53	x	0.63	x	0.7	=	81.08	(78)
South	0.9x	0.77	x	1.91	x	110.23	x	0.63	x	0.7	=	64.35	(78)
South	0.9x	0.77	x	1	x	110.23	x	0.63	x	0.7	=	33.69	(78)
South	0.9x	0.77	x	2.72	x	110.23	x	0.63	x	0.7	=	91.63	(78)
South	0.9x	0.77	x	1.91	x	114.87	x	0.63	x	0.7	=	67.05	(78)
South	0.9x	0.77	x	1	x	114.87	x	0.63	x	0.7	=	35.11	(78)
South	0.9x	0.77	x	2.72	x	114.87	x	0.63	x	0.7	=	95.49	(78)
South	0.9x	0.77	x	1.91	x	110.55	x	0.63	x	0.7	=	64.53	(78)
South	0.9x	0.77	x	1	x	110.55	x	0.63	x	0.7	=	33.78	(78)
South	0.9x	0.77	x	2.72	x	110.55	x	0.63	x	0.7	=	91.89	(78)
South	0.9x	0.77	x	1.91	x	108.01	x	0.63	x	0.7	=	63.05	(78)
South	0.9x	0.77	x	1	x	108.01	x	0.63	x	0.7	=	33.01	(78)
South	0.9x	0.77	x	2.72	x	108.01	x	0.63	x	0.7	=	89.79	(78)
South	0.9x	0.77	x	1.91	x	104.89	x	0.63	x	0.7	=	61.23	(78)
South	0.9x	0.77	x	1	x	104.89	x	0.63	x	0.7	=	32.06	(78)
South	0.9x	0.77	x	2.72	x	104.89	x	0.63	x	0.7	=	87.2	(78)
South	0.9x	0.77	x	1.91	x	101.89	x	0.63	x	0.7	=	59.47	(78)

TER WorkSheet: New dwelling design stage

South	0.9x	0.77	x	1	x	101.89	x	0.63	x	0.7	=	31.14	(78)
South	0.9x	0.77	x	2.72	x	101.89	x	0.63	x	0.7	=	84.69	(78)
South	0.9x	0.77	x	1.91	x	82.59	x	0.63	x	0.7	=	48.21	(78)
South	0.9x	0.77	x	1	x	82.59	x	0.63	x	0.7	=	25.24	(78)
South	0.9x	0.77	x	2.72	x	82.59	x	0.63	x	0.7	=	68.65	(78)
South	0.9x	0.77	x	1.91	x	55.42	x	0.63	x	0.7	=	32.35	(78)
South	0.9x	0.77	x	1	x	55.42	x	0.63	x	0.7	=	16.94	(78)
South	0.9x	0.77	x	2.72	x	55.42	x	0.63	x	0.7	=	46.07	(78)
South	0.9x	0.77	x	1.91	x	40.4	x	0.63	x	0.7	=	23.58	(78)
South	0.9x	0.77	x	1	x	40.4	x	0.63	x	0.7	=	12.35	(78)
South	0.9x	0.77	x	2.72	x	40.4	x	0.63	x	0.7	=	33.58	(78)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m=	145.57	258.05	378.26	508.29	603.58	613.78	585.73	512.74	423.17	292.14	176.24	123.34	(83)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=	604.01	714.32	819.67	925.59	996.22	982.76	939.39	872.68	795.53	688.84	600.91	569.18	(84)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m=	1	0.99	0.98	0.95	0.87	0.7	0.54	0.6	0.84	0.97	0.99	1	(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	19.62	19.8	20.08	20.45	20.76	20.94	20.99	20.98	20.85	20.45	19.97	19.59	(87)
--------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	19.86	19.86	19.86	19.87	19.88	19.89	19.89	19.89	19.88	19.88	19.87	19.87	(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	1	0.99	0.98	0.93	0.82	0.61	0.41	0.46	0.76	0.96	0.99	1	(89)
--------	---	------	------	------	------	------	------	------	------	------	------	---	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.03	18.29	18.71	19.24	19.65	19.85	19.88	19.88	19.77	19.24	18.55	18	(90)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	----	------

$$fLA = \text{Living area} \div 4 =$$

0.36

(91)

Mean internal temperature (for the whole dwelling) = fLA × T1 + (1 – fLA) × T2

(92)m=	18.61	18.84	19.21	19.68	20.05	20.24	20.28	20.28	20.16	19.68	19.06	18.58	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	18.61	18.84	19.21	19.68	20.05	20.24	20.28	20.28	20.16	19.68	19.06	18.58	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that $Ti,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	1	0.99	0.97	0.93	0.82	0.64	0.46	0.51	0.78	0.95	0.99	1	(94)
--------	---	------	------	------	------	------	------	------	------	------	------	---	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	601.05	706.66	798.46	860.46	821.49	628.25	428.91	446.88	621.18	656.45	594.89	567.04	(95)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

TER WorkSheet: New dwelling design stage

Heat loss rate for mean internal temperature, Lm , W =[(39)m x [(93)m– (96)m]

(97)m=	1742.26	1692.96	1539.27	1289.88	996.97	666.56	435.11	457.33	718.91	1083.9	1434.84	1732.87	(97)
--------	---------	---------	---------	---------	--------	--------	--------	--------	--------	--------	---------	---------	------

Space heating requirement for each month, kWh/month = $0.024 \times [(97)m – (95)m] \times (41)m$

(98)m=	849.06	662.79	551.17	309.18	130.56	0	0	0	0	318.02	604.76	867.38	
--------	--------	--------	--------	--------	--------	---	---	---	---	--------	--------	--------	--

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1...5,9...12} = 4292.92 \quad (98)$$

Space heating requirement in kWh/m²/year

$$45.09 \quad (99)$$

9a. Energy requirements – Individual heating systems including micro-CHP

Space heating:

Fraction of space heat from secondary/supplementary system

$$0 \quad (201)$$

Fraction of space heat from main system(s)

$$(202) = 1 - (201) = 1 \quad (202)$$

Fraction of total heating from main system 1

$$(204) = (202) \times [1 - (203)] = 1 \quad (204)$$

Efficiency of main space heating system 1

$$93.5 \quad (206)$$

Efficiency of secondary/supplementary heating system, %

$$0 \quad (208)$$

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

849.06	662.79	551.17	309.18	130.56	0	0	0	0	318.02	604.76	867.38	
--------	--------	--------	--------	--------	---	---	---	---	--------	--------	--------	--

$$(211)m = \{(98)m \times (204)\} \times 100 \div (206) = 908.09 \quad (211)$$

908.09	708.87	589.48	330.67	139.63	0	0	0	0	340.13	646.8	927.68	
--------	--------	--------	--------	--------	---	---	---	---	--------	-------	--------	--

$$\text{Total (kWh/year)} = \text{Sum}(211)_{1...5,10...12} = 4591.36 \quad (211)$$

Space heating fuel (secondary), kWh/month

$$= \{(98)m \times (201)\} \times 100 \div (208)$$

(215)m=	0	0	0	0	0	0	0	0	0	0	0	0	
---------	---	---	---	---	---	---	---	---	---	---	---	---	--

$$\text{Total (kWh/year)} = \text{Sum}(215)_{1...5,10...12} = 0 \quad (215)$$

Water heating

Output from water heater (calculated above)

206.62	182.04	191.02	171	167.41	149.35	143.2	157.45	157.27	177.33	187.8	201.57	
--------	--------	--------	-----	--------	--------	-------	--------	--------	--------	-------	--------	--

Efficiency of water heater

$$79.8 \quad (216)$$

(217)m=	88.19	87.96	87.48	86.38	84.16	79.8	79.8	79.8	79.8	86.35	87.71	88.27	
---------	-------	-------	-------	-------	-------	------	------	------	------	-------	-------	-------	--

$$(217)$$

Fuel for water heating, kWh/month

$$(219)m = (64)m \times 100 \div (217)m$$

(219)m=	234.3	206.96	218.35	197.98	198.92	187.15	179.45	197.31	197.09	205.35	214.11	228.36	
---------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--

$$\text{Total} = \text{Sum}(219a)_{1...12} = 2465.34 \quad (219)$$

Annual totals

Space heating fuel used, main system 1

$$\text{kWh/year}$$

$$4591.36$$

Water heating fuel used

$$2465.34$$

Electricity for pumps, fans and electric keep-hot

central heating pump:

$$30 \quad (230c)$$

boiler with a fan-assisted flue

$$45 \quad (230e)$$

Total electricity for the above, kWh/year

$$\text{sum of (230a)...(230g)} = 75 \quad (231)$$

Electricity for lighting

$$390.97 \quad (232)$$

12a. CO2 emissions – Individual heating systems including micro-CHP

TER WorkSheet: New dwelling design stage

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating (main system 1)	(211) x	0.216	= 991.73 (261)
Space heating (secondary)	(215) x	0.519	= 0 (263)
Water heating	(219) x	0.216	= 532.51 (264)
Space and water heating	(261) + (262) + (263) + (264) =		1524.25 (265)
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	= 38.93 (267)
Electricity for lighting	(232) x	0.519	= 202.91 (268)
Total CO2, kg/year		sum of (265)...(271) =	1766.09 (272)
TER =			18.55 (273)

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name: John Simpson **Stroma Number:** STRO006273
Software Name: Stroma FSAP 2012 **Software Version:** Version: 1.0.5.8

Property Address: AC 106 - Be Lean

Address : AC 106, Aspen Court, Maitland Park Estate, London, NW3 2EH

1. Overall dwelling dimensions:

	Area(m ²)	Av. Height(m)	Volume(m ³)
Ground floor	75.1	(1a) x 2.6	(3a) 195.26
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	75.1	(4)	
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	195.26 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m ³ per hour
Number of chimneys	0	+	0	= 0	x 40 = 0 (6a)
Number of open flues	0	+	0	= 0	x 20 = 0 (6b)
Number of intermittent fans					x 10 = 0 (7a)
Number of passive vents					x 10 = 0 (7b)
Number of flueless gas fires					x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 0 ÷ (5) = 0 (8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] = 0 (15)

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) =

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area 2 (17)

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] = 0.85 (20)

Infiltration rate incorporating shelter factor (21) = (18) x (20) = 0.08 (21)

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(22)m= 5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7

Wind Factor (22a)m = (22)m ÷ 4

(22a)m= 1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
--------------	------	------	-----	------	------	------	------	---	------	------	------

DER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.11	0.11	0.1	0.09	0.09	0.08	0.08	0.08	0.08	0.09	0.1	0.1
------	------	-----	------	------	------	------	------	------	------	-----	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.21	0.21	0.22
---------	------	------	------	------	------	-----	-----	-----	------	------	------

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.2	0.21	0.21	0.22
--------	------	------	------	------	------	-----	-----	-----	-----	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m²)	Openings m²	Net Area A ,m²	U-value W/m²K	A X U (W/K)	k-value kJ/m²·K	A X k kJ/K
Windows Type 1			1.67	x1/[1/(1.4)+ 0.04] =	2.21		(27)
Windows Type 2			1.66	x1/[1/(1.4)+ 0.04] =	2.2		(27)
Windows Type 3			6.18	x1/[1/(1.4)+ 0.04] =	8.19		(27)
Windows Type 4			2.24	x1/[1/(1.4)+ 0.04] =	2.97		(27)
Windows Type 5			1.5	x1/[1/(1.4)+ 0.04] =	1.99		(27)
Windows Type 6			4.1	x1/[1/(1.4)+ 0.04] =	5.44		(27)
Walls	47.92	17.35	30.57	x 0.12 =	3.67		(29)
Total area of elements, m²			47.92				(31)
Party wall			44.62	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 26.67 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 7.43 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 34.1 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	14.55	14.42	14.28	13.6	13.46	12.77	12.77	12.64	13.05	13.46	13.73	14.01

(38)

Heat transfer coefficient, W/K (39)m = (37) + (38)m

(39)m=	48.65	48.51	48.38	47.69	47.55	46.87	46.87	46.73	47.14	47.55	47.83	48.1
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Stroma FSAP 2012 Version: 1.0.5.8 (SAP 9.92) - http://www.stroma.com Average = Sum(39)₁...₁₂ / 12= 47.66 (39)

Page 2 of 8

DER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	0.65	0.65	0.64	0.64	0.63	0.62	0.62	0.62	0.63	0.63	0.64	0.64	
													Average = Sum(40) _{1...12} /12=

$$(40)m = (39)m \div (4)$$

0.63 (40)

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(41)m=	31	28	31	30	31	30	31	31	30	31	30	31

(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

2.36

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

90.33

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	99.36	95.75	92.14	88.52	84.91	81.3	81.3	84.91	88.52	92.14	95.75	99.36
--------	-------	-------	-------	-------	-------	------	------	-------	-------	-------	-------	-------

$$\text{Total} = \text{Sum}(44)_{1...12} =$$

1083.95

(44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	147.35	128.87	132.99	115.94	111.25	96	88.96	102.08	103.3	120.38	131.41	142.7
--------	--------	--------	--------	--------	--------	----	-------	--------	-------	--------	--------	-------

$$\text{Total} = \text{Sum}(45)_{1...12} =$$

1421.23

(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	22.1	19.33	19.95	17.39	16.69	14.4	13.34	15.31	15.49	18.06	19.71	21.41
--------	------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------

(46)

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0

(48)

Temperature factor from Table 2b

0

(49)

Energy lost from water storage, kWh/year

$$(48) \times (49) =$$

110

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0.02

(51)

If community heating see section 4.3

Volume factor from Table 2a

1.03

(52)

Temperature factor from Table 2b

0.6

(53)

Energy lost from water storage, kWh/year

$$(47) \times (51) \times (52) \times (53) =$$

1.03

(54)

Enter (50) or (54) in (55)

1.03

(55)

Water storage loss calculated for each month

$$((56)m = (55) \times (41)m)$$

(56)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(56)

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(57)

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(59)

DER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	202.63	178.8	188.26	169.43	166.52	149.49	144.23	157.36	156.79	175.66	184.9	197.98	(62)
--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	202.63	178.8	188.26	169.43	166.52	149.49	144.23	157.36	156.79	175.66	184.9	197.98	
Output from water heater (annual) 1...12											2072.07	(64)	

Heat gains from water heating, kWh/month 0.25 [$0.85 \times (45)m + (61)m$] + $0.8 \times [(46)m + (57)m + (59)m]$]

(65)m=	93.22	82.79	88.44	81.35	81.21	74.71	73.8	78.16	77.14	84.25	86.49	91.67	(65)
--------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(66)m=	118.17	118.17	118.17	118.17	118.17	118.17	118.17	118.17	118.17	118.17	118.17	118.17

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	18.62	16.54	13.45	10.18	7.61	6.43	6.94	9.03	12.12	15.38	17.96	19.14	(67)
--------	-------	-------	-------	-------	------	------	------	------	-------	-------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	208.9	211.06	205.6	193.97	179.29	165.5	156.28	154.11	159.57	171.2	185.88	199.68	(68)
--------	-------	--------	-------	--------	--------	-------	--------	--------	--------	-------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	34.82	34.82	34.82	34.82	34.82	34.82	34.82	34.82	34.82	34.82	34.82	34.82	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	0	0	0	0	0	0	0	0	0	0	0	0	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-94.53	-94.53	-94.53	-94.53	-94.53	-94.53	-94.53	-94.53	-94.53	-94.53	-94.53	-94.53	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	125.29	123.2	118.87	112.98	109.16	103.77	99.19	105.06	107.14	113.24	120.12	123.21	(72)
--------	--------	-------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	------

Total internal gains = $(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$

(73)m=	411.26	409.26	396.37	375.59	354.51	334.14	320.87	326.65	337.28	358.27	382.41	400.48	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_ Table 6b	FF Table 6c	Gains (W)
East	0.9x	0.77	x 1.66	x 19.64	x 0.4	x 0.8 = 7.23 (76)
East	0.9x	0.77	x 6.18	x 19.64	x 0.4	x 0.8 = 26.92 (76)
East	0.9x	0.77	x 4.1	x 19.64	x 0.4	x 0.8 = 17.86 (76)
East	0.9x	0.77	x 1.66	x 38.42	x 0.4	x 0.8 = 14.14 (76)
East	0.9x	0.77	x 6.18	x 38.42	x 0.4	x 0.8 = 52.65 (76)

DER WorkSheet: New dwelling design stage

East	0.9x	0.77	x	4.1	x	38.42	x	0.4	x	0.8	=	34.93	(76)
East	0.9x	0.77	x	1.66	x	63.27	x	0.4	x	0.8	=	23.29	(76)
East	0.9x	0.77	x	6.18	x	63.27	x	0.4	x	0.8	=	86.71	(76)
East	0.9x	0.77	x	4.1	x	63.27	x	0.4	x	0.8	=	57.53	(76)
East	0.9x	0.77	x	1.66	x	92.28	x	0.4	x	0.8	=	33.97	(76)
East	0.9x	0.77	x	6.18	x	92.28	x	0.4	x	0.8	=	126.47	(76)
East	0.9x	0.77	x	4.1	x	92.28	x	0.4	x	0.8	=	83.9	(76)
East	0.9x	0.77	x	1.66	x	113.09	x	0.4	x	0.8	=	41.63	(76)
East	0.9x	0.77	x	6.18	x	113.09	x	0.4	x	0.8	=	154.99	(76)
East	0.9x	0.77	x	4.1	x	113.09	x	0.4	x	0.8	=	102.83	(76)
East	0.9x	0.77	x	1.66	x	115.77	x	0.4	x	0.8	=	42.62	(76)
East	0.9x	0.77	x	6.18	x	115.77	x	0.4	x	0.8	=	158.66	(76)
East	0.9x	0.77	x	4.1	x	115.77	x	0.4	x	0.8	=	105.26	(76)
East	0.9x	0.77	x	1.66	x	110.22	x	0.4	x	0.8	=	40.57	(76)
East	0.9x	0.77	x	6.18	x	110.22	x	0.4	x	0.8	=	151.05	(76)
East	0.9x	0.77	x	4.1	x	110.22	x	0.4	x	0.8	=	100.21	(76)
East	0.9x	0.77	x	1.66	x	94.68	x	0.4	x	0.8	=	34.85	(76)
East	0.9x	0.77	x	6.18	x	94.68	x	0.4	x	0.8	=	129.75	(76)
East	0.9x	0.77	x	4.1	x	94.68	x	0.4	x	0.8	=	86.08	(76)
East	0.9x	0.77	x	1.66	x	73.59	x	0.4	x	0.8	=	27.09	(76)
East	0.9x	0.77	x	6.18	x	73.59	x	0.4	x	0.8	=	100.85	(76)
East	0.9x	0.77	x	4.1	x	73.59	x	0.4	x	0.8	=	66.91	(76)
East	0.9x	0.77	x	1.66	x	45.59	x	0.4	x	0.8	=	16.78	(76)
East	0.9x	0.77	x	6.18	x	45.59	x	0.4	x	0.8	=	62.48	(76)
East	0.9x	0.77	x	4.1	x	45.59	x	0.4	x	0.8	=	41.45	(76)
East	0.9x	0.77	x	1.66	x	24.49	x	0.4	x	0.8	=	9.01	(76)
East	0.9x	0.77	x	6.18	x	24.49	x	0.4	x	0.8	=	33.56	(76)
East	0.9x	0.77	x	4.1	x	24.49	x	0.4	x	0.8	=	22.27	(76)
East	0.9x	0.77	x	1.66	x	16.15	x	0.4	x	0.8	=	5.95	(76)
East	0.9x	0.77	x	6.18	x	16.15	x	0.4	x	0.8	=	22.13	(76)
East	0.9x	0.77	x	4.1	x	16.15	x	0.4	x	0.8	=	14.68	(76)
West	0.9x	0.77	x	1.67	x	19.64	x	0.4	x	0.8	=	7.27	(80)
West	0.9x	0.77	x	2.24	x	19.64	x	0.4	x	0.8	=	9.76	(80)
West	0.9x	0.77	x	1.5	x	19.64	x	0.4	x	0.8	=	6.53	(80)
West	0.9x	0.77	x	1.67	x	38.42	x	0.4	x	0.8	=	14.23	(80)
West	0.9x	0.77	x	2.24	x	38.42	x	0.4	x	0.8	=	19.09	(80)
West	0.9x	0.77	x	1.5	x	38.42	x	0.4	x	0.8	=	12.78	(80)
West	0.9x	0.77	x	1.67	x	63.27	x	0.4	x	0.8	=	23.43	(80)
West	0.9x	0.77	x	2.24	x	63.27	x	0.4	x	0.8	=	31.43	(80)
West	0.9x	0.77	x	1.5	x	63.27	x	0.4	x	0.8	=	21.05	(80)
West	0.9x	0.77	x	1.67	x	92.28	x	0.4	x	0.8	=	34.17	(80)

DER WorkSheet: New dwelling design stage

West	0.9x	0.77	x	2.24	x	92.28	x	0.4	x	0.8	=	45.84	(80)
West	0.9x	0.77	x	1.5	x	92.28	x	0.4	x	0.8	=	30.7	(80)
West	0.9x	0.77	x	1.67	x	113.09	x	0.4	x	0.8	=	41.88	(80)
West	0.9x	0.77	x	2.24	x	113.09	x	0.4	x	0.8	=	56.18	(80)
West	0.9x	0.77	x	1.5	x	113.09	x	0.4	x	0.8	=	37.62	(80)
West	0.9x	0.77	x	1.67	x	115.77	x	0.4	x	0.8	=	42.87	(80)
West	0.9x	0.77	x	2.24	x	115.77	x	0.4	x	0.8	=	57.51	(80)
West	0.9x	0.77	x	1.5	x	115.77	x	0.4	x	0.8	=	38.51	(80)
West	0.9x	0.77	x	1.67	x	110.22	x	0.4	x	0.8	=	40.82	(80)
West	0.9x	0.77	x	2.24	x	110.22	x	0.4	x	0.8	=	54.75	(80)
West	0.9x	0.77	x	1.5	x	110.22	x	0.4	x	0.8	=	36.66	(80)
West	0.9x	0.77	x	1.67	x	94.68	x	0.4	x	0.8	=	35.06	(80)
West	0.9x	0.77	x	2.24	x	94.68	x	0.4	x	0.8	=	47.03	(80)
West	0.9x	0.77	x	1.5	x	94.68	x	0.4	x	0.8	=	31.49	(80)
West	0.9x	0.77	x	1.67	x	73.59	x	0.4	x	0.8	=	27.25	(80)
West	0.9x	0.77	x	2.24	x	73.59	x	0.4	x	0.8	=	36.55	(80)
West	0.9x	0.77	x	1.5	x	73.59	x	0.4	x	0.8	=	24.48	(80)
West	0.9x	0.77	x	1.67	x	45.59	x	0.4	x	0.8	=	16.88	(80)
West	0.9x	0.77	x	2.24	x	45.59	x	0.4	x	0.8	=	22.65	(80)
West	0.9x	0.77	x	1.5	x	45.59	x	0.4	x	0.8	=	15.16	(80)
West	0.9x	0.77	x	1.67	x	24.49	x	0.4	x	0.8	=	9.07	(80)
West	0.9x	0.77	x	2.24	x	24.49	x	0.4	x	0.8	=	12.16	(80)
West	0.9x	0.77	x	1.5	x	24.49	x	0.4	x	0.8	=	8.15	(80)
West	0.9x	0.77	x	1.67	x	16.15	x	0.4	x	0.8	=	5.98	(80)
West	0.9x	0.77	x	2.24	x	16.15	x	0.4	x	0.8	=	8.02	(80)
West	0.9x	0.77	x	1.5	x	16.15	x	0.4	x	0.8	=	5.37	(80)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m=

75.57	147.82	243.45	355.05	435.13	445.43	424.07	364.27	283.14	175.41	94.22	62.14
-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	-------

 (83)

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=

486.83	557.08	639.82	730.64	789.64	779.57	744.94	690.91	620.42	533.68	476.63	462.62
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m= 0.99	0.98	0.93	0.76	0.56	0.38	0.28	0.31	0.52	0.86	0.98	1		(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=

20.55	20.68	20.85	20.97	21	21	21	21	21	20.95	20.73	20.52
-------	-------	-------	-------	----	----	----	----	----	-------	-------	-------

 (87)

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=

20.39	20.39	20.39	20.4	20.4	20.41	20.41	20.41	20.41	20.4	20.4	20.39
-------	-------	-------	------	------	-------	-------	-------	-------	------	------	-------

 (88)

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=

0.99	0.98	0.91	0.73	0.52	0.35	0.24	0.27	0.48	0.82	0.98	0.99
------	------	------	------	------	------	------	------	------	------	------	------

 (89)

DER WorkSheet: New dwelling design stage

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	19.78	19.97	20.21	20.37	20.4	20.41	20.41	20.41	20.4	20.35	20.05	19.75	(90)
	$fLA = \text{Living area} \div (4) =$												0.35 (91)

Mean internal temperature (for the whole dwelling) = $fLA \times T1 + (1 - fLA) \times T2$

(92)m=	20.05	20.22	20.44	20.58	20.61	20.62	20.62	20.62	20.61	20.56	20.29	20.02	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	20.05	20.22	20.44	20.58	20.61	20.62	20.62	20.62	20.61	20.56	20.29	20.02	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set T_i to the mean internal temperature obtained at step 11 of Table 9b, so that $T_{i,m} = (76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, h_m :

(94)m=	0.99	0.97	0.91	0.74	0.54	0.36	0.25	0.29	0.49	0.83	0.97	0.99	(94)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Useful gains, $h_m G_m$, $W = (94)m \times (84)m$

(95)m=	482.35	542.81	584.12	541.93	422.52	281.91	188.21	197.05	306.6	444.09	464.23	459.57	(95)
--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, L_m , $W = [(39)m \times [(93)m - (96)m]]$

(97)m=	766.28	743.1	674.15	557.13	423.63	281.95	188.21	197.06	307.03	473.49	630.77	760.97	(97)
--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Space heating requirement for each month, $kWh/month = 0.024 \times [(97)m - (95)m] \times (41)m$

(98)m=	211.24	134.6	66.98	10.95	0.83	0	0	0	21.88	119.91	224.24	Total per year (kWh/year) = Sum(98) _{1..5,9..12} =	790.63 (98)
--------	--------	-------	-------	-------	------	---	---	---	-------	--------	--------	---	-------------

Space heating requirement in $kWh/m^2/year$

10.53 (99)

9b. Energy requirements – Community heating scheme

This part is used for space heating, space cooling or water heating provided by a community scheme.

Fraction of space heat from secondary/supplementary heating (Table 11) '0' if none

0 (301)

Fraction of space heat from community system 1 – (301) =

1 (302)

The community scheme may obtain heat from several sources. The procedure allows for CHP and up to four other heat sources; the latter includes boilers, heat pumps, geothermal and waste heat from power stations. See Appendix C.

Fraction of heat from Community boilers

1 (303a)

Fraction of total space heat from Community boilers

(302) x (303a) =

1 (304a)

Factor for control and charging method (Table 4c(3)) for community heating system

1 (305)

Distribution loss factor (Table 12c) for community heating system

1.1 (306)

Space heating

Annual space heating requirement

kWh/year

790.63

Space heat from Community boilers

(98) x (304a) x (305) x (306) =

869.69 (307a)

Efficiency of secondary/supplementary heating system in % (from Table 4a or Appendix E)

0 (308)

Space heating requirement from secondary/supplementary system $(98) \times (301) \times 100 \div (308) =$

0 (309)

Water heating

Annual water heating requirement

2072.07

If DHW from community scheme:

DER WorkSheet: New dwelling design stage

Water heat from Community boilers	$(64) \times (303a) \times (305) \times (306) =$	2279.27	(310a)
Electricity used for heat distribution	$0.01 \times [(307a) \dots (307e) + (310a) \dots (310e)] =$	31.49	(313)
Cooling System Energy Efficiency Ratio		0	(314)
Space cooling (if there is a fixed cooling system, if not enter 0)	$= (107) \div (314) =$	0	(315)
Electricity for pumps and fans within dwelling (Table 4f): mechanical ventilation - balanced, extract or positive input from outside		157.82	(330a)
warm air heating system fans		0	(330b)
pump for solar water heating		0	(330g)
Total electricity for the above, kWh/year	$= (330a) + (330b) + (330g) =$	157.82	(331)
Energy for lighting (calculated in Appendix L)		328.89	(332)

12b. CO2 Emissions – Community heating scheme

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
CO2 from other sources of space and water heating (not CHP)			
Efficiency of heat source 1 (%)	If there is CHP using two fuels repeat (363) to (366) for the second fuel	95	(367a)
CO2 associated with heat source 1	$[(307b)+(310b)] \times 100 \div (367b) \times$	0.22	= 715.98 (367)
Electrical energy for heat distribution	$(313) \times$	0.52	= 16.34 (372)
Total CO2 associated with community systems	$(363) \dots (366) + (368) \dots (372)$		= 732.32 (373)
CO2 associated with space heating (secondary)	$(309) \times$	0	= 0 (374)
CO2 associated with water from immersion heater or instantaneous heater	$(312) \times$	0.22	= 0 (375)
Total CO2 associated with space and water heating	$(373) + (374) + (375) =$		= 732.32 (376)
CO2 associated with electricity for pumps and fans within dwelling	$(331)) \times$	0.52	= 81.91 (378)
CO2 associated with electricity for lighting	$(332))) \times$	0.52	= 170.7 (379)
Total CO2, kg/year	sum of (376)...(382) =		984.92 (383)
Dwelling CO2 Emission Rate	$(383) \div (4) =$		13.11 (384)
EI rating (section 14)			89.01 (385)

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 106 - Be Lean			
Address :	AC 106, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	75.1 (1a)	x (2a)	= 195.26 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	75.1 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	195.26 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					3 x 10 = 30 (7a)
Number of passive vents					0 x 10 = 0 (7b)
Number of flueless gas fires					0 x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =	30	÷ (5) = 0.15 (8)
---	----	---------------------

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration $0.25 - [0.2 \times (14) \div 100] =$

Infiltration rate $(8) + (10) + (11) + (12) + (13) + (15) =$

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area

If based on air permeability value, then $(18) = [(17) \div 20] + (8)$, otherwise $(18) = (16)$

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor $(20) = 1 - [0.075 \times (19)] =$

Infiltration rate incorporating shelter factor $(21) = (18) \times (20) =$

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

TER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.44	0.43	0.42	0.38	0.37	0.33	0.33	0.32	0.34	0.37	0.39	0.4
------	------	------	------	------	------	------	------	------	------	------	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0.6	0.59	0.59	0.57	0.57	0.55	0.55	0.55	0.56	0.57	0.57	0.58
---------	-----	------	------	------	------	------	------	------	------	------	------	------

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.6	0.59	0.59	0.57	0.57	0.55	0.55	0.55	0.56	0.57	0.57	0.58
--------	-----	------	------	------	------	------	------	------	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Windows Type 1			1.67	x1/[1/(1.4)+ 0.04] =	2.21		(27)
Windows Type 2			1.66	x1/[1/(1.4)+ 0.04] =	2.2		(27)
Windows Type 3			6.18	x1/[1/(1.4)+ 0.04] =	8.19		(27)
Windows Type 4			2.24	x1/[1/(1.4)+ 0.04] =	2.97		(27)
Windows Type 5			1.5	x1/[1/(1.4)+ 0.04] =	1.99		(27)
Windows Type 6			4.1	x1/[1/(1.4)+ 0.04] =	5.44		(27)
Walls	47.92	17.35	30.57	x 0.18 =	5.5		(29)
Total area of elements, m ²			47.92				(31)
Party wall			44.62	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 28.5 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 5.2 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 33.71 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	38.38	38.14	37.91	36.81	36.6	35.64	35.64	35.46	36.01	36.6	37.02	37.45

(38)

Heat transfer coefficient, W/K (39)m = (37) + (38)m

(39)m=	72.09	71.85	71.62	70.51	70.31	69.35	69.35	69.17	69.72	70.31	70.73	71.16
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Stroma FSAP 2012 Version: 1.0.5.8 (SAP 9.92) - http://www.stroma.com Average = Sum(39)_{1...12} /12= 70.54 (39)

Page 2 of 8

TER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	0.96	0.96	0.95	0.94	0.94	0.92	0.92	0.92	0.93	0.94	0.94	0.95	(40)
													Average = Sum(40) _{1...12} /12=

$$(40)m = (39)m \div (4)$$

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(41)m=	31	28	31	30	31	30	31	31	30	31	30	31	(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

2.36

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

90.33

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	99.36	95.75	92.14	88.52	84.91	81.3	81.3	84.91	88.52	92.14	95.75	99.36
--------	-------	-------	-------	-------	-------	------	------	-------	-------	-------	-------	-------

$$\text{Total} = \text{Sum}(44)_{1...12} =$$

1083.95

(44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	147.35	128.87	132.99	115.94	111.25	96	88.96	102.08	103.3	120.38	131.41	142.7
--------	--------	--------	--------	--------	--------	----	-------	--------	-------	--------	--------	-------

$$\text{Total} = \text{Sum}(45)_{1...12} =$$

1421.23

(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	22.1	19.33	19.95	17.39	16.69	14.4	13.34	15.31	15.49	18.06	19.71	21.41
--------	------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

150

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

1.39

(48)

Temperature factor from Table 2b

0.54

(49)

Energy lost from water storage, kWh/year

$$(48) \times (49) =$$

0.75

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0

(51)

If community heating see section 4.3

Volume factor from Table 2a

0

(52)

Temperature factor from Table 2b

0

(53)

Energy lost from water storage, kWh/year

$$(47) \times (51) \times (52) \times (53) =$$

0

(54)

Enter (50) or (54) in (55)

0.75

(55)

Water storage loss calculated for each month

$$((56)m = (55) \times (41)m)$$

(56)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

0

(58)

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(59)

TER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	193.95	170.96	179.58	161.03	157.84	141.09	135.55	148.67	148.39	166.98	176.5	189.3	(62)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	-------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRS applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	193.95	170.96	179.58	161.03	157.84	141.09	135.55	148.67	148.39	166.98	176.5	189.3	Output from water heater (annual) 1...12	1969.84	(64)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	-------	--	---------	------

Heat gains from water heating, kWh/month 0.25 $[0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	86.27	76.52	81.49	74.62	74.27	67.99	66.85	71.22	70.42	77.3	79.77	84.72	(65)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m=	118.17	118.17	118.17	118.17	118.17	118.17	118.17	118.17	118.17	118.17	118.17	118.17	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	18.62	16.54	13.45	10.18	7.61	6.43	6.94	9.03	12.12	15.38	17.96	19.14	(67)
--------	-------	-------	-------	-------	------	------	------	------	-------	-------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	208.9	211.06	205.6	193.97	179.29	165.5	156.28	154.11	159.57	171.2	185.88	199.68	(68)
--------	-------	--------	-------	--------	--------	-------	--------	--------	--------	-------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	34.82	34.82	34.82	34.82	34.82	34.82	34.82	34.82	34.82	34.82	34.82	34.82	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	3	3	3	3	3	3	3	3	3	3	3	3	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-94.53	-94.53	-94.53	-94.53	-94.53	-94.53	-94.53	-94.53	-94.53	-94.53	-94.53	-94.53	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	115.95	113.87	109.53	103.64	99.82	94.43	89.86	95.72	97.81	103.9	110.79	113.88	(72)
--------	--------	--------	--------	--------	-------	-------	-------	-------	-------	-------	--------	--------	------

Total internal gains = $(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$

(73)m=	404.92	402.92	390.04	369.25	348.18	327.81	314.53	320.31	330.95	351.94	376.08	394.15	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_ Table 6b	FF Table 6c	Gains (W)
East	0.9x	0.77	x 1.66	x 19.64	x 0.63	x 0.7 = 9.96
East	0.9x	0.77	x 6.18	x 19.64	x 0.63	x 0.7 = 37.09
East	0.9x	0.77	x 4.1	x 19.64	x 0.63	x 0.7 = 24.61
East	0.9x	0.77	x 1.66	x 38.42	x 0.63	x 0.7 = 19.49
East	0.9x	0.77	x 6.18	x 38.42	x 0.63	x 0.7 = 72.56

TER WorkSheet: New dwelling design stage

East	0.9x	0.77	x	4.1	x	38.42	x	0.63	x	0.7	=	48.14	(76)
East	0.9x	0.77	x	1.66	x	63.27	x	0.63	x	0.7	=	32.1	(76)
East	0.9x	0.77	x	6.18	x	63.27	x	0.63	x	0.7	=	119.5	(76)
East	0.9x	0.77	x	4.1	x	63.27	x	0.63	x	0.7	=	79.28	(76)
East	0.9x	0.77	x	1.66	x	92.28	x	0.63	x	0.7	=	46.82	(76)
East	0.9x	0.77	x	6.18	x	92.28	x	0.63	x	0.7	=	174.29	(76)
East	0.9x	0.77	x	4.1	x	92.28	x	0.63	x	0.7	=	115.63	(76)
East	0.9x	0.77	x	1.66	x	113.09	x	0.63	x	0.7	=	57.37	(76)
East	0.9x	0.77	x	6.18	x	113.09	x	0.63	x	0.7	=	213.6	(76)
East	0.9x	0.77	x	4.1	x	113.09	x	0.63	x	0.7	=	141.71	(76)
East	0.9x	0.77	x	1.66	x	115.77	x	0.63	x	0.7	=	58.73	(76)
East	0.9x	0.77	x	6.18	x	115.77	x	0.63	x	0.7	=	218.65	(76)
East	0.9x	0.77	x	4.1	x	115.77	x	0.63	x	0.7	=	145.06	(76)
East	0.9x	0.77	x	1.66	x	110.22	x	0.63	x	0.7	=	55.92	(76)
East	0.9x	0.77	x	6.18	x	110.22	x	0.63	x	0.7	=	208.17	(76)
East	0.9x	0.77	x	4.1	x	110.22	x	0.63	x	0.7	=	138.1	(76)
East	0.9x	0.77	x	1.66	x	94.68	x	0.63	x	0.7	=	48.03	(76)
East	0.9x	0.77	x	6.18	x	94.68	x	0.63	x	0.7	=	178.81	(76)
East	0.9x	0.77	x	4.1	x	94.68	x	0.63	x	0.7	=	118.63	(76)
East	0.9x	0.77	x	1.66	x	73.59	x	0.63	x	0.7	=	37.33	(76)
East	0.9x	0.77	x	6.18	x	73.59	x	0.63	x	0.7	=	138.99	(76)
East	0.9x	0.77	x	4.1	x	73.59	x	0.63	x	0.7	=	92.21	(76)
East	0.9x	0.77	x	1.66	x	45.59	x	0.63	x	0.7	=	23.13	(76)
East	0.9x	0.77	x	6.18	x	45.59	x	0.63	x	0.7	=	86.1	(76)
East	0.9x	0.77	x	4.1	x	45.59	x	0.63	x	0.7	=	57.12	(76)
East	0.9x	0.77	x	1.66	x	24.49	x	0.63	x	0.7	=	12.42	(76)
East	0.9x	0.77	x	6.18	x	24.49	x	0.63	x	0.7	=	46.25	(76)
East	0.9x	0.77	x	4.1	x	24.49	x	0.63	x	0.7	=	30.69	(76)
East	0.9x	0.77	x	1.66	x	16.15	x	0.63	x	0.7	=	8.19	(76)
East	0.9x	0.77	x	6.18	x	16.15	x	0.63	x	0.7	=	30.5	(76)
East	0.9x	0.77	x	4.1	x	16.15	x	0.63	x	0.7	=	20.24	(76)
West	0.9x	0.77	x	1.67	x	19.64	x	0.63	x	0.7	=	10.02	(80)
West	0.9x	0.77	x	2.24	x	19.64	x	0.63	x	0.7	=	13.45	(80)
West	0.9x	0.77	x	1.5	x	19.64	x	0.63	x	0.7	=	9	(80)
West	0.9x	0.77	x	1.67	x	38.42	x	0.63	x	0.7	=	19.61	(80)
West	0.9x	0.77	x	2.24	x	38.42	x	0.63	x	0.7	=	26.3	(80)
West	0.9x	0.77	x	1.5	x	38.42	x	0.63	x	0.7	=	17.61	(80)
West	0.9x	0.77	x	1.67	x	63.27	x	0.63	x	0.7	=	32.29	(80)
West	0.9x	0.77	x	2.24	x	63.27	x	0.63	x	0.7	=	43.32	(80)
West	0.9x	0.77	x	1.5	x	63.27	x	0.63	x	0.7	=	29.01	(80)
West	0.9x	0.77	x	1.67	x	92.28	x	0.63	x	0.7	=	47.1	(80)

TER WorkSheet: New dwelling design stage

West	0.9x	0.77	x	2.24	x	92.28	x	0.63	x	0.7	=	63.17	(80)
West	0.9x	0.77	x	1.5	x	92.28	x	0.63	x	0.7	=	42.3	(80)
West	0.9x	0.77	x	1.67	x	113.09	x	0.63	x	0.7	=	57.72	(80)
West	0.9x	0.77	x	2.24	x	113.09	x	0.63	x	0.7	=	77.42	(80)
West	0.9x	0.77	x	1.5	x	113.09	x	0.63	x	0.7	=	51.84	(80)
West	0.9x	0.77	x	1.67	x	115.77	x	0.63	x	0.7	=	59.09	(80)
West	0.9x	0.77	x	2.24	x	115.77	x	0.63	x	0.7	=	79.25	(80)
West	0.9x	0.77	x	1.5	x	115.77	x	0.63	x	0.7	=	53.07	(80)
West	0.9x	0.77	x	1.67	x	110.22	x	0.63	x	0.7	=	56.25	(80)
West	0.9x	0.77	x	2.24	x	110.22	x	0.63	x	0.7	=	75.45	(80)
West	0.9x	0.77	x	1.5	x	110.22	x	0.63	x	0.7	=	50.53	(80)
West	0.9x	0.77	x	1.67	x	94.68	x	0.63	x	0.7	=	48.32	(80)
West	0.9x	0.77	x	2.24	x	94.68	x	0.63	x	0.7	=	64.81	(80)
West	0.9x	0.77	x	1.5	x	94.68	x	0.63	x	0.7	=	43.4	(80)
West	0.9x	0.77	x	1.67	x	73.59	x	0.63	x	0.7	=	37.56	(80)
West	0.9x	0.77	x	2.24	x	73.59	x	0.63	x	0.7	=	50.38	(80)
West	0.9x	0.77	x	1.5	x	73.59	x	0.63	x	0.7	=	33.73	(80)
West	0.9x	0.77	x	1.67	x	45.59	x	0.63	x	0.7	=	23.27	(80)
West	0.9x	0.77	x	2.24	x	45.59	x	0.63	x	0.7	=	31.21	(80)
West	0.9x	0.77	x	1.5	x	45.59	x	0.63	x	0.7	=	20.9	(80)
West	0.9x	0.77	x	1.67	x	24.49	x	0.63	x	0.7	=	12.5	(80)
West	0.9x	0.77	x	2.24	x	24.49	x	0.63	x	0.7	=	16.76	(80)
West	0.9x	0.77	x	1.5	x	24.49	x	0.63	x	0.7	=	11.23	(80)
West	0.9x	0.77	x	1.67	x	16.15	x	0.63	x	0.7	=	8.24	(80)
West	0.9x	0.77	x	2.24	x	16.15	x	0.63	x	0.7	=	11.06	(80)
West	0.9x	0.77	x	1.5	x	16.15	x	0.63	x	0.7	=	7.4	(80)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m=

104.14	203.72	335.5	489.3	599.66	613.86	584.42	502.01	390.2	241.73	129.85	85.64
--------	--------	-------	-------	--------	--------	--------	--------	-------	--------	--------	-------

 (83)

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=

509.06	606.64	725.54	858.56	947.84	941.67	898.95	822.32	721.14	593.67	505.93	479.79
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21 (85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m=	1	0.99	0.96	0.85	0.66	0.47	0.34	0.39	0.65	0.93	0.99	1	(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=

20.1	20.28	20.56	20.84	20.97	21	21	21	20.98	20.77	20.37	20.07
------	-------	-------	-------	-------	----	----	----	-------	-------	-------	-------

 (87)

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=

20.12	20.12	20.12	20.13	20.14	20.15	20.15	20.15	20.14	20.14	20.13	20.13
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (88)

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=

0.99	0.99	0.95	0.82	0.61	0.41	0.27	0.32	0.57	0.9	0.99	1
------	------	------	------	------	------	------	------	------	-----	------	---

 (89)

TER WorkSheet: New dwelling design stage

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.91	19.18	19.58	19.97	20.11	20.15	20.15	20.15	20.13	19.88	19.33	18.88		(90)
										fLA = Living area ÷ (4) =		0.35		(91)

Mean internal temperature (for the whole dwelling) = fLA × T1 + (1 – fLA) × T2

(92)m=	19.33	19.56	19.92	20.27	20.41	20.44	20.45	20.45	20.43	20.19	19.69	19.3		(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------	--	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.33	19.56	19.92	20.27	20.41	20.44	20.45	20.45	20.43	20.19	19.69	19.3		(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------	--	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that Ti,m=(76)m and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	0.99	0.98	0.94	0.82	0.63	0.43	0.3	0.34	0.6	0.9	0.98	1		(94)
--------	------	------	------	------	------	------	-----	------	-----	-----	------	---	--	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	505.73	596.15	685.4	708.27	595.45	403.8	266.58	279.65	431.82	536.95	498.07	477.47		(95)
--------	--------	--------	-------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2		(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	--	------

Heat loss rate for mean internal temperature, Lm , W =[(39)m x [(93)m – (96)m]

(97)m=	1083.43	1053.6	961.01	801.93	612.42	405.25	266.71	279.93	441.15	674.28	890.72	1074.32		(97)
--------	---------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	---------	--	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m – (95)m] x (41)m

(98)m=	429.81	307.4	205.06	67.43	12.62	0	0	0	0	102.17	282.71	444.06	Total per year (kWh/year) = Sum(98) _{1...5,9...12} =	1851.27	(98)
--------	--------	-------	--------	-------	-------	---	---	---	---	--------	--------	--------	---	---------	------

Space heating requirement in kWh/m²/year

24.65 (99)

9a. Energy requirements – Individual heating systems including micro-CHP

Space heating:

Fraction of space heat from secondary/supplementary system

0 (201)

Fraction of space heat from main system(s)

(202) = 1 – (201) = 1 (202)

Fraction of total heating from main system 1

(204) = (202) × [1 – (203)] = 1 (204)

Efficiency of main space heating system 1

93.5 (206)

Efficiency of secondary/supplementary heating system, %

0 (208)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

429.81	307.4	205.06	67.43	12.62	0	0	0	0	102.17	282.71	444.06
--------	-------	--------	-------	-------	---	---	---	---	--------	--------	--------

$$(211)m = \{[(98)m \times (204)]\} \times 100 \div (206) \quad (211)$$

459.69	328.77	219.31	72.12	13.5	0	0	0	0	109.28	302.36	474.93
--------	--------	--------	-------	------	---	---	---	---	--------	--------	--------

Total (kWh/year) =Sum(211)_{1...5,10...12}= 1979.97 (211)

Space heating fuel (secondary), kWh/month

$$= \{[(98)m \times (201)]\} \times 100 \div (208) \quad (208)$$

(215)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

Total (kWh/year) =Sum(215)_{1...5,10...12}= 0 (215)

Water heating

Output from water heater (calculated above)

193.95	170.96	179.58	161.03	157.84	141.09	135.55	148.67	148.39	166.98	176.5	189.3
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	-------

Efficiency of water heater 79.8 (216)

TER WorkSheet: New dwelling design stage

(217)m=	86.88	86.36	85.17	82.69	80.5	79.8	79.8	79.8	83.55	86.06	87.01	(217)
---------	-------	-------	-------	-------	------	------	------	------	-------	-------	-------	-------

Fuel for water heating, kWh/month

$$(219)m = (64)m \times 100 \div (217)m$$

(219)m=	223.24	197.96	210.85	194.75	196.07	176.8	169.86	186.31	185.95	199.86	205.08	217.55	Total = Sum(219a) _{1...12} =	2364.29	(219)
---------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	---------------------------------------	---------	-------

Annual totals

Space heating fuel used, main system 1

kWh/year

1979.97

Water heating fuel used

2364.29

Electricity for pumps, fans and electric keep-hot

central heating pump:

30

(230c)

boiler with a fan-assisted flue

45

(230e)

Total electricity for the above, kWh/year

sum of (230a)...(230g) =

75

(231)

Electricity for lighting

328.89

(232)

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year	
Space heating (main system 1)	(211) x	0.216	=	427.67
Space heating (secondary)	(215) x	0.519	=	0
Water heating	(219) x	0.216	=	510.69
Space and water heating	(261) + (262) + (263) + (264) =			938.36
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	=	38.93
Electricity for lighting	(232) x	0.519	=	170.7
Total CO2, kg/year		sum of (265)...(271) =		1147.98

TER =

15.29

(273)

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name: John Simpson **Stroma Number:** STRO006273
Software Name: Stroma FSAP 2012 **Software Version:** Version: 1.0.5.8

Property Address: AC 107 - Be Lean

Address : AC 107, Aspen Court, Maitland Park Estate, London, NW3 2EH

1. Overall dwelling dimensions:

	Area(m ²)	Av. Height(m)	Volume(m ³)
Ground floor	80	(1a) x (2a) =	208 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	80 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	208 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m ³ per hour
Number of chimneys	0	+	0	= 0	x 40 = 0 (6a)
Number of open flues	0	+	0	= 0	x 20 = 0 (6b)
Number of intermittent fans					x 10 = 0 (7a)
Number of passive vents					x 10 = 0 (7b)
Number of flueless gas fires					x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 0 ÷ (5) = 0 (8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] = 0 (15)

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) = 0 (16)

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] = 2 (19)

Infiltration rate incorporating shelter factor (21) = (18) x (20) = 0.85 (20)

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(22)m= 5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7

Wind Factor (22a)m = (22)m ÷ 4

(22a)m= 1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
--------------	------	------	-----	------	------	------	------	---	------	------	------

DER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.11	0.11	0.1	0.09	0.09	0.08	0.08	0.08	0.08	0.09	0.1	0.1
------	------	-----	------	------	------	------	------	------	------	-----	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.21	0.21	0.22
---------	------	------	------	------	------	-----	-----	-----	------	------	------

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.2	0.21	0.21	0.22
--------	------	------	------	------	------	-----	-----	-----	-----	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m²)	Openings m²	Net Area A ,m²	U-value W/m²K	A X U (W/K)	k-value kJ/m²·K	A X k kJ/K
Windows Type 1			1.87	x1/[1/(1.4)+ 0.04] =	2.48		(27)
Windows Type 2			2.24	x1/[1/(1.4)+ 0.04] =	2.97		(27)
Windows Type 3			9.83	x1/[1/(1.4)+ 0.04] =	13.03		(27)
Windows Type 4			1.5	x1/[1/(1.4)+ 0.04] =	1.99		(27)
Windows Type 5			1.5	x1/[1/(1.4)+ 0.04] =	1.99		(27)
Windows Type 6			2.71	x1/[1/(1.4)+ 0.04] =	3.59		(27)
Walls	48.85	19.65	29.2	x 0.12 =	3.5		(29)
Total area of elements, m²			48.85				(31)
Party wall			44.62	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 29.56 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 7.62 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 37.18 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	15.5	15.36	15.21	14.48	14.34	13.61	13.61	13.46	13.9	14.34	14.63	14.92

(38)

Heat transfer coefficient, W/K (39)m = (37) + (38)m

(39)m=	52.68	52.53	52.39	51.66	51.51	50.78	50.78	50.64	51.08	51.51	51.8	52.1
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------	------

Stroma FSAP 2012 Version: 1.0.5.8 (SAP 9.92) - http://www.stroma.com Average = Sum(39)₁...₁₂ / 12= 51.68 (39)

Page 2 of 8

DER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	0.66	0.66	0.65	0.65	0.64	0.63	0.63	0.63	0.64	0.64	0.65	0.65	
													Average = Sum(40) _{1...12} /12=

$$(40)m = (39)m \div (4)$$

0.65 (40)

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(41)m=
31	28	31	30	31	30	31	31	30	31	30	31	

(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

2.46

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)^2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

92.69

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	101.96	98.25	94.55	90.84	87.13	83.42	83.42	87.13	90.84	94.55	98.25	101.96
--------	--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--------

$$\text{Total} = \text{Sum}(44)_{1...12} =$$

1112.32

(44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	151.21	132.25	136.47	118.97	114.16	98.51	91.28	104.75	106	123.53	134.85	146.44
--------	--------	--------	--------	--------	--------	-------	-------	--------	-----	--------	--------	--------

$$\text{Total} = \text{Sum}(45)_{1...12} =$$

1458.42

(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	22.68	19.84	20.47	17.85	17.12	14.78	13.69	15.71	15.9	18.53	20.23	21.97
--------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------

(46)

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0

(48)

Temperature factor from Table 2b

0

(49)

Energy lost from water storage, kWh/year

$$(48) \times (49) =$$

110

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0.02

(51)

If community heating see section 4.3

Volume factor from Table 2a

1.03

(52)

Temperature factor from Table 2b

0.6

(53)

Energy lost from water storage, kWh/year

$$(47) \times (51) \times (52) \times (53) =$$

1.03

(54)

Enter (50) or (54) in (55)

1.03

(55)

Water storage loss calculated for each month

$$((56)m = (55) \times (41)m)$$

(56)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(56)

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(57)

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(59)

DER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	206.48	182.17	191.74	172.47	169.44	152	146.56	160.03	159.5	178.81	188.34	201.71	(62)
--------	--------	--------	--------	--------	--------	-----	--------	--------	-------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	206.48	182.17	191.74	172.47	169.44	152	146.56	160.03	159.5	178.81	188.34	201.71	
Output from water heater (annual) 1...12											2109.26	(64)	

Heat gains from water heating, kWh/month 0.25 $[0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	94.5	83.91	89.6	82.35	82.18	75.55	74.57	79.05	78.04	85.3	87.63	92.91	(65)
--------	------	-------	------	-------	-------	-------	-------	-------	-------	------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(66)m=	123.14	123.14	123.14	123.14	123.14	123.14	123.14	123.14	123.14	123.14	123.14	123.14

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	19.56	17.38	14.13	10.7	8	6.75	7.3	9.48	12.73	16.16	18.86	20.11	(67)
--------	-------	-------	-------	------	---	------	-----	------	-------	-------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	219.44	221.72	215.98	203.76	188.34	173.85	164.17	161.89	167.63	179.84	195.27	209.76	(68)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	35.31	35.31	35.31	35.31	35.31	35.31	35.31	35.31	35.31	35.31	35.31	35.31	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	0	0	0	0	0	0	0	0	0	0	0	0	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-98.51	-98.51	-98.51	-98.51	-98.51	-98.51	-98.51	-98.51	-98.51	-98.51	-98.51	-98.51	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	127.01	124.87	120.43	114.38	110.46	104.93	100.23	106.25	108.39	114.65	121.71	124.88	(72)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Total internal gains = $(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$

(73)m=	425.96	423.91	410.48	388.79	366.74	345.47	331.64	337.57	348.69	370.59	395.78	414.69	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_ Table 6b	FF Table 6c	Gains (W)
North	0.9x	0.77	x 2.24	x 10.63	x 0.4	x 0.8 = 5.28 (74)
North	0.9x	0.77	x 9.83	x 10.63	x 0.4	x 0.8 = 23.18 (74)
North	0.9x	0.77	x 2.24	x 20.32	x 0.4	x 0.8 = 10.09 (74)
North	0.9x	0.77	x 9.83	x 20.32	x 0.4	x 0.8 = 44.3 (74)
North	0.9x	0.77	x 2.24	x 34.53	x 0.4	x 0.8 = 17.15 (74)

DER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	9.83	x	34.53	x	0.4	x	0.8	=	75.27	(74)
North	0.9x	0.77	x	2.24	x	55.46	x	0.4	x	0.8	=	27.55	(74)
North	0.9x	0.77	x	9.83	x	55.46	x	0.4	x	0.8	=	120.91	(74)
North	0.9x	0.77	x	2.24	x	74.72	x	0.4	x	0.8	=	37.11	(74)
North	0.9x	0.77	x	9.83	x	74.72	x	0.4	x	0.8	=	162.87	(74)
North	0.9x	0.77	x	2.24	x	79.99	x	0.4	x	0.8	=	39.73	(74)
North	0.9x	0.77	x	9.83	x	79.99	x	0.4	x	0.8	=	174.36	(74)
North	0.9x	0.77	x	2.24	x	74.68	x	0.4	x	0.8	=	37.1	(74)
North	0.9x	0.77	x	9.83	x	74.68	x	0.4	x	0.8	=	162.79	(74)
North	0.9x	0.77	x	2.24	x	59.25	x	0.4	x	0.8	=	29.43	(74)
North	0.9x	0.77	x	9.83	x	59.25	x	0.4	x	0.8	=	129.15	(74)
North	0.9x	0.77	x	2.24	x	41.52	x	0.4	x	0.8	=	20.62	(74)
North	0.9x	0.77	x	9.83	x	41.52	x	0.4	x	0.8	=	90.5	(74)
North	0.9x	0.77	x	2.24	x	24.19	x	0.4	x	0.8	=	12.02	(74)
North	0.9x	0.77	x	9.83	x	24.19	x	0.4	x	0.8	=	52.73	(74)
North	0.9x	0.77	x	2.24	x	13.12	x	0.4	x	0.8	=	6.52	(74)
North	0.9x	0.77	x	9.83	x	13.12	x	0.4	x	0.8	=	28.6	(74)
North	0.9x	0.77	x	2.24	x	8.86	x	0.4	x	0.8	=	4.4	(74)
North	0.9x	0.77	x	9.83	x	8.86	x	0.4	x	0.8	=	19.32	(74)
West	0.9x	0.77	x	1.87	x	19.64	x	0.4	x	0.8	=	8.14	(80)
West	0.9x	0.77	x	1.5	x	19.64	x	0.4	x	0.8	=	6.53	(80)
West	0.9x	0.77	x	1.5	x	19.64	x	0.4	x	0.8	=	6.53	(80)
West	0.9x	0.77	x	2.71	x	19.64	x	0.4	x	0.8	=	11.8	(80)
West	0.9x	0.77	x	1.87	x	38.42	x	0.4	x	0.8	=	15.93	(80)
West	0.9x	0.77	x	1.5	x	38.42	x	0.4	x	0.8	=	12.78	(80)
West	0.9x	0.77	x	1.5	x	38.42	x	0.4	x	0.8	=	12.78	(80)
West	0.9x	0.77	x	2.71	x	38.42	x	0.4	x	0.8	=	23.09	(80)
West	0.9x	0.77	x	1.87	x	63.27	x	0.4	x	0.8	=	26.24	(80)
West	0.9x	0.77	x	1.5	x	63.27	x	0.4	x	0.8	=	21.05	(80)
West	0.9x	0.77	x	1.5	x	63.27	x	0.4	x	0.8	=	21.05	(80)
West	0.9x	0.77	x	2.71	x	63.27	x	0.4	x	0.8	=	38.03	(80)
West	0.9x	0.77	x	1.87	x	92.28	x	0.4	x	0.8	=	38.27	(80)
West	0.9x	0.77	x	1.5	x	92.28	x	0.4	x	0.8	=	30.7	(80)
West	0.9x	0.77	x	1.5	x	92.28	x	0.4	x	0.8	=	30.7	(80)
West	0.9x	0.77	x	2.71	x	92.28	x	0.4	x	0.8	=	55.46	(80)
West	0.9x	0.77	x	1.87	x	113.09	x	0.4	x	0.8	=	46.9	(80)
West	0.9x	0.77	x	1.5	x	113.09	x	0.4	x	0.8	=	37.62	(80)
West	0.9x	0.77	x	1.5	x	113.09	x	0.4	x	0.8	=	37.62	(80)
West	0.9x	0.77	x	2.71	x	113.09	x	0.4	x	0.8	=	67.97	(80)
West	0.9x	0.77	x	1.87	x	115.77	x	0.4	x	0.8	=	48.01	(80)
West	0.9x	0.77	x	1.5	x	115.77	x	0.4	x	0.8	=	38.51	(80)

DER WorkSheet: New dwelling design stage

West	0.9x	0.77	x	1.5	x	115.77	x	0.4	x	0.8	=	38.51	(80)
West	0.9x	0.77	x	2.71	x	115.77	x	0.4	x	0.8	=	69.57	(80)
West	0.9x	0.77	x	1.87	x	110.22	x	0.4	x	0.8	=	45.71	(80)
West	0.9x	0.77	x	1.5	x	110.22	x	0.4	x	0.8	=	36.66	(80)
West	0.9x	0.77	x	1.5	x	110.22	x	0.4	x	0.8	=	36.66	(80)
West	0.9x	0.77	x	2.71	x	110.22	x	0.4	x	0.8	=	66.24	(80)
West	0.9x	0.77	x	1.87	x	94.68	x	0.4	x	0.8	=	39.26	(80)
West	0.9x	0.77	x	1.5	x	94.68	x	0.4	x	0.8	=	31.49	(80)
West	0.9x	0.77	x	1.5	x	94.68	x	0.4	x	0.8	=	31.49	(80)
West	0.9x	0.77	x	2.71	x	94.68	x	0.4	x	0.8	=	56.9	(80)
West	0.9x	0.77	x	1.87	x	73.59	x	0.4	x	0.8	=	30.52	(80)
West	0.9x	0.77	x	1.5	x	73.59	x	0.4	x	0.8	=	24.48	(80)
West	0.9x	0.77	x	1.5	x	73.59	x	0.4	x	0.8	=	24.48	(80)
West	0.9x	0.77	x	2.71	x	73.59	x	0.4	x	0.8	=	44.22	(80)
West	0.9x	0.77	x	1.87	x	45.59	x	0.4	x	0.8	=	18.91	(80)
West	0.9x	0.77	x	1.5	x	45.59	x	0.4	x	0.8	=	15.16	(80)
West	0.9x	0.77	x	1.5	x	45.59	x	0.4	x	0.8	=	15.16	(80)
West	0.9x	0.77	x	2.71	x	45.59	x	0.4	x	0.8	=	27.4	(80)
West	0.9x	0.77	x	1.87	x	24.49	x	0.4	x	0.8	=	10.16	(80)
West	0.9x	0.77	x	1.5	x	24.49	x	0.4	x	0.8	=	8.15	(80)
West	0.9x	0.77	x	1.5	x	24.49	x	0.4	x	0.8	=	8.15	(80)
West	0.9x	0.77	x	2.71	x	24.49	x	0.4	x	0.8	=	14.72	(80)
West	0.9x	0.77	x	1.87	x	16.15	x	0.4	x	0.8	=	6.7	(80)
West	0.9x	0.77	x	1.5	x	16.15	x	0.4	x	0.8	=	5.37	(80)
West	0.9x	0.77	x	1.5	x	16.15	x	0.4	x	0.8	=	5.37	(80)
West	0.9x	0.77	x	2.71	x	16.15	x	0.4	x	0.8	=	9.71	(80)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m=	61.48	118.97	198.78	303.58	390.09	408.7	385.15	317.73	234.82	141.38	76.28	50.88	(83)
--------	-------	--------	--------	--------	--------	-------	--------	--------	--------	--------	-------	-------	------

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=	487.44	542.88	609.26	692.36	756.83	754.17	716.79	655.29	583.51	511.97	472.06	465.57	(84)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(86)	
(86)m=	1	0.99	0.96	0.84	0.63	0.43	0.31	0.36	0.6	0.91	0.99	1	

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	20.49	20.6	20.78	20.94	20.99	21	21	21	21	20.91	20.67	20.47	(87)
--------	-------	------	-------	-------	-------	----	----	----	----	-------	-------	-------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	20.38	20.38	20.38	20.39	20.39	20.4	20.4	20.4	20.4	20.39	20.39	20.38	(88)
--------	-------	-------	-------	-------	-------	------	------	------	------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.99	0.99	0.95	0.81	0.59	0.39	0.27	0.31	0.55	0.88	0.98	1	(89)
--------	------	------	------	------	------	------	------	------	------	------	------	---	------

DER WorkSheet: New dwelling design stage

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	19.69	19.86	20.1	20.33	20.39	20.4	20.4	20.4	20.39	20.29	19.96	19.67	(90)
	$fLA = \text{Living area} \div (4) =$												0.43 (91)

Mean internal temperature (for the whole dwelling) = $fLA \times T1 + (1 - fLA) \times T2$

(92)m=	20.03	20.17	20.39	20.59	20.65	20.65	20.66	20.66	20.65	20.56	20.27	20.01	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	20.03	20.17	20.39	20.59	20.65	20.65	20.66	20.66	20.65	20.56	20.27	20.01	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set T_i to the mean internal temperature obtained at step 11 of Table 9b, so that $T_{i,m}=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, h_m :

(94)m=	0.99	0.99	0.95	0.82	0.6	0.41	0.29	0.33	0.57	0.89	0.98	1	(94)
--------	------	------	------	------	-----	------	------	------	------	------	------	---	------

Useful gains, $h_m G_m$, $W = (94)m \times (84)m$

(95)m=	484.59	535.1	579.7	568.58	457.67	307.38	205.92	215.5	333.12	456.66	464.56	463.57	(95)
--------	--------	-------	-------	--------	--------	--------	--------	-------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, L_m , $W = [(39)m \times [(93)m - (96)m]]$

(97)m=	828.86	802.37	727.62	603.94	460.8	307.49	205.93	215.51	334.58	512.86	682.08	823.58	(97)
--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	------

Space heating requirement for each month, $kWh/month = 0.024 \times [(97)m - (95)m] \times (41)m$

(98)m=	256.14	179.61	110.05	25.46	2.33	0	0	0	0	41.81	156.62	267.85	Total per year (kWh/year) = Sum(98) _{1..5,9..12} = 1039.87 (98)
--------	--------	--------	--------	-------	------	---	---	---	---	-------	--------	--------	--

Space heating requirement in $kWh/m^2/year$

9b. Energy requirements – Community heating scheme	0 (301)
--	---------

This part is used for space heating, space cooling or water heating provided by a community scheme.

Fraction of space heat from secondary/supplementary heating (Table 11) '0' if none

0 (301)

Fraction of space heat from community system 1 – (301) =

1 (302)

The community scheme may obtain heat from several sources. The procedure allows for CHP and up to four other heat sources; the latter includes boilers, heat pumps, geothermal and waste heat from power stations. See Appendix C.

Fraction of heat from Community boilers

1 (303a)

Fraction of total space heat from Community boilers

(302) x (303a) = 1 (304a)

Factor for control and charging method (Table 4c(3)) for community heating system

1 (305)

Distribution loss factor (Table 12c) for community heating system

1.1 (306)

Space heating

Annual space heating requirement

kWh/year

1039.87

Space heat from Community boilers

(98) x (304a) x (305) x (306) = 1143.86 (307a)

Efficiency of secondary/supplementary heating system in % (from Table 4a or Appendix E)

0 (308)

Space heating requirement from secondary/supplementary system (98) x (301) x 100 ÷ (308) = 0 (309)

Water heating

Annual water heating requirement

2109.26

If DHW from community scheme:

DER WorkSheet: New dwelling design stage

Water heat from Community boilers	$(64) \times (303a) \times (305) \times (306) =$	2320.19 (310a)
Electricity used for heat distribution	$0.01 \times [(307a) \dots (307e) + (310a) \dots (310e)] =$	34.64 (313)
Cooling System Energy Efficiency Ratio		0 (314)
Space cooling (if there is a fixed cooling system, if not enter 0)	$= (107) \div (314) =$	0 (315)
Electricity for pumps and fans within dwelling (Table 4f): mechanical ventilation - balanced, extract or positive input from outside		168.12 (330a)
warm air heating system fans		0 (330b)
pump for solar water heating		0 (330g)
Total electricity for the above, kWh/year	$= (330a) + (330b) + (330g) =$	168.12 (331)
Energy for lighting (calculated in Appendix L)		345.49 (332)

12b. CO2 Emissions – Community heating scheme

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
CO2 from other sources of space and water heating (not CHP) Efficiency of heat source 1 (%)			
	If there is CHP using two fuels repeat (363) to (366) for the second fuel	95	(367a)
CO2 associated with heat source 1	$[(307b)+(310b)] \times 100 \div (367b) \times$	0.22	= 787.61 (367)
Electrical energy for heat distribution	$(313) \times$	0.52	= 17.98 (372)
Total CO2 associated with community systems	$(363) \dots (366) + (368) \dots (372)$		= 805.59 (373)
CO2 associated with space heating (secondary)	$(309) \times$	0	= 0 (374)
CO2 associated with water from immersion heater or instantaneous heater	$(312) \times$	0.22	= 0 (375)
Total CO2 associated with space and water heating	$(373) + (374) + (375) =$		= 805.59 (376)
CO2 associated with electricity for pumps and fans within dwelling	$(331)) \times$	0.52	= 87.25 (378)
CO2 associated with electricity for lighting	$(332))) \times$	0.52	= 179.31 (379)
Total CO2, kg/year	sum of (376)...(382) =		1072.16 (383)
Dwelling CO2 Emission Rate	$(383) \div (4) =$		13.4 (384)
EI rating (section 14)			88.51 (385)

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name: John Simpson **Stroma Number:** STRO006273
Software Name: Stroma FSAP 2012 **Software Version:** Version: 1.0.5.8

Property Address: AC 107 - Be Lean

Address : AC 107, Aspen Court, Maitland Park Estate, London, NW3 2EH

1. Overall dwelling dimensions:

	Area(m ²)	Av. Height(m)	Volume(m ³)
Ground floor	80	(1a) x (2a) =	208 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	80 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	208 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m ³ per hour
Number of chimneys	0	+	0	= 0	x 40 = 0 (6a)
Number of open flues	0	+	0	= 0	x 20 = 0 (6b)
Number of intermittent fans				3	x 10 = 30 (7a)
Number of passive vents				0	x 10 = 0 (7b)
Number of flueless gas fires				0	x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 30 ÷ (5) = 0.14 (8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] = 0

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) = 0

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area 5

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16) 0.39

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] = 0.85

Infiltration rate incorporating shelter factor (21) = (18) x (20) = 0.34

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(22)m= 5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7

Wind Factor (22a)m = (22)m ÷ 4

(22a)m= 1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
--------------	------	------	-----	------	------	------	------	---	------	------	------

TER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.43	0.42	0.41	0.37	0.36	0.32	0.32	0.31	0.34	0.36	0.38	0.39
------	------	------	------	------	------	------	------	------	------	------	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0.59	0.59	0.58	0.57	0.56	0.55	0.55	0.55	0.56	0.56	0.57	0.58
---------	------	------	------	------	------	------	------	------	------	------	------	------

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.59	0.59	0.58	0.57	0.56	0.55	0.55	0.55	0.56	0.56	0.57	0.58
--------	------	------	------	------	------	------	------	------	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Windows Type 1			1.87	x1/[1/(1.4) + 0.04] =	2.48		(27)
Windows Type 2			2.24	x1/[1/(1.4)+ 0.04] =	2.97		(27)
Windows Type 3			9.83	x1/[1/(1.4)+ 0.04] =	13.03		(27)
Windows Type 4			1.5	x1/[1/(1.4)+ 0.04] =	1.99		(27)
Windows Type 5			1.5	x1/[1/(1.4)+ 0.04] =	1.99		(27)
Windows Type 6			2.71	x1/[1/(1.4)+ 0.04] =	3.59		(27)
Walls	48.85	19.65	29.2	x 0.18 =	5.26		(29)
Total area of elements, m ²			48.85				(31)
Party wall			44.62	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 31.31 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 5.24 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 36.55 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	40.58	40.34	40.1	38.98	38.77	37.8	37.8	37.62	38.17	38.77	39.2	39.64

(38)

Heat transfer coefficient, W/K (39)m = (37) + (38)m

(39)m=	77.13	76.89	76.65	75.53	75.32	74.35	74.35	74.17	74.72	75.32	75.75	76.19
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

TER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	0.96	0.96	0.96	0.94	0.94	0.93	0.93	0.93	0.93	0.94	0.95	0.95	(40)
													Average = Sum(40) _{1...12} /12=

$$(40)m = (39)m \div (4)$$

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(41)m=	31	28	31	30	31	30	31	31	30	31	30	31	(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

2.46

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

92.69

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	101.96	98.25	94.55	90.84	87.13	83.42	83.42	87.13	90.84	94.55	98.25	101.96	Total = Sum(44) _{1...12} =	1112.32	(44)
--------	--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--------	-------------------------------------	---------	------

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	151.21	132.25	136.47	118.97	114.16	98.51	91.28	104.75	106	123.53	134.85	146.44	Total = Sum(45) _{1...12} =	1458.42	(45)
--------	--------	--------	--------	--------	--------	-------	-------	--------	-----	--------	--------	--------	-------------------------------------	---------	------

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	22.68	19.84	20.47	17.85	17.12	14.78	13.69	15.71	15.9	18.53	20.23	21.97			(46)
--------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	--	--	------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

150

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

1.39

(48)

Temperature factor from Table 2b

0.54

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

0.75

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0

(51)

If community heating see section 4.3

Volume factor from Table 2a

0

(52)

Temperature factor from Table 2b

0

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

0

(54)

Enter (50) or (54) in (55)

0.75

(55)

Water storage loss calculated for each month

((56)m = (55) x (41)m)

(56)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33		(56)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--	------

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33		(57)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--	------

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26		(59)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--	------

TER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	197.8	174.33	183.06	164.07	160.75	143.6	137.88	151.35	151.09	170.13	179.94	193.03	(62)
--------	-------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	197.8	174.33	183.06	164.07	160.75	143.6	137.88	151.35	151.09	170.13	179.94	193.03	Output from water heater (annual) 1...12	2007.04	(64)
--------	-------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--	---------	------

Heat gains from water heating, kWh/month 0.25 [$0.85 \times (45)m + (61)m$] + $0.8 \times [(46)m + (57)m + (59)m]$]

(65)m=	87.55	77.64	82.65	75.63	75.23	68.83	67.63	72.11	71.32	78.35	80.91	85.97	(65)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m=	123.14	123.14	123.14	123.14	123.14	123.14	123.14	123.14	123.14	123.14	123.14	123.14	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	19.56	17.38	14.13	10.7	8	6.75	7.3	9.48	12.73	16.16	18.86	20.11	(67)
--------	-------	-------	-------	------	---	------	-----	------	-------	-------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	219.44	221.72	215.98	203.76	188.34	173.85	164.17	161.89	167.63	179.84	195.27	209.76	(68)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	35.31	35.31	35.31	35.31	35.31	35.31	35.31	35.31	35.31	35.31	35.31	35.31	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	3	3	3	3	3	3	3	3	3	3	3	3	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-98.51	-98.51	-98.51	-98.51	-98.51	-98.51	-98.51	-98.51	-98.51	-98.51	-98.51	-98.51	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	117.68	115.54	111.09	105.05	101.12	95.59	90.9	96.92	99.05	105.31	112.38	115.55	(72)
--------	--------	--------	--------	--------	--------	-------	------	-------	-------	--------	--------	--------	------

Total internal gains = $(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$

(73)m=	419.62	417.57	404.14	382.45	360.4	339.14	325.3	331.23	342.35	364.26	389.44	408.35	(73)
--------	--------	--------	--------	--------	-------	--------	-------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)		
North	0.9x	0.77	x 2.24	x 10.63	x 0.63	= 0.7	7.28	(74)
North	0.9x	0.77	x 9.83	x 10.63	x 0.63	= 0.7	31.94	(74)
North	0.9x	0.77	x 2.24	x 20.32	x 0.63	= 0.7	13.91	(74)
North	0.9x	0.77	x 9.83	x 20.32	x 0.63	= 0.7	61.05	(74)
North	0.9x	0.77	x 2.24	x 34.53	x 0.63	= 0.7	23.64	(74)

TER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	9.83	x	34.53	x	0.63	x	0.7	=	103.73	(74)
North	0.9x	0.77	x	2.24	x	55.46	x	0.63	x	0.7	=	37.97	(74)
North	0.9x	0.77	x	9.83	x	55.46	x	0.63	x	0.7	=	166.62	(74)
North	0.9x	0.77	x	2.24	x	74.72	x	0.63	x	0.7	=	51.15	(74)
North	0.9x	0.77	x	9.83	x	74.72	x	0.63	x	0.7	=	224.46	(74)
North	0.9x	0.77	x	2.24	x	79.99	x	0.63	x	0.7	=	54.76	(74)
North	0.9x	0.77	x	9.83	x	79.99	x	0.63	x	0.7	=	240.29	(74)
North	0.9x	0.77	x	2.24	x	74.68	x	0.63	x	0.7	=	51.12	(74)
North	0.9x	0.77	x	9.83	x	74.68	x	0.63	x	0.7	=	224.34	(74)
North	0.9x	0.77	x	2.24	x	59.25	x	0.63	x	0.7	=	40.56	(74)
North	0.9x	0.77	x	9.83	x	59.25	x	0.63	x	0.7	=	177.99	(74)
North	0.9x	0.77	x	2.24	x	41.52	x	0.63	x	0.7	=	28.42	(74)
North	0.9x	0.77	x	9.83	x	41.52	x	0.63	x	0.7	=	124.72	(74)
North	0.9x	0.77	x	2.24	x	24.19	x	0.63	x	0.7	=	16.56	(74)
North	0.9x	0.77	x	9.83	x	24.19	x	0.63	x	0.7	=	72.67	(74)
North	0.9x	0.77	x	2.24	x	13.12	x	0.63	x	0.7	=	8.98	(74)
North	0.9x	0.77	x	9.83	x	13.12	x	0.63	x	0.7	=	39.41	(74)
North	0.9x	0.77	x	2.24	x	8.86	x	0.63	x	0.7	=	6.07	(74)
North	0.9x	0.77	x	9.83	x	8.86	x	0.63	x	0.7	=	26.63	(74)
West	0.9x	0.77	x	1.87	x	19.64	x	0.63	x	0.7	=	11.22	(80)
West	0.9x	0.77	x	1.5	x	19.64	x	0.63	x	0.7	=	9	(80)
West	0.9x	0.77	x	1.5	x	19.64	x	0.63	x	0.7	=	9	(80)
West	0.9x	0.77	x	2.71	x	19.64	x	0.63	x	0.7	=	16.27	(80)
West	0.9x	0.77	x	1.87	x	38.42	x	0.63	x	0.7	=	21.96	(80)
West	0.9x	0.77	x	1.5	x	38.42	x	0.63	x	0.7	=	17.61	(80)
West	0.9x	0.77	x	1.5	x	38.42	x	0.63	x	0.7	=	17.61	(80)
West	0.9x	0.77	x	2.71	x	38.42	x	0.63	x	0.7	=	31.82	(80)
West	0.9x	0.77	x	1.87	x	63.27	x	0.63	x	0.7	=	36.16	(80)
West	0.9x	0.77	x	1.5	x	63.27	x	0.63	x	0.7	=	29.01	(80)
West	0.9x	0.77	x	1.5	x	63.27	x	0.63	x	0.7	=	29.01	(80)
West	0.9x	0.77	x	2.71	x	63.27	x	0.63	x	0.7	=	52.4	(80)
West	0.9x	0.77	x	1.87	x	92.28	x	0.63	x	0.7	=	52.74	(80)
West	0.9x	0.77	x	1.5	x	92.28	x	0.63	x	0.7	=	42.3	(80)
West	0.9x	0.77	x	1.5	x	92.28	x	0.63	x	0.7	=	42.3	(80)
West	0.9x	0.77	x	2.71	x	92.28	x	0.63	x	0.7	=	76.43	(80)
West	0.9x	0.77	x	1.87	x	113.09	x	0.63	x	0.7	=	64.63	(80)
West	0.9x	0.77	x	1.5	x	113.09	x	0.63	x	0.7	=	51.84	(80)
West	0.9x	0.77	x	1.5	x	113.09	x	0.63	x	0.7	=	51.84	(80)
West	0.9x	0.77	x	2.71	x	113.09	x	0.63	x	0.7	=	93.66	(80)
West	0.9x	0.77	x	1.87	x	115.77	x	0.63	x	0.7	=	66.16	(80)
West	0.9x	0.77	x	1.5	x	115.77	x	0.63	x	0.7	=	53.07	(80)

TER WorkSheet: New dwelling design stage

West	0.9x	0.77	x	1.5	x	115.77	x	0.63	x	0.7	=	53.07	(80)
West	0.9x	0.77	x	2.71	x	115.77	x	0.63	x	0.7	=	95.88	(80)
West	0.9x	0.77	x	1.87	x	110.22	x	0.63	x	0.7	=	62.99	(80)
West	0.9x	0.77	x	1.5	x	110.22	x	0.63	x	0.7	=	50.53	(80)
West	0.9x	0.77	x	1.5	x	110.22	x	0.63	x	0.7	=	50.53	(80)
West	0.9x	0.77	x	2.71	x	110.22	x	0.63	x	0.7	=	91.28	(80)
West	0.9x	0.77	x	1.87	x	94.68	x	0.63	x	0.7	=	54.11	(80)
West	0.9x	0.77	x	1.5	x	94.68	x	0.63	x	0.7	=	43.4	(80)
West	0.9x	0.77	x	1.5	x	94.68	x	0.63	x	0.7	=	43.4	(80)
West	0.9x	0.77	x	2.71	x	94.68	x	0.63	x	0.7	=	78.41	(80)
West	0.9x	0.77	x	1.87	x	73.59	x	0.63	x	0.7	=	42.06	(80)
West	0.9x	0.77	x	1.5	x	73.59	x	0.63	x	0.7	=	33.73	(80)
West	0.9x	0.77	x	1.5	x	73.59	x	0.63	x	0.7	=	33.73	(80)
West	0.9x	0.77	x	2.71	x	73.59	x	0.63	x	0.7	=	60.95	(80)
West	0.9x	0.77	x	1.87	x	45.59	x	0.63	x	0.7	=	26.05	(80)
West	0.9x	0.77	x	1.5	x	45.59	x	0.63	x	0.7	=	20.9	(80)
West	0.9x	0.77	x	1.5	x	45.59	x	0.63	x	0.7	=	20.9	(80)
West	0.9x	0.77	x	2.71	x	45.59	x	0.63	x	0.7	=	37.76	(80)
West	0.9x	0.77	x	1.87	x	24.49	x	0.63	x	0.7	=	14	(80)
West	0.9x	0.77	x	1.5	x	24.49	x	0.63	x	0.7	=	11.23	(80)
West	0.9x	0.77	x	1.5	x	24.49	x	0.63	x	0.7	=	11.23	(80)
West	0.9x	0.77	x	2.71	x	24.49	x	0.63	x	0.7	=	20.28	(80)
West	0.9x	0.77	x	1.87	x	16.15	x	0.63	x	0.7	=	9.23	(80)
West	0.9x	0.77	x	1.5	x	16.15	x	0.63	x	0.7	=	7.4	(80)
West	0.9x	0.77	x	1.5	x	16.15	x	0.63	x	0.7	=	7.4	(80)
West	0.9x	0.77	x	2.71	x	16.15	x	0.63	x	0.7	=	13.38	(80)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m=	84.72	163.96	273.95	418.37	537.59	563.23	530.79	437.87	323.62	194.84	105.12	70.11	(83)
--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	------

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=	504.35	581.53	678.09	800.82	898	902.37	856.09	769.1	665.97	559.1	494.56	478.47	(84)
--------	--------	--------	--------	--------	-----	--------	--------	-------	--------	-------	--------	--------	------

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(86)	
(86)m=	1	0.99	0.98	0.91	0.73	0.52	0.38	0.44	0.73	0.96	0.99	1	

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	20.05	20.2	20.45	20.77	20.95	20.99	21	21	20.96	20.7	20.32	20.02	(87)
--------	-------	------	-------	-------	-------	-------	----	----	-------	------	-------	-------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	20.11	20.12	20.12	20.13	20.13	20.14	20.14	20.14	20.14	20.13	20.13	20.12	(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	1	0.99	0.97	0.88	0.68	0.45	0.31	0.36	0.65	0.94	0.99	1	(89)
--------	---	------	------	------	------	------	------	------	------	------	------	---	------

TER WorkSheet: New dwelling design stage

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.84	19.06	19.43	19.87	20.09	20.14	20.14	20.14	20.11	19.79	19.24	18.81	(90)
	$fLA = \text{Living area} \div (4) =$												0.43 (91)

Mean internal temperature (for the whole dwelling) = $fLA \times T1 + (1 - fLA) \times T2$

(92)m=	19.35	19.54	19.87	20.25	20.45	20.5	20.51	20.51	20.47	20.17	19.7	19.33	(92)
--------	-------	-------	-------	-------	-------	------	-------	-------	-------	-------	------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.35	19.54	19.87	20.25	20.45	20.5	20.51	20.51	20.47	20.17	19.7	19.33	(93)
--------	-------	-------	-------	-------	-------	------	-------	-------	-------	-------	------	-------	------

8. Space heating requirement

Set T_i to the mean internal temperature obtained at step 11 of Table 9b, so that $T_{i,m} = (76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, h_m :

(94)m=	1	0.99	0.97	0.88	0.7	0.48	0.34	0.4	0.68	0.94	0.99	1	(94)
--------	---	------	------	------	-----	------	------	-----	------	------	------	---	------

Useful gains, $h_m G_m$, $W = (94)m \times (84)m$

(95)m=	502.08	575.44	656.13	706.92	627.36	435.85	290.22	303.96	455.9	525.46	489.55	476.85	(95)
--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, L_m , $W = [(39)m \times (93)m - (96)m]$

(97)m=	1161.04	1126	1024.6	857.62	659.28	438.9	290.52	304.68	476.3	721.21	954.35	1152.54	(97)
--------	---------	------	--------	--------	--------	-------	--------	--------	-------	--------	--------	---------	------

Space heating requirement for each month, kWh/month = $0.024 \times [(97)m - (95)m] \times (41)m$

(98)m=	490.27	369.98	274.14	108.5	23.75	0	0	0	0	145.64	334.66	502.72	Total per year (kWh/year) = Sum(98) _{1...5,9...12} = 2249.66 (98)
--------	--------	--------	--------	-------	-------	---	---	---	---	--------	--------	--------	--

Space heating requirement in kWh/m²/year

	28.12 (99)
--	------------

9a. Energy requirements – Individual heating systems including micro-CHP

Space heating:

Fraction of space heat from secondary/supplementary system

	0 (201)
--	---------

Fraction of space heat from main system(s)

(202) = 1 - (201) = 1 (202)

Fraction of total heating from main system 1

(204) = (202) × [1 - (203)] = 1 (204)

Efficiency of main space heating system 1

93.5 (206)

Efficiency of secondary/supplementary heating system, %

0 (208)

Jan Feb Mar Apr May Jun Jul Aug Sep Oct Nov Dec kWh/year
--

Space heating requirement (calculated above)

490.27 369.98 274.14 108.5 23.75 0 0 0 0 145.64 334.66 502.72

$$(211)m = \{[(98)m \times (204)]\} \times 100 \div (206) \quad (211)$$

524.36 395.7 293.2 116.05 25.4 0 0 0 0 155.76 357.92 537.67

$$\text{Total (kWh/year)} = \text{Sum}(211)_{1...5,10...12} = 2406.05 \quad (211)$$

Space heating fuel (secondary), kWh/month

$$= \{[(98)m \times (201)]\} \times 100 \div (208) \quad (208)$$

(215)m= 0 0 0 0 0 0 0 0 0 0 0 0 0

$$\text{Total (kWh/year)} = \text{Sum}(215)_{1...5,10...12} = 0 \quad (215)$$

Water heating

Output from water heater (calculated above)

197.8 174.33 183.06 164.07 160.75 143.6 137.88 151.35 151.09 170.13 179.94 193.03

Efficiency of water heater

79.8 (216)

TER WorkSheet: New dwelling design stage

(217)m =	87.14	86.77	85.89	83.74	81.03	79.8	79.8	79.8	84.4	86.45	87.25	(217)
----------	-------	-------	-------	-------	-------	------	------	------	------	-------	-------	-------

Fuel for water heating, kWh/month

$$(219)m = (64)m \times 100 \div (217)m$$

(219)m =	226.99	200.91	213.14	195.92	198.38	179.95	172.78	189.66	189.34	201.57	208.15	221.23	Total = Sum(219a) _{1...12} = 2398.01 (219)
----------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	---

Annual totals

Space heating fuel used, main system 1

kWh/year

2406.05

Water heating fuel used

2398.01

Electricity for pumps, fans and electric keep-hot

central heating pump:

30

(230c)

boiler with a fan-assisted flue

45

(230e)

Total electricity for the above, kWh/year

sum of (230a)...(230g) =

75

(231)

Electricity for lighting

345.49

(232)

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year	
Space heating (main system 1)	(211) x	0.216	= 519.71	(261)
Space heating (secondary)	(215) x	0.519	= 0	(263)
Water heating	(219) x	0.216	= 517.97	(264)
Space and water heating	(261) + (262) + (263) + (264) =		1037.68	(265)
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	= 38.93	(267)
Electricity for lighting	(232) x	0.519	= 179.31	(268)
Total CO2, kg/year		sum of (265)...(271) =	1255.91	(272)

TER =

15.7

(273)

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 108 - Be Lean			
Address :	AC 108, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	52.1 (1a)	x (2a)	2.6 = 135.46 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	52.1 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	135.46 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 x 20 = 0 (6b)
Number of intermittent fans					x 10 = 0 (7a)
Number of passive vents					x 10 = 0 (7b)
Number of flueless gas fires					x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =	0	÷ (5) = 0 (8)
If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)		
Number of storeys in the dwelling (ns)	0	(9)
Additional infiltration	[(9)-1]x0.1 = 0	(10)
Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction	0	(11)

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0	0 (12)
If no draught lobby, enter 0.05, else enter 0	0 (13)
Percentage of windows and doors draught stripped	0 (14)
Window infiltration	0.25 - [0.2 x (14) ÷ 100] = 0 (15)
Infiltration rate	(8) + (10) + (11) + (12) + (13) + (15) = 0 (16)
Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area	2 (17)
If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)	0.1 (18)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered	2 (19)
Shelter factor	(20) = 1 - [0.075 x (19)] = 0.85 (20)
Infiltration rate incorporating shelter factor	(21) = (18) x (20) = 0.08 (21)

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

DER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.11	0.11	0.1	0.09	0.09	0.08	0.08	0.08	0.08	0.09	0.1	0.1
------	------	-----	------	------	------	------	------	------	------	-----	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.21	0.21	0.22
---------	------	------	------	------	------	-----	-----	-----	------	------	------

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.2	0.21	0.21	0.22
--------	------	------	------	------	------	-----	-----	-----	-----	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Windows Type 1			4.1	x1/[1/(1.4)+ 0.04] =	5.44		(27)
Windows Type 2			1.71	x1/[1/(1.4)+ 0.04] =	2.27		(27)
Windows Type 3			6.18	x1/[1/(1.4)+ 0.04] =	8.19		(27)
Windows Type 4			1.67	x1/[1/(1.4)+ 0.04] =	2.21		(27)
Walls	31.1	13.66	17.44	x 0.12 =	2.09		(29)
Total area of elements, m ²			31.1				(31)
Party wall			44.62	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 20.2 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 5.43 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 25.63 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	10.1	10	9.91	9.43	9.34	8.86	8.86	8.77	9.05	9.34	9.53	9.72

(38)

Heat transfer coefficient, W/K (39)m = (37) + (38)m

(39)m=	35.73	35.63	35.54	35.06	34.97	34.49	34.49	34.4	34.68	34.97	35.16	35.35
--------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	-------

Average = Sum(39)_{1...12} / 12= 35.04 (39)

DER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	0.69	0.68	0.68	0.67	0.67	0.66	0.66	0.66	0.67	0.67	0.67	0.68	
	Average = Sum(40) _{1...12} /12=											0.67	(40)

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(41)m=	31	28	31	30	31	30	31	31	30	31	30	31	(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

1.75

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd,\text{average} = (25 \times N) + 36$

75.81

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	83.39	80.36	77.33	74.29	71.26	68.23	68.23	71.26	74.29	77.33	80.36	83.39	
	Total = Sum(44) _{1...12} =											909.73	(44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	123.67	108.16	111.61	97.31	93.37	80.57	74.66	85.67	86.7	101.03	110.29	119.77	
	Total = Sum(45) _{1...12} =											1192.79	(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	18.55	16.22	16.74	14.6	14.01	12.09	11.2	12.85	13	15.16	16.54	17.96
--------	-------	-------	-------	------	-------	-------	------	-------	----	-------	-------	-------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0

(48)

Temperature factor from Table 2b

0

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

110

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0.02

(51)

If community heating see section 4.3

Volume factor from Table 2a

1.03

(52)

Temperature factor from Table 2b

0.6

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

1.03

(54)

Enter (50) or (54) in (55)

1.03

(55)

Water storage loss calculated for each month

((56)m = (55) x (41)m)

(56)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

If cylinder contains dedicated solar storage, (57)m = (56)m x [(50) - (H11)] ÷ (50), else (57)m = (56)m where (H11) is from Appendix H

(57)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month (59)m = (58) ÷ 365 x (41)m

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

DER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	178.94	158.09	166.89	150.8	148.64	134.06	129.94	140.95	140.19	156.31	163.78	175.04	(62)
--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	178.94	158.09	166.89	150.8	148.64	134.06	129.94	140.95	140.19	156.31	163.78	175.04	Output from water heater (annual) 1...12	1843.63	(64)
--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--	---------	------

Heat gains from water heating, kWh/month 0.25 $[0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	85.34	75.91	81.33	75.15	75.27	69.58	69.05	72.71	71.62	77.82	79.47	84.04	(65)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m=	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	13.61	12.09	9.83	7.44	5.56	4.7	5.08	6.6	8.86	11.24	13.12	13.99	(67)
--------	-------	-------	------	------	------	-----	------	-----	------	-------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	152.69	154.27	150.28	141.78	131.05	120.96	114.23	112.64	116.63	125.13	135.86	145.95	(68)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	0	0	0	0	0	0	0	0	0	0	0	0	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	114.71	112.95	109.32	104.37	101.16	96.64	92.8	97.72	99.47	104.59	110.37	112.96	(72)
--------	--------	--------	--------	--------	--------	-------	------	-------	-------	--------	--------	--------	------

Total internal gains =

$$(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$$

(73)m=	330.28	328.59	318.71	302.87	287.06	271.59	261.39	266.25	274.24	290.25	308.64	322.18	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)
North	0.9x	0.77	x 1.71	x 10.63	x 0.4	x 0.8 = 4.03
North	0.9x	0.77	x 6.18	x 10.63	x 0.4	x 0.8 = 14.57
North	0.9x	0.77	x 1.71	x 20.32	x 0.4	x 0.8 = 7.71
North	0.9x	0.77	x 6.18	x 20.32	x 0.4	x 0.8 = 27.85
North	0.9x	0.77	x 1.71	x 34.53	x 0.4	x 0.8 = 13.09

DER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	6.18	x	34.53	x	0.4	x	0.8	=	47.32	(74)
North	0.9x	0.77	x	1.71	x	55.46	x	0.4	x	0.8	=	21.03	(74)
North	0.9x	0.77	x	6.18	x	55.46	x	0.4	x	0.8	=	76.01	(74)
North	0.9x	0.77	x	1.71	x	74.72	x	0.4	x	0.8	=	28.33	(74)
North	0.9x	0.77	x	6.18	x	74.72	x	0.4	x	0.8	=	102.4	(74)
North	0.9x	0.77	x	1.71	x	79.99	x	0.4	x	0.8	=	30.33	(74)
North	0.9x	0.77	x	6.18	x	79.99	x	0.4	x	0.8	=	109.62	(74)
North	0.9x	0.77	x	1.71	x	74.68	x	0.4	x	0.8	=	28.32	(74)
North	0.9x	0.77	x	6.18	x	74.68	x	0.4	x	0.8	=	102.34	(74)
North	0.9x	0.77	x	1.71	x	59.25	x	0.4	x	0.8	=	22.47	(74)
North	0.9x	0.77	x	6.18	x	59.25	x	0.4	x	0.8	=	81.2	(74)
North	0.9x	0.77	x	1.71	x	41.52	x	0.4	x	0.8	=	15.74	(74)
North	0.9x	0.77	x	6.18	x	41.52	x	0.4	x	0.8	=	56.9	(74)
North	0.9x	0.77	x	1.71	x	24.19	x	0.4	x	0.8	=	9.17	(74)
North	0.9x	0.77	x	6.18	x	24.19	x	0.4	x	0.8	=	33.15	(74)
North	0.9x	0.77	x	1.71	x	13.12	x	0.4	x	0.8	=	4.97	(74)
North	0.9x	0.77	x	6.18	x	13.12	x	0.4	x	0.8	=	17.98	(74)
North	0.9x	0.77	x	1.71	x	8.86	x	0.4	x	0.8	=	3.36	(74)
North	0.9x	0.77	x	6.18	x	8.86	x	0.4	x	0.8	=	12.15	(74)
South	0.9x	0.77	x	4.1	x	46.75	x	0.4	x	0.8	=	42.51	(78)
South	0.9x	0.77	x	1.67	x	46.75	x	0.4	x	0.8	=	17.31	(78)
South	0.9x	0.77	x	4.1	x	76.57	x	0.4	x	0.8	=	69.62	(78)
South	0.9x	0.77	x	1.67	x	76.57	x	0.4	x	0.8	=	28.36	(78)
South	0.9x	0.77	x	4.1	x	97.53	x	0.4	x	0.8	=	88.68	(78)
South	0.9x	0.77	x	1.67	x	97.53	x	0.4	x	0.8	=	36.12	(78)
South	0.9x	0.77	x	4.1	x	110.23	x	0.4	x	0.8	=	100.23	(78)
South	0.9x	0.77	x	1.67	x	110.23	x	0.4	x	0.8	=	40.82	(78)
South	0.9x	0.77	x	4.1	x	114.87	x	0.4	x	0.8	=	104.44	(78)
South	0.9x	0.77	x	1.67	x	114.87	x	0.4	x	0.8	=	42.54	(78)
South	0.9x	0.77	x	4.1	x	110.55	x	0.4	x	0.8	=	100.51	(78)
South	0.9x	0.77	x	1.67	x	110.55	x	0.4	x	0.8	=	40.94	(78)
South	0.9x	0.77	x	4.1	x	108.01	x	0.4	x	0.8	=	98.21	(78)
South	0.9x	0.77	x	1.67	x	108.01	x	0.4	x	0.8	=	40	(78)
South	0.9x	0.77	x	4.1	x	104.89	x	0.4	x	0.8	=	95.37	(78)
South	0.9x	0.77	x	1.67	x	104.89	x	0.4	x	0.8	=	38.85	(78)
South	0.9x	0.77	x	4.1	x	101.89	x	0.4	x	0.8	=	92.64	(78)
South	0.9x	0.77	x	1.67	x	101.89	x	0.4	x	0.8	=	37.73	(78)
South	0.9x	0.77	x	4.1	x	82.59	x	0.4	x	0.8	=	75.09	(78)
South	0.9x	0.77	x	1.67	x	82.59	x	0.4	x	0.8	=	30.58	(78)
South	0.9x	0.77	x	4.1	x	55.42	x	0.4	x	0.8	=	50.39	(78)
South	0.9x	0.77	x	1.67	x	55.42	x	0.4	x	0.8	=	20.52	(78)

DER WorkSheet: New dwelling design stage

South	$0.9 \times$	0.77	\times	4.1	\times	40.4	\times	0.4	\times	0.8	=	36.73	(78)
South	$0.9 \times$	0.77	\times	1.67	\times	40.4	\times	0.4	\times	0.8	=	14.96	(78)

Solar gains in watts, calculated for each month $(83)m = \text{Sum}(74)m \dots (82)m$

(83)m=	78.43	133.53	185.22	238.1	277.71	281.4	268.87	237.88	203.01	148	93.86	67.2	(83)
--------	-------	--------	--------	-------	--------	-------	--------	--------	--------	-----	-------	------	------

Total gains – internal and solar $(84)m = (73)m + (83)m$, watts

(84)m=	408.71	462.12	503.92	540.97	564.77	552.99	530.25	504.13	477.25	438.25	402.5	389.38	(84)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	------

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 ($^{\circ}\text{C}$)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m=	0.98	0.96	0.9	0.76	0.57	0.4	0.29	0.31	0.5	0.79	0.95	0.99	(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	20.62	20.74	20.87	20.97	21	21	21	21	21	20.97	20.79	20.59	(87)
--------	-------	-------	-------	-------	----	----	----	----	----	-------	-------	-------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 ($^{\circ}\text{C}$)

(88)m=	20.35	20.36	20.36	20.36	20.37	20.37	20.37	20.38	20.37	20.37	20.36	20.36	(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.98	0.95	0.88	0.72	0.53	0.36	0.25	0.27	0.46	0.75	0.94	0.98	(89)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	19.85	20.03	20.21	20.33	20.36	20.37	20.37	20.38	20.37	20.33	20.11	19.82	(90)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

fLA = Living area $\div (4) =$

0.51

(91)

Mean internal temperature (for the whole dwelling) = fLA \times T1 + (1 – fLA) \times T2

(92)m=	20.24	20.39	20.55	20.66	20.69	20.69	20.69	20.69	20.69	20.65	20.46	20.21	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	20.24	20.39	20.55	20.66	20.69	20.69	20.69	20.69	20.69	20.65	20.46	20.21	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that $Ti,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	--	--

Utilisation factor for gains, hm:

(94)m=	0.98	0.95	0.88	0.74	0.55	0.38	0.27	0.29	0.48	0.77	0.94	0.98	(94)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Useful gains, hmGm , W = (94)m \times (84)m

(95)m=	399.38	438.17	444.46	399.59	312.84	210.1	141.17	147.68	228.23	337.38	379.53	382.61	(95)
--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W = [(39)m \times [(93)m – (96)m]

(97)m=	569.53	552.02	499.22	412.25	314.21	210.15	141.17	147.69	228.57	351.58	469.62	565.87	(97)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Space heating requirement for each month, kWh/month = 0.024 \times [(97)m – (95)m] \times (41)m

(98)m=	126.59	76.51	40.74	9.12	1.02	0	0	0	0	10.57	64.87	136.34	
--------	--------	-------	-------	------	------	---	---	---	---	-------	-------	--------	--

Total per year (kWh/year) = Sum(98)_{1...5,9...12} = 465.76 (98)

Space heating requirement in kWh/m²/year 8.94 (99)

9b. Energy requirements – Community heating scheme

This part is used for space heating, space cooling or water heating provided by a community scheme.

DER WorkSheet: New dwelling design stage

Fraction of space heat from secondary/supplementary heating (Table 11) '0' if none	<input type="text" value="0"/>	(301)
Fraction of space heat from community system 1 – (301) =	<input type="text" value="1"/>	(302)

The community scheme may obtain heat from several sources. The procedure allows for CHP and up to four other heat sources; the latter includes boilers, heat pumps, geothermal and waste heat from power stations. See Appendix C.

Fraction of heat from Community boilers	<input type="text" value="1"/>	(303a)
Fraction of total space heat from Community boilers	<input type="text" value="1"/>	(304a)
Factor for control and charging method (Table 4c(3)) for community heating system	<input type="text" value="1"/>	(305)
Distribution loss factor (Table 12c) for community heating system	<input type="text" value="1.1"/>	(306)

Space heating

Annual space heating requirement	<input type="text" value="465.76"/>	kWh/year
Space heat from Community boilers	<input type="text" value="512.33"/>	(307a)
Efficiency of secondary/supplementary heating system in % (from Table 4a or Appendix E)	<input type="text" value="0"/>	(308)
Space heating requirement from secondary/supplementary system	<input type="text" value="0"/>	(309)

Water heating

Annual water heating requirement	<input type="text" value="1843.63"/>	
If DHW from community scheme:		
Water heat from Community boilers	<input type="text" value="2028"/>	(310a)
Electricity used for heat distribution	<input type="text" value="25.4"/>	(313)
Cooling System Energy Efficiency Ratio	<input type="text" value="0"/>	(314)
Space cooling (if there is a fixed cooling system, if not enter 0)	<input type="text" value="0"/>	(315)
Electricity for pumps and fans within dwelling (Table 4f): mechanical ventilation - balanced, extract or positive input from outside	<input type="text" value="103.29"/>	(330a)
warm air heating system fans	<input type="text" value="0"/>	(330b)
pump for solar water heating	<input type="text" value="0"/>	(330g)
Total electricity for the above, kWh/year	<input type="text" value="103.29"/>	(331)
Energy for lighting (calculated in Appendix L)	<input type="text" value="240.39"/>	(332)

12b. CO2 Emissions – Community heating scheme

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
CO2 from other sources of space and water heating (not CHP)			
Efficiency of heat source 1 (%)		If there is CHP using two fuels repeat (363) to (366) for the second fuel	<input type="text" value="95"/>
CO2 associated with heat source 1	$[(307b)+(310b)] \times 100 \div (367b) \times$	<input type="text" value="0.22"/>	$= 577.59$
Electrical energy for heat distribution	$[(313) \times$	<input type="text" value="0.52"/>	$= 13.18$
Total CO2 associated with community systems	$(363)...(366) + (368)...(372)$		$= 590.77$
CO2 associated with space heating (secondary)	$(309) \times$	<input type="text" value="0"/>	$= 0$
CO2 associated with water from immersion heater or instantaneous heater	$(312) \times$	<input type="text" value="0.22"/>	$= 0$
Total CO2 associated with space and water heating	$(373) + (374) + (375) =$		$= 590.77$
CO2 associated with electricity for pumps and fans within dwelling	$(331) \times$	<input type="text" value="0.52"/>	$= 53.61$

DER WorkSheet: New dwelling design stage

CO2 associated with electricity for lighting	(332)) x	0.52	=	124.76	(379)
Total CO2, kg/year	sum of (376)...(382) =	769.15		769.15	(383)
Dwelling CO2 Emission Rate	(383) ÷ (4) =	14.76		14.76	(384)
EI rating (section 14)		89.39		89.39	(385)

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 108 - Be Lean			
Address :	AC 108, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	52.1 (1a)	x (2a)	2.6 = 135.46 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	52.1 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	135.46 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour	
Number of chimneys	0	+	0	+	0	x 40 = 0 (6a)
Number of open flues	0	+	0	+	0	x 20 = 0 (6b)
Number of intermittent fans					2	x 10 = 20 (7a)
Number of passive vents					0	x 10 = 0 (7b)
Number of flueless gas fires					0	x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 20 ÷ (5) = 0.15 (8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] = 0

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) = 0

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area 5

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] = 0.85

Infiltration rate incorporating shelter factor (21) = (18) x (20) = 0.34

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

TER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.43	0.42	0.41	0.37	0.36	0.32	0.32	0.31	0.34	0.36	0.38	0.4
------	------	------	------	------	------	------	------	------	------	------	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0.59	0.59	0.59	0.57	0.57	0.55	0.55	0.55	0.56	0.57	0.57	0.58
---------	------	------	------	------	------	------	------	------	------	------	------	------

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.59	0.59	0.59	0.57	0.57	0.55	0.55	0.55	0.56	0.57	0.57	0.58
--------	------	------	------	------	------	------	------	------	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Windows Type 1			3.91	x1/[1/(1.4)+ 0.04] =	5.18		(27)
Windows Type 2			1.63	x1/[1/(1.4)+ 0.04] =	2.16		(27)
Windows Type 3			5.89	x1/[1/(1.4)+ 0.04] =	7.81		(27)
Windows Type 4			1.59	x1/[1/(1.4)+ 0.04] =	2.11		(27)
Walls	31.1	13.02	18.08	x 0.18 =	3.25		(29)
Total area of elements, m ²			31.1				(31)
Party wall			44.62	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 20.52 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 3.74 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 24.26 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	26.5	26.34	26.18	25.44	25.3	24.66	24.66	24.54	24.9	25.3	25.58	25.88

(38)

Heat transfer coefficient, W/K (39)m = (37) + (38)m

(39)m=	50.76	50.6	50.44	49.7	49.56	48.91	48.91	48.79	49.16	49.56	49.84	50.14
Average = Sum(39) _{1...12} /12=												49.7 (39)

TER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	0.97	0.97	0.97	0.95	0.95	0.94	0.94	0.94	0.94	0.95	0.96	0.96	(40)
													Average = Sum(40) _{1...12} /12=

$$(40)m = (39)m \div (4)$$

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(41)
(41)m=	31	28	31	30	31	30	31	31	30	31	30	31

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

1.75

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

75.81

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$											

(44)m=	83.39	80.36	77.33	74.29	71.26	68.23	68.23	71.26	74.29	77.33	80.36	83.39	
													Total = Sum(44) _{1...12} =

909.73

(44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	123.67	108.16	111.61	97.31	93.37	80.57	74.66	85.67	86.7	101.03	110.29	119.77	
													Total = Sum(45) _{1...12} =

1192.79

(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	18.55	16.22	16.74	14.6	14.01	12.09	11.2	12.85	13	15.16	16.54	17.96	
													150

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

150

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

1.39

(48)

Temperature factor from Table 2b

0.54

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

0.75

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0

(51)

If community heating see section 4.3

Volume factor from Table 2a

0

(52)

Temperature factor from Table 2b

0

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

0

(54)

Enter (50) or (54) in (55)

0.75

(55)

Water storage loss calculated for each month

((56)m = (55) x (41)m)

(56)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	
													(56)

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	
													(57)

0

(58)

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26	
													(59)

TER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	170.26	150.25	158.21	142.4	139.96	125.66	121.25	132.27	131.79	147.63	155.38	166.36	(62)
--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	170.26	150.25	158.21	142.4	139.96	125.66	121.25	132.27	131.79	147.63	155.38	166.36	Output from water heater (annual) 1...12	1741.41	(64)
--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--	---------	------

Heat gains from water heating, kWh/month 0.25 $[0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	78.4	69.63	74.39	68.43	68.32	62.86	62.1	65.76	64.9	70.87	72.74	77.1	(65)
--------	------	-------	-------	-------	-------	-------	------	-------	------	-------	-------	------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m=	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	13.61	12.09	9.83	7.44	5.56	4.7	5.08	6.6	8.86	11.24	13.12	13.99	(67)
--------	-------	-------	------	------	------	-----	------	-----	------	-------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	152.69	154.27	150.28	141.78	131.05	120.96	114.23	112.64	116.63	125.13	135.86	145.95	(68)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	3	3	3	3	3	3	3	3	3	3	3	3	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	105.37	103.62	99.98	95.04	91.83	87.31	83.47	88.39	90.14	95.26	101.03	103.63	(72)
--------	--------	--------	-------	-------	-------	-------	-------	-------	-------	-------	--------	--------	------

Total internal gains = $(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$

(73)m=	323.95	322.26	312.37	296.54	280.72	265.25	255.05	259.91	267.91	283.91	302.3	315.85	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)		
North	0.9x	0.77	x 1.63	x 10.63	x 0.63	= 0.7	= 5.3	(74)
North	0.9x	0.77	x 5.89	x 10.63	x 0.63	= 0.7	= 19.14	(74)
North	0.9x	0.77	x 1.63	x 20.32	x 0.63	= 0.7	= 10.12	(74)
North	0.9x	0.77	x 5.89	x 20.32	x 0.63	= 0.7	= 36.58	(74)
North	0.9x	0.77	x 1.63	x 34.53	x 0.63	= 0.7	= 17.2	(74)

TER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	5.89	x	34.53	x	0.63	x	0.7	=	62.16	(74)
North	0.9x	0.77	x	1.63	x	55.46	x	0.63	x	0.7	=	27.63	(74)
North	0.9x	0.77	x	5.89	x	55.46	x	0.63	x	0.7	=	99.84	(74)
North	0.9x	0.77	x	1.63	x	74.72	x	0.63	x	0.7	=	37.22	(74)
North	0.9x	0.77	x	5.89	x	74.72	x	0.63	x	0.7	=	134.49	(74)
North	0.9x	0.77	x	1.63	x	79.99	x	0.63	x	0.7	=	39.84	(74)
North	0.9x	0.77	x	5.89	x	79.99	x	0.63	x	0.7	=	143.98	(74)
North	0.9x	0.77	x	1.63	x	74.68	x	0.63	x	0.7	=	37.2	(74)
North	0.9x	0.77	x	5.89	x	74.68	x	0.63	x	0.7	=	134.42	(74)
North	0.9x	0.77	x	1.63	x	59.25	x	0.63	x	0.7	=	29.51	(74)
North	0.9x	0.77	x	5.89	x	59.25	x	0.63	x	0.7	=	106.65	(74)
North	0.9x	0.77	x	1.63	x	41.52	x	0.63	x	0.7	=	20.68	(74)
North	0.9x	0.77	x	5.89	x	41.52	x	0.63	x	0.7	=	74.73	(74)
North	0.9x	0.77	x	1.63	x	24.19	x	0.63	x	0.7	=	12.05	(74)
North	0.9x	0.77	x	5.89	x	24.19	x	0.63	x	0.7	=	43.54	(74)
North	0.9x	0.77	x	1.63	x	13.12	x	0.63	x	0.7	=	6.53	(74)
North	0.9x	0.77	x	5.89	x	13.12	x	0.63	x	0.7	=	23.61	(74)
North	0.9x	0.77	x	1.63	x	8.86	x	0.63	x	0.7	=	4.42	(74)
North	0.9x	0.77	x	5.89	x	8.86	x	0.63	x	0.7	=	15.96	(74)
South	0.9x	0.77	x	3.91	x	46.75	x	0.63	x	0.7	=	55.87	(78)
South	0.9x	0.77	x	1.59	x	46.75	x	0.63	x	0.7	=	22.72	(78)
South	0.9x	0.77	x	3.91	x	76.57	x	0.63	x	0.7	=	91.49	(78)
South	0.9x	0.77	x	1.59	x	76.57	x	0.63	x	0.7	=	37.21	(78)
South	0.9x	0.77	x	3.91	x	97.53	x	0.63	x	0.7	=	116.55	(78)
South	0.9x	0.77	x	1.59	x	97.53	x	0.63	x	0.7	=	47.39	(78)
South	0.9x	0.77	x	3.91	x	110.23	x	0.63	x	0.7	=	131.72	(78)
South	0.9x	0.77	x	1.59	x	110.23	x	0.63	x	0.7	=	53.57	(78)
South	0.9x	0.77	x	3.91	x	114.87	x	0.63	x	0.7	=	137.26	(78)
South	0.9x	0.77	x	1.59	x	114.87	x	0.63	x	0.7	=	55.82	(78)
South	0.9x	0.77	x	3.91	x	110.55	x	0.63	x	0.7	=	132.1	(78)
South	0.9x	0.77	x	1.59	x	110.55	x	0.63	x	0.7	=	53.72	(78)
South	0.9x	0.77	x	3.91	x	108.01	x	0.63	x	0.7	=	129.07	(78)
South	0.9x	0.77	x	1.59	x	108.01	x	0.63	x	0.7	=	52.49	(78)
South	0.9x	0.77	x	3.91	x	104.89	x	0.63	x	0.7	=	125.34	(78)
South	0.9x	0.77	x	1.59	x	104.89	x	0.63	x	0.7	=	50.97	(78)
South	0.9x	0.77	x	3.91	x	101.89	x	0.63	x	0.7	=	121.75	(78)
South	0.9x	0.77	x	1.59	x	101.89	x	0.63	x	0.7	=	49.51	(78)
South	0.9x	0.77	x	3.91	x	82.59	x	0.63	x	0.7	=	98.69	(78)
South	0.9x	0.77	x	1.59	x	82.59	x	0.63	x	0.7	=	40.13	(78)
South	0.9x	0.77	x	3.91	x	55.42	x	0.63	x	0.7	=	66.22	(78)
South	0.9x	0.77	x	1.59	x	55.42	x	0.63	x	0.7	=	26.93	(78)

TER WorkSheet: New dwelling design stage

South	$0.9 \times$	0.77	\times	3.91	\times	40.4	\times	0.63	\times	0.7	=	48.27	(78)
South	$0.9 \times$	0.77	\times	1.59	\times	40.4	\times	0.63	\times	0.7	=	19.63	(78)

Solar gains in watts, calculated for each month $(83)m = \text{Sum}(74)m \dots (82)m$

(83)m=	103.02	175.4	243.3	312.76	364.8	369.64	353.18	312.47	266.67	194.41	123.3	88.28	(83)
--------	--------	-------	-------	--------	-------	--------	--------	--------	--------	--------	-------	-------	------

Total gains – internal and solar $(84)m = (73)m + (83)m$, watts

(84)m=	426.97	497.66	555.67	609.3	645.52	634.89	608.23	572.38	534.58	478.32	425.6	404.12	(84)
--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	-------	--------	------

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 ($^{\circ}\text{C}$)

21 (85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(86)m=	0.99	0.98	0.94	0.85	0.68	0.49	0.35	0.39	0.62	0.88	0.98	0.99

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	20.21	20.39	20.61	20.84	20.96	21	21	21	20.98	20.83	20.48	20.18	(87)
--------	-------	-------	-------	-------	-------	----	----	----	-------	-------	-------	-------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 ($^{\circ}\text{C}$)

(88)m=	20.1	20.11	20.11	20.12	20.12	20.13	20.13	20.14	20.13	20.12	20.12	20.11	(88)
--------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.99	0.97	0.93	0.81	0.63	0.42	0.28	0.32	0.55	0.85	0.97	0.99	(89)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	19.07	19.32	19.64	19.95	20.09	20.13	20.13	20.14	20.12	19.94	19.47	19.03	(90)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

fLA = Living area $\div (4) =$

0.51 (91)

Mean internal temperature (for the whole dwelling) = fLA \times T1 + (1 - fLA) \times T2

(92)m=	19.65	19.87	20.13	20.41	20.53	20.57	20.57	20.58	20.56	20.39	19.99	19.61	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.65	19.87	20.13	20.41	20.53	20.57	20.57	20.58	20.56	20.39	19.99	19.61	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that $Ti,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	0.99	0.97	0.93	0.83	0.65	0.46	0.32	0.36	0.58	0.86	0.97	0.99	(94)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Useful gains, hmGm , W = (94)m \times (84)m

(95)m=	420.79	481.56	515	503.05	422.31	290.49	194.25	203.44	311.42	411.6	411.78	399.61	(95)
--------	--------	--------	-----	--------	--------	--------	--------	--------	--------	-------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W = [(39)m \times [(93)m - (96)m]

(97)m=	779.05	757.24	687.77	571.8	437.83	292.08	194.41	203.72	317.54	485.34	642.26	772.7	(97)
--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	-------	------

Space heating requirement for each month, kWh/month = 0.024 \times [(97)m - (95)m] \times (41)m

(98)m=	266.55	185.25	128.54	49.5	11.55	0	0	0	0	54.86	165.94	277.58	
--------	--------	--------	--------	------	-------	---	---	---	---	-------	--------	--------	--

Total per year (kWh/year) = Sum(98)_{1...5,9...12} = 1139.77 (98)

Space heating requirement in kWh/m²/year 21.88 (99)

9a. Energy requirements – Individual heating systems including micro-CHP

Space heating:

Fraction of space heat from secondary/supplementary system 0 (201)

TER WorkSheet: New dwelling design stage

Fraction of space heat from main system(s)	$(202) = 1 - (201) =$	1	(202)
Fraction of total heating from main system 1	$(204) = (202) \times [1 - (203)] =$	1	(204)
Efficiency of main space heating system 1		93.5	(206)
Efficiency of secondary/supplementary heating system, %		0	(208)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

266.55	185.25	128.54	49.5	11.55	0	0	0	0	54.86	165.94	277.58	
--------	--------	--------	------	-------	---	---	---	---	-------	--------	--------	--

$$(211)m = \{[(98)m \times (204)]\} \times 100 \div (206) \quad (211)$$

285.08	198.13	137.48	52.94	12.35	0	0	0	0	58.67	177.48	296.87	
--------	--------	--------	-------	-------	---	---	---	---	-------	--------	--------	--

$$\text{Total (kWh/year)} = \text{Sum}(211)_{1...5,10...12} = 1219 \quad (211)$$

Space heating fuel (secondary), kWh/month

$$= \{[(98)m \times (201)]\} \times 100 \div (208)$$

0	0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---	---

$$\text{Total (kWh/year)} = \text{Sum}(215)_{1...5,10...12} = 0 \quad (215)$$

Water heating

Output from water heater (calculated above)

170.26	150.25	158.21	142.4	139.96	125.66	121.25	132.27	131.79	147.63	155.38	166.36	
--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--

Efficiency of water heater

86	85.37	84.27	82.31	80.53	79.8	79.8	79.8	79.8	82.44	84.99	86.17	
----	-------	-------	-------	-------	------	------	------	------	-------	-------	-------	--

$$79.8 \quad (216)$$

Fuel for water heating, kWh/month

$$(219)m = (64)m \times 100 \div (217)m$$

197.97	175.99	187.75	173	173.81	157.47	151.95	165.75	165.15	179.07	182.82	193.06	
--------	--------	--------	-----	--------	--------	--------	--------	--------	--------	--------	--------	--

$$\text{Total} = \text{Sum}(219a)_{1...12} = 2103.78 \quad (219)$$

Annual totals

Space heating fuel used, main system 1

kWh/year

	1219	
--	------	--

Water heating fuel used

kWh/year

	2103.78	
--	---------	--

Electricity for pumps, fans and electric keep-hot

central heating pump:

30 (230c)

boiler with a fan-assisted flue

45 (230e)

Total electricity for the above, kWh/year

$$\text{sum of (230a)...(230g)} = 75 \quad (231)$$

Electricity for lighting

240.39 (232)

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating (main system 1)	(211) x	0.216	= 263.3 (261)
Space heating (secondary)	(215) x	0.519	= 0 (263)
Water heating	(219) x	0.216	= 454.42 (264)
Space and water heating	(261) + (262) + (263) + (264) =		717.72 (265)
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	= 38.93 (267)
Electricity for lighting	(232) x	0.519	= 124.76 (268)

TER WorkSheet: New dwelling design stage

Total CO2, kg/year

sum of (265)...(271) =

881.41

(272)

TER =

16.92

(273)

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 109 - Be Lean			
Address :	AC 109, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	77.6 (1a)	x (2a)	= 201.76 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	77.6 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	201.76 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					x 10 = 0 (7a)
Number of passive vents					x 10 = 0 (7b)
Number of flueless gas fires					x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 0 ÷ (5) = 0
(8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] =

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) =

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] =

Infiltration rate incorporating shelter factor (21) = (18) x (20) =

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

DER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.11	0.11	0.1	0.09	0.09	0.08	0.08	0.08	0.08	0.09	0.1	0.1
------	------	-----	------	------	------	------	------	------	------	-----	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.21	0.21	0.22
---------	------	------	------	------	------	-----	-----	-----	------	------	------

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.2	0.21	0.21	0.22
--------	------	------	------	------	------	-----	-----	-----	-----	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m²)	Openings m²	Net Area A ,m²	U-value W/m²K	A X U (W/K)	k-value kJ/m²·K	A X k kJ/K
Windows Type 1			2.24	x1/[1/(1.4)+ 0.04] =	2.97		(27)
Windows Type 2			4.1	x1/[1/(1.4)+ 0.04] =	5.44		(27)
Windows Type 3			6.18	x1/[1/(1.4)+ 0.04] =	8.19		(27)
Windows Type 4			1.71	x1/[1/(1.4)+ 0.04] =	2.27		(27)
Windows Type 5			1.71	x1/[1/(1.4)+ 0.04] =	2.27		(27)
Walls	46.59	15.94	30.65	x 0.12 =	3.68		(29)
Total area of elements, m²			46.59				(31)
Party wall			44.62	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 24.81 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 6.9 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 31.71 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	15.04	14.9	14.76	14.05	13.91	13.2	13.2	13.06	13.48	13.91	14.19	14.47

(38)

Heat transfer coefficient, W/K (39)m = (37) + (38)m

(39)m=	46.75	46.61	46.47	45.76	45.62	44.91	44.91	44.77	45.19	45.62	45.9	46.18
Average = Sum(39) _{1...12} /12=	45.72 (39)											

DER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	0.6	0.6	0.6	0.59	0.59	0.58	0.58	0.58	0.58	0.59	0.59	0.6			
													Average = Sum(40) _{1...12} /12=	0.59	(40)

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
(41)m=	31	28	31	30	31	30	31	31	30	31	30	31		(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

2.42

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd,\text{average} = (25 \times N) + 36$

91.57

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	100.73	97.07	93.41	89.74	86.08	82.42	82.42	86.08	89.74	93.41	97.07	100.73			
													Total = Sum(44) _{1...12} =	1098.89	(44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	149.38	130.65	134.82	117.54	112.78	97.32	90.18	103.49	104.72	122.04	133.22	144.67			
													Total = Sum(45) _{1...12} =	1440.81	(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	22.41	19.6	20.22	17.63	16.92	14.6	13.53	15.52	15.71	18.31	19.98	21.7			
													0		(46)

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0

(48)

Temperature factor from Table 2b

0

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

110

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0.02

(51)

If community heating see section 4.3

Volume factor from Table 2a

1.03

(52)

Temperature factor from Table 2b

0.6

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

1.03

(54)

Enter (50) or (54) in (55)

1.03

(55)

Water storage loss calculated for each month

((56)m = (55) x (41)m)

(56)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01		
														(56)

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01		
														(57)

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26		
														(59)

DER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	204.66	180.58	190.1	171.03	168.06	150.82	145.46	158.76	158.22	177.32	186.71	199.94	(62)
--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	204.66	180.58	190.1	171.03	168.06	150.82	145.46	158.76	158.22	177.32	186.71	199.94	
Output from water heater (annual) 1...12												2091.65	(64)

Heat gains from water heating, kWh/month 0.25 [$0.85 \times (45)m + (61)m$] + $0.8 \times [(46)m + (57)m + (59)m]$]

(65)m=	93.89	83.38	89.05	81.88	81.72	75.15	74.21	78.63	77.62	84.8	87.09	92.32	(65)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m=	120.79	120.79	120.79	120.79	120.79	120.79	120.79	120.79	120.79	120.79	120.79	120.79	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	19.11	16.97	13.8	10.45	7.81	6.59	7.13	9.26	12.43	15.79	18.42	19.64	(67)
--------	-------	-------	------	-------	------	------	------	------	-------	-------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	214.35	216.58	210.97	199.04	183.98	169.82	160.36	158.14	163.74	175.67	190.74	204.89	(68)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	35.08	35.08	35.08	35.08	35.08	35.08	35.08	35.08	35.08	35.08	35.08	35.08	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	0	0	0	0	0	0	0	0	0	0	0	0	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-96.63	-96.63	-96.63	-96.63	-96.63	-96.63	-96.63	-96.63	-96.63	-96.63	-96.63	-96.63	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	126.2	124.08	119.69	113.72	109.84	104.38	99.74	105.69	107.8	113.98	120.96	124.09	(72)
--------	-------	--------	--------	--------	--------	--------	-------	--------	-------	--------	--------	--------	------

Total internal gains = $(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$

(73)m=	418.89	416.87	403.7	382.44	360.86	340.03	326.46	332.32	343.21	364.68	389.36	407.86	(73)
--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_ Table 6b	FF Table 6c	Gains (W)
North	0.9x	0.77	x 2.24	x 10.63	x 0.4	x 0.8 = 5.28 (74)
North	0.9x	0.77	x 6.18	x 10.63	x 0.4	x 0.8 = 14.57 (74)
North	0.9x	0.77	x 1.71	x 10.63	x 0.4	x 0.8 = 4.03 (74)
North	0.9x	0.77	x 2.24	x 20.32	x 0.4	x 0.8 = 10.09 (74)
North	0.9x	0.77	x 6.18	x 20.32	x 0.4	x 0.8 = 27.85 (74)

DER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	1.71	x	20.32	x	0.4	x	0.8	=	7.71	(74)
North	0.9x	0.77	x	2.24	x	34.53	x	0.4	x	0.8	=	17.15	(74)
North	0.9x	0.77	x	6.18	x	34.53	x	0.4	x	0.8	=	47.32	(74)
North	0.9x	0.77	x	1.71	x	34.53	x	0.4	x	0.8	=	13.09	(74)
North	0.9x	0.77	x	2.24	x	55.46	x	0.4	x	0.8	=	27.55	(74)
North	0.9x	0.77	x	6.18	x	55.46	x	0.4	x	0.8	=	76.01	(74)
North	0.9x	0.77	x	1.71	x	55.46	x	0.4	x	0.8	=	21.03	(74)
North	0.9x	0.77	x	2.24	x	74.72	x	0.4	x	0.8	=	37.11	(74)
North	0.9x	0.77	x	6.18	x	74.72	x	0.4	x	0.8	=	102.4	(74)
North	0.9x	0.77	x	1.71	x	74.72	x	0.4	x	0.8	=	28.33	(74)
North	0.9x	0.77	x	2.24	x	79.99	x	0.4	x	0.8	=	39.73	(74)
North	0.9x	0.77	x	6.18	x	79.99	x	0.4	x	0.8	=	109.62	(74)
North	0.9x	0.77	x	1.71	x	79.99	x	0.4	x	0.8	=	30.33	(74)
North	0.9x	0.77	x	2.24	x	74.68	x	0.4	x	0.8	=	37.1	(74)
North	0.9x	0.77	x	6.18	x	74.68	x	0.4	x	0.8	=	102.34	(74)
North	0.9x	0.77	x	1.71	x	74.68	x	0.4	x	0.8	=	28.32	(74)
North	0.9x	0.77	x	2.24	x	59.25	x	0.4	x	0.8	=	29.43	(74)
North	0.9x	0.77	x	6.18	x	59.25	x	0.4	x	0.8	=	81.2	(74)
North	0.9x	0.77	x	1.71	x	59.25	x	0.4	x	0.8	=	22.47	(74)
North	0.9x	0.77	x	2.24	x	41.52	x	0.4	x	0.8	=	20.62	(74)
North	0.9x	0.77	x	6.18	x	41.52	x	0.4	x	0.8	=	56.9	(74)
North	0.9x	0.77	x	1.71	x	41.52	x	0.4	x	0.8	=	15.74	(74)
North	0.9x	0.77	x	2.24	x	24.19	x	0.4	x	0.8	=	12.02	(74)
North	0.9x	0.77	x	6.18	x	24.19	x	0.4	x	0.8	=	33.15	(74)
North	0.9x	0.77	x	1.71	x	24.19	x	0.4	x	0.8	=	9.17	(74)
North	0.9x	0.77	x	2.24	x	13.12	x	0.4	x	0.8	=	6.52	(74)
North	0.9x	0.77	x	6.18	x	13.12	x	0.4	x	0.8	=	17.98	(74)
North	0.9x	0.77	x	1.71	x	13.12	x	0.4	x	0.8	=	4.97	(74)
North	0.9x	0.77	x	2.24	x	8.86	x	0.4	x	0.8	=	4.4	(74)
North	0.9x	0.77	x	6.18	x	8.86	x	0.4	x	0.8	=	12.15	(74)
North	0.9x	0.77	x	1.71	x	8.86	x	0.4	x	0.8	=	3.36	(74)
South	0.9x	0.77	x	4.1	x	46.75	x	0.4	x	0.8	=	42.51	(78)
South	0.9x	0.77	x	1.71	x	46.75	x	0.4	x	0.8	=	17.73	(78)
South	0.9x	0.77	x	4.1	x	76.57	x	0.4	x	0.8	=	69.62	(78)
South	0.9x	0.77	x	1.71	x	76.57	x	0.4	x	0.8	=	29.04	(78)
South	0.9x	0.77	x	4.1	x	97.53	x	0.4	x	0.8	=	88.68	(78)
South	0.9x	0.77	x	1.71	x	97.53	x	0.4	x	0.8	=	36.99	(78)
South	0.9x	0.77	x	4.1	x	110.23	x	0.4	x	0.8	=	100.23	(78)
South	0.9x	0.77	x	1.71	x	110.23	x	0.4	x	0.8	=	41.8	(78)
South	0.9x	0.77	x	4.1	x	114.87	x	0.4	x	0.8	=	104.44	(78)
South	0.9x	0.77	x	1.71	x	114.87	x	0.4	x	0.8	=	43.56	(78)

DER WorkSheet: New dwelling design stage

South	0.9x	0.77	x	4.1	x	110.55	x	0.4	x	0.8	=	100.51	(78)
South	0.9x	0.77	x	1.71	x	110.55	x	0.4	x	0.8	=	41.92	(78)
South	0.9x	0.77	x	4.1	x	108.01	x	0.4	x	0.8	=	98.21	(78)
South	0.9x	0.77	x	1.71	x	108.01	x	0.4	x	0.8	=	40.96	(78)
South	0.9x	0.77	x	4.1	x	104.89	x	0.4	x	0.8	=	95.37	(78)
South	0.9x	0.77	x	1.71	x	104.89	x	0.4	x	0.8	=	39.78	(78)
South	0.9x	0.77	x	4.1	x	101.89	x	0.4	x	0.8	=	92.64	(78)
South	0.9x	0.77	x	1.71	x	101.89	x	0.4	x	0.8	=	38.64	(78)
South	0.9x	0.77	x	4.1	x	82.59	x	0.4	x	0.8	=	75.09	(78)
South	0.9x	0.77	x	1.71	x	82.59	x	0.4	x	0.8	=	31.32	(78)
South	0.9x	0.77	x	4.1	x	55.42	x	0.4	x	0.8	=	50.39	(78)
South	0.9x	0.77	x	1.71	x	55.42	x	0.4	x	0.8	=	21.01	(78)
South	0.9x	0.77	x	4.1	x	40.4	x	0.4	x	0.8	=	36.73	(78)
South	0.9x	0.77	x	1.71	x	40.4	x	0.4	x	0.8	=	15.32	(78)

Solar gains in watts, calculated for each month

(83)m = Sum(74)m ... (82)m

(83)m=	84.12	144.3	203.23	266.63	315.85	322.11	306.92	268.24	224.54	160.75	100.87	71.96	(83)
--------	-------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	------

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=	503.02	561.17	606.93	649.07	676.71	662.14	633.38	600.56	567.74	525.42	490.22	479.82	(84)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m=	0.99	0.98	0.94	0.81	0.62	0.43	0.31	0.34	0.55	0.85	0.98	0.99	(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	20.62	20.73	20.86	20.97	21	21	21	21	21	20.96	20.78	20.6	(87)
--------	-------	-------	-------	-------	----	----	----	----	----	-------	-------	------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	20.43	20.43	20.43	20.44	20.44	20.45	20.45	20.45	20.45	20.44	20.44	20.43	(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.99	0.97	0.92	0.79	0.59	0.4	0.27	0.3	0.5	0.82	0.97	0.99	(89)
--------	------	------	------	------	------	-----	------	-----	-----	------	------	------	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	19.92	20.08	20.26	20.4	20.44	20.45	20.45	20.45	20.45	20.4	20.17	19.9	(90)
--------	-------	-------	-------	------	-------	-------	-------	-------	-------	------	-------	------	------

fLA = Living area ÷ (4) =

0.42

(91)

Mean internal temperature (for the whole dwelling) = fLA × T1 + (1 – fLA) × T2

(92)m=	20.22	20.35	20.51	20.64	20.67	20.68	20.68	20.68	20.68	20.64	20.43	20.19	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	20.22	20.35	20.51	20.64	20.67	20.68	20.68	20.68	20.68	20.64	20.43	20.19	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that $Ti,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	0.99	0.97	0.93	0.8	0.6	0.41	0.29	0.32	0.52	0.83	0.97	0.99	(94)
--------	------	------	------	-----	-----	------	------	------	------	------	------	------	------

DER WorkSheet: New dwelling design stage

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	497.45	545.68	561.89	516.63	407.4	272.99	183.22	191.64	296.81	434.45	474.65	475.95	(95)
--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W = [(39)m x [(93)m – (96)m]

(97)m=	744.05	720.17	651.04	537.16	409.27	273.04	183.23	191.65	297.24	457.77	611.64	738.44	(97)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m – (95)m] x (41)m

(98)m=	183.47	117.26	66.33	14.78	1.4	0	0	0	0	17.35	98.63	195.29	
--------	--------	--------	-------	-------	-----	---	---	---	---	-------	-------	--------	--

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1..5,9..12} = 694.5 \quad (98)$$

Space heating requirement in kWh/m²/year

$$8.95 \quad (99)$$

9b. Energy requirements – Community heating scheme

This part is used for space heating, space cooling or water heating provided by a community scheme.

Fraction of space heat from secondary/supplementary heating (Table 11) '0' if none

$$0 \quad (301)$$

Fraction of space heat from community system 1 – (301) =

$$1 \quad (302)$$

The community scheme may obtain heat from several sources. The procedure allows for CHP and up to four other heat sources; the latter includes boilers, heat pumps, geothermal and waste heat from power stations. See Appendix C.

Fraction of heat from Community boilers

$$1 \quad (303a)$$

Fraction of total space heat from Community boilers

$$(302) \times (303a) =$$

$$1 \quad (304a)$$

Factor for control and charging method (Table 4c(3)) for community heating system

$$1 \quad (305)$$

Distribution loss factor (Table 12c) for community heating system

$$1.1 \quad (306)$$

Space heating

Annual space heating requirement

$$\text{kWh/year}$$

$$694.5$$

Space heat from Community boilers

$$(98) \times (304a) \times (305) \times (306) =$$

$$763.95$$

Efficiency of secondary/supplementary heating system in % (from Table 4a or Appendix E)

$$(307a) \quad (308)$$

Space heating requirement from secondary/supplementary system

$$(98) \times (301) \times 100 \div (308) =$$

$$0 \quad (309)$$

Water heating

Annual water heating requirement

$$2091.65$$

If DHW from community scheme:

Water heat from Community boilers

$$(64) \times (303a) \times (305) \times (306) =$$

$$2300.82$$

Electricity used for heat distribution

$$0.01 \times [(307a) \dots (307e) + (310a) \dots (310e)] =$$

$$30.65$$

Cooling System Energy Efficiency Ratio

$$(313)$$

Space cooling (if there is a fixed cooling system, if not enter 0)

$$= (107) \div (314) =$$

$$0 \quad (315)$$

Electricity for pumps and fans within dwelling (Table 4f):

mechanical ventilation - balanced, extract or positive input from outside

$$163.07$$

$$(330a)$$

warm air heating system fans

$$0$$

$$(330b)$$

pump for solar water heating

$$0$$

$$(330g)$$

Total electricity for the above, kWh/year

$$=(330a) + (330b) + (330g) =$$

$$163.07$$

$$(331)$$

Energy for lighting (calculated in Appendix L)

$$337.48$$

$$(332)$$

12b. CO2 Emissions – Community heating scheme

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
--	--------------------	-------------------------------	--------------------------

DER WorkSheet: New dwelling design stage

CO2 from other sources of space and water heating (not CHP)

Efficiency of heat source 1 (%)

If there is CHP using two fuels repeat (363) to (366) for the second fuel

95

(367a)

CO2 associated with heat source 1

$[(307b)+(310b)] \times 100 \div (367b) \times$

0.22

=

696.83

(367)

Electrical energy for heat distribution

$[(313) \times$

0.52

=

15.91

(372)

Total CO2 associated with community systems

(363)...(366) + (368)...(372)

=

712.74

(373)

CO2 associated with space heating (secondary)

$(309) \times$

0

=

0

(374)

CO2 associated with water from immersion heater or instantaneous heater

$(312) \times$

0.22

=

0

(375)

Total CO2 associated with space and water heating

$(373) + (374) + (375) =$

=

712.74

(376)

CO2 associated with electricity for pumps and fans within dwelling

$(331)) \times$

0.52

=

84.63

(378)

CO2 associated with electricity for lighting

$(332))) \times$

0.52

=

175.15

(379)

Total CO2, kg/year sum of (376)...(382) =

972.53

(383)

Dwelling CO2 Emission Rate $(383) \div (4) =$

12.53

(384)

EI rating (section 14)

89.37

(385)

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 109 - Be Lean			
Address :	AC 109, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	77.6 (1a)	x (2a)	= 201.76 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	77.6 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	201.76 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					3 x 10 = 30 (7a)
Number of passive vents					0 x 10 = 0 (7b)
Number of flueless gas fires					0 x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =	30	÷ (5) = 0.15 (8)
---	----	---------------------

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)	0 (9)
Additional infiltration	[(9)-1]x0.1 = 0 (10)
Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction	0 (11)

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0	0 (12)
If no draught lobby, enter 0.05, else enter 0	0 (13)
Percentage of windows and doors draught stripped	0 (14)
Window infiltration	0.25 - [0.2 x (14) ÷ 100] = 0 (15)
Infiltration rate	(8) + (10) + (11) + (12) + (13) + (15) = 0 (16)
Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area	5 (17)
If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)	0.4 (18)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered	2 (19)
Shelter factor	(20) = 1 - [0.075 x (19)] = 0.85 (20)
Infiltration rate incorporating shelter factor	(21) = (18) x (20) = 0.34 (21)

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

TER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.43	0.42	0.42	0.37	0.36	0.32	0.32	0.31	0.34	0.36	0.38	0.4
------	------	------	------	------	------	------	------	------	------	------	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0.59	0.59	0.59	0.57	0.57	0.55	0.55	0.55	0.56	0.57	0.57	0.58
---------	------	------	------	------	------	------	------	------	------	------	------	------

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.59	0.59	0.59	0.57	0.57	0.55	0.55	0.55	0.56	0.57	0.57	0.58
--------	------	------	------	------	------	------	------	------	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Windows Type 1			2.24	x1/[1/(1.4)+ 0.04] =	2.97		(27)
Windows Type 2			4.1	x1/[1/(1.4)+ 0.04] =	5.44		(27)
Windows Type 3			6.18	x1/[1/(1.4)+ 0.04] =	8.19		(27)
Windows Type 4			1.71	x1/[1/(1.4)+ 0.04] =	2.27		(27)
Windows Type 5			1.71	x1/[1/(1.4)+ 0.04] =	2.27		(27)
Walls	46.59	15.94	30.65	x 0.18 =	5.52		(29)
Total area of elements, m ²			46.59				(31)
Party wall			44.62	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 26.65 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 4.88 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 31.53 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	39.51	39.26	39.03	37.92	37.71	36.74	36.74	36.56	37.11	37.71	38.13	38.57

(38)

Heat transfer coefficient, W/K (39)m = (37) + (38)m

(39)m=	71.04	70.8	70.56	69.45	69.24	68.27	68.27	68.09	68.65	69.24	69.66	70.1
Average = Sum(39) _{1...12} /12=												69.45 (39)

TER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	0.92	0.91	0.91	0.89	0.89	0.88	0.88	0.88	0.88	0.89	0.9	0.9	(40)m = (39)m ÷ (4)
													Average = Sum(40) _{1...12} /12=

0.89

(40)

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(41)m=	31	28	31	30	31	30	31	31	30	31	30	31

(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

2.42

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

91.57

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	100.73	97.07	93.41	89.74	86.08	82.42	82.42	86.08	89.74	93.41	97.07	100.73	
	Total = Sum(44) _{1...12} =												1098.89

(44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	149.38	130.65	134.82	117.54	112.78	97.32	90.18	103.49	104.72	122.04	133.22	144.67	
	Total = Sum(45) _{1...12} =												1440.81

(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	22.41	19.6	20.22	17.63	16.92	14.6	13.53	15.52	15.71	18.31	19.98	21.7
--------	-------	------	-------	-------	-------	------	-------	-------	-------	-------	-------	------

(46)

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

150

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

1.39

(48)

Temperature factor from Table 2b

0.54

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

0.75

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0

(51)

If community heating see section 4.3

Volume factor from Table 2a

0

(52)

Temperature factor from Table 2b

0

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

0

(54)

Enter (50) or (54) in (55)

0.75

(55)

Water storage loss calculated for each month

((56)m = (55) x (41)m)

(56)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(56)

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(57)

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(59)

TER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	195.98	172.74	181.41	162.63	159.38	142.41	136.78	150.08	149.81	168.64	178.31	191.26	(62)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	195.98	172.74	181.41	162.63	159.38	142.41	136.78	150.08	149.81	168.64	178.31	191.26	
Output from water heater (annual) 1...12												1989.43	(64)

Heat gains from water heating, kWh/month 0.25 $[0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	86.95	77.11	82.1	75.16	74.78	68.43	67.26	71.69	70.89	77.86	80.37	85.38	(65)
--------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m=	120.79	120.79	120.79	120.79	120.79	120.79	120.79	120.79	120.79	120.79	120.79	120.79	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	19.2	17.05	13.87	10.5	7.85	6.62	7.16	9.3	12.49	15.86	18.51	19.73	(67)
--------	------	-------	-------	------	------	------	------	-----	-------	-------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	214.35	216.58	210.97	199.04	183.98	169.82	160.36	158.14	163.74	175.67	190.74	204.89	(68)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	35.08	35.08	35.08	35.08	35.08	35.08	35.08	35.08	35.08	35.08	35.08	35.08	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	3	3	3	3	3	3	3	3	3	3	3	3	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-96.63	-96.63	-96.63	-96.63	-96.63	-96.63	-96.63	-96.63	-96.63	-96.63	-96.63	-96.63	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	116.86	114.75	110.35	104.38	100.5	95.05	90.41	96.35	98.46	104.64	111.62	114.76	(72)
--------	--------	--------	--------	--------	-------	-------	-------	-------	-------	--------	--------	--------	------

Total internal gains = $(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$

(73)m=	412.64	410.61	397.43	376.15	354.56	333.72	320.16	326.03	336.93	358.41	383.1	401.61	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_ Table 6b	FF Table 6c	Gains (W)		
North	0.9x	0.77	x 2.24	x 10.63	x 0.63	= 0.7	7.28	(74)
North	0.9x	0.77	x 6.18	x 10.63	x 0.63	= 0.7	20.08	(74)
North	0.9x	0.77	x 1.71	x 10.63	x 0.63	= 0.7	5.56	(74)
North	0.9x	0.77	x 2.24	x 20.32	x 0.63	= 0.7	13.91	(74)
North	0.9x	0.77	x 6.18	x 20.32	x 0.63	= 0.7	38.38	(74)

TER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	1.71	x	20.32	x	0.63	x	0.7	=	10.62	(74)
North	0.9x	0.77	x	2.24	x	34.53	x	0.63	x	0.7	=	23.64	(74)
North	0.9x	0.77	x	6.18	x	34.53	x	0.63	x	0.7	=	65.22	(74)
North	0.9x	0.77	x	1.71	x	34.53	x	0.63	x	0.7	=	18.05	(74)
North	0.9x	0.77	x	2.24	x	55.46	x	0.63	x	0.7	=	37.97	(74)
North	0.9x	0.77	x	6.18	x	55.46	x	0.63	x	0.7	=	104.76	(74)
North	0.9x	0.77	x	1.71	x	55.46	x	0.63	x	0.7	=	28.99	(74)
North	0.9x	0.77	x	2.24	x	74.72	x	0.63	x	0.7	=	51.15	(74)
North	0.9x	0.77	x	6.18	x	74.72	x	0.63	x	0.7	=	141.11	(74)
North	0.9x	0.77	x	1.71	x	74.72	x	0.63	x	0.7	=	39.05	(74)
North	0.9x	0.77	x	2.24	x	79.99	x	0.63	x	0.7	=	54.76	(74)
North	0.9x	0.77	x	6.18	x	79.99	x	0.63	x	0.7	=	151.07	(74)
North	0.9x	0.77	x	1.71	x	79.99	x	0.63	x	0.7	=	41.8	(74)
North	0.9x	0.77	x	2.24	x	74.68	x	0.63	x	0.7	=	51.12	(74)
North	0.9x	0.77	x	6.18	x	74.68	x	0.63	x	0.7	=	141.04	(74)
North	0.9x	0.77	x	1.71	x	74.68	x	0.63	x	0.7	=	39.03	(74)
North	0.9x	0.77	x	2.24	x	59.25	x	0.63	x	0.7	=	40.56	(74)
North	0.9x	0.77	x	6.18	x	59.25	x	0.63	x	0.7	=	111.9	(74)
North	0.9x	0.77	x	1.71	x	59.25	x	0.63	x	0.7	=	30.96	(74)
North	0.9x	0.77	x	2.24	x	41.52	x	0.63	x	0.7	=	28.42	(74)
North	0.9x	0.77	x	6.18	x	41.52	x	0.63	x	0.7	=	78.41	(74)
North	0.9x	0.77	x	1.71	x	41.52	x	0.63	x	0.7	=	21.7	(74)
North	0.9x	0.77	x	2.24	x	24.19	x	0.63	x	0.7	=	16.56	(74)
North	0.9x	0.77	x	6.18	x	24.19	x	0.63	x	0.7	=	45.69	(74)
North	0.9x	0.77	x	1.71	x	24.19	x	0.63	x	0.7	=	12.64	(74)
North	0.9x	0.77	x	2.24	x	13.12	x	0.63	x	0.7	=	8.98	(74)
North	0.9x	0.77	x	6.18	x	13.12	x	0.63	x	0.7	=	24.78	(74)
North	0.9x	0.77	x	1.71	x	13.12	x	0.63	x	0.7	=	6.86	(74)
North	0.9x	0.77	x	2.24	x	8.86	x	0.63	x	0.7	=	6.07	(74)
North	0.9x	0.77	x	6.18	x	8.86	x	0.63	x	0.7	=	16.74	(74)
North	0.9x	0.77	x	1.71	x	8.86	x	0.63	x	0.7	=	4.63	(74)
South	0.9x	0.77	x	4.1	x	46.75	x	0.63	x	0.7	=	58.58	(78)
South	0.9x	0.77	x	1.71	x	46.75	x	0.63	x	0.7	=	24.43	(78)
South	0.9x	0.77	x	4.1	x	76.57	x	0.63	x	0.7	=	95.94	(78)
South	0.9x	0.77	x	1.71	x	76.57	x	0.63	x	0.7	=	40.01	(78)
South	0.9x	0.77	x	4.1	x	97.53	x	0.63	x	0.7	=	122.21	(78)
South	0.9x	0.77	x	1.71	x	97.53	x	0.63	x	0.7	=	50.97	(78)
South	0.9x	0.77	x	4.1	x	110.23	x	0.63	x	0.7	=	138.13	(78)
South	0.9x	0.77	x	1.71	x	110.23	x	0.63	x	0.7	=	57.61	(78)
South	0.9x	0.77	x	4.1	x	114.87	x	0.63	x	0.7	=	143.94	(78)
South	0.9x	0.77	x	1.71	x	114.87	x	0.63	x	0.7	=	60.03	(78)

TER WorkSheet: New dwelling design stage

South	0.9x	0.77	x	4.1	x	110.55	x	0.63	x	0.7	=	138.52	(78)
South	0.9x	0.77	x	1.71	x	110.55	x	0.63	x	0.7	=	57.77	(78)
South	0.9x	0.77	x	4.1	x	108.01	x	0.63	x	0.7	=	135.34	(78)
South	0.9x	0.77	x	1.71	x	108.01	x	0.63	x	0.7	=	56.45	(78)
South	0.9x	0.77	x	4.1	x	104.89	x	0.63	x	0.7	=	131.43	(78)
South	0.9x	0.77	x	1.71	x	104.89	x	0.63	x	0.7	=	54.82	(78)
South	0.9x	0.77	x	4.1	x	101.89	x	0.63	x	0.7	=	127.66	(78)
South	0.9x	0.77	x	1.71	x	101.89	x	0.63	x	0.7	=	53.25	(78)
South	0.9x	0.77	x	4.1	x	82.59	x	0.63	x	0.7	=	103.48	(78)
South	0.9x	0.77	x	1.71	x	82.59	x	0.63	x	0.7	=	43.16	(78)
South	0.9x	0.77	x	4.1	x	55.42	x	0.63	x	0.7	=	69.44	(78)
South	0.9x	0.77	x	1.71	x	55.42	x	0.63	x	0.7	=	28.96	(78)
South	0.9x	0.77	x	4.1	x	40.4	x	0.63	x	0.7	=	50.62	(78)
South	0.9x	0.77	x	1.71	x	40.4	x	0.63	x	0.7	=	21.11	(78)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m=	115.93	198.87	280.08	367.44	435.28	443.91	422.98	369.67	309.44	221.53	139.01	99.17	(83)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	------

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=	528.58	609.47	677.51	743.6	789.84	777.64	743.14	695.7	646.37	579.94	522.11	500.79	(84)
--------	--------	--------	--------	-------	--------	--------	--------	-------	--------	--------	--------	--------	------

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m=	1	0.99	0.97	0.91	0.76	0.56	0.4	0.45	0.7	0.94	0.99	1	(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	20.17	20.32	20.54	20.79	20.94	20.99	21	21	20.97	20.77	20.43	20.14	(87)
--------	-------	-------	-------	-------	-------	-------	----	----	-------	-------	-------	-------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	20.15	20.16	20.16	20.17	20.17	20.18	20.18	20.19	20.18	20.17	20.17	20.16	(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.99	0.99	0.96	0.88	0.71	0.49	0.33	0.37	0.63	0.91	0.99	1	(89)
--------	------	------	------	------	------	------	------	------	------	------	------	---	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	19.04	19.27	19.58	19.94	20.12	20.18	20.18	20.19	20.16	19.92	19.43	19.01	(90)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

$$fLA = \text{Living area} \div 4 =$$

0.42

(91)

Mean internal temperature (for the whole dwelling) = fLA × T1 + (1 – fLA) × T2

(92)m=	19.51	19.71	19.98	20.29	20.47	20.52	20.53	20.53	20.5	20.28	19.85	19.49	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.51	19.71	19.98	20.29	20.47	20.52	20.53	20.53	20.5	20.28	19.85	19.49	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that $Ti,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	0.99	0.98	0.96	0.89	0.73	0.52	0.36	0.4	0.66	0.91	0.98	0.99	(94)
--------	------	------	------	------	------	------	------	-----	------	------	------	------	------

TER WorkSheet: New dwelling design stage

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	525.01	599.81	650.4	658.7	574.61	400.98	267.73	280.41	425.94	530.6	513.76	498.25		(95)
--------	--------	--------	-------	-------	--------	--------	--------	--------	--------	-------	--------	--------	--	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2		(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	--	------

Heat loss rate for mean internal temperature, Lm , W = [(39)m x [(93)m – (96)m]

(97)m=	1080.68	1048.48	951.27	791.24	607.06	404.24	268.02	280.98	439.47	670.27	888.18	1071.51		(97)
--------	---------	---------	--------	--------	--------	--------	--------	--------	--------	--------	--------	---------	--	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m – (95)m] x (41)m

(98)m=	413.42	301.51	223.85	95.43	24.14	0	0	0	0	103.91	269.59	426.51		
--------	--------	--------	--------	-------	-------	---	---	---	---	--------	--------	--------	--	--

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1,5,9...12} = 1858.35 \quad (98)$$

Space heating requirement in kWh/m²/year

$$23.95 \quad (99)$$

9a. Energy requirements – Individual heating systems including micro-CHP

Space heating:

Fraction of space heat from secondary/supplementary system

$$0 \quad (201)$$

Fraction of space heat from main system(s)

$$(202) = 1 - (201) = 1 \quad (202)$$

Fraction of total heating from main system 1

$$(204) = (202) \times [1 - (203)] = 1 \quad (204)$$

Efficiency of main space heating system 1

$$93.5 \quad (206)$$

Efficiency of secondary/supplementary heating system, %

$$0 \quad (208)$$

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	--	----------

Space heating requirement (calculated above)

413.42	301.51	223.85	95.43	24.14	0	0	0	0	103.91	269.59	426.51	
--------	--------	--------	-------	-------	---	---	---	---	--------	--------	--------	--

$$(211)m = \{[(98)m \times (204)]\} \times 100 \div (206) \quad (211)$$

442.16	322.47	239.41	102.06	25.82	0	0	0	0	111.14	288.33	456.16	
--------	--------	--------	--------	-------	---	---	---	---	--------	--------	--------	--

$$\text{Total (kWh/year)} = \text{Sum}(211)_{1,5,10...12} = 1987.54 \quad (211)$$

Space heating fuel (secondary), kWh/month

$$= \{[(98)m \times (201)]\} \times 100 \div (208)$$

(215)m=	0	0	0	0	0	0	0	0	0	0	0	0	
---------	---	---	---	---	---	---	---	---	---	---	---	---	--

$$\text{Total (kWh/year)} = \text{Sum}(215)_{1,5,10...12} = 0 \quad (215)$$

Water heating

Output from water heater (calculated above)

195.98	172.74	181.41	162.63	159.38	142.41	136.78	150.08	149.81	168.64	178.31	191.26	
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--

$$79.8 \quad (216)$$

Efficiency of water heater

(217)m=	86.76	86.29	85.38	83.45	81.06	79.8	79.8	79.8	83.57	85.91	86.89	
---------	-------	-------	-------	-------	-------	------	------	------	-------	-------	-------	--

$$217 \quad (217)$$

Fuel for water heating, kWh/month

$$(219)m = (64)m \times 100 \div (217)m$$

(219)m=	225.89	200.19	212.49	194.89	196.61	178.46	171.4	188.07	187.74	201.8	207.55	220.11	
---------	--------	--------	--------	--------	--------	--------	-------	--------	--------	-------	--------	--------	--

$$\text{Total} = \text{Sum}(219a)_{1,...12} = 2385.2 \quad (219)$$

Annual totals

Space heating fuel used, main system 1

$$\text{kWh/year}$$

$$1987.54$$

	1987.54
--	---------

Water heating fuel used

$$2385.2$$

	2385.2
--	--------

Electricity for pumps, fans and electric keep-hot

central heating pump:

$$30 \quad (230c)$$

TER WorkSheet: New dwelling design stage

boiler with a fan-assisted flue	45	(230e)
Total electricity for the above, kWh/year	sum of (230a)...(230g) =	75 (231)
Electricity for lighting	338.99 (232)	

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating (main system 1)	(211) x	0.216	= 429.31 (261)
Space heating (secondary)	(215) x	0.519	= 0 (263)
Water heating	(219) x	0.216	= 515.2 (264)
Space and water heating	(261) + (262) + (263) + (264) =		944.51 (265)
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	= 38.93 (267)
Electricity for lighting	(232) x	0.519	= 175.94 (268)
Total CO2, kg/year		sum of (265)...(271) =	1159.37 (272)

TER = 14.94 (273)

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 208 - Be Lean			
Address :	AC 208, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	52.1 (1a)	x (2a)	2.6 = 135.46 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	52.1 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	135.46 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour	
Number of chimneys	0	+	0	+	0	x 40 = 0 (6a)
Number of open flues	0	+	0	+	0	x 20 = 0 (6b)
Number of intermittent fans						x 10 = 0 (7a)
Number of passive vents						x 10 = 0 (7b)
Number of flueless gas fires						x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 0 ÷ (5) = 0 (8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] =

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) =

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] =

Infiltration rate incorporating shelter factor (21) = (18) x (20) =

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

DER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.11	0.11	0.1	0.09	0.09	0.08	0.08	0.08	0.08	0.09	0.1	0.1
------	------	-----	------	------	------	------	------	------	------	-----	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.21	0.21	0.22
---------	------	------	------	------	------	-----	-----	-----	------	------	------

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.2	0.21	0.21	0.22
--------	------	------	------	------	------	-----	-----	-----	-----	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Windows Type 1			6.18	x1/[1/(1.4)+ 0.04] =	8.19		(27)
Windows Type 2			1.66	x1/[1/(1.4)+ 0.04] =	2.2		(27)
Windows Type 3			4.1	x1/[1/(1.4)+ 0.04] =	5.44		(27)
Windows Type 4			1.64	x1/[1/(1.4)+ 0.04] =	2.17		(27)
Walls	31.1	13.58	17.52	x 0.12 =	2.1		(29)
Total area of elements, m ²			31.1				(31)
Party wall			44.62	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 20.11 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 5.41 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 25.52 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	10.1	10	9.91	9.43	9.34	8.86	8.86	8.77	9.05	9.34	9.53	9.72

(38)

Heat transfer coefficient, W/K (39)m = (37) + (38)m 34.92 (39)

(39)m=	35.61	35.52	35.42	34.95	34.85	34.38	34.38	34.28	34.57	34.85	35.04	35.23
Average = Sum(39) _{1...12} /12=												34.92 (39)

DER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	0.68	0.68	0.68	0.67	0.67	0.66	0.66	0.66	0.67	0.67	0.68		(40)
												Average = Sum(40) _{1...12} /12=	0.67

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(41)
31	28	31	30	31	30	31	31	30	31	30	31	

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

1.75

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)^2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

75.81

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	83.39	80.36	77.33	74.29	71.26	68.23	68.23	71.26	74.29	77.33	80.36	83.39	Total = Sum(44) _{1...12} =	909.73	(44)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------------------------------------	--------	------

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	123.67	108.16	111.61	97.31	93.37	80.57	74.66	85.67	86.7	101.03	110.29	119.77	Total = Sum(45) _{1...12} =	1192.79	(45)
--------	--------	--------	--------	-------	-------	-------	-------	-------	------	--------	--------	--------	-------------------------------------	---------	------

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	18.55	16.22	16.74	14.6	14.01	12.09	11.2	12.85	13	15.16	16.54	17.96		(46)
--------	-------	-------	-------	------	-------	-------	------	-------	----	-------	-------	-------	--	------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0

(48)

Temperature factor from Table 2b

0

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

110

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0.02

(51)

If community heating see section 4.3

Volume factor from Table 2a

1.03

(52)

Temperature factor from Table 2b

0.6

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

1.03

(54)

Enter (50) or (54) in (55)

1.03

(55)

Water storage loss calculated for each month

((56)m = (55) x (41)m)

(56)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01		(56)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--	------

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01		(57)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--	------

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26		(59)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--	------

DER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	178.94	158.09	166.89	150.8	148.64	134.06	129.94	140.95	140.19	156.31	163.78	175.04	(62)
--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	178.94	158.09	166.89	150.8	148.64	134.06	129.94	140.95	140.19	156.31	163.78	175.04	
Output from water heater (annual) 1...12												1843.63	(64)

Heat gains from water heating, kWh/month 0.25 $[0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	85.34	75.91	81.33	75.15	75.27	69.58	69.05	72.71	71.62	77.82	79.47	84.04	(65)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m=	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	13.61	12.09	9.83	7.44	5.56	4.7	5.08	6.6	8.86	11.24	13.12	13.99	(67)
--------	-------	-------	------	------	------	-----	------	-----	------	-------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	152.69	154.27	150.28	141.78	131.05	120.96	114.23	112.64	116.63	125.13	135.86	145.95	(68)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	0	0	0	0	0	0	0	0	0	0	0	0	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	114.71	112.95	109.32	104.37	101.16	96.64	92.8	97.72	99.47	104.59	110.37	112.96	(72)
--------	--------	--------	--------	--------	--------	-------	------	-------	-------	--------	--------	--------	------

Total internal gains =

$$(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$$

(73)m=	330.28	328.59	318.71	302.87	287.06	271.59	261.39	266.25	274.24	290.25	308.64	322.18	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)
North	0.9x	0.77	x 4.1	x 10.63	x 0.4	x 0.8 = 9.67 (74)
North	0.9x	0.77	x 1.64	x 10.63	x 0.4	x 0.8 = 3.87 (74)
North	0.9x	0.77	x 4.1	x 20.32	x 0.4	x 0.8 = 18.48 (74)
North	0.9x	0.77	x 1.64	x 20.32	x 0.4	x 0.8 = 7.39 (74)
North	0.9x	0.77	x 4.1	x 34.53	x 0.4	x 0.8 = 31.4 (74)

DER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	1.64	x	34.53	x	0.4	x	0.8	=	12.56	(74)
North	0.9x	0.77	x	4.1	x	55.46	x	0.4	x	0.8	=	50.43	(74)
North	0.9x	0.77	x	1.64	x	55.46	x	0.4	x	0.8	=	20.17	(74)
North	0.9x	0.77	x	4.1	x	74.72	x	0.4	x	0.8	=	67.93	(74)
North	0.9x	0.77	x	1.64	x	74.72	x	0.4	x	0.8	=	27.17	(74)
North	0.9x	0.77	x	4.1	x	79.99	x	0.4	x	0.8	=	72.72	(74)
North	0.9x	0.77	x	1.64	x	79.99	x	0.4	x	0.8	=	29.09	(74)
North	0.9x	0.77	x	4.1	x	74.68	x	0.4	x	0.8	=	67.9	(74)
North	0.9x	0.77	x	1.64	x	74.68	x	0.4	x	0.8	=	27.16	(74)
North	0.9x	0.77	x	4.1	x	59.25	x	0.4	x	0.8	=	53.87	(74)
North	0.9x	0.77	x	1.64	x	59.25	x	0.4	x	0.8	=	21.55	(74)
North	0.9x	0.77	x	4.1	x	41.52	x	0.4	x	0.8	=	37.75	(74)
North	0.9x	0.77	x	1.64	x	41.52	x	0.4	x	0.8	=	15.1	(74)
North	0.9x	0.77	x	4.1	x	24.19	x	0.4	x	0.8	=	21.99	(74)
North	0.9x	0.77	x	1.64	x	24.19	x	0.4	x	0.8	=	8.8	(74)
North	0.9x	0.77	x	4.1	x	13.12	x	0.4	x	0.8	=	11.93	(74)
North	0.9x	0.77	x	1.64	x	13.12	x	0.4	x	0.8	=	4.77	(74)
North	0.9x	0.77	x	4.1	x	8.86	x	0.4	x	0.8	=	8.06	(74)
North	0.9x	0.77	x	1.64	x	8.86	x	0.4	x	0.8	=	3.22	(74)
South	0.9x	0.77	x	6.18	x	46.75	x	0.4	x	0.8	=	64.07	(78)
South	0.9x	0.77	x	1.66	x	46.75	x	0.4	x	0.8	=	17.21	(78)
South	0.9x	0.77	x	6.18	x	76.57	x	0.4	x	0.8	=	104.93	(78)
South	0.9x	0.77	x	1.66	x	76.57	x	0.4	x	0.8	=	28.19	(78)
South	0.9x	0.77	x	6.18	x	97.53	x	0.4	x	0.8	=	133.67	(78)
South	0.9x	0.77	x	1.66	x	97.53	x	0.4	x	0.8	=	35.9	(78)
South	0.9x	0.77	x	6.18	x	110.23	x	0.4	x	0.8	=	151.07	(78)
South	0.9x	0.77	x	1.66	x	110.23	x	0.4	x	0.8	=	40.58	(78)
South	0.9x	0.77	x	6.18	x	114.87	x	0.4	x	0.8	=	157.43	(78)
South	0.9x	0.77	x	1.66	x	114.87	x	0.4	x	0.8	=	42.29	(78)
South	0.9x	0.77	x	6.18	x	110.55	x	0.4	x	0.8	=	151.5	(78)
South	0.9x	0.77	x	1.66	x	110.55	x	0.4	x	0.8	=	40.7	(78)
South	0.9x	0.77	x	6.18	x	108.01	x	0.4	x	0.8	=	148.03	(78)
South	0.9x	0.77	x	1.66	x	108.01	x	0.4	x	0.8	=	39.76	(78)
South	0.9x	0.77	x	6.18	x	104.89	x	0.4	x	0.8	=	143.76	(78)
South	0.9x	0.77	x	1.66	x	104.89	x	0.4	x	0.8	=	38.61	(78)
South	0.9x	0.77	x	6.18	x	101.89	x	0.4	x	0.8	=	139.63	(78)
South	0.9x	0.77	x	1.66	x	101.89	x	0.4	x	0.8	=	37.51	(78)
South	0.9x	0.77	x	6.18	x	82.59	x	0.4	x	0.8	=	113.18	(78)
South	0.9x	0.77	x	1.66	x	82.59	x	0.4	x	0.8	=	30.4	(78)
South	0.9x	0.77	x	6.18	x	55.42	x	0.4	x	0.8	=	75.95	(78)
South	0.9x	0.77	x	1.66	x	55.42	x	0.4	x	0.8	=	20.4	(78)

DER WorkSheet: New dwelling design stage

South	$0.9 \times$	0.77	\times	6.18	\times	40.4	\times	0.4	\times	0.8	=	55.36	(78)
South	$0.9 \times$	0.77	\times	1.66	\times	40.4	\times	0.4	\times	0.8	=	14.87	(78)

Solar gains in watts, calculated for each month $(83)m = \text{Sum}(74)m \dots (82)m$

(83)m=	94.82	158.99	213.53	262.25	294.82	294.01	282.85	257.78	229.98	174.37	113.05	81.52	(83)
--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	------

Total gains – internal and solar $(84)m = (73)m + (83)m$, watts

(84)m=	425.1	487.58	532.23	565.13	581.88	565.6	544.23	524.03	504.23	464.62	421.68	403.7	(84)
--------	-------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	-------	------

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 ($^{\circ}\text{C}$)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m=	0.98	0.94	0.87	0.73	0.55	0.39	0.28	0.3	0.47	0.75	0.94	0.98	(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	20.65	20.78	20.9	20.98	21	21	21	21	20.98	20.82	20.62		(87)
--------	-------	-------	------	-------	----	----	----	----	-------	-------	-------	--	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 ($^{\circ}\text{C}$)

(88)m=	20.36	20.36	20.36	20.37	20.37	20.38	20.38	20.38	20.37	20.37	20.37	20.36	(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.97	0.93	0.85	0.69	0.52	0.35	0.24	0.26	0.43	0.71	0.93	0.98	(89)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	19.9	20.08	20.24	20.34	20.37	20.38	20.38	20.38	20.37	20.34	20.15	19.86	(90)
$fLA = \text{Living area} \div (4) =$												0.49	(91)

Mean internal temperature (for the whole dwelling) = $fLA \times T1 + (1 - fLA) \times T2$

(92)m=	20.26	20.42	20.56	20.65	20.67	20.68	20.68	20.68	20.68	20.65	20.48	20.23	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	20.26	20.42	20.56	20.65	20.67	20.68	20.68	20.68	20.68	20.65	20.48	20.23	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set T_i to the mean internal temperature obtained at step 11 of Table 9b, so that $T_i,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	--	--

Utilisation factor for gains, hm:

(94)m=	0.97	0.93	0.86	0.71	0.54	0.37	0.26	0.28	0.45	0.73	0.93	0.98	(94)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	412.96	454.81	455.1	401.14	311.7	208.98	140.27	146.77	227.18	340.32	391.52	394.98	(95)
--------	--------	--------	-------	--------	-------	--------	--------	--------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W = [(39)m x [(93)m - (96)m]

(97)m=	568.5	551.33	498.18	410.72	312.76	209.03	140.28	146.77	227.4	350.34	468.77	564.71	(97)
--------	-------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	------

Space heating requirement for each month, kWh/month = $0.024 \times [(97)m - (95)m] \times (41)m$

(98)m=	115.72	64.86	32.05	6.89	0.79	0	0	0	0	7.45	55.62	126.27	
--------	--------	-------	-------	------	------	---	---	---	---	------	-------	--------	--

Total per year (kWh/year) = Sum(98)_{1...5,9...12} = 409.67 (98)

Space heating requirement in kWh/m²/year 7.86 (99)

9b. Energy requirements – Community heating scheme

This part is used for space heating, space cooling or water heating provided by a community scheme.

DER WorkSheet: New dwelling design stage

Fraction of space heat from secondary/supplementary heating (Table 11) '0' if none	<input type="text" value="0"/>	(301)
Fraction of space heat from community system 1 – (301) =	<input type="text" value="1"/>	(302)

The community scheme may obtain heat from several sources. The procedure allows for CHP and up to four other heat sources; the latter includes boilers, heat pumps, geothermal and waste heat from power stations. See Appendix C.

Fraction of heat from Community boilers	<input type="text" value="1"/>	(303a)
Fraction of total space heat from Community boilers	<input type="text" value="1"/>	(304a)
Factor for control and charging method (Table 4c(3)) for community heating system	<input type="text" value="1"/>	(305)
Distribution loss factor (Table 12c) for community heating system	<input type="text" value="1.1"/>	(306)

Space heating

Annual space heating requirement	<input type="text" value="409.67"/>	kWh/year
Space heat from Community boilers	<input type="text" value="450.63"/>	(307a)
Efficiency of secondary/supplementary heating system in % (from Table 4a or Appendix E)	<input type="text" value="0"/>	(308)
Space heating requirement from secondary/supplementary system	<input type="text" value="0"/>	(309)

Water heating

Annual water heating requirement	<input type="text" value="1843.63"/>	
If DHW from community scheme:		
Water heat from Community boilers	<input type="text" value="2028"/>	(310a)
Electricity used for heat distribution	<input type="text" value="24.79"/>	(313)
Cooling System Energy Efficiency Ratio	<input type="text" value="0"/>	(314)
Space cooling (if there is a fixed cooling system, if not enter 0)	<input type="text" value="0"/>	(315)
Electricity for pumps and fans within dwelling (Table 4f): mechanical ventilation - balanced, extract or positive input from outside	<input type="text" value="103.29"/>	(330a)
warm air heating system fans	<input type="text" value="0"/>	(330b)
pump for solar water heating	<input type="text" value="0"/>	(330g)
Total electricity for the above, kWh/year	<input type="text" value="103.29"/>	(331)
Energy for lighting (calculated in Appendix L)	<input type="text" value="240.39"/>	(332)

12b. CO2 Emissions – Community heating scheme

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
CO2 from other sources of space and water heating (not CHP)			
Efficiency of heat source 1 (%)		If there is CHP using two fuels repeat (363) to (366) for the second fuel	<input type="text" value="95"/>
CO2 associated with heat source 1	$[(307b)+(310b)] \times 100 \div (367b) \times$	<input type="text" value="0.22"/>	$= 563.56$
Electrical energy for heat distribution	$[(313) \times$	<input type="text" value="0.52"/>	$= 12.86$
Total CO2 associated with community systems	$(363)...(366) + (368)...(372)$		$= 576.43$
CO2 associated with space heating (secondary)	$(309) \times$	<input type="text" value="0"/>	$= 0$
CO2 associated with water from immersion heater or instantaneous heater	$(312) \times$	<input type="text" value="0.22"/>	$= 0$
Total CO2 associated with space and water heating	$(373) + (374) + (375) =$		$= 576.43$
CO2 associated with electricity for pumps and fans within dwelling	$(331) \times$	<input type="text" value="0.52"/>	$= 53.61$

DER WorkSheet: New dwelling design stage

CO2 associated with electricity for lighting	(332)) x	0.52	=	124.76	(379)
Total CO2, kg/year	sum of (376)...(382) =	754.8			(383)
Dwelling CO2 Emission Rate	(383) ÷ (4) =	14.49			(384)
EI rating (section 14)		89.58			(385)

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 208 - Be Lean			
Address :	AC 208, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	52.1 (1a)	x (2a)	2.6 = 135.46 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	52.1 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	135.46 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour	
Number of chimneys	0	+	0	+	0	x 40 = 0 (6a)
Number of open flues	0	+	0	+	0	x 20 = 0 (6b)
Number of intermittent fans					2	x 10 = 20 (7a)
Number of passive vents					0	x 10 = 0 (7b)
Number of flueless gas fires					0	x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 20 ÷ (5) = 0.15 (8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

If both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] = 0

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) = 0

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] = 0.85

Infiltration rate incorporating shelter factor (21) = (18) x (20) = 0.34

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

TER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.43	0.42	0.41	0.37	0.36	0.32	0.32	0.31	0.34	0.36	0.38	0.4
------	------	------	------	------	------	------	------	------	------	------	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0.59	0.59	0.59	0.57	0.57	0.55	0.55	0.55	0.56	0.57	0.57	0.58
---------	------	------	------	------	------	------	------	------	------	------	------	------

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.59	0.59	0.59	0.57	0.57	0.55	0.55	0.55	0.56	0.57	0.57	0.58
--------	------	------	------	------	------	------	------	------	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Windows Type 1			5.93	x1/[1/(1.4)+ 0.04] =	7.86		(27)
Windows Type 2			1.59	x1/[1/(1.4)+ 0.04] =	2.11		(27)
Windows Type 3			3.93	x1/[1/(1.4)+ 0.04] =	5.21		(27)
Windows Type 4			1.57	x1/[1/(1.4)+ 0.04] =	2.08		(27)
Walls	31.1	13.02	18.08	x 0.18 =	3.25		(29)
Total area of elements, m ²			31.1				(31)
Party wall			44.62	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 20.52 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 3.74 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 24.25 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	26.5	26.34	26.18	25.44	25.3	24.66	24.66	24.54	24.9	25.3	25.58	25.88

(38)

Heat transfer coefficient, W/K (39)m = (37) + (38)m

(39)m=	50.76	50.59	50.44	49.69	49.56	48.91	48.91	48.79	49.16	49.56	49.84	50.13
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

Average = Sum(39)_{1...12} /12= 49.69 (39)

TER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	0.97	0.97	0.97	0.95	0.95	0.94	0.94	0.94	0.94	0.95	0.96	0.96	(40)
													Average = Sum(40) _{1...12} /12=

$$(40)m = (39)m \div (4)$$

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(41)
(41)m=	31	28	31	30	31	30	31	31	30	31	30	31

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

1.75

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

75.81

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$											

(44)m=	83.39	80.36	77.33	74.29	71.26	68.23	68.23	71.26	74.29	77.33	80.36	83.39	
													Total = Sum(44) _{1...12} =

909.73

(44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	123.67	108.16	111.61	97.31	93.37	80.57	74.66	85.67	86.7	101.03	110.29	119.77	
													Total = Sum(45) _{1...12} =

1192.79

(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	18.55	16.22	16.74	14.6	14.01	12.09	11.2	12.85	13	15.16	16.54	17.96	
													150

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

150

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

1.39

(48)

Temperature factor from Table 2b

0.54

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

0.75

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0

(51)

If community heating see section 4.3

Volume factor from Table 2a

0

(52)

Temperature factor from Table 2b

0

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

0

(54)

Enter (50) or (54) in (55)

0.75

(55)

Water storage loss calculated for each month

((56)m = (55) x (41)m)

(56)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	
													(56)

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	
													(57)

0

(58)

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26	
													(59)

TER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	170.26	150.25	158.21	142.4	139.96	125.66	121.25	132.27	131.79	147.63	155.38	166.36	(62)
--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	170.26	150.25	158.21	142.4	139.96	125.66	121.25	132.27	131.79	147.63	155.38	166.36	Output from water heater (annual) 1...12	1741.41	(64)
--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--	---------	------

Heat gains from water heating, kWh/month 0.25 $[0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	78.4	69.63	74.39	68.43	68.32	62.86	62.1	65.76	64.9	70.87	72.74	77.1	(65)
--------	------	-------	-------	-------	-------	-------	------	-------	------	-------	-------	------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(66)
87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	13.61	12.09	9.83	7.44	5.56	4.7	5.08	6.6	8.86	11.24	13.12	13.99	(67)
--------	-------	-------	------	------	------	-----	------	-----	------	-------	-------	-------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	152.69	154.27	150.28	141.78	131.05	120.96	114.23	112.64	116.63	125.13	135.86	145.95	(68)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	31.76	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	3	3	3	3	3	3	3	3	3	3	3	3	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	-70.08	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	105.37	103.62	99.98	95.04	91.83	87.31	83.47	88.39	90.14	95.26	101.03	103.63	(72)
--------	--------	--------	-------	-------	-------	-------	-------	-------	-------	-------	--------	--------	------

Total internal gains = $(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$

(73)m=	323.95	322.26	312.37	296.54	280.72	265.25	255.05	259.91	267.91	283.91	302.3	315.85	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_< Table 6b	FF Table 6c	Gains (W)
North	0.9x	0.77	x 3.93	x 10.63	x 0.63	= 12.77
North	0.9x	0.77	x 1.57	x 10.63	x 0.63	= 5.1
North	0.9x	0.77	x 3.93	x 20.32	x 0.63	= 24.41
North	0.9x	0.77	x 1.57	x 20.32	x 0.63	= 9.75
North	0.9x	0.77	x 3.93	x 34.53	x 0.63	= 41.47

TER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	1.57	x	34.53	x	0.63	x	0.7	=	16.57	(74)
North	0.9x	0.77	x	3.93	x	55.46	x	0.63	x	0.7	=	66.62	(74)
North	0.9x	0.77	x	1.57	x	55.46	x	0.63	x	0.7	=	26.61	(74)
North	0.9x	0.77	x	3.93	x	74.72	x	0.63	x	0.7	=	89.74	(74)
North	0.9x	0.77	x	1.57	x	74.72	x	0.63	x	0.7	=	35.85	(74)
North	0.9x	0.77	x	3.93	x	79.99	x	0.63	x	0.7	=	96.07	(74)
North	0.9x	0.77	x	1.57	x	79.99	x	0.63	x	0.7	=	38.38	(74)
North	0.9x	0.77	x	3.93	x	74.68	x	0.63	x	0.7	=	89.69	(74)
North	0.9x	0.77	x	1.57	x	74.68	x	0.63	x	0.7	=	35.83	(74)
North	0.9x	0.77	x	3.93	x	59.25	x	0.63	x	0.7	=	71.16	(74)
North	0.9x	0.77	x	1.57	x	59.25	x	0.63	x	0.7	=	28.43	(74)
North	0.9x	0.77	x	3.93	x	41.52	x	0.63	x	0.7	=	49.86	(74)
North	0.9x	0.77	x	1.57	x	41.52	x	0.63	x	0.7	=	19.92	(74)
North	0.9x	0.77	x	3.93	x	24.19	x	0.63	x	0.7	=	29.05	(74)
North	0.9x	0.77	x	1.57	x	24.19	x	0.63	x	0.7	=	11.61	(74)
North	0.9x	0.77	x	3.93	x	13.12	x	0.63	x	0.7	=	15.76	(74)
North	0.9x	0.77	x	1.57	x	13.12	x	0.63	x	0.7	=	6.29	(74)
North	0.9x	0.77	x	3.93	x	8.86	x	0.63	x	0.7	=	10.65	(74)
North	0.9x	0.77	x	1.57	x	8.86	x	0.63	x	0.7	=	4.25	(74)
South	0.9x	0.77	x	5.93	x	46.75	x	0.63	x	0.7	=	84.73	(78)
South	0.9x	0.77	x	1.59	x	46.75	x	0.63	x	0.7	=	22.72	(78)
South	0.9x	0.77	x	5.93	x	76.57	x	0.63	x	0.7	=	138.76	(78)
South	0.9x	0.77	x	1.59	x	76.57	x	0.63	x	0.7	=	37.21	(78)
South	0.9x	0.77	x	5.93	x	97.53	x	0.63	x	0.7	=	176.76	(78)
South	0.9x	0.77	x	1.59	x	97.53	x	0.63	x	0.7	=	47.39	(78)
South	0.9x	0.77	x	5.93	x	110.23	x	0.63	x	0.7	=	199.78	(78)
South	0.9x	0.77	x	1.59	x	110.23	x	0.63	x	0.7	=	53.57	(78)
South	0.9x	0.77	x	5.93	x	114.87	x	0.63	x	0.7	=	208.18	(78)
South	0.9x	0.77	x	1.59	x	114.87	x	0.63	x	0.7	=	55.82	(78)
South	0.9x	0.77	x	5.93	x	110.55	x	0.63	x	0.7	=	200.34	(78)
South	0.9x	0.77	x	1.59	x	110.55	x	0.63	x	0.7	=	53.72	(78)
South	0.9x	0.77	x	5.93	x	108.01	x	0.63	x	0.7	=	195.75	(78)
South	0.9x	0.77	x	1.59	x	108.01	x	0.63	x	0.7	=	52.49	(78)
South	0.9x	0.77	x	5.93	x	104.89	x	0.63	x	0.7	=	190.1	(78)
South	0.9x	0.77	x	1.59	x	104.89	x	0.63	x	0.7	=	50.97	(78)
South	0.9x	0.77	x	5.93	x	101.89	x	0.63	x	0.7	=	184.65	(78)
South	0.9x	0.77	x	1.59	x	101.89	x	0.63	x	0.7	=	49.51	(78)
South	0.9x	0.77	x	5.93	x	82.59	x	0.63	x	0.7	=	149.67	(78)
South	0.9x	0.77	x	1.59	x	82.59	x	0.63	x	0.7	=	40.13	(78)
South	0.9x	0.77	x	5.93	x	55.42	x	0.63	x	0.7	=	100.43	(78)
South	0.9x	0.77	x	1.59	x	55.42	x	0.63	x	0.7	=	26.93	(78)

TER WorkSheet: New dwelling design stage

South	$0.9x$	0.77	x	5.93	x	40.4	x	0.63	x	0.7	=	73.21	(78)
South	$0.9x$	0.77	x	1.59	x	40.4	x	0.63	x	0.7	=	19.63	(78)

Solar gains in watts, calculated for each month $(83)m = \text{Sum}(74)m \dots (82)m$

(83)m=	125.32	210.13	282.19	346.57	389.59	388.51	373.76	340.66	303.94	230.46	149.41	107.74	(83)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Total gains – internal and solar $(84)m = (73)m + (83)m$, watts

(84)m=	449.27	532.38	594.57	643.11	670.31	653.76	628.81	600.57	571.85	514.37	451.71	423.59	(84)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 ($^{\circ}\text{C}$)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(86)m=	0.99	0.97	0.93	0.82	0.66	0.48	0.34	0.37	0.58	0.86	0.97	0.99

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	20.25	20.44	20.66	20.87	20.97	21	21	21	20.99	20.86	20.52	20.21	(87)
--------	-------	-------	-------	-------	-------	----	----	----	-------	-------	-------	-------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 ($^{\circ}\text{C}$)

(88)m=	20.1	20.11	20.11	20.12	20.12	20.13	20.13	20.14	20.13	20.12	20.12	20.11	(88)
--------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	0.98	0.96	0.91	0.79	0.61	0.41	0.27	0.3	0.51	0.82	0.96	0.99	(89)
--------	------	------	------	------	------	------	------	-----	------	------	------	------	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	19.12	19.4	19.71	19.98	20.1	20.13	20.13	20.14	20.12	19.98	19.53	19.08	(90)
--------	-------	------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	------

fLA = Living area ÷ (4) =

0.49

(91)

Mean internal temperature (for the whole dwelling) = fLA × T1 + (1 – fLA) × T2

(92)m=	19.67	19.91	20.17	20.41	20.52	20.55	20.56	20.56	20.54	20.41	20.02	19.63	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.67	19.91	20.17	20.41	20.52	20.55	20.56	20.56	20.54	20.41	20.02	19.63	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set T_i to the mean internal temperature obtained at step 11 of Table 9b, so that $T_i,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	--

Utilisation factor for gains, hm:

(94)m=	0.98	0.96	0.91	0.8	0.63	0.44	0.31	0.34	0.55	0.83	0.96	0.99	(94)
--------	------	------	------	-----	------	------	------	------	------	------	------	------	------

Useful gains, hmGm , W = (94)m × (84)m

(95)m=	441.1	509.82	539.75	514.36	424.06	289.84	193.37	202.61	312.4	426.48	433.02	417.7	(95)
--------	-------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	-------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W = [(39)m × [(93)m – (96)m]

(97)m=	780.17	759.4	689.6	572.11	437.13	291.18	193.5	202.82	316.79	486.06	643.63	773.53	(97)
--------	--------	-------	-------	--------	--------	--------	-------	--------	--------	--------	--------	--------	------

Space heating requirement for each month, kWh/month = 0.024 × [(97)m – (95)m] × (41)m

(98)m=	252.27	167.71	111.48	41.58	9.73	0	0	0	0	44.33	151.64	264.74	
--------	--------	--------	--------	-------	------	---	---	---	---	-------	--------	--------	--

Total per year (kWh/year) = Sum(98)_{1...5,9...12} = 1043.47 (98)

Space heating requirement in kWh/m²/year 20.03 (99)

9a. Energy requirements – Individual heating systems including micro-CHP

Space heating:

Fraction of space heat from secondary/supplementary system

0

(201)

TER WorkSheet: New dwelling design stage

Fraction of space heat from main system(s)	$(202) = 1 - (201) =$	1	(202)
Fraction of total heating from main system 1	$(204) = (202) \times [1 - (203)] =$	1	(204)
Efficiency of main space heating system 1		93.5	(206)
Efficiency of secondary/supplementary heating system, %		0	(208)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

252.27	167.71	111.48	41.58	9.73	0	0	0	0	44.33	151.64	264.74
--------	--------	--------	-------	------	---	---	---	---	-------	--------	--------

$$(211)m = \{[(98)m \times (204)]\} \times 100 \div (206) \quad (211)$$

269.8	179.37	119.23	44.47	10.4	0	0	0	0	47.41	162.19	283.14
-------	--------	--------	-------	------	---	---	---	---	-------	--------	--------

$$\text{Total (kWh/year)} = \text{Sum}(211)_{1...5,10...12} = 1116.01 \quad (211)$$

Space heating fuel (secondary), kWh/month

$$= \{[(98)m \times (201)]\} \times 100 \div (208)$$

0	0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---	---

$$\text{Total (kWh/year)} = \text{Sum}(215)_{1...5,10...12} = 0 \quad (215)$$

Water heating

Output from water heater (calculated above)

170.26	150.25	158.21	142.4	139.96	125.66	121.25	132.27	131.79	147.63	155.38	166.36
--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------

Efficiency of water heater

85.86	85.11	83.9	81.99	80.42	79.8	79.8	79.8	79.8	82.04	84.75	86.05
-------	-------	------	-------	-------	------	------	------	------	-------	-------	-------

$$79.8 \quad (216)$$

Fuel for water heating, kWh/month

$$(219)m = (64)m \times 100 \div (217)m$$

198.3	176.54	188.56	173.68	174.04	157.47	151.95	165.75	165.15	179.95	183.34	193.33
-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

$$\text{Total} = \text{Sum}(219a)_{1...12} = 2108.06 \quad (219)$$

Annual totals

Space heating fuel used, main system 1

kWh/year

1116.01

Water heating fuel used

kWh/year

2108.06

Electricity for pumps, fans and electric keep-hot

central heating pump:

30 (230c)

boiler with a fan-assisted flue

45 (230e)

Total electricity for the above, kWh/year

sum of (230a)...(230g) = 75 (231)

Electricity for lighting

240.39 (232)

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating (main system 1)	(211) x	0.216	= 241.06 (261)
Space heating (secondary)	(215) x	0.519	= 0 (263)
Water heating	(219) x	0.216	= 455.34 (264)
Space and water heating	(261) + (262) + (263) + (264) =		696.4 (265)
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	= 38.93 (267)
Electricity for lighting	(232) x	0.519	= 124.76 (268)

TER WorkSheet: New dwelling design stage

Total CO₂, kg/year

sum of (265)...(271) =

860.09 (272)

TER =

16.51 (273)

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name: John Simpson **Stroma Number:** STRO006273
Software Name: Stroma FSAP 2012 **Software Version:** Version: 1.0.5.8

Property Address: AC 209 - Be Lean

Address : AC 209, Aspen Court, Maitland Park Estate, London, NW3 2EH

1. Overall dwelling dimensions:

	Area(m ²)	Av. Height(m)	Volume(m ³)
Ground floor	77.4 (1a)	x (2a)	= 201.24 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	77.4 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	201.24 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m ³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					x 10 = 0 (7a)
Number of passive vents					x 10 = 0 (7b)
Number of flueless gas fires					x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 0 ÷ (5) = 0
(8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] = 0

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) =

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area 2

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

Shelter factor (20) = 1 - [0.075 x (19)] = 0.85

Infiltration rate incorporating shelter factor (21) = (18) x (20) = 0.08

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

DER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.11	0.11	0.1	0.09	0.09	0.08	0.08	0.08	0.08	0.09	0.1	0.1
------	------	-----	------	------	------	------	------	------	------	-----	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.21	0.21	0.22
---------	------	------	------	------	------	-----	-----	-----	------	------	------

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.23	0.22	0.22	0.21	0.21	0.2	0.2	0.2	0.2	0.21	0.21	0.22
--------	------	------	------	------	------	-----	-----	-----	-----	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Windows Type 1			2.24	x1/[1/(1.4)+ 0.04] =	2.97		(27)
Windows Type 2			6.18	x1/[1/(1.4)+ 0.04] =	8.19		(27)
Windows Type 3			1.71	x1/[1/(1.4)+ 0.04] =	2.27		(27)
Windows Type 4			4.1	x1/[1/(1.4)+ 0.04] =	5.44		(27)
Windows Type 5			2.24	x1/[1/(1.4)+ 0.04] =	2.97		(27)
Windows Type 6			1.68	x1/[1/(1.4)+ 0.04] =	2.23		(27)
Walls	46.54	18.15	28.39	x 0.12 =	3.41		(29)
Total area of elements, m ²			46.54				(31)
Party wall			44.62	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 27.47 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 7.52 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 34.99 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	15	14.86	14.72	14.01	13.87	13.17	13.17	13.02	13.45	13.87	14.15	14.44

(38)

Heat transfer coefficient, W/K (39)m = (37) + (38)m

(39)m=	49.99	49.85	49.71	49	48.86	48.15	48.15	48.01	48.43	48.86	49.14	49.42
--------	-------	-------	-------	----	-------	-------	-------	-------	-------	-------	-------	-------

Stroma FSAP 2012 Version: 1.0.5.8 (SAP 9.92) - http://www.stroma.com Average = Sum(39)_{1...12} /12= 48.96 (39)

Page 2 of 8

DER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

$$(40)m = (39)m \div (4)$$

(40)m=	0.65	0.64	0.64	0.63	0.63	0.62	0.62	0.62	0.63	0.63	0.63	0.64	Average = Sum(40) _{1...12} /12=	0.63	(40)
--------	------	------	------	------	------	------	------	------	------	------	------	------	--	------	------

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(41)m=	31	28	31	30	31	30	31	31	30	31	(41)
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	--------	----	----	----	----	----	----	----	----	----	----	------

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

2.41

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

91.48

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	100.63	96.97	93.31	89.65	85.99	82.33	82.33	85.99	89.65	93.31	96.97	100.63	Total = Sum(44) _{1...12} =	1097.73	(44)
--------	--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	--------	-------------------------------------	---------	------

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	149.22	130.51	134.68	117.41	112.66	97.22	90.09	103.38	104.61	121.91	133.08	144.52	Total = Sum(45) _{1...12} =	1439.29	(45)
--------	--------	--------	--------	--------	--------	-------	-------	--------	--------	--------	--------	--------	-------------------------------------	---------	------

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	22.38	19.58	20.2	17.61	16.9	14.58	13.51	15.51	15.69	18.29	19.96	21.68	0	(46)
--------	-------	-------	------	-------	------	-------	-------	-------	-------	-------	-------	-------	---	------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0

(48)

Temperature factor from Table 2b

0

(49)

Energy lost from water storage, kWh/year

$$(48) \times (49) =$$

110

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0.02

(51)

If community heating see section 4.3

Volume factor from Table 2a

1.03

(52)

Temperature factor from Table 2b

0.6

(53)

Energy lost from water storage, kWh/year

$$(47) \times (51) \times (52) \times (53) =$$

1.03

(54)

Enter (50) or (54) in (55)

1.03

(55)

Water storage loss calculated for each month

$$((56)m = (55) \times (41)m)$$

(56)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01	0	(56)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	---	------

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01	0	(57)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	---	------

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26	0	(59)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	---	------

DER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	204.5	180.44	189.95	170.91	167.94	150.71	145.36	158.65	158.11	177.19	186.57	199.79	(62)
--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	204.5	180.44	189.95	170.91	167.94	150.71	145.36	158.65	158.11	177.19	186.57	199.79	
Output from water heater (annual) 1...12												2090.13	(64)

Heat gains from water heating, kWh/month 0.25 [$0.85 \times (45)m + (61)m$] + $0.8 \times [(46)m + (57)m + (59)m]$]

(65)m=	93.84	83.34	89	81.84	81.68	75.12	74.18	78.59	77.58	84.76	87.04	92.27	(65)
--------	-------	-------	----	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m=	120.58	120.58	120.58	120.58	120.58	120.58	120.58	120.58	120.58	120.58	120.58	120.58	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	19.07	16.94	13.78	10.43	7.8	6.58	7.11	9.24	12.41	15.75	18.39	19.6	(67)
--------	-------	-------	-------	-------	-----	------	------	------	-------	-------	-------	------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	213.92	216.14	210.55	198.64	183.61	169.48	160.04	157.82	163.41	175.32	190.35	204.48	(68)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	35.06	35.06	35.06	35.06	35.06	35.06	35.06	35.06	35.06	35.06	35.06	35.06	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	0	0	0	0	0	0	0	0	0	0	0	0	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-96.47	-96.47	-96.47	-96.47	-96.47	-96.47	-96.47	-96.47	-96.47	-96.47	-96.47	-96.47	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	126.13	124.01	119.63	113.66	109.79	104.33	99.7	105.64	107.75	113.92	120.89	124.02	(72)
--------	--------	--------	--------	--------	--------	--------	------	--------	--------	--------	--------	--------	------

Total internal gains = $(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$

(73)m=	418.29	416.27	403.12	381.9	360.36	339.57	326.02	331.87	342.74	364.17	388.81	407.28	(73)
--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_ Table 6b	FF Table 6c	Gains (W)
North	0.9x	0.77	x 4.1	x 10.63	x 0.4	x 0.8 = 9.67 (74)
North	0.9x	0.77	x 2.24	x 10.63	x 0.4	x 0.8 = 5.28 (74)
North	0.9x	0.77	x 1.68	x 10.63	x 0.4	x 0.8 = 3.96 (74)
North	0.9x	0.77	x 4.1	x 20.32	x 0.4	x 0.8 = 18.48 (74)
North	0.9x	0.77	x 2.24	x 20.32	x 0.4	x 0.8 = 10.09 (74)

DER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	1.68	x	20.32	x	0.4	x	0.8	=	7.57	(74)
North	0.9x	0.77	x	4.1	x	34.53	x	0.4	x	0.8	=	31.4	(74)
North	0.9x	0.77	x	2.24	x	34.53	x	0.4	x	0.8	=	17.15	(74)
North	0.9x	0.77	x	1.68	x	34.53	x	0.4	x	0.8	=	12.86	(74)
North	0.9x	0.77	x	4.1	x	55.46	x	0.4	x	0.8	=	50.43	(74)
North	0.9x	0.77	x	2.24	x	55.46	x	0.4	x	0.8	=	27.55	(74)
North	0.9x	0.77	x	1.68	x	55.46	x	0.4	x	0.8	=	20.66	(74)
North	0.9x	0.77	x	4.1	x	74.72	x	0.4	x	0.8	=	67.93	(74)
North	0.9x	0.77	x	2.24	x	74.72	x	0.4	x	0.8	=	37.11	(74)
North	0.9x	0.77	x	1.68	x	74.72	x	0.4	x	0.8	=	27.84	(74)
North	0.9x	0.77	x	4.1	x	79.99	x	0.4	x	0.8	=	72.72	(74)
North	0.9x	0.77	x	2.24	x	79.99	x	0.4	x	0.8	=	39.73	(74)
North	0.9x	0.77	x	1.68	x	79.99	x	0.4	x	0.8	=	29.8	(74)
North	0.9x	0.77	x	4.1	x	74.68	x	0.4	x	0.8	=	67.9	(74)
North	0.9x	0.77	x	2.24	x	74.68	x	0.4	x	0.8	=	37.1	(74)
North	0.9x	0.77	x	1.68	x	74.68	x	0.4	x	0.8	=	27.82	(74)
North	0.9x	0.77	x	4.1	x	59.25	x	0.4	x	0.8	=	53.87	(74)
North	0.9x	0.77	x	2.24	x	59.25	x	0.4	x	0.8	=	29.43	(74)
North	0.9x	0.77	x	1.68	x	59.25	x	0.4	x	0.8	=	22.07	(74)
North	0.9x	0.77	x	4.1	x	41.52	x	0.4	x	0.8	=	37.75	(74)
North	0.9x	0.77	x	2.24	x	41.52	x	0.4	x	0.8	=	20.62	(74)
North	0.9x	0.77	x	1.68	x	41.52	x	0.4	x	0.8	=	15.47	(74)
North	0.9x	0.77	x	4.1	x	24.19	x	0.4	x	0.8	=	21.99	(74)
North	0.9x	0.77	x	2.24	x	24.19	x	0.4	x	0.8	=	12.02	(74)
North	0.9x	0.77	x	1.68	x	24.19	x	0.4	x	0.8	=	9.01	(74)
North	0.9x	0.77	x	4.1	x	13.12	x	0.4	x	0.8	=	11.93	(74)
North	0.9x	0.77	x	2.24	x	13.12	x	0.4	x	0.8	=	6.52	(74)
North	0.9x	0.77	x	1.68	x	13.12	x	0.4	x	0.8	=	4.89	(74)
North	0.9x	0.77	x	4.1	x	8.86	x	0.4	x	0.8	=	8.06	(74)
North	0.9x	0.77	x	2.24	x	8.86	x	0.4	x	0.8	=	4.4	(74)
North	0.9x	0.77	x	1.68	x	8.86	x	0.4	x	0.8	=	3.3	(74)
South	0.9x	0.77	x	2.24	x	46.75	x	0.4	x	0.8	=	23.22	(78)
South	0.9x	0.77	x	6.18	x	46.75	x	0.4	x	0.8	=	64.07	(78)
South	0.9x	0.77	x	1.71	x	46.75	x	0.4	x	0.8	=	17.73	(78)
South	0.9x	0.77	x	2.24	x	76.57	x	0.4	x	0.8	=	38.03	(78)
South	0.9x	0.77	x	6.18	x	76.57	x	0.4	x	0.8	=	104.93	(78)
South	0.9x	0.77	x	1.71	x	76.57	x	0.4	x	0.8	=	29.04	(78)
South	0.9x	0.77	x	2.24	x	97.53	x	0.4	x	0.8	=	48.45	(78)
South	0.9x	0.77	x	6.18	x	97.53	x	0.4	x	0.8	=	133.67	(78)
South	0.9x	0.77	x	1.71	x	97.53	x	0.4	x	0.8	=	36.99	(78)
South	0.9x	0.77	x	2.24	x	110.23	x	0.4	x	0.8	=	54.76	(78)

DER WorkSheet: New dwelling design stage

South	0.9x	0.77	x	6.18	x	110.23	x	0.4	x	0.8	=	151.07	(78)
South	0.9x	0.77	x	1.71	x	110.23	x	0.4	x	0.8	=	41.8	(78)
South	0.9x	0.77	x	2.24	x	114.87	x	0.4	x	0.8	=	57.06	(78)
South	0.9x	0.77	x	6.18	x	114.87	x	0.4	x	0.8	=	157.43	(78)
South	0.9x	0.77	x	1.71	x	114.87	x	0.4	x	0.8	=	43.56	(78)
South	0.9x	0.77	x	2.24	x	110.55	x	0.4	x	0.8	=	54.91	(78)
South	0.9x	0.77	x	6.18	x	110.55	x	0.4	x	0.8	=	151.5	(78)
South	0.9x	0.77	x	1.71	x	110.55	x	0.4	x	0.8	=	41.92	(78)
South	0.9x	0.77	x	2.24	x	108.01	x	0.4	x	0.8	=	53.65	(78)
South	0.9x	0.77	x	6.18	x	108.01	x	0.4	x	0.8	=	148.03	(78)
South	0.9x	0.77	x	1.71	x	108.01	x	0.4	x	0.8	=	40.96	(78)
South	0.9x	0.77	x	2.24	x	104.89	x	0.4	x	0.8	=	52.11	(78)
South	0.9x	0.77	x	6.18	x	104.89	x	0.4	x	0.8	=	143.76	(78)
South	0.9x	0.77	x	1.71	x	104.89	x	0.4	x	0.8	=	39.78	(78)
South	0.9x	0.77	x	2.24	x	101.89	x	0.4	x	0.8	=	50.61	(78)
South	0.9x	0.77	x	6.18	x	101.89	x	0.4	x	0.8	=	139.63	(78)
South	0.9x	0.77	x	1.71	x	101.89	x	0.4	x	0.8	=	38.64	(78)
South	0.9x	0.77	x	2.24	x	82.59	x	0.4	x	0.8	=	41.02	(78)
South	0.9x	0.77	x	6.18	x	82.59	x	0.4	x	0.8	=	113.18	(78)
South	0.9x	0.77	x	1.71	x	82.59	x	0.4	x	0.8	=	31.32	(78)
South	0.9x	0.77	x	2.24	x	55.42	x	0.4	x	0.8	=	27.53	(78)
South	0.9x	0.77	x	6.18	x	55.42	x	0.4	x	0.8	=	75.95	(78)
South	0.9x	0.77	x	1.71	x	55.42	x	0.4	x	0.8	=	21.01	(78)
South	0.9x	0.77	x	2.24	x	40.4	x	0.4	x	0.8	=	20.07	(78)
South	0.9x	0.77	x	6.18	x	40.4	x	0.4	x	0.8	=	55.36	(78)
South	0.9x	0.77	x	1.71	x	40.4	x	0.4	x	0.8	=	15.32	(78)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m=

123.94	208.15	280.52	346.28	390.93	390.59	375.45	341.01	302.72	228.54	147.82	106.52
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

 (83)

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=

542.23	624.41	683.64	728.18	751.3	730.16	701.48	672.88	645.46	592.72	536.63	513.8
--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	-------

 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m=	0.99	0.97	0.91	0.78	0.6	0.42	0.3	0.33	0.52	0.81	0.97	0.99	(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=

20.6	20.74	20.87	20.97	21	21	21	21	21	20.96	20.78	20.57
------	-------	-------	-------	----	----	----	----	----	-------	-------	-------

 (87)

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=

20.39	20.39	20.39	20.4	20.4	20.41	20.41	20.41	20.41	20.4	20.4	20.4
-------	-------	-------	------	------	-------	-------	-------	-------	------	------	------

 (88)

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=

0.99	0.96	0.9	0.75	0.56	0.38	0.26	0.29	0.47	0.78	0.96	0.99
------	------	-----	------	------	------	------	------	------	------	------	------

 (89)

DER WorkSheet: New dwelling design stage

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	19.86	20.05	20.24	20.37	20.4	20.41	20.41	20.41	20.37	20.13	19.82		(90)
												fLA = Living area ÷ (4) =	0.42 (91)

Mean internal temperature (for the whole dwelling) = fLA × T1 + (1 – fLA) × T2

(92)m=	20.17	20.34	20.5	20.62	20.65	20.66	20.66	20.66	20.62	20.4	20.14		(92)
--------	-------	-------	------	-------	-------	-------	-------	-------	-------	------	-------	--	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	20.17	20.34	20.5	20.62	20.65	20.66	20.66	20.66	20.62	20.4	20.14		(93)
--------	-------	-------	------	-------	-------	-------	-------	-------	-------	------	-------	--	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that Ti,m=(76)m and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	0.99	0.96	0.9	0.76	0.58	0.4	0.28	0.3	0.49	0.79	0.96	0.99	(94)
--------	------	------	-----	------	------	-----	------	-----	------	------	------	------	------

Useful gains, hmGm , W = (94)m x (84)m

(95)m=	534.33	599.5	614.79	555.34	435.25	291.62	195.39	204.46	317.08	468.67	514.34	508.43	(95)
--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm , W =[(39)m x [(93)m – (96)m]

(97)m=	793.42	769.62	696.1	574.27	437.27	291.69	195.39	204.47	317.5	489.45	653.61	787.7	(97)
--------	--------	--------	-------	--------	--------	--------	--------	--------	-------	--------	--------	-------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m – (95)m] x (41)m

(98)m=	192.77	114.32	60.5	13.63	1.5	0	0	0	0	15.46	100.27	207.77	
	Total per year (kWh/year) = Sum(98) _{1..5,9..12} =												706.22 (98)

Space heating requirement in kWh/m²/year

9. Energy requirements – Community heating scheme

This part is used for space heating, space cooling or water heating provided by a community scheme.

Fraction of space heat from secondary/supplementary heating (Table 11) '0' if none

0 (301)

Fraction of space heat from community system 1 – (301) =

1 (302)

The community scheme may obtain heat from several sources. The procedure allows for CHP and up to four other heat sources; the latter includes boilers, heat pumps, geothermal and waste heat from power stations. See Appendix C.

Fraction of heat from Community boilers

1 (303a)

Fraction of total space heat from Community boilers

(302) x (303a) = 1 (304a)

Factor for control and charging method (Table 4c(3)) for community heating system

1 (305)

Distribution loss factor (Table 12c) for community heating system

1.1 (306)

Space heating

Annual space heating requirement

kWh/year

706.22

Space heat from Community boilers

(98) x (304a) x (305) x (306) = 776.84 (307a)

Efficiency of secondary/supplementary heating system in % (from Table 4a or Appendix E)

0 (308)

Space heating requirement from secondary/supplementary system (98) x (301) x 100 ÷ (308) = 0 (309)

Water heating

Annual water heating requirement

2090.13

If DHW from community scheme:

DER WorkSheet: New dwelling design stage

Water heat from Community boilers	$(64) \times (303a) \times (305) \times (306) =$	2299.15 (310a)
Electricity used for heat distribution	$0.01 \times [(307a) \dots (307e) + (310a) \dots (310e)] =$	30.76 (313)
Cooling System Energy Efficiency Ratio		0 (314)
Space cooling (if there is a fixed cooling system, if not enter 0)	$= (107) \div (314) =$	0 (315)
Electricity for pumps and fans within dwelling (Table 4f): mechanical ventilation - balanced, extract or positive input from outside		162.65 (330a)
warm air heating system fans		0 (330b)
pump for solar water heating		0 (330g)
Total electricity for the above, kWh/year	$= (330a) + (330b) + (330g) =$	162.65 (331)
Energy for lighting (calculated in Appendix L)		336.8 (332)

12b. CO2 Emissions – Community heating scheme

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
CO2 from other sources of space and water heating (not CHP) Efficiency of heat source 1 (%)			
	If there is CHP using two fuels repeat (363) to (366) for the second fuel	95 (367a)	
CO2 associated with heat source 1	$[(307b)+(310b)] \times 100 \div (367b) \times$	0.22 (367)	= 699.38 (367)
Electrical energy for heat distribution	$(313) \times$	0.52 (372)	= 15.96 (372)
Total CO2 associated with community systems	$(363) \dots (366) + (368) \dots (372)$		= 715.35 (373)
CO2 associated with space heating (secondary)	$(309) \times$	0 (374)	= 0 (374)
CO2 associated with water from immersion heater or instantaneous heater	$(312) \times$	0.22 (375)	= 0 (375)
Total CO2 associated with space and water heating	$(373) + (374) + (375) =$		715.35 (376)
CO2 associated with electricity for pumps and fans within dwelling	$(331)) \times$	0.52 (378)	= 84.42 (378)
CO2 associated with electricity for lighting	$(332))) \times$	0.52 (379)	= 174.8 (379)
Total CO2, kg/year	sum of (376)...(382) =		974.56 (383)
Dwelling CO2 Emission Rate	$(383) \div (4) =$		12.59 (384)
EI rating (section 14)			89.33 (385)

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 209 - Be Lean			
Address :	AC 209, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	77.4 (1a)	x (2a)	2.6 = 201.24 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	77.4 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	201.24 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour
Number of chimneys	0	+	0	+	0 = 0 x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0 x 20 = 0 (6b)
Number of intermittent fans					3 x 10 = 30 (7a)
Number of passive vents					0 x 10 = 0 (7b)
Number of flueless gas fires					0 x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =	30	÷ (5) = 0.15 (8)
If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)		
Number of storeys in the dwelling (ns)	0	(9)
Additional infiltration	[(9)-1]x0.1 = 0	(10)
Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction	0	(11)

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0	0 (12)
If no draught lobby, enter 0.05, else enter 0	0 (13)
Percentage of windows and doors draught stripped	0 (14)
Window infiltration	0.25 - [0.2 x (14) ÷ 100] = 0 (15)
Infiltration rate	(8) + (10) + (11) + (12) + (13) + (15) = 0 (16)
Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area	5 (17)
If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)	0.4 (18)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered	2 (19)
Shelter factor	(20) = 1 - [0.075 x (19)] = 0.85 (20)
Infiltration rate incorporating shelter factor	(21) = (18) x (20) = 0.34 (21)

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

TER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.43	0.42	0.42	0.37	0.36	0.32	0.32	0.31	0.34	0.36	0.38	0.4
------	------	------	------	------	------	------	------	------	------	------	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0.59	0.59	0.59	0.57	0.57	0.55	0.55	0.55	0.56	0.57	0.57	0.58
---------	------	------	------	------	------	------	------	------	------	------	------	------

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.59	0.59	0.59	0.57	0.57	0.55	0.55	0.55	0.56	0.57	0.57	0.58
--------	------	------	------	------	------	------	------	------	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m²)	Openings m²	Net Area A ,m²	U-value W/m²K	A X U (W/K)	k-value kJ/m²·K	A X k kJ/K
Windows Type 1			2.24	x1/[1/(1.4)+ 0.04] =	2.97		(27)
Windows Type 2			6.18	x1/[1/(1.4)+ 0.04] =	8.19		(27)
Windows Type 3			1.71	x1/[1/(1.4)+ 0.04] =	2.27		(27)
Windows Type 4			4.1	x1/[1/(1.4)+ 0.04] =	5.44		(27)
Windows Type 5			2.24	x1/[1/(1.4)+ 0.04] =	2.97		(27)
Windows Type 6			1.68	x1/[1/(1.4)+ 0.04] =	2.23		(27)
Walls	46.54	18.15	28.39	x 0.18 =	5.11		(29)
Total area of elements, m²			46.54				(31)
Party wall			44.62	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 29.17 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 5.18 (36)

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss (33) + (36) = 34.35 (37)

Ventilation heat loss calculated monthly (38)m = 0.33 x (25)m x (5)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	39.42	39.17	38.94	37.83	37.62	36.65	36.65	36.47	37.03	37.62	38.04	38.48

(38)

Heat transfer coefficient, W/K (39)m = (37) + (38)m

(39)m=	73.77	73.53	73.29	72.18	71.97	71	71	70.82	71.38	71.97	72.39	72.83
--------	-------	-------	-------	-------	-------	----	----	-------	-------	-------	-------	-------

TER WorkSheet: New dwelling design stage

Heat loss parameter (HLP), W/m²K

(40)m=	0.95	0.95	0.95	0.93	0.93	0.92	0.92	0.92	0.92	0.93	0.94	0.94			
													Average = Sum(40) _{1...12} /12=	0.93	(40)

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
(41)m=	31	28	31	30	31	30	31	31	30	31	30	31		(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

2.41

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd, \text{average} = (25 \times N) + 36$

91.48

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m=	100.63	96.97	93.31	89.65	85.99	82.33	82.33	85.99	89.65	93.31	96.97	100.63			
													Total = Sum(44) _{1...12} =	1097.73	(44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m=	149.22	130.51	134.68	117.41	112.66	97.22	90.09	103.38	104.61	121.91	133.08	144.52			
													Total = Sum(45) _{1...12} =	1439.29	(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	22.38	19.58	20.2	17.61	16.9	14.58	13.51	15.51	15.69	18.29	19.96	21.68			
															(46)

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

150

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

1.39

(48)

Temperature factor from Table 2b

0.54

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

0.75

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0

(51)

If community heating see section 4.3

Volume factor from Table 2a

0

(52)

Temperature factor from Table 2b

0

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

0

(54)

Enter (50) or (54) in (55)

0.75

(55)

Water storage loss calculated for each month

((56)m = (55) x (41)m)

(56)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33		
														(56)

If cylinder contains dedicated solar storage, $(57)m = (56)m \times [(50) - (H11)] \div (50)$, else $(57)m = (56)m$ where (H11) is from Appendix H

(57)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33		
														(57)

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month $(59)m = (58) \div 365 \times (41)m$

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26		
														(59)

TER WorkSheet: New dwelling design stage

Combi loss calculated for each month (61)m = $(60) \div 365 \times (41)m$

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = $0.85 \times (45)m + (46)m + (57)m + (59)m + (61)m$

(62)m=	195.82	172.6	181.27	162.51	159.26	142.31	136.68	149.97	149.7	168.51	178.17	191.11	(62)
--------	--------	-------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	195.82	172.6	181.27	162.51	159.26	142.31	136.68	149.97	149.7	168.51	178.17	191.11	Output from water heater (annual) 1...12	1987.91	(64)
--------	--------	-------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--	---------	------

Heat gains from water heating, kWh/month 0.25 $[0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	86.89	77.06	82.06	75.11	74.74	68.4	67.23	71.65	70.86	77.81	80.32	85.33	(65)
--------	-------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m=	120.58	120.58	120.58	120.58	120.58	120.58	120.58	120.58	120.58	120.58	120.58	120.58	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	19.07	16.94	13.78	10.43	7.8	6.58	7.11	9.24	12.41	15.75	18.39	19.6	(67)
--------	-------	-------	-------	-------	-----	------	------	------	-------	-------	-------	------	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	213.92	216.14	210.55	198.64	183.61	169.48	160.04	157.82	163.41	175.32	190.35	204.48	(68)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	35.06	35.06	35.06	35.06	35.06	35.06	35.06	35.06	35.06	35.06	35.06	35.06	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	3	3	3	3	3	3	3	3	3	3	3	3	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-96.47	-96.47	-96.47	-96.47	-96.47	-96.47	-96.47	-96.47	-96.47	-96.47	-96.47	-96.47	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	116.79	114.68	110.29	104.32	100.45	95	90.36	96.3	98.41	104.59	111.56	114.69	(72)
--------	--------	--------	--------	--------	--------	----	-------	------	-------	--------	--------	--------	------

Total internal gains = $(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$

(73)m=	411.96	409.93	396.79	375.57	354.03	333.23	319.69	325.54	336.41	357.84	382.47	400.95	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g_ Table 6b	FF Table 6c	Gains (W)
North	0.9x	0.77	x 4.1	x 10.63	x 0.63	x 0.7 = 13.32
North	0.9x	0.77	x 2.24	x 10.63	x 0.63	x 0.7 = 7.28
North	0.9x	0.77	x 1.68	x 10.63	x 0.63	x 0.7 = 5.46
North	0.9x	0.77	x 4.1	x 20.32	x 0.63	x 0.7 = 25.46
North	0.9x	0.77	x 2.24	x 20.32	x 0.63	x 0.7 = 13.91

TER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	1.68	x	20.32	x	0.63	x	0.7	=	10.43	(74)
North	0.9x	0.77	x	4.1	x	34.53	x	0.63	x	0.7	=	43.27	(74)
North	0.9x	0.77	x	2.24	x	34.53	x	0.63	x	0.7	=	23.64	(74)
North	0.9x	0.77	x	1.68	x	34.53	x	0.63	x	0.7	=	17.73	(74)
North	0.9x	0.77	x	4.1	x	55.46	x	0.63	x	0.7	=	69.5	(74)
North	0.9x	0.77	x	2.24	x	55.46	x	0.63	x	0.7	=	37.97	(74)
North	0.9x	0.77	x	1.68	x	55.46	x	0.63	x	0.7	=	28.48	(74)
North	0.9x	0.77	x	4.1	x	74.72	x	0.63	x	0.7	=	93.62	(74)
North	0.9x	0.77	x	2.24	x	74.72	x	0.63	x	0.7	=	51.15	(74)
North	0.9x	0.77	x	1.68	x	74.72	x	0.63	x	0.7	=	38.36	(74)
North	0.9x	0.77	x	4.1	x	79.99	x	0.63	x	0.7	=	100.22	(74)
North	0.9x	0.77	x	2.24	x	79.99	x	0.63	x	0.7	=	54.76	(74)
North	0.9x	0.77	x	1.68	x	79.99	x	0.63	x	0.7	=	41.07	(74)
North	0.9x	0.77	x	4.1	x	74.68	x	0.63	x	0.7	=	93.57	(74)
North	0.9x	0.77	x	2.24	x	74.68	x	0.63	x	0.7	=	51.12	(74)
North	0.9x	0.77	x	1.68	x	74.68	x	0.63	x	0.7	=	38.34	(74)
North	0.9x	0.77	x	4.1	x	59.25	x	0.63	x	0.7	=	74.24	(74)
North	0.9x	0.77	x	2.24	x	59.25	x	0.63	x	0.7	=	40.56	(74)
North	0.9x	0.77	x	1.68	x	59.25	x	0.63	x	0.7	=	30.42	(74)
North	0.9x	0.77	x	4.1	x	41.52	x	0.63	x	0.7	=	52.02	(74)
North	0.9x	0.77	x	2.24	x	41.52	x	0.63	x	0.7	=	28.42	(74)
North	0.9x	0.77	x	1.68	x	41.52	x	0.63	x	0.7	=	21.32	(74)
North	0.9x	0.77	x	4.1	x	24.19	x	0.63	x	0.7	=	30.31	(74)
North	0.9x	0.77	x	2.24	x	24.19	x	0.63	x	0.7	=	16.56	(74)
North	0.9x	0.77	x	1.68	x	24.19	x	0.63	x	0.7	=	12.42	(74)
North	0.9x	0.77	x	4.1	x	13.12	x	0.63	x	0.7	=	16.44	(74)
North	0.9x	0.77	x	2.24	x	13.12	x	0.63	x	0.7	=	8.98	(74)
North	0.9x	0.77	x	1.68	x	13.12	x	0.63	x	0.7	=	6.73	(74)
North	0.9x	0.77	x	4.1	x	8.86	x	0.63	x	0.7	=	11.11	(74)
North	0.9x	0.77	x	2.24	x	8.86	x	0.63	x	0.7	=	6.07	(74)
North	0.9x	0.77	x	1.68	x	8.86	x	0.63	x	0.7	=	4.55	(74)
South	0.9x	0.77	x	2.24	x	46.75	x	0.63	x	0.7	=	32.01	(78)
South	0.9x	0.77	x	6.18	x	46.75	x	0.63	x	0.7	=	88.3	(78)
South	0.9x	0.77	x	1.71	x	46.75	x	0.63	x	0.7	=	24.43	(78)
South	0.9x	0.77	x	2.24	x	76.57	x	0.63	x	0.7	=	52.42	(78)
South	0.9x	0.77	x	6.18	x	76.57	x	0.63	x	0.7	=	144.61	(78)
South	0.9x	0.77	x	1.71	x	76.57	x	0.63	x	0.7	=	40.01	(78)
South	0.9x	0.77	x	2.24	x	97.53	x	0.63	x	0.7	=	66.77	(78)
South	0.9x	0.77	x	6.18	x	97.53	x	0.63	x	0.7	=	184.21	(78)
South	0.9x	0.77	x	1.71	x	97.53	x	0.63	x	0.7	=	50.97	(78)
South	0.9x	0.77	x	2.24	x	110.23	x	0.63	x	0.7	=	75.46	(78)

TER WorkSheet: New dwelling design stage

South	0.9x	0.77	x	6.18	x	110.23	x	0.63	x	0.7	=	208.2	(78)
South	0.9x	0.77	x	1.71	x	110.23	x	0.63	x	0.7	=	57.61	(78)
South	0.9x	0.77	x	2.24	x	114.87	x	0.63	x	0.7	=	78.64	(78)
South	0.9x	0.77	x	6.18	x	114.87	x	0.63	x	0.7	=	216.96	(78)
South	0.9x	0.77	x	1.71	x	114.87	x	0.63	x	0.7	=	60.03	(78)
South	0.9x	0.77	x	2.24	x	110.55	x	0.63	x	0.7	=	75.68	(78)
South	0.9x	0.77	x	6.18	x	110.55	x	0.63	x	0.7	=	208.79	(78)
South	0.9x	0.77	x	1.71	x	110.55	x	0.63	x	0.7	=	57.77	(78)
South	0.9x	0.77	x	2.24	x	108.01	x	0.63	x	0.7	=	73.94	(78)
South	0.9x	0.77	x	6.18	x	108.01	x	0.63	x	0.7	=	204	(78)
South	0.9x	0.77	x	1.71	x	108.01	x	0.63	x	0.7	=	56.45	(78)
South	0.9x	0.77	x	2.24	x	104.89	x	0.63	x	0.7	=	71.81	(78)
South	0.9x	0.77	x	6.18	x	104.89	x	0.63	x	0.7	=	198.11	(78)
South	0.9x	0.77	x	1.71	x	104.89	x	0.63	x	0.7	=	54.82	(78)
South	0.9x	0.77	x	2.24	x	101.89	x	0.63	x	0.7	=	69.75	(78)
South	0.9x	0.77	x	6.18	x	101.89	x	0.63	x	0.7	=	192.43	(78)
South	0.9x	0.77	x	1.71	x	101.89	x	0.63	x	0.7	=	53.25	(78)
South	0.9x	0.77	x	2.24	x	82.59	x	0.63	x	0.7	=	56.54	(78)
South	0.9x	0.77	x	6.18	x	82.59	x	0.63	x	0.7	=	155.98	(78)
South	0.9x	0.77	x	1.71	x	82.59	x	0.63	x	0.7	=	43.16	(78)
South	0.9x	0.77	x	2.24	x	55.42	x	0.63	x	0.7	=	37.94	(78)
South	0.9x	0.77	x	6.18	x	55.42	x	0.63	x	0.7	=	104.67	(78)
South	0.9x	0.77	x	1.71	x	55.42	x	0.63	x	0.7	=	28.96	(78)
South	0.9x	0.77	x	2.24	x	40.4	x	0.63	x	0.7	=	27.66	(78)
South	0.9x	0.77	x	6.18	x	40.4	x	0.63	x	0.7	=	76.3	(78)
South	0.9x	0.77	x	1.71	x	40.4	x	0.63	x	0.7	=	21.11	(78)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m=

170.8	286.85	386.59	477.21	538.75	538.29	517.42	469.95	417.18	314.96	203.72	146.79
-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

 (83)

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=

582.76	696.78	783.37	852.78	892.78	871.52	837.11	795.49	753.59	672.8	586.19	547.74
--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------

 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m=	0.99	0.98	0.95	0.87	0.71	0.52	0.37	0.41	0.64	0.9	0.98	1	(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=

20.18	20.37	20.6	20.83	20.96	20.99	21	21	20.98	20.82	20.46	20.14
-------	-------	------	-------	-------	-------	----	----	-------	-------	-------	-------

 (87)

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=

20.12	20.13	20.13	20.14	20.14	20.15	20.15	20.15	20.15	20.14	20.14	20.13
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (88)

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=

0.99	0.98	0.94	0.83	0.66	0.45	0.3	0.33	0.56	0.87	0.98	0.99
------	------	------	------	------	------	-----	------	------	------	------	------

 (89)

TER WorkSheet: New dwelling design stage

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	19.04	19.31	19.64	19.96	20.1	20.15	20.15	20.15	20.14	19.95	19.45	18.99		(90)
	$fLA = \text{Living area} \div (4) =$												0.42	(91)

Mean internal temperature (for the whole dwelling) = $fLA \times T1 + (1 - fLA) \times T2$

(92)m=	19.52	19.76	20.04	20.32	20.46	20.5	20.51	20.51	20.49	20.31	19.87	19.48		(92)
--------	-------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	--	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.52	19.76	20.04	20.32	20.46	20.5	20.51	20.51	20.49	20.31	19.87	19.48		(93)
--------	-------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	--	------

8. Space heating requirement

Set T_i to the mean internal temperature obtained at step 11 of Table 9b, so that $T_{i,m} = (76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, h_m :

(94)m=	0.99	0.97	0.93	0.84	0.68	0.48	0.33	0.37	0.59	0.87	0.97	0.99		(94)
--------	------	------	------	------	------	------	------	------	------	------	------	------	--	------

Useful gains, $h_m G_m$, $W = (94)m \times (84)m$

(95)m=	576.67	677.94	732.42	717.66	605.18	416.61	277.26	290.6	447.18	587.08	571.32	543.52		(95)
--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2		(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	--	------

Heat loss rate for mean internal temperature, L_m , $W = [(39)m \times (93)m - (96)m]$

(97)m=	1122.41	1092.43	992.47	824.46	630.58	419.23	277.49	291.01	456.22	699.09	924.68	1112.66		(97)
--------	---------	---------	--------	--------	--------	--------	--------	--------	--------	--------	--------	---------	--	------

Space heating requirement for each month, $kWh/month = 0.024 \times [(97)m - (95)m] \times (41)m$

(98)m=	406.03	278.54	193.48	76.89	18.9	0	0	0	0	83.34	254.43	423.44	Total per year (kWh/year) = Sum(98) _{1...5,9...12} =	1735.04	(98)
--------	--------	--------	--------	-------	------	---	---	---	---	-------	--------	--------	---	---------	------

Space heating requirement in $kWh/m^2/year$

													22.42	(99)
--	--	--	--	--	--	--	--	--	--	--	--	--	-------	------

9a. Energy requirements – Individual heating systems including micro-CHP

Space heating:

Fraction of space heat from secondary/supplementary system

	0	(201)
--	---	-------

Fraction of space heat from main system(s)

(202) = 1 - (201) =	
---------------------	--

Fraction of total heating from main system 1

(204) = (202) $\times [1 - (203)] =$	
--------------------------------------	--

Efficiency of main space heating system 1

93.5	(206)
------	-------

Efficiency of secondary/supplementary heating system, %

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	--	----------

Space heating requirement (calculated above)

406.03	278.54	193.48	76.89	18.9	0	0	0	0	83.34	254.43	423.44	
--------	--------	--------	-------	------	---	---	---	---	-------	--------	--------	--

$$(211)m = \{[(98)m \times (204)]\} \times 100 \div (206) \quad (211)$$

434.26	297.9	206.93	82.24	20.22	0	0	0	0	89.13	272.11	452.88	
--------	-------	--------	-------	-------	---	---	---	---	-------	--------	--------	--

$$\text{Total (kWh/year)} = \text{Sum}(211)_{1...5,10...12} = \quad 1855.66 \quad (211)$$

Space heating fuel (secondary), $kWh/month$

$$= \{[(98)m \times (201)]\} \times 100 \div (208)$$

(215)m=	0	0	0	0	0	0	0	0	0	0	0	0	
---------	---	---	---	---	---	---	---	---	---	---	---	---	--

$$\text{Total (kWh/year)} = \text{Sum}(215)_{1...5,10...12} = \quad 0 \quad (215)$$

Water heating

Output from water heater (calculated above)

195.82	172.6	181.27	162.51	159.26	142.31	136.68	149.97	149.7	168.51	178.17	191.11	
--------	-------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--

Efficiency of water heater

												79.8	(216)
--	--	--	--	--	--	--	--	--	--	--	--	------	-------

TER WorkSheet: New dwelling design stage

(217)m =	86.72	86.08	84.99	82.95	80.81	79.8	79.8	79.8	83.05	85.76	86.88	(217)
----------	-------	-------	-------	-------	-------	------	------	------	-------	-------	-------	-------

Fuel for water heating, kWh/month

$$(219)m = (64)m \times 100 \div (217)m$$

(219)m =	225.81	200.5	213.29	195.91	197.07	178.33	171.28	187.93	187.6	202.9	207.75	219.98	Total = Sum(219a) _{1...12} = 2388.36 (219)
----------	--------	-------	--------	--------	--------	--------	--------	--------	-------	-------	--------	--------	---

Annual totals

Space heating fuel used, main system 1

kWh/year

1855.66

Water heating fuel used

2388.36

Electricity for pumps, fans and electric keep-hot

central heating pump:

30

(230c)

boiler with a fan-assisted flue

45

(230e)

Total electricity for the above, kWh/year

sum of (230a)...(230g) =

75

(231)

Electricity for lighting

336.8

(232)

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year	
Space heating (main system 1)	(211) x	0.216	= 400.82	(261)
Space heating (secondary)	(215) x	0.519	= 0	(263)
Water heating	(219) x	0.216	= 515.88	(264)
Space and water heating	(261) + (262) + (263) + (264) =		916.71	(265)
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	= 38.93	(267)
Electricity for lighting	(232) x	0.519	= 174.8	(268)
Total CO2, kg/year		sum of (265)...(271) =	1130.43	(272)

TER =

14.61

(273)

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 210 - Be Lean			
Address :	AC 210, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	94.7 (1a)	x (2a)	2.6 = 246.22 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	94.7 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	246.22 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour	
Number of chimneys	0	+	0	+	0	x 40 = 0 (6a)
Number of open flues	0	+	0	+	0	x 20 = 0 (6b)
Number of intermittent fans						x 10 = 0 (7a)
Number of passive vents						x 10 = 0 (7b)
Number of flueless gas fires						x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 0 ÷ (5) = 0 (8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] =

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) =

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

(20) = 1 - [0.075 x (19)] =

Infiltration rate incorporating shelter factor

(21) = (18) x (20) =

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

DER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.12	0.12	0.11	0.1	0.1	0.09	0.09	0.09	0.09	0.1	0.1	0.11
------	------	------	-----	-----	------	------	------	------	-----	-----	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5

(23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5

(23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5

(23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0.24	0.23	0.23	0.22	0.22	0.21	0.21	0.2	0.21	0.22	0.22	0.23
---------	------	------	------	------	------	------	------	-----	------	------	------	------

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.24	0.23	0.23	0.22	0.22	0.21	0.21	0.2	0.21	0.22	0.22	0.23
--------	------	------	------	------	------	------	------	-----	------	------	------	------

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Windows Type 1			2.24	x1/[1/(1.4)+ 0.04] =	2.97		(27)
Windows Type 2			2.71	x1/[1/(1.4)+ 0.04] =	3.59		(27)
Windows Type 3			6.73	x1/[1/(1.4)+ 0.04] =	8.92		(27)
Windows Type 4			2.24	x1/[1/(1.4)+ 0.04] =	2.97		(27)
Windows Type 5			1.5	x1/[1/(1.4)+ 0.04] =	1.99		(27)
Windows Type 6			1.65	x1/[1/(1.4)+ 0.04] =	2.19		(27)
Windows Type 7			1.68	x1/[1/(1.4)+ 0.04] =	2.23		(27)
Windows Type 8			2.71	x1/[1/(1.4)+ 0.04] =	3.59		(27)
Windows Type 9			2.71	x1/[1/(1.4)+ 0.04] =	3.59		(27)
Windows Type 10			2.71	x1/[1/(1.4)+ 0.04] =	3.59		(27)
Windows Type 11			4.1	x1/[1/(1.4)+ 0.04] =	5.44		(27)
Windows Type 12			1.5	x1/[1/(1.4)+ 0.04] =	1.99		(27)
Walls	79.14	32.48	46.66	x 0.12 =	5.6		(29)
Total area of elements, m ²			79.14				(31)
Party wall			22.31	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U)

(26)...(30) + (32) =

48.66

(33)

Heat capacity Cm = S(A x k)

((28)...(30) + (32) + (32a)...(32e) =

0

(34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K

Indicative Value: Medium

250

(35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f

DER WorkSheet: New dwelling design stage

can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K

13.33

(36)

if details of thermal bridging are not known (36) = $0.05 \times (31)$

Total fabric heat loss

(33) + (36) =

61.99

(37)

Ventilation heat loss calculated monthly

(38)m = $0.33 \times (25)m \times (5)$

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m= 19.13	18.94	18.75	17.81	17.63	16.69	16.69	16.5	17.06	17.63	18	18.38

(38)

Heat transfer coefficient, W/K

(39)m = (37) + (38)m

(39)m= 81.12	80.93	80.75	79.81	79.62	78.68	78.68	78.49	79.05	79.62	79.99	80.37
Average = Sum(39) _{1...12} /12=											79.76

(39)

Heat loss parameter (HLP), W/m²K

(40)m = (39)m ÷ (4)

(40)m= 0.86	0.85	0.85	0.84	0.84	0.83	0.83	0.83	0.83	0.84	0.84	0.85
Average = Sum(40) _{1...12} /12=											0.84

(40)

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(41)m= 31	28	31	30	31	30	31	31	30	31	30	31

(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

2.68

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd,\text{average} = (25 \times N) + 36$

97.96

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m= 107.76	103.84	99.92	96	92.09	88.17	88.17	92.09	96	99.92	103.84	107.76
Total = Sum(44) _{1...12} =											1175.55

(44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m= 159.8	139.77	144.23	125.74	120.65	104.11	96.47	110.71	112.03	130.56	142.51	154.76
Total = Sum(45) _{1...12} =											1541.34

(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m= 23.97	20.96	21.63	18.86	18.1	15.62	14.47	16.61	16.8	19.58	21.38	23.21
--------------	-------	-------	-------	------	-------	-------	-------	------	-------	-------	-------

(46)

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0

(48)

Temperature factor from Table 2b

0

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

110

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0.02

(51)

If community heating see section 4.3

Volume factor from Table 2a

1.03

(52)

Temperature factor from Table 2b

0.6

(53)

DER WorkSheet: New dwelling design stage

Energy lost from water storage, kWh/year $(47) \times (51) \times (52) \times (53) =$ 1.03 (54)
 Enter (50) or (54) in (55) 1.03 (55)

Water storage loss calculated for each month $((56)m = (55) \times (41)m$ (56)

(56)m= 32.01 28.92 32.01 30.98 32.01 30.98 32.01 32.01 30.98 32.01 30.98 32.01 (56)

If cylinder contains dedicated solar storage, (57)m = (56)m x [(50) – (H11)] ÷ (50), else (57)m = (56)m where (H11) is from Appendix H

(57)m= 32.01 28.92 32.01 30.98 32.01 30.98 32.01 32.01 30.98 32.01 30.98 32.01 (57)

Primary circuit loss (annual) from Table 3 0 (58)

Primary circuit loss calculated for each month (59)m = (58) ÷ 365 × (41)m

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat) (59)

(59)m= 23.26 21.01 23.26 22.51 23.26 22.51 23.26 23.26 22.51 23.26 22.51 23.26 (59)

Combi loss calculated for each month (61)m = (60) ÷ 365 × (41)m (61)

(61)m= 0 0 0 0 0 0 0 0 0 0 0 0 (61)

Total heat required for water heating calculated for each month (62)m = 0.85 × (45)m + (46)m + (57)m + (59)m + (61)m

(62)m= 215.08 189.69 199.5 179.23 175.93 157.61 151.75 165.98 165.52 185.83 196.01 210.04 (62)

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G) (63)

(63)m= 0 0 0 0 0 0 0 0 0 0 0 0 (63)

Output from water heater (64)

(64)m= 215.08 189.69 199.5 179.23 175.93 157.61 151.75 165.98 165.52 185.83 196.01 210.04 2192.18 (64)

Heat gains from water heating, kWh/month 0.25 [0.85 × (45)m + (61)m] + 0.8 × [(46)m + (57)m + (59)m]

(65)m= 97.36 86.41 92.18 84.6 84.34 77.41 76.3 81.03 80.04 87.63 90.18 95.68 (65)

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts (66)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(66)m= 134.24	134.24	134.24	134.24	134.24	134.24	134.24	134.24	134.24	134.24	134.24	134.24

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5 (67)

(67)m= 22.06 19.59 15.94 12.06 9.02 7.61 8.23 10.69 14.35 18.22 21.27 22.67 (67)

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5 (68)

(68)m= 247.46 250.03 243.56 229.78 212.4 196.05 185.13 182.56 189.04 202.81 220.2 236.55 (68)

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5 (69)

(69)m= 36.42 36.42 36.42 36.42 36.42 36.42 36.42 36.42 36.42 36.42 36.42 36.42 (69)

Pumps and fans gains (Table 5a) (70)

(70)m= 0 0 0 0 0 0 0 0 0 0 0 0 (70)

Losses e.g. evaporation (negative values) (Table 5) (71)

(71)m= -107.39 -107.39 -107.39 -107.39 -107.39 -107.39 -107.39 -107.39 -107.39 -107.39 -107.39 -107.39 (71)

Water heating gains (Table 5) (72)

(72)m= 130.86 128.59 123.89 117.5 113.36 107.52 102.55 108.91 111.17 117.78 125.25 128.6 (72)

Total internal gains = $(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m$ (73)

(73)m= 463.65 461.49 446.66 422.62 398.04 374.45 359.18 365.44 377.83 402.09 429.99 451.09 (73)

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

DER WorkSheet: New dwelling design stage

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g Table 6b	FF Table 6c	Gains (W)
North	0.9x 0.77	x 2.24	x 10.63	x 0.4	x 0.8	= 5.28 (74)
North	0.9x 0.77	x 2.71	x 10.63	x 0.4	x 0.8	= 6.39 (74)
North	0.9x 0.77	x 4.1	x 10.63	x 0.4	x 0.8	= 9.67 (74)
North	0.9x 0.77	x 1.5	x 10.63	x 0.4	x 0.8	= 3.54 (74)
North	0.9x 0.77	x 2.24	x 20.32	x 0.4	x 0.8	= 10.09 (74)
North	0.9x 0.77	x 2.71	x 20.32	x 0.4	x 0.8	= 12.21 (74)
North	0.9x 0.77	x 4.1	x 20.32	x 0.4	x 0.8	= 18.48 (74)
North	0.9x 0.77	x 1.5	x 20.32	x 0.4	x 0.8	= 6.76 (74)
North	0.9x 0.77	x 2.24	x 34.53	x 0.4	x 0.8	= 17.15 (74)
North	0.9x 0.77	x 2.71	x 34.53	x 0.4	x 0.8	= 20.75 (74)
North	0.9x 0.77	x 4.1	x 34.53	x 0.4	x 0.8	= 31.4 (74)
North	0.9x 0.77	x 1.5	x 34.53	x 0.4	x 0.8	= 11.49 (74)
North	0.9x 0.77	x 2.24	x 55.46	x 0.4	x 0.8	= 27.55 (74)
North	0.9x 0.77	x 2.71	x 55.46	x 0.4	x 0.8	= 33.33 (74)
North	0.9x 0.77	x 4.1	x 55.46	x 0.4	x 0.8	= 50.43 (74)
North	0.9x 0.77	x 1.5	x 55.46	x 0.4	x 0.8	= 18.45 (74)
North	0.9x 0.77	x 2.24	x 74.72	x 0.4	x 0.8	= 37.11 (74)
North	0.9x 0.77	x 2.71	x 74.72	x 0.4	x 0.8	= 44.9 (74)
North	0.9x 0.77	x 4.1	x 74.72	x 0.4	x 0.8	= 67.93 (74)
North	0.9x 0.77	x 1.5	x 74.72	x 0.4	x 0.8	= 24.85 (74)
North	0.9x 0.77	x 2.24	x 79.99	x 0.4	x 0.8	= 39.73 (74)
North	0.9x 0.77	x 2.71	x 79.99	x 0.4	x 0.8	= 48.07 (74)
North	0.9x 0.77	x 4.1	x 79.99	x 0.4	x 0.8	= 72.72 (74)
North	0.9x 0.77	x 1.5	x 79.99	x 0.4	x 0.8	= 26.61 (74)
North	0.9x 0.77	x 2.24	x 74.68	x 0.4	x 0.8	= 37.1 (74)
North	0.9x 0.77	x 2.71	x 74.68	x 0.4	x 0.8	= 44.88 (74)
North	0.9x 0.77	x 4.1	x 74.68	x 0.4	x 0.8	= 67.9 (74)
North	0.9x 0.77	x 1.5	x 74.68	x 0.4	x 0.8	= 24.84 (74)
North	0.9x 0.77	x 2.24	x 59.25	x 0.4	x 0.8	= 29.43 (74)
North	0.9x 0.77	x 2.71	x 59.25	x 0.4	x 0.8	= 35.61 (74)
North	0.9x 0.77	x 4.1	x 59.25	x 0.4	x 0.8	= 53.87 (74)
North	0.9x 0.77	x 1.5	x 59.25	x 0.4	x 0.8	= 19.71 (74)
North	0.9x 0.77	x 2.24	x 41.52	x 0.4	x 0.8	= 20.62 (74)
North	0.9x 0.77	x 2.71	x 41.52	x 0.4	x 0.8	= 24.95 (74)
North	0.9x 0.77	x 4.1	x 41.52	x 0.4	x 0.8	= 37.75 (74)
North	0.9x 0.77	x 1.5	x 41.52	x 0.4	x 0.8	= 13.81 (74)
North	0.9x 0.77	x 2.24	x 24.19	x 0.4	x 0.8	= 12.02 (74)
North	0.9x 0.77	x 2.71	x 24.19	x 0.4	x 0.8	= 14.54 (74)
North	0.9x 0.77	x 4.1	x 24.19	x 0.4	x 0.8	= 21.99 (74)

DER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	1.5	x	24.19	x	0.4	x	0.8	=	8.05	(74)
North	0.9x	0.77	x	2.24	x	13.12	x	0.4	x	0.8	=	6.52	(74)
North	0.9x	0.77	x	2.71	x	13.12	x	0.4	x	0.8	=	7.88	(74)
North	0.9x	0.77	x	4.1	x	13.12	x	0.4	x	0.8	=	11.93	(74)
North	0.9x	0.77	x	1.5	x	13.12	x	0.4	x	0.8	=	4.36	(74)
North	0.9x	0.77	x	2.24	x	8.86	x	0.4	x	0.8	=	4.4	(74)
North	0.9x	0.77	x	2.71	x	8.86	x	0.4	x	0.8	=	5.33	(74)
North	0.9x	0.77	x	4.1	x	8.86	x	0.4	x	0.8	=	8.06	(74)
North	0.9x	0.77	x	1.5	x	8.86	x	0.4	x	0.8	=	2.95	(74)
East	0.9x	0.77	x	2.71	x	19.64	x	0.4	x	0.8	=	11.8	(76)
East	0.9x	0.77	x	6.73	x	19.64	x	0.4	x	0.8	=	29.31	(76)
East	0.9x	0.77	x	2.71	x	19.64	x	0.4	x	0.8	=	11.8	(76)
East	0.9x	0.77	x	2.71	x	38.42	x	0.4	x	0.8	=	23.09	(76)
East	0.9x	0.77	x	6.73	x	38.42	x	0.4	x	0.8	=	57.34	(76)
East	0.9x	0.77	x	2.71	x	38.42	x	0.4	x	0.8	=	23.09	(76)
East	0.9x	0.77	x	2.71	x	63.27	x	0.4	x	0.8	=	38.03	(76)
East	0.9x	0.77	x	6.73	x	63.27	x	0.4	x	0.8	=	94.43	(76)
East	0.9x	0.77	x	2.71	x	63.27	x	0.4	x	0.8	=	38.03	(76)
East	0.9x	0.77	x	2.71	x	92.28	x	0.4	x	0.8	=	55.46	(76)
East	0.9x	0.77	x	6.73	x	92.28	x	0.4	x	0.8	=	137.72	(76)
East	0.9x	0.77	x	2.71	x	92.28	x	0.4	x	0.8	=	55.46	(76)
East	0.9x	0.77	x	2.71	x	113.09	x	0.4	x	0.8	=	67.97	(76)
East	0.9x	0.77	x	6.73	x	113.09	x	0.4	x	0.8	=	168.78	(76)
East	0.9x	0.77	x	2.71	x	113.09	x	0.4	x	0.8	=	67.97	(76)
East	0.9x	0.77	x	2.71	x	115.77	x	0.4	x	0.8	=	69.57	(76)
East	0.9x	0.77	x	6.73	x	115.77	x	0.4	x	0.8	=	172.78	(76)
East	0.9x	0.77	x	2.71	x	115.77	x	0.4	x	0.8	=	69.57	(76)
East	0.9x	0.77	x	2.71	x	110.22	x	0.4	x	0.8	=	66.24	(76)
East	0.9x	0.77	x	6.73	x	110.22	x	0.4	x	0.8	=	164.49	(76)
East	0.9x	0.77	x	2.71	x	110.22	x	0.4	x	0.8	=	66.24	(76)
East	0.9x	0.77	x	2.71	x	94.68	x	0.4	x	0.8	=	56.9	(76)
East	0.9x	0.77	x	6.73	x	94.68	x	0.4	x	0.8	=	141.3	(76)
East	0.9x	0.77	x	2.71	x	94.68	x	0.4	x	0.8	=	56.9	(76)
East	0.9x	0.77	x	2.71	x	73.59	x	0.4	x	0.8	=	44.22	(76)
East	0.9x	0.77	x	6.73	x	73.59	x	0.4	x	0.8	=	109.83	(76)
East	0.9x	0.77	x	2.71	x	73.59	x	0.4	x	0.8	=	44.22	(76)
East	0.9x	0.77	x	2.71	x	45.59	x	0.4	x	0.8	=	27.4	(76)
East	0.9x	0.77	x	6.73	x	45.59	x	0.4	x	0.8	=	68.04	(76)
East	0.9x	0.77	x	2.71	x	45.59	x	0.4	x	0.8	=	27.4	(76)
East	0.9x	0.77	x	2.71	x	24.49	x	0.4	x	0.8	=	14.72	(76)
East	0.9x	0.77	x	6.73	x	24.49	x	0.4	x	0.8	=	36.55	(76)

DER WorkSheet: New dwelling design stage

East	0.9x	0.77	x	2.71	x	24.49	x	0.4	x	0.8	=	14.72	(76)
East	0.9x	0.77	x	2.71	x	16.15	x	0.4	x	0.8	=	9.71	(76)
East	0.9x	0.77	x	6.73	x	16.15	x	0.4	x	0.8	=	24.1	(76)
East	0.9x	0.77	x	2.71	x	16.15	x	0.4	x	0.8	=	9.71	(76)
South	0.9x	0.77	x	2.24	x	46.75	x	0.4	x	0.8	=	23.22	(78)
South	0.9x	0.77	x	1.5	x	46.75	x	0.4	x	0.8	=	15.55	(78)
South	0.9x	0.77	x	1.65	x	46.75	x	0.4	x	0.8	=	17.11	(78)
South	0.9x	0.77	x	1.68	x	46.75	x	0.4	x	0.8	=	17.42	(78)
South	0.9x	0.77	x	2.71	x	46.75	x	0.4	x	0.8	=	28.1	(78)
South	0.9x	0.77	x	2.24	x	76.57	x	0.4	x	0.8	=	38.03	(78)
South	0.9x	0.77	x	1.5	x	76.57	x	0.4	x	0.8	=	25.47	(78)
South	0.9x	0.77	x	1.65	x	76.57	x	0.4	x	0.8	=	28.02	(78)
South	0.9x	0.77	x	1.68	x	76.57	x	0.4	x	0.8	=	28.53	(78)
South	0.9x	0.77	x	2.71	x	76.57	x	0.4	x	0.8	=	46.01	(78)
South	0.9x	0.77	x	2.24	x	97.53	x	0.4	x	0.8	=	48.45	(78)
South	0.9x	0.77	x	1.5	x	97.53	x	0.4	x	0.8	=	32.44	(78)
South	0.9x	0.77	x	1.65	x	97.53	x	0.4	x	0.8	=	35.69	(78)
South	0.9x	0.77	x	1.68	x	97.53	x	0.4	x	0.8	=	36.34	(78)
South	0.9x	0.77	x	2.71	x	97.53	x	0.4	x	0.8	=	58.61	(78)
South	0.9x	0.77	x	2.24	x	110.23	x	0.4	x	0.8	=	54.76	(78)
South	0.9x	0.77	x	1.5	x	110.23	x	0.4	x	0.8	=	36.67	(78)
South	0.9x	0.77	x	1.65	x	110.23	x	0.4	x	0.8	=	40.34	(78)
South	0.9x	0.77	x	1.68	x	110.23	x	0.4	x	0.8	=	41.07	(78)
South	0.9x	0.77	x	2.71	x	110.23	x	0.4	x	0.8	=	66.25	(78)
South	0.9x	0.77	x	2.24	x	114.87	x	0.4	x	0.8	=	57.06	(78)
South	0.9x	0.77	x	1.5	x	114.87	x	0.4	x	0.8	=	38.21	(78)
South	0.9x	0.77	x	1.65	x	114.87	x	0.4	x	0.8	=	42.03	(78)
South	0.9x	0.77	x	1.68	x	114.87	x	0.4	x	0.8	=	42.8	(78)
South	0.9x	0.77	x	2.71	x	114.87	x	0.4	x	0.8	=	69.03	(78)
South	0.9x	0.77	x	2.24	x	110.55	x	0.4	x	0.8	=	54.91	(78)
South	0.9x	0.77	x	1.5	x	110.55	x	0.4	x	0.8	=	36.77	(78)
South	0.9x	0.77	x	1.65	x	110.55	x	0.4	x	0.8	=	40.45	(78)
South	0.9x	0.77	x	1.68	x	110.55	x	0.4	x	0.8	=	41.19	(78)
South	0.9x	0.77	x	2.71	x	110.55	x	0.4	x	0.8	=	66.44	(78)
South	0.9x	0.77	x	2.24	x	108.01	x	0.4	x	0.8	=	53.65	(78)
South	0.9x	0.77	x	1.5	x	108.01	x	0.4	x	0.8	=	35.93	(78)
South	0.9x	0.77	x	1.65	x	108.01	x	0.4	x	0.8	=	39.52	(78)
South	0.9x	0.77	x	1.68	x	108.01	x	0.4	x	0.8	=	40.24	(78)
South	0.9x	0.77	x	2.71	x	108.01	x	0.4	x	0.8	=	64.91	(78)
South	0.9x	0.77	x	2.24	x	104.89	x	0.4	x	0.8	=	52.11	(78)
South	0.9x	0.77	x	1.5	x	104.89	x	0.4	x	0.8	=	34.89	(78)

DER WorkSheet: New dwelling design stage

South	0.9x	0.77	x	1.65	x	104.89	x	0.4	x	0.8	=	38.38	(78)
South	0.9x	0.77	x	1.68	x	104.89	x	0.4	x	0.8	=	39.08	(78)
South	0.9x	0.77	x	2.71	x	104.89	x	0.4	x	0.8	=	63.04	(78)
South	0.9x	0.77	x	2.24	x	101.89	x	0.4	x	0.8	=	50.61	(78)
South	0.9x	0.77	x	1.5	x	101.89	x	0.4	x	0.8	=	33.89	(78)
South	0.9x	0.77	x	1.65	x	101.89	x	0.4	x	0.8	=	37.28	(78)
South	0.9x	0.77	x	1.68	x	101.89	x	0.4	x	0.8	=	37.96	(78)
South	0.9x	0.77	x	2.71	x	101.89	x	0.4	x	0.8	=	61.23	(78)
South	0.9x	0.77	x	2.24	x	82.59	x	0.4	x	0.8	=	41.02	(78)
South	0.9x	0.77	x	1.5	x	82.59	x	0.4	x	0.8	=	27.47	(78)
South	0.9x	0.77	x	1.65	x	82.59	x	0.4	x	0.8	=	30.22	(78)
South	0.9x	0.77	x	1.68	x	82.59	x	0.4	x	0.8	=	30.77	(78)
South	0.9x	0.77	x	2.71	x	82.59	x	0.4	x	0.8	=	49.63	(78)
South	0.9x	0.77	x	2.24	x	55.42	x	0.4	x	0.8	=	27.53	(78)
South	0.9x	0.77	x	1.5	x	55.42	x	0.4	x	0.8	=	18.43	(78)
South	0.9x	0.77	x	1.65	x	55.42	x	0.4	x	0.8	=	20.28	(78)
South	0.9x	0.77	x	1.68	x	55.42	x	0.4	x	0.8	=	20.65	(78)
South	0.9x	0.77	x	2.71	x	55.42	x	0.4	x	0.8	=	33.3	(78)
South	0.9x	0.77	x	2.24	x	40.4	x	0.4	x	0.8	=	20.07	(78)
South	0.9x	0.77	x	1.5	x	40.4	x	0.4	x	0.8	=	13.44	(78)
South	0.9x	0.77	x	1.65	x	40.4	x	0.4	x	0.8	=	14.78	(78)
South	0.9x	0.77	x	1.68	x	40.4	x	0.4	x	0.8	=	15.05	(78)
South	0.9x	0.77	x	2.71	x	40.4	x	0.4	x	0.8	=	24.28	(78)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m=

179.19	317.12	462.8	617.48	728.65	738.82	705.94	621.2	516.38	358.54	216.86	151.87
--------	--------	-------	--------	--------	--------	--------	-------	--------	--------	--------	--------

 (83)

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m=

642.84	778.61	909.46	1040.1	1126.69	1113.27	1065.12	986.64	894.21	760.63	646.86	602.97
--------	--------	--------	--------	---------	---------	---------	--------	--------	--------	--------	--------

 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
(86)m= 1	0.98	0.95	0.83	0.64	0.45	0.32	0.37	0.6	0.9	0.99	1		(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=

20.25	20.44	20.68	20.89	20.98	21	21	21	20.99	20.85	20.5	20.21
-------	-------	-------	-------	-------	----	----	----	-------	-------	------	-------

 (87)

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=

20.2	20.21	20.21	20.22	20.22	20.23	20.23	20.23	20.22	20.22	20.21	20.21
------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (88)

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=

0.99	0.98	0.93	0.8	0.59	0.4	0.27	0.3	0.54	0.87	0.98	1
------	------	------	-----	------	-----	------	-----	------	------	------	---

 (89)

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=

19.21	19.48	19.81	20.1	20.2	20.23	20.23	20.23	20.22	20.06	19.58	19.16
-------	-------	-------	------	------	-------	-------	-------	-------	-------	-------	-------

 (90)

$$fLA = \text{Living area} \div (4) =$$

0.42

(91)

DER WorkSheet: New dwelling design stage

Mean internal temperature (for the whole dwelling) = $f_{LA} \times T_1 + (1 - f_{LA}) \times T_2$

(92)m=	19.64	19.88	20.17	20.43	20.53	20.55	20.55	20.55	20.54	20.39	19.96	19.6	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.64	19.88	20.17	20.43	20.53	20.55	20.55	20.55	20.54	20.39	19.96	19.6	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------	------

8. Space heating requirement

Set T_i to the mean internal temperature obtained at step 11 of Table 9b, so that $T_{i,m} = (76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, h_m :

(94)m=	0.99	0.98	0.93	0.81	0.61	0.42	0.29	0.33	0.56	0.88	0.98	1	(94)
--------	------	------	------	------	------	------	------	------	------	------	------	---	------

Useful gains, $h_m G_m$, $W = (94)m \times (84)m$

(95)m=	638.29	761.72	849.09	840.65	690.21	467.07	310.65	325.59	503.53	667.12	634.62	599.97	(95)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, L_m , $W = [(39)m \times [(93)m - (96)m]]$

(97)m=	1244.54	1212.19	1104.05	920.5	702.84	467.99	310.72	325.74	509.1	779.31	1029.08	1237.51	(97)
--------	---------	---------	---------	-------	--------	--------	--------	--------	-------	--------	---------	---------	------

Space heating requirement for each month, kWh/month = $0.024 \times [(97)m - (95)m] \times (41)m$

(98)m=	451.05	302.72	189.69	57.49	9.4	0	0	0	83.47	284.01	474.33	
--------	--------	--------	--------	-------	-----	---	---	---	-------	--------	--------	--

Total per year (kWh/year) = Sum(98)_{1...5,9...12} = 1852.16 (98)

Space heating requirement in kWh/m²/year

19.56 (99)

9b. Energy requirements – Community heating scheme

This part is used for space heating, space cooling or water heating provided by a community scheme.

Fraction of space heat from secondary/supplementary heating (Table 11) '0' if none

0 (301)

Fraction of space heat from community system 1 – (301) =

1 (302)

The community scheme may obtain heat from several sources. The procedure allows for CHP and up to four other heat sources; the latter includes boilers, heat pumps, geothermal and waste heat from power stations. See Appendix C.

Fraction of heat from Community boilers

1 (303a)

Fraction of total space heat from Community boilers

(302) x (303a) =

1 (304a)

Factor for control and charging method (Table 4c(3)) for community heating system

1 (305)

Distribution loss factor (Table 12c) for community heating system

1.1 (306)

Space heating

Annual space heating requirement

1852.16

Space heat from Community boilers

(98) x (304a) x (305) x (306) =

2037.38 (307a)

Efficiency of secondary/supplementary heating system in % (from Table 4a or Appendix E)

0 (308)

Space heating requirement from secondary/supplementary system

(98) x (301) x 100 ÷ (308) =

0 (309)

Water heating

Annual water heating requirement

2192.18

If DHW from community scheme:

Water heat from Community boilers

(64) x (303a) x (305) x (306) =

2411.39 (310a)

Electricity used for heat distribution

0.01 x [(307a)...(307e) + (310a)...(310e)] =

44.49 (313)

Cooling System Energy Efficiency Ratio

0 (314)

Space cooling (if there is a fixed cooling system, if not enter 0)

= (107) ÷ (314) =

0 (315)

DER WorkSheet: New dwelling design stage

Electricity for pumps and fans within dwelling (Table 4f):

mechanical ventilation - balanced, extract or positive input from outside

199.01

(330a)

warm air heating system fans

0

(330b)

pump for solar water heating

0

(330g)

Total electricity for the above, kWh/year

= (330a) + (330b) + (330g) =

199.01

(331)

Energy for lighting (calculated in Appendix L)

389.61

(332)

12b. CO₂ Emissions – Community heating scheme

	Energy kWh/year	Emission factor kg CO ₂ /kWh	Emissions kg CO ₂ /year
CO ₂ from other sources of space and water heating (not CHP)			
Efficiency of heat source 1 (%)	If there is CHP using two fuels repeat (363) to (366) for the second fuel	95	(367a)
CO ₂ associated with heat source 1	$[(307b)+(310b)] \times 100 \div (367b) \times$	0.22	= 1011.51 (367)
Electrical energy for heat distribution	$(313) \times$	0.52	= 23.09 (372)
Total CO ₂ associated with community systems	$(363) \dots (366) + (368) \dots (372)$		= 1034.6 (373)
CO ₂ associated with space heating (secondary)	$(309) \times$	0	= 0 (374)
CO ₂ associated with water from immersion heater or instantaneous heater	$(312) \times$	0.22	= 0 (375)
Total CO ₂ associated with space and water heating	$(373) + (374) + (375) =$		1034.6 (376)
CO ₂ associated with electricity for pumps and fans within dwelling	$(331) \times$	0.52	= 103.28 (378)
CO ₂ associated with electricity for lighting	$(332) \times$	0.52	= 202.21 (379)
Total CO₂, kg/year	sum of (376)...(382) =		1340.09 (383)
Dwelling CO₂ Emission Rate	$(383) \div (4) =$		14.15 (384)
EI rating (section 14)			87.15 (385)

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 210 - Be Lean			
Address :	AC 210, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	94.7 (1a)	x (2a)	= 246.22 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	94.7 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	246.22 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour	
Number of chimneys	0	+	0	+	0 = 0	x 40 = 0 (6a)
Number of open flues	0	+	0	+	0 = 0	x 20 = 0 (6b)
Number of intermittent fans					3 = 30	x 10 = 30 (7a)
Number of passive vents					0 = 0	x 10 = 0 (7b)
Number of flueless gas fires					0 = 0	x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =	30	÷ (5) = 0.12 (8)
<i>If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)</i>		
Number of storeys in the dwelling (ns)	0	(9)
Additional infiltration	0	[(9)-1]x0.1 = 0 (10)
Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction	0	0 (11)

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0	0 (12)
If no draught lobby, enter 0.05, else enter 0	0 (13)
Percentage of windows and doors draught stripped	0 (14)
Window infiltration	0.25 - [0.2 x (14) ÷ 100] = 0 (15)
Infiltration rate	(8) + (10) + (11) + (12) + (13) + (15) = 0 (16)
Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area	5 (17)
If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)	0.37 (18)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered	1 (19)
Shelter factor	(20) = 1 - [0.075 x (19)] = 0.92 (20)
Infiltration rate incorporating shelter factor	(21) = (18) x (20) = 0.34 (21)

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

TER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.44	0.43	0.42	0.38	0.37	0.33	0.33	0.32	0.34	0.37	0.39	0.4
------	------	------	------	------	------	------	------	------	------	------	-----

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0.6	0.59	0.59	0.57	0.57	0.55	0.55	0.55	0.56	0.57	0.57
---------	-----	------	------	------	------	------	------	------	------	------	------

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.6	0.59	0.59	0.57	0.57	0.55	0.55	0.55	0.56	0.57	0.57
--------	-----	------	------	------	------	------	------	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Windows Type 1			1.63	x1/[1/(1.4)+ 0.04] =	2.16		(27)
Windows Type 2			1.98	x1/[1/(1.4)+ 0.04] =	2.62		(27)
Windows Type 3			4.91	x1/[1/(1.4)+ 0.04] =	6.51		(27)
Windows Type 4			1.63	x1/[1/(1.4)+ 0.04] =	2.16		(27)
Windows Type 5			1.09	x1/[1/(1.4)+ 0.04] =	1.45		(27)
Windows Type 6			1.2	x1/[1/(1.4)+ 0.04] =	1.59		(27)
Windows Type 7			1.22	x1/[1/(1.4)+ 0.04] =	1.62		(27)
Windows Type 8			1.98	x1/[1/(1.4)+ 0.04] =	2.62		(27)
Windows Type 9			1.98	x1/[1/(1.4)+ 0.04] =	2.62		(27)
Windows Type 10			1.98	x1/[1/(1.4)+ 0.04] =	2.62		(27)
Windows Type 11			2.99	x1/[1/(1.4)+ 0.04] =	3.96		(27)
Windows Type 12			1.09	x1/[1/(1.4)+ 0.04] =	1.45		(27)
Walls	79.14	23.68	55.46	x 0.18 =	9.98		(29)
Total area of elements, m ²			79.14				(31)
Party wall			22.31	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[1/(U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U)

(26)...(30) + (32) =

41.38 (33)

Heat capacity Cm = S(A x k)

((28)...(30) + (32) + (32a)...(32e) =

0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K

Indicative Value: Medium

250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f

TER WorkSheet: New dwelling design stage

can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K

8.94

(36)

if details of thermal bridging are not known (36) = $0.05 \times (31)$

Total fabric heat loss

(33) + (36) =

50.31

(37)

Ventilation heat loss calculated monthly

(38)m = $0.33 \times (25)m \times (5)$

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m= 48.44	48.14	47.84	46.44	46.18	44.96	44.96	44.74	45.43	46.18	46.71	47.26

(38)

Heat transfer coefficient, W/K

(39)m = (37) + (38)m

(39)m= 98.75	98.45	98.15	96.76	96.49	95.28	95.28	95.05	95.75	96.49	97.02	97.58
Average = Sum(39) _{1...12} /12=											96.75

(39)

Heat loss parameter (HLP), W/m²K

(40)m = (39)m ÷ (4)

(40)m= 1.04	1.04	1.04	1.02	1.02	1.01	1.01	1	1.01	1.02	1.02	1.03
Average = Sum(40) _{1...12} /12=											1.02

(40)

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(41)m= 31	28	31	30	31	30	31	31	30	31	30	31

(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

2.68

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (TFA - 13.9)2)] + 0.0013 \times (TFA - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd,average = (25 \times N) + 36$

97.96

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m= 107.76	103.84	99.92	96	92.09	88.17	88.17	92.09	96	99.92	103.84	107.76
---------------	--------	-------	----	-------	-------	-------	-------	----	-------	--------	--------

Total = Sum(44)_{1...12} = 1175.55 (44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m= 159.8	139.77	144.23	125.74	120.65	104.11	96.47	110.71	112.03	130.56	142.51	154.76
--------------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------

Total = Sum(45)_{1...12} = 1541.34 (45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m= 23.97	20.96	21.63	18.86	18.1	15.62	14.47	16.61	16.8	19.58	21.38	23.21
--------------	-------	-------	-------	------	-------	-------	-------	------	-------	-------	-------

(46)

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

150

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

1.39

(48)

Temperature factor from Table 2b

0.54

(49)

Energy lost from water storage, kWh/year $(48) \times (49) =$

0.75

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0

(51)

If community heating see section 4.3

Volume factor from Table 2a

0

(52)

Temperature factor from Table 2b

0

(53)

TER WorkSheet: New dwelling design stage

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g Table 6b	FF Table 6c	Gains (W)
North	0.9x 0.77	x 1.63	x 10.63	x 0.63	x 0.7	= 5.3 (74)
North	0.9x 0.77	x 1.98	x 10.63	x 0.63	x 0.7	= 6.43 (74)
North	0.9x 0.77	x 2.99	x 10.63	x 0.63	x 0.7	= 9.72 (74)
North	0.9x 0.77	x 1.09	x 10.63	x 0.63	x 0.7	= 3.54 (74)
North	0.9x 0.77	x 1.63	x 20.32	x 0.63	x 0.7	= 10.12 (74)
North	0.9x 0.77	x 1.98	x 20.32	x 0.63	x 0.7	= 12.3 (74)
North	0.9x 0.77	x 2.99	x 20.32	x 0.63	x 0.7	= 18.57 (74)
North	0.9x 0.77	x 1.09	x 20.32	x 0.63	x 0.7	= 6.77 (74)
North	0.9x 0.77	x 1.63	x 34.53	x 0.63	x 0.7	= 17.2 (74)
North	0.9x 0.77	x 1.98	x 34.53	x 0.63	x 0.7	= 20.89 (74)
North	0.9x 0.77	x 2.99	x 34.53	x 0.63	x 0.7	= 31.55 (74)
North	0.9x 0.77	x 1.09	x 34.53	x 0.63	x 0.7	= 11.5 (74)
North	0.9x 0.77	x 1.63	x 55.46	x 0.63	x 0.7	= 27.63 (74)
North	0.9x 0.77	x 1.98	x 55.46	x 0.63	x 0.7	= 33.56 (74)
North	0.9x 0.77	x 2.99	x 55.46	x 0.63	x 0.7	= 50.68 (74)
North	0.9x 0.77	x 1.09	x 55.46	x 0.63	x 0.7	= 18.48 (74)
North	0.9x 0.77	x 1.63	x 74.72	x 0.63	x 0.7	= 37.22 (74)
North	0.9x 0.77	x 1.98	x 74.72	x 0.63	x 0.7	= 45.21 (74)
North	0.9x 0.77	x 2.99	x 74.72	x 0.63	x 0.7	= 68.27 (74)
North	0.9x 0.77	x 1.09	x 74.72	x 0.63	x 0.7	= 24.89 (74)
North	0.9x 0.77	x 1.63	x 79.99	x 0.63	x 0.7	= 39.84 (74)
North	0.9x 0.77	x 1.98	x 79.99	x 0.63	x 0.7	= 48.4 (74)
North	0.9x 0.77	x 2.99	x 79.99	x 0.63	x 0.7	= 73.09 (74)
North	0.9x 0.77	x 1.09	x 79.99	x 0.63	x 0.7	= 26.64 (74)
North	0.9x 0.77	x 1.63	x 74.68	x 0.63	x 0.7	= 37.2 (74)
North	0.9x 0.77	x 1.98	x 74.68	x 0.63	x 0.7	= 45.19 (74)
North	0.9x 0.77	x 2.99	x 74.68	x 0.63	x 0.7	= 68.24 (74)
North	0.9x 0.77	x 1.09	x 74.68	x 0.63	x 0.7	= 24.88 (74)
North	0.9x 0.77	x 1.63	x 59.25	x 0.63	x 0.7	= 29.51 (74)
North	0.9x 0.77	x 1.98	x 59.25	x 0.63	x 0.7	= 35.85 (74)
North	0.9x 0.77	x 2.99	x 59.25	x 0.63	x 0.7	= 54.14 (74)
North	0.9x 0.77	x 1.09	x 59.25	x 0.63	x 0.7	= 19.74 (74)
North	0.9x 0.77	x 1.63	x 41.52	x 0.63	x 0.7	= 20.68 (74)
North	0.9x 0.77	x 1.98	x 41.52	x 0.63	x 0.7	= 25.12 (74)
North	0.9x 0.77	x 2.99	x 41.52	x 0.63	x 0.7	= 37.94 (74)
North	0.9x 0.77	x 1.09	x 41.52	x 0.63	x 0.7	= 13.83 (74)
North	0.9x 0.77	x 1.63	x 24.19	x 0.63	x 0.7	= 12.05 (74)
North	0.9x 0.77	x 1.98	x 24.19	x 0.63	x 0.7	= 14.64 (74)
North	0.9x 0.77	x 2.99	x 24.19	x 0.63	x 0.7	= 22.1 (74)

TER WorkSheet: New dwelling design stage

North	0.9x	0.77	x	1.09	x	24.19	x	0.63	x	0.7	=	8.06	(74)
North	0.9x	0.77	x	1.63	x	13.12	x	0.63	x	0.7	=	6.53	(74)
North	0.9x	0.77	x	1.98	x	13.12	x	0.63	x	0.7	=	7.94	(74)
North	0.9x	0.77	x	2.99	x	13.12	x	0.63	x	0.7	=	11.99	(74)
North	0.9x	0.77	x	1.09	x	13.12	x	0.63	x	0.7	=	4.37	(74)
North	0.9x	0.77	x	1.63	x	8.86	x	0.63	x	0.7	=	4.42	(74)
North	0.9x	0.77	x	1.98	x	8.86	x	0.63	x	0.7	=	5.36	(74)
North	0.9x	0.77	x	2.99	x	8.86	x	0.63	x	0.7	=	8.1	(74)
North	0.9x	0.77	x	1.09	x	8.86	x	0.63	x	0.7	=	2.95	(74)
East	0.9x	0.77	x	1.98	x	19.64	x	0.63	x	0.7	=	11.88	(76)
East	0.9x	0.77	x	4.91	x	19.64	x	0.63	x	0.7	=	29.47	(76)
East	0.9x	0.77	x	1.98	x	19.64	x	0.63	x	0.7	=	11.88	(76)
East	0.9x	0.77	x	1.98	x	38.42	x	0.63	x	0.7	=	23.25	(76)
East	0.9x	0.77	x	4.91	x	38.42	x	0.63	x	0.7	=	57.65	(76)
East	0.9x	0.77	x	1.98	x	38.42	x	0.63	x	0.7	=	23.25	(76)
East	0.9x	0.77	x	1.98	x	63.27	x	0.63	x	0.7	=	38.29	(76)
East	0.9x	0.77	x	4.91	x	63.27	x	0.63	x	0.7	=	94.95	(76)
East	0.9x	0.77	x	1.98	x	63.27	x	0.63	x	0.7	=	38.29	(76)
East	0.9x	0.77	x	1.98	x	92.28	x	0.63	x	0.7	=	55.84	(76)
East	0.9x	0.77	x	4.91	x	92.28	x	0.63	x	0.7	=	138.47	(76)
East	0.9x	0.77	x	1.98	x	92.28	x	0.63	x	0.7	=	55.84	(76)
East	0.9x	0.77	x	1.98	x	113.09	x	0.63	x	0.7	=	68.43	(76)
East	0.9x	0.77	x	4.91	x	113.09	x	0.63	x	0.7	=	169.7	(76)
East	0.9x	0.77	x	1.98	x	113.09	x	0.63	x	0.7	=	68.43	(76)
East	0.9x	0.77	x	1.98	x	115.77	x	0.63	x	0.7	=	70.05	(76)
East	0.9x	0.77	x	4.91	x	115.77	x	0.63	x	0.7	=	173.72	(76)
East	0.9x	0.77	x	1.98	x	115.77	x	0.63	x	0.7	=	70.05	(76)
East	0.9x	0.77	x	1.98	x	110.22	x	0.63	x	0.7	=	66.69	(76)
East	0.9x	0.77	x	4.91	x	110.22	x	0.63	x	0.7	=	165.39	(76)
East	0.9x	0.77	x	1.98	x	110.22	x	0.63	x	0.7	=	66.69	(76)
East	0.9x	0.77	x	1.98	x	94.68	x	0.63	x	0.7	=	57.29	(76)
East	0.9x	0.77	x	4.91	x	94.68	x	0.63	x	0.7	=	142.07	(76)
East	0.9x	0.77	x	1.98	x	94.68	x	0.63	x	0.7	=	57.29	(76)
East	0.9x	0.77	x	1.98	x	73.59	x	0.63	x	0.7	=	44.53	(76)
East	0.9x	0.77	x	4.91	x	73.59	x	0.63	x	0.7	=	110.43	(76)
East	0.9x	0.77	x	1.98	x	73.59	x	0.63	x	0.7	=	44.53	(76)
East	0.9x	0.77	x	1.98	x	45.59	x	0.63	x	0.7	=	27.59	(76)
East	0.9x	0.77	x	4.91	x	45.59	x	0.63	x	0.7	=	68.41	(76)
East	0.9x	0.77	x	1.98	x	45.59	x	0.63	x	0.7	=	27.59	(76)
East	0.9x	0.77	x	1.98	x	24.49	x	0.63	x	0.7	=	14.82	(76)
East	0.9x	0.77	x	4.91	x	24.49	x	0.63	x	0.7	=	36.75	(76)

TER WorkSheet: New dwelling design stage

East	0.9x	0.77	x	1.98	x	24.49	x	0.63	x	0.7	=	14.82	(76)
East	0.9x	0.77	x	1.98	x	16.15	x	0.63	x	0.7	=	9.77	(76)
East	0.9x	0.77	x	4.91	x	16.15	x	0.63	x	0.7	=	24.24	(76)
East	0.9x	0.77	x	1.98	x	16.15	x	0.63	x	0.7	=	9.77	(76)
South	0.9x	0.77	x	1.63	x	46.75	x	0.63	x	0.7	=	23.29	(78)
South	0.9x	0.77	x	1.09	x	46.75	x	0.63	x	0.7	=	15.57	(78)
South	0.9x	0.77	x	1.2	x	46.75	x	0.63	x	0.7	=	17.15	(78)
South	0.9x	0.77	x	1.22	x	46.75	x	0.63	x	0.7	=	17.43	(78)
South	0.9x	0.77	x	1.98	x	46.75	x	0.63	x	0.7	=	28.29	(78)
South	0.9x	0.77	x	1.63	x	76.57	x	0.63	x	0.7	=	38.14	(78)
South	0.9x	0.77	x	1.09	x	76.57	x	0.63	x	0.7	=	25.51	(78)
South	0.9x	0.77	x	1.2	x	76.57	x	0.63	x	0.7	=	28.08	(78)
South	0.9x	0.77	x	1.22	x	76.57	x	0.63	x	0.7	=	28.55	(78)
South	0.9x	0.77	x	1.98	x	76.57	x	0.63	x	0.7	=	46.33	(78)
South	0.9x	0.77	x	1.63	x	97.53	x	0.63	x	0.7	=	48.59	(78)
South	0.9x	0.77	x	1.09	x	97.53	x	0.63	x	0.7	=	32.49	(78)
South	0.9x	0.77	x	1.2	x	97.53	x	0.63	x	0.7	=	35.77	(78)
South	0.9x	0.77	x	1.22	x	97.53	x	0.63	x	0.7	=	36.37	(78)
South	0.9x	0.77	x	1.98	x	97.53	x	0.63	x	0.7	=	59.02	(78)
South	0.9x	0.77	x	1.63	x	110.23	x	0.63	x	0.7	=	54.91	(78)
South	0.9x	0.77	x	1.09	x	110.23	x	0.63	x	0.7	=	36.72	(78)
South	0.9x	0.77	x	1.2	x	110.23	x	0.63	x	0.7	=	40.43	(78)
South	0.9x	0.77	x	1.22	x	110.23	x	0.63	x	0.7	=	41.1	(78)
South	0.9x	0.77	x	1.98	x	110.23	x	0.63	x	0.7	=	66.7	(78)
South	0.9x	0.77	x	1.63	x	114.87	x	0.63	x	0.7	=	57.22	(78)
South	0.9x	0.77	x	1.09	x	114.87	x	0.63	x	0.7	=	38.27	(78)
South	0.9x	0.77	x	1.2	x	114.87	x	0.63	x	0.7	=	42.13	(78)
South	0.9x	0.77	x	1.22	x	114.87	x	0.63	x	0.7	=	42.83	(78)
South	0.9x	0.77	x	1.98	x	114.87	x	0.63	x	0.7	=	69.51	(78)
South	0.9x	0.77	x	1.63	x	110.55	x	0.63	x	0.7	=	55.07	(78)
South	0.9x	0.77	x	1.09	x	110.55	x	0.63	x	0.7	=	36.83	(78)
South	0.9x	0.77	x	1.2	x	110.55	x	0.63	x	0.7	=	40.54	(78)
South	0.9x	0.77	x	1.22	x	110.55	x	0.63	x	0.7	=	41.22	(78)
South	0.9x	0.77	x	1.98	x	110.55	x	0.63	x	0.7	=	66.89	(78)
South	0.9x	0.77	x	1.63	x	108.01	x	0.63	x	0.7	=	53.81	(78)
South	0.9x	0.77	x	1.09	x	108.01	x	0.63	x	0.7	=	35.98	(78)
South	0.9x	0.77	x	1.2	x	108.01	x	0.63	x	0.7	=	39.61	(78)
South	0.9x	0.77	x	1.22	x	108.01	x	0.63	x	0.7	=	40.27	(78)
South	0.9x	0.77	x	1.98	x	108.01	x	0.63	x	0.7	=	65.36	(78)
South	0.9x	0.77	x	1.63	x	104.89	x	0.63	x	0.7	=	52.25	(78)
South	0.9x	0.77	x	1.09	x	104.89	x	0.63	x	0.7	=	34.94	(78)

TER WorkSheet: New dwelling design stage

South	0.9x	0.77	x	1.2	x	104.89	x	0.63	x	0.7	=	38.47	(78)
South	0.9x	0.77	x	1.22	x	104.89	x	0.63	x	0.7	=	39.11	(78)
South	0.9x	0.77	x	1.98	x	104.89	x	0.63	x	0.7	=	63.47	(78)
South	0.9x	0.77	x	1.63	x	101.89	x	0.63	x	0.7	=	50.75	(78)
South	0.9x	0.77	x	1.09	x	101.89	x	0.63	x	0.7	=	33.94	(78)
South	0.9x	0.77	x	1.2	x	101.89	x	0.63	x	0.7	=	37.37	(78)
South	0.9x	0.77	x	1.22	x	101.89	x	0.63	x	0.7	=	37.99	(78)
South	0.9x	0.77	x	1.98	x	101.89	x	0.63	x	0.7	=	61.65	(78)
South	0.9x	0.77	x	1.63	x	82.59	x	0.63	x	0.7	=	41.14	(78)
South	0.9x	0.77	x	1.09	x	82.59	x	0.63	x	0.7	=	27.51	(78)
South	0.9x	0.77	x	1.2	x	82.59	x	0.63	x	0.7	=	30.29	(78)
South	0.9x	0.77	x	1.22	x	82.59	x	0.63	x	0.7	=	30.79	(78)
South	0.9x	0.77	x	1.98	x	82.59	x	0.63	x	0.7	=	49.97	(78)
South	0.9x	0.77	x	1.63	x	55.42	x	0.63	x	0.7	=	27.61	(78)
South	0.9x	0.77	x	1.09	x	55.42	x	0.63	x	0.7	=	18.46	(78)
South	0.9x	0.77	x	1.2	x	55.42	x	0.63	x	0.7	=	20.32	(78)
South	0.9x	0.77	x	1.22	x	55.42	x	0.63	x	0.7	=	20.66	(78)
South	0.9x	0.77	x	1.98	x	55.42	x	0.63	x	0.7	=	33.53	(78)
South	0.9x	0.77	x	1.63	x	40.4	x	0.63	x	0.7	=	20.12	(78)
South	0.9x	0.77	x	1.09	x	40.4	x	0.63	x	0.7	=	13.46	(78)
South	0.9x	0.77	x	1.2	x	40.4	x	0.63	x	0.7	=	14.82	(78)
South	0.9x	0.77	x	1.22	x	40.4	x	0.63	x	0.7	=	15.06	(78)
South	0.9x	0.77	x	1.98	x	40.4	x	0.63	x	0.7	=	24.45	(78)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

(83)m =	179.96	318.52	464.9	620.37	732.12	742.36	709.31	624.13	518.76	360.14	217.8	152.52	(83)
---------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	-------	--------	------

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m =	637.28	773.67	905.23	1036.66	1123.83	1110.47	1062.16	983.24	890.25	755.89	641.46	597.28	(84)
---------	--------	--------	--------	---------	---------	---------	---------	--------	--------	--------	--------	--------	------

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
(86)m =	1	0.99	0.97	0.89	0.74	0.54	0.39	0.44	0.7	0.94	0.99	1	(86)	

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m =	19.97	20.17	20.45	20.75	20.93	20.99	21	21	20.96	20.7	20.28	19.94	(87)
---------	-------	-------	-------	-------	-------	-------	----	----	-------	------	-------	-------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m =	20.05	20.05	20.05	20.07	20.07	20.08	20.08	20.08	20.07	20.07	20.06	20.06	(88)
---------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m =	1	0.99	0.96	0.86	0.68	0.47	0.31	0.36	0.62	0.92	0.99	1	(89)
---------	---	------	------	------	------	------	------	------	------	------	------	---	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m =	18.68	18.97	19.37	19.79	20.01	20.07	20.08	20.08	20.05	19.74	19.14	18.64	(90)
---------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

$$fLA = \text{Living area} \div (4) =$$

0.42	(91)
------	------

TER WorkSheet: New dwelling design stage

Mean internal temperature (for the whole dwelling) = $f_{LA} \times T_1 + (1 - f_{LA}) \times T_2$

(92)m=	19.22	19.47	19.82	20.19	20.39	20.46	20.46	20.46	20.43	20.14	19.61	19.19	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.22	19.47	19.82	20.19	20.39	20.46	20.46	20.46	20.43	20.14	19.61	19.19	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set T_i to the mean internal temperature obtained at step 11 of Table 9b, so that $T_{i,m} = (76)m$ and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, h_m :

(94)m=	0.99	0.98	0.95	0.87	0.7	0.5	0.35	0.39	0.65	0.92	0.99	1	(94)
--------	------	------	------	------	-----	-----	------	------	------	------	------	---	------

Useful gains, $h_m G_m$, $W = (94)m \times (84)m$

(95)m=	633.48	761.15	864.04	900.03	789.47	551.92	367.31	384.88	581.35	693.3	632.36	594.69	(95)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, L_m , $W = [(39)m \times [(93)m - (96)m]]$

(97)m=	1473.6	1434.54	1307.01	1092.5	838.76	557.86	367.95	386.12	605.93	920.52	1213.89	1462.24	(97)
--------	--------	---------	---------	--------	--------	--------	--------	--------	--------	--------	---------	---------	------

Space heating requirement for each month, kWh/month = $0.024 \times [(97)m - (95)m] \times (41)m$

(98)m=	625.05	452.52	329.57	138.58	36.67	0	0	0	0	169.05	418.7	645.46
--------	--------	--------	--------	--------	-------	---	---	---	---	--------	-------	--------

Total per year (kWh/year) = Sum(98)_{1...5,9...12} = 2815.6 (98)

Space heating requirement in kWh/m²/year

29.73 (99)

9a. Energy requirements – Individual heating systems including micro-CHP)

Space heating:

Fraction of space heat from secondary/supplementary system

0 (201)

Fraction of space heat from main system(s)

(202) = 1 - (201) = 1 (202)

Fraction of total heating from main system 1

(204) = (202) × [1 - (203)] = 1 (204)

Efficiency of main space heating system 1

93.5 (206)

Efficiency of secondary/supplementary heating system, %

0 (208)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Space heating requirement (calculated above)

625.05	452.52	329.57	138.58	36.67	0	0	0	0	169.05	418.7	645.46
--------	--------	--------	--------	-------	---	---	---	---	--------	-------	--------

(211)m = $\{[(98)m \times (204)]\} \times 100 \div (206)$ (211)

668.5	483.98	352.49	148.21	39.22	0	0	0	0	180.8	447.81	690.33
-------	--------	--------	--------	-------	---	---	---	---	-------	--------	--------

Total (kWh/year) = Sum(211)_{1...5,10...12} = 3011.34 (211)

Space heating fuel (secondary), kWh/month

= $\{[(98)m \times (201)]\} \times 100 \div (208)$

(215)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

Total (kWh/year) = Sum(215)_{1...5,10...12} = 0 (215)

Water heating

Output from water heater (calculated above)

206.4	181.85	190.82	170.83	167.24	149.2	143.07	157.3	157.12	177.15	187.61	201.36
-------	--------	--------	--------	--------	-------	--------	-------	--------	--------	--------	--------

Efficiency of water heater

79.8 (216)

(217)m=	87.58	87.15	86.26	84.26	81.53	79.8	79.8	79.8	84.69	86.89	87.7
---------	-------	-------	-------	-------	-------	------	------	------	-------	-------	------

Fuel for water heating, kWh/month

(219)m = $(64)m \times 100 \div (217)m$

(219)m=	235.66	208.66	221.22	202.74	205.12	186.97	179.29	197.12	196.89	209.18	215.9	229.59
---------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------

Total = Sum(219a)_{1...12} = 2488.33 (219)

TER WorkSheet: New dwelling design stage

Annual totals	kWh/year	kWh/year
Space heating fuel used, main system 1		3011.34
Water heating fuel used		2488.33
Electricity for pumps, fans and electric keep-hot		
central heating pump:	30	(230c)
boiler with a fan-assisted flue	45	(230e)
Total electricity for the above, kWh/year	sum of (230a)...(230g) =	75 (231)
Electricity for lighting		389.61 (232)

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating (main system 1)	(211) x	0.216	= 650.45 (261)
Space heating (secondary)	(215) x	0.519	= 0 (263)
Water heating	(219) x	0.216	= 537.48 (264)
Space and water heating	(261) + (262) + (263) + (264) =		1187.93 (265)
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	= 38.93 (267)
Electricity for lighting	(232) x	0.519	= 202.21 (268)
Total CO2, kg/year	sum of (265)...(271) =		1429.06 (272)

TER = 15.09 (273)

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 410 - Be Lean			
Address :	AC 410, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	74.4 (1a)	x (2a)	2.6 = 193.44 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	74.4 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	193.44 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour	
Number of chimneys	0	+	0	+	0	x 40 = 0 (6a)
Number of open flues	0	+	0	+	0	x 20 = 0 (6b)
Number of intermittent fans						x 10 = 0 (7a)
Number of passive vents						x 10 = 0 (7b)
Number of flueless gas fires						x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =	0	÷ (5) = 0 (8)
If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)		
Number of storeys in the dwelling (ns)	0	(9)
Additional infiltration	[(9)-1]x0.1 = 0	(10)
Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction	0	(11)

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0	0 (12)
If no draught lobby, enter 0.05, else enter 0	0 (13)
Percentage of windows and doors draught stripped	0 (14)
Window infiltration	0.25 - [0.2 x (14) ÷ 100] = 0 (15)
Infiltration rate	(8) + (10) + (11) + (12) + (13) + (15) = 0 (16)
Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area	2 (17)
If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)	0.1 (18)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered	1 (19)
Shelter factor	(20) = 1 - [0.075 x (19)] = 0.92 (20)
Infiltration rate incorporating shelter factor	(21) = (18) x (20) = 0.09 (21)

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

DER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.12	0.12	0.11	0.1	0.1	0.09	0.09	0.09	0.09	0.1	0.1	0.11
------	------	------	-----	-----	------	------	------	------	-----	-----	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5

(23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5

(23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5

(23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0.24	0.23	0.23	0.22	0.22	0.21	0.21	0.2	0.21	0.22	0.22	0.23
---------	------	------	------	------	------	------	------	-----	------	------	------	------

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.24	0.23	0.23	0.22	0.22	0.21	0.21	0.2	0.21	0.22	0.22	0.23
--------	------	------	------	------	------	------	------	-----	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Windows Type 1			2.24	x1/[1/(1.4)+ 0.04] =	2.97		
Windows Type 2			2.71	x1/[1/(1.4)+ 0.04] =	3.59		
Windows Type 3			6.73	x1/[1/(1.4)+ 0.04] =	8.92		
Windows Type 4			2.24	x1/[1/(1.4)+ 0.04] =	2.97		
Windows Type 5			1.5	x1/[1/(1.4)+ 0.04] =	1.99		
Windows Type 6			2.71	x1/[1/(1.4)+ 0.04] =	3.59		
Windows Type 7			2.71	x1/[1/(1.4)+ 0.04] =	3.59		
Windows Type 8			2.71	x1/[1/(1.4)+ 0.04] =	3.59		
Windows Type 9			1.5	x1/[1/(1.4)+ 0.04] =	1.99		
Walls	66.82	25.05	41.77	x 0.12 =	5.01		
Roof	74.4	0	74.4	x 0.1 =	7.44		
Total area of elements, m ²			141.22				
Party wall			44.62	x 0 =	0		

(29)

(30)

(31)

(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 45.66 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K

11.37

(36)

DER WorkSheet: New dwelling design stage

if details of thermal bridging are not known (36) = $0.05 \times (31)$

Total fabric heat loss

(33) + (36) =

57.03

(37)

Ventilation heat loss calculated monthly

(38)m = $0.33 \times (25)m \times (5)$

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m= 15.03	14.88	14.73	14	13.85	13.11	13.11	12.96	13.41	13.85	14.14	14.44

(38)

Heat transfer coefficient, W/K

(39)m = (37) + (38)m

(39)m= 72.06	71.91	71.76	71.03	70.88	70.14	70.14	69.99	70.43	70.88	71.17	71.47
Average = Sum(39) _{1...12} /12=											70.99

(39)

Heat loss parameter (HLP), W/m²K

(40)m = (39)m ÷ (4)

(40)m= 0.97	0.97	0.96	0.95	0.95	0.94	0.94	0.94	0.95	0.95	0.96	0.96
Average = Sum(40) _{1...12} /12=											0.95

(40)

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(41)m= 31	28	31	30	31	30	31	31	30	31	30	31

(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

2.35

(42)

if TFA > 13.9, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)^2)] + 0.0013 \times (\text{TFA} - 13.9)$

if TFA £ 13.9, $N = 1$

Annual average hot water usage in litres per day $Vd,\text{average} = (25 \times N) + 36$

89.97

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month $Vd,m = \text{factor from Table 1c} \times (43)$

(44)m= 98.96	95.36	91.77	88.17	84.57	80.97	80.97	84.57	88.17	91.77	95.36	98.96
Total = Sum(44) _{1...12} =											1079.59

(44)

Energy content of hot water used - calculated monthly = $4.190 \times Vd,m \times nm \times DTm / 3600 \text{ kWh/month}$ (see Tables 1b, 1c, 1d)

(45)m= 146.76	128.36	132.45	115.47	110.8	95.61	88.6	101.67	102.88	119.9	130.88	142.13
Total = Sum(45) _{1...12} =											1415.52

(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m= 22.01	19.25	19.87	17.32	16.62	14.34	13.29	15.25	15.43	17.99	19.63	21.32
--------------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(46)

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0

(48)

Temperature factor from Table 2b

0

(49)

Energy lost from water storage, kWh/year

(48) x (49) =

110

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0.02

(51)

If community heating see section 4.3

Volume factor from Table 2a

1.03

(52)

Temperature factor from Table 2b

0.6

(53)

Energy lost from water storage, kWh/year

(47) x (51) x (52) x (53) =

1.03

(54)

Enter (50) or (54) in (55)

1.03

(55)

DER WorkSheet: New dwelling design stage

Water storage loss calculated for each month

$$((56)m = (55) \times (41)m)$$

(56)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01	(56)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

If cylinder contains dedicated solar storage, (57)m = (56)m x [(50) – (H11)] ÷ (50), else (57)m = (56)m where (H11) is from Appendix H

(57)m=	32.01	28.92	32.01	30.98	32.01	30.98	32.01	32.01	30.98	32.01	30.98	32.01	(57)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month (59)m = (58) ÷ 365 x (41)m

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26	(59)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Combi loss calculated for each month (61)m = (60) ÷ 365 x (41)m

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = 0.85 x (45)m + (46)m + (57)m + (59)m + (61)m

(62)m=	202.04	178.28	187.73	168.97	166.08	149.11	143.88	156.95	156.38	175.18	184.37	197.4	(62)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRS applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	202.04	178.28	187.73	168.97	166.08	149.11	143.88	156.95	156.38	175.18	184.37	197.4	Output from water heater (annual) 1...12	2066.36	(64)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--	---------	------

Heat gains from water heating, kWh/month 0.25 [0.85 x (45)m + (61)m] + 0.8 x [(46)m + (57)m + (59)m]

(65)m=	93.02	82.62	88.26	81.19	81.06	74.59	73.68	78.03	77	84.09	86.31	91.48	(65)
--------	-------	-------	-------	-------	-------	-------	-------	-------	----	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

(66)m=	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	(66)
(66)m=	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	18.48	16.42	13.35	10.11	7.56	6.38	6.89	8.96	12.03	15.27	17.82	19	(67)
--------	-------	-------	-------	-------	------	------	------	------	-------	-------	-------	----	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	207.34	209.49	204.07	192.53	177.96	164.26	155.12	152.96	158.39	169.93	184.5	198.19	(68)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	0	0	0	0	0	0	0	0	0	0	0	0	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	125.03	122.95	118.63	112.76	108.96	103.59	99.03	104.87	106.95	113.02	119.88	122.96	(72)
--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	------

Total internal gains = (66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m

(73)m=	409.07	407.08	394.27	373.62	352.69	332.46	319.26	325.02	335.58	356.44	380.42	398.37	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

DER WorkSheet: New dwelling design stage

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g Table 6b	FF Table 6c	Gains (W)
North	0.9x 0.77	x 2.24	x 10.63	x 0.4	x 0.8	= 5.28 (74)
North	0.9x 0.77	x 2.71	x 10.63	x 0.4	x 0.8	= 6.39 (74)
North	0.9x 0.77	x 1.5	x 10.63	x 0.4	x 0.8	= 3.54 (74)
North	0.9x 0.77	x 2.24	x 20.32	x 0.4	x 0.8	= 10.09 (74)
North	0.9x 0.77	x 2.71	x 20.32	x 0.4	x 0.8	= 12.21 (74)
North	0.9x 0.77	x 1.5	x 20.32	x 0.4	x 0.8	= 6.76 (74)
North	0.9x 0.77	x 2.24	x 34.53	x 0.4	x 0.8	= 17.15 (74)
North	0.9x 0.77	x 2.71	x 34.53	x 0.4	x 0.8	= 20.75 (74)
North	0.9x 0.77	x 1.5	x 34.53	x 0.4	x 0.8	= 11.49 (74)
North	0.9x 0.77	x 2.24	x 55.46	x 0.4	x 0.8	= 27.55 (74)
North	0.9x 0.77	x 2.71	x 55.46	x 0.4	x 0.8	= 33.33 (74)
North	0.9x 0.77	x 1.5	x 55.46	x 0.4	x 0.8	= 18.45 (74)
North	0.9x 0.77	x 2.24	x 74.72	x 0.4	x 0.8	= 37.11 (74)
North	0.9x 0.77	x 2.71	x 74.72	x 0.4	x 0.8	= 44.9 (74)
North	0.9x 0.77	x 1.5	x 74.72	x 0.4	x 0.8	= 24.85 (74)
North	0.9x 0.77	x 2.24	x 79.99	x 0.4	x 0.8	= 39.73 (74)
North	0.9x 0.77	x 2.71	x 79.99	x 0.4	x 0.8	= 48.07 (74)
North	0.9x 0.77	x 1.5	x 79.99	x 0.4	x 0.8	= 26.61 (74)
North	0.9x 0.77	x 2.24	x 74.68	x 0.4	x 0.8	= 37.1 (74)
North	0.9x 0.77	x 2.71	x 74.68	x 0.4	x 0.8	= 44.88 (74)
North	0.9x 0.77	x 1.5	x 74.68	x 0.4	x 0.8	= 24.84 (74)
North	0.9x 0.77	x 2.24	x 59.25	x 0.4	x 0.8	= 29.43 (74)
North	0.9x 0.77	x 2.71	x 59.25	x 0.4	x 0.8	= 35.61 (74)
North	0.9x 0.77	x 1.5	x 59.25	x 0.4	x 0.8	= 19.71 (74)
North	0.9x 0.77	x 2.24	x 41.52	x 0.4	x 0.8	= 20.62 (74)
North	0.9x 0.77	x 2.71	x 41.52	x 0.4	x 0.8	= 24.95 (74)
North	0.9x 0.77	x 1.5	x 41.52	x 0.4	x 0.8	= 13.81 (74)
North	0.9x 0.77	x 2.24	x 24.19	x 0.4	x 0.8	= 12.02 (74)
North	0.9x 0.77	x 2.71	x 24.19	x 0.4	x 0.8	= 14.54 (74)
North	0.9x 0.77	x 1.5	x 24.19	x 0.4	x 0.8	= 8.05 (74)
North	0.9x 0.77	x 2.24	x 13.12	x 0.4	x 0.8	= 6.52 (74)
North	0.9x 0.77	x 2.71	x 13.12	x 0.4	x 0.8	= 7.88 (74)
North	0.9x 0.77	x 1.5	x 13.12	x 0.4	x 0.8	= 4.36 (74)
North	0.9x 0.77	x 2.24	x 8.86	x 0.4	x 0.8	= 4.4 (74)
North	0.9x 0.77	x 2.71	x 8.86	x 0.4	x 0.8	= 5.33 (74)
North	0.9x 0.77	x 1.5	x 8.86	x 0.4	x 0.8	= 2.95 (74)
East	0.9x 0.77	x 2.71	x 19.64	x 0.4	x 0.8	= 11.8 (76)
East	0.9x 0.77	x 6.73	x 19.64	x 0.4	x 0.8	= 29.31 (76)
East	0.9x 0.77	x 2.71	x 19.64	x 0.4	x 0.8	= 11.8 (76)

DER WorkSheet: New dwelling design stage

East	0.9x	0.77	x	2.71	x	38.42	x	0.4	x	0.8	=	23.09	(76)
East	0.9x	0.77	x	6.73	x	38.42	x	0.4	x	0.8	=	57.34	(76)
East	0.9x	0.77	x	2.71	x	38.42	x	0.4	x	0.8	=	23.09	(76)
East	0.9x	0.77	x	2.71	x	63.27	x	0.4	x	0.8	=	38.03	(76)
East	0.9x	0.77	x	6.73	x	63.27	x	0.4	x	0.8	=	94.43	(76)
East	0.9x	0.77	x	2.71	x	63.27	x	0.4	x	0.8	=	38.03	(76)
East	0.9x	0.77	x	2.71	x	92.28	x	0.4	x	0.8	=	55.46	(76)
East	0.9x	0.77	x	6.73	x	92.28	x	0.4	x	0.8	=	137.72	(76)
East	0.9x	0.77	x	2.71	x	92.28	x	0.4	x	0.8	=	55.46	(76)
East	0.9x	0.77	x	2.71	x	113.09	x	0.4	x	0.8	=	67.97	(76)
East	0.9x	0.77	x	6.73	x	113.09	x	0.4	x	0.8	=	168.78	(76)
East	0.9x	0.77	x	2.71	x	113.09	x	0.4	x	0.8	=	67.97	(76)
East	0.9x	0.77	x	2.71	x	115.77	x	0.4	x	0.8	=	69.57	(76)
East	0.9x	0.77	x	6.73	x	115.77	x	0.4	x	0.8	=	172.78	(76)
East	0.9x	0.77	x	2.71	x	115.77	x	0.4	x	0.8	=	69.57	(76)
East	0.9x	0.77	x	2.71	x	110.22	x	0.4	x	0.8	=	66.24	(76)
East	0.9x	0.77	x	6.73	x	110.22	x	0.4	x	0.8	=	164.49	(76)
East	0.9x	0.77	x	2.71	x	110.22	x	0.4	x	0.8	=	66.24	(76)
East	0.9x	0.77	x	2.71	x	94.68	x	0.4	x	0.8	=	56.9	(76)
East	0.9x	0.77	x	6.73	x	94.68	x	0.4	x	0.8	=	141.3	(76)
East	0.9x	0.77	x	2.71	x	94.68	x	0.4	x	0.8	=	56.9	(76)
East	0.9x	0.77	x	2.71	x	73.59	x	0.4	x	0.8	=	44.22	(76)
East	0.9x	0.77	x	6.73	x	73.59	x	0.4	x	0.8	=	109.83	(76)
East	0.9x	0.77	x	2.71	x	73.59	x	0.4	x	0.8	=	44.22	(76)
East	0.9x	0.77	x	2.71	x	45.59	x	0.4	x	0.8	=	27.4	(76)
East	0.9x	0.77	x	6.73	x	45.59	x	0.4	x	0.8	=	68.04	(76)
East	0.9x	0.77	x	2.71	x	45.59	x	0.4	x	0.8	=	27.4	(76)
East	0.9x	0.77	x	2.71	x	24.49	x	0.4	x	0.8	=	14.72	(76)
East	0.9x	0.77	x	6.73	x	24.49	x	0.4	x	0.8	=	36.55	(76)
East	0.9x	0.77	x	2.71	x	24.49	x	0.4	x	0.8	=	14.72	(76)
East	0.9x	0.77	x	2.71	x	16.15	x	0.4	x	0.8	=	9.71	(76)
East	0.9x	0.77	x	6.73	x	16.15	x	0.4	x	0.8	=	24.1	(76)
East	0.9x	0.77	x	2.71	x	16.15	x	0.4	x	0.8	=	9.71	(76)
South	0.9x	0.77	x	2.24	x	46.75	x	0.4	x	0.8	=	23.22	(78)
South	0.9x	0.77	x	1.5	x	46.75	x	0.4	x	0.8	=	15.55	(78)
South	0.9x	0.77	x	2.71	x	46.75	x	0.4	x	0.8	=	28.1	(78)
South	0.9x	0.77	x	2.24	x	76.57	x	0.4	x	0.8	=	38.03	(78)
South	0.9x	0.77	x	1.5	x	76.57	x	0.4	x	0.8	=	25.47	(78)
South	0.9x	0.77	x	2.71	x	76.57	x	0.4	x	0.8	=	46.01	(78)
South	0.9x	0.77	x	2.24	x	97.53	x	0.4	x	0.8	=	48.45	(78)
South	0.9x	0.77	x	1.5	x	97.53	x	0.4	x	0.8	=	32.44	(78)

DER WorkSheet: New dwelling design stage

South	0.9x	0.77	x	2.71	x	97.53	x	0.4	x	0.8	=	58.61	(78)
South	0.9x	0.77	x	2.24	x	110.23	x	0.4	x	0.8	=	54.76	(78)
South	0.9x	0.77	x	1.5	x	110.23	x	0.4	x	0.8	=	36.67	(78)
South	0.9x	0.77	x	2.71	x	110.23	x	0.4	x	0.8	=	66.25	(78)
South	0.9x	0.77	x	2.24	x	114.87	x	0.4	x	0.8	=	57.06	(78)
South	0.9x	0.77	x	1.5	x	114.87	x	0.4	x	0.8	=	38.21	(78)
South	0.9x	0.77	x	2.71	x	114.87	x	0.4	x	0.8	=	69.03	(78)
South	0.9x	0.77	x	2.24	x	110.55	x	0.4	x	0.8	=	54.91	(78)
South	0.9x	0.77	x	1.5	x	110.55	x	0.4	x	0.8	=	36.77	(78)
South	0.9x	0.77	x	2.71	x	110.55	x	0.4	x	0.8	=	66.44	(78)
South	0.9x	0.77	x	2.24	x	108.01	x	0.4	x	0.8	=	53.65	(78)
South	0.9x	0.77	x	1.5	x	108.01	x	0.4	x	0.8	=	35.93	(78)
South	0.9x	0.77	x	2.71	x	108.01	x	0.4	x	0.8	=	64.91	(78)
South	0.9x	0.77	x	2.24	x	104.89	x	0.4	x	0.8	=	52.11	(78)
South	0.9x	0.77	x	1.5	x	104.89	x	0.4	x	0.8	=	34.89	(78)
South	0.9x	0.77	x	2.71	x	104.89	x	0.4	x	0.8	=	63.04	(78)
South	0.9x	0.77	x	2.24	x	101.89	x	0.4	x	0.8	=	50.61	(78)
South	0.9x	0.77	x	1.5	x	101.89	x	0.4	x	0.8	=	33.89	(78)
South	0.9x	0.77	x	2.71	x	101.89	x	0.4	x	0.8	=	61.23	(78)
South	0.9x	0.77	x	2.24	x	82.59	x	0.4	x	0.8	=	41.02	(78)
South	0.9x	0.77	x	1.5	x	82.59	x	0.4	x	0.8	=	27.47	(78)
South	0.9x	0.77	x	2.71	x	82.59	x	0.4	x	0.8	=	49.63	(78)
South	0.9x	0.77	x	2.24	x	55.42	x	0.4	x	0.8	=	27.53	(78)
South	0.9x	0.77	x	1.5	x	55.42	x	0.4	x	0.8	=	18.43	(78)
South	0.9x	0.77	x	2.71	x	55.42	x	0.4	x	0.8	=	33.3	(78)
South	0.9x	0.77	x	2.24	x	40.4	x	0.4	x	0.8	=	20.07	(78)
South	0.9x	0.77	x	1.5	x	40.4	x	0.4	x	0.8	=	13.44	(78)
South	0.9x	0.77	x	2.71	x	40.4	x	0.4	x	0.8	=	24.28	(78)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

$$(83)m = \boxed{135 \quad 242.1 \quad 359.38 \quad 485.65 \quad 575.89 \quad 584.46 \quad 558.28 \quad 489.87 \quad 403.39 \quad 275.56 \quad 164.01 \quad 113.98} \quad (83)$$

Total gains – internal and solar $(84)m = (73)m + (83)m$, watts

$$(84)m = \boxed{544.07 \quad 649.18 \quad 753.66 \quad 859.27 \quad 928.58 \quad 916.92 \quad 877.54 \quad 814.89 \quad 738.98 \quad 632 \quad 544.43 \quad 512.35} \quad (84)$$

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 ($^{\circ}\text{C}$)

21

(85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		(86)
(86)m=	0.99	0.98	0.95	0.85	0.68	0.49	0.35	0.39	0.64	0.91	0.99	1	

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

$$(87)m = \boxed{20.14 \quad 20.32 \quad 20.58 \quad 20.84 \quad 20.96 \quad 21 \quad 21 \quad 21 \quad 20.98 \quad 20.79 \quad 20.41 \quad 20.1} \quad (87)$$

Temperature during heating periods in rest of dwelling from Table 9, Th2 ($^{\circ}\text{C}$)

$$(88)m = \boxed{20.11 \quad 20.11 \quad 20.11 \quad 20.12 \quad 20.12 \quad 20.13 \quad 20.13 \quad 20.13 \quad 20.13 \quad 20.12 \quad 20.12 \quad 20.12} \quad (88)$$

DER WorkSheet: New dwelling design stage

Utilisation factor for gains for rest of dwelling, h_{2,m} (see Table 9a)

(89)m=	0.99	0.98	0.94	0.82	0.62	0.42	0.28	0.32	0.56	0.88	0.98	0.99		(89)
--------	------	------	------	------	------	------	------	------	------	------	------	------	--	------

Mean internal temperature in the rest of dwelling T₂ (follow steps 3 to 7 in Table 9c)

(90)m=	18.96	19.24	19.6	19.94	20.09	20.13	20.13	20.13	20.11	19.9	19.37	18.91		(90)
									fLA = Living area ÷ (4) =				0.4	(91)

Mean internal temperature (for the whole dwelling) = f_{LA} × T₁ + (1 – f_{LA}) × T₂

(92)m=	19.44	19.68	19.99	20.3	20.44	20.48	20.48	20.48	20.46	20.26	19.79	19.39		(92)
--------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	--	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	19.44	19.68	19.99	20.3	20.44	20.48	20.48	20.48	20.46	20.26	19.79	19.39		(93)
--------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	--	------

8. Space heating requirement

Set T_i to the mean internal temperature obtained at step 11 of Table 9b, so that T_{i,m}=(76)m and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, h_m:

(94)m=	0.99	0.98	0.94	0.83	0.65	0.45	0.31	0.35	0.59	0.89	0.98	0.99		(94)
--------	------	------	------	------	------	------	------	------	------	------	------	------	--	------

Useful gains, h_{mGm}, W = (94)m × (84)m

(95)m=	539.13	634.08	705.93	711.18	599.16	410.35	272.13	285.41	438.71	559.95	532.81	508.91		(95)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2		(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	--	------

Heat loss rate for mean internal temperature, L_m, W = [(39)m × [(93)m – (96)m]]

(97)m=	1090.82	1062.5	968.39	810.04	619.72	412.38	272.31	285.78	448.3	684.49	903.07	1085.8		(97)
--------	---------	--------	--------	--------	--------	--------	--------	--------	-------	--------	--------	--------	--	------

Space heating requirement for each month, kWh/month = 0.024 × [(97)m – (95)m] × (41)m

(98)m=	410.45	287.9	195.27	71.18	15.3	0	0	0	0	92.65	266.59	429.21	
--------	--------	-------	--------	-------	------	---	---	---	---	-------	--------	--------	--

Total per year (kWh/year) = Sum(98)_{1...5,9...12} = 1768.54 (98)

Space heating requirement in kWh/m²/year

23.77 (99)

9b. Energy requirements – Community heating scheme

This part is used for space heating, space cooling or water heating provided by a community scheme.

Fraction of space heat from secondary/supplementary heating (Table 11) '0' if none

0 (301)

Fraction of space heat from community system 1 – (301) =

1 (302)

The community scheme may obtain heat from several sources. The procedure allows for CHP and up to four other heat sources; the latter includes boilers, heat pumps, geothermal and waste heat from power stations. See Appendix C.

Fraction of heat from Community boilers

1 (303a)

Fraction of total space heat from Community boilers

(302) × (303a) =

1 (304a)

Factor for control and charging method (Table 4c(3)) for community heating system

1 (305)

Distribution loss factor (Table 12c) for community heating system

1.1 (306)

Space heating

Annual space heating requirement

1768.54

Space heat from Community boilers

(98) × (304a) × (305) × (306) =

1945.39 (307a)

Efficiency of secondary/supplementary heating system in % (from Table 4a or Appendix E)

0 (308)

Space heating requirement from secondary/supplementary system

(98) × (301) × 100 ÷ (308) =

0 (309)

DER WorkSheet: New dwelling design stage

Water heating

Annual water heating requirement

2066.36

If DHW from community scheme:

Water heat from Community boilers

$(64) \times (303a) \times (305) \times (306) =$ 2272.99 (310a)

Electricity used for heat distribution

$0.01 \times [(307a) \dots (307e) + (310a) \dots (310e)] =$ 42.18 (313)

Cooling System Energy Efficiency Ratio

0 (314)

Space cooling (if there is a fixed cooling system, if not enter 0)

$= (107) \div (314) =$ 0 (315)

Electricity for pumps and fans within dwelling (Table 4f):

mechanical ventilation - balanced, extract or positive input from outside

156.35 (330a)

warm air heating system fans

0 (330b)

pump for solar water heating

0 (330g)

Total electricity for the above, kWh/year

$= (330a) + (330b) + (330g) =$ 156.35 (331)

Energy for lighting (calculated in Appendix L)

326.44 (332)

12b. CO2 Emissions – Community heating scheme

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
CO2 from other sources of space and water heating (not CHP)			
Efficiency of heat source 1 (%)	If there is CHP using two fuels repeat (363) to (366) for the second fuel	95	(367a)
CO2 associated with heat source 1	$[(307b)+(310b)] \times 100 \div (367b) \times$	0.22	= 959.13 (367)
Electrical energy for heat distribution	$(313) \times$	0.52	= 21.89 (372)
Total CO2 associated with community systems	$(363) \dots (366) + (368) \dots (372)$		= 981.02 (373)
CO2 associated with space heating (secondary)	$(309) \times$	0	= 0 (374)
CO2 associated with water from immersion heater or instantaneous heater	$(312) \times$	0.22	= 0 (375)
Total CO2 associated with space and water heating	$(373) + (374) + (375) =$		= 981.02 (376)
CO2 associated with electricity for pumps and fans within dwelling	$(331) \times$	0.52	= 81.14 (378)
CO2 associated with electricity for lighting	$(332) \times$	0.52	= 169.42 (379)
Total CO2, kg/year	sum of (376)...(382) =		1231.59 (383)
Dwelling CO2 Emission Rate	$(383) \div (4) =$		16.55 (384)
EI rating (section 14)			86.18 (385)

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name:	John Simpson	Stroma Number:	STRO006273
Software Name:	Stroma FSAP 2012	Software Version:	Version: 1.0.5.8
Property Address: AC 410 - Be Lean			
Address :	AC 410, Aspen Court, Maitland Park Estate, London, NW3 2EH		

1. Overall dwelling dimensions:

	Area(m²)	Av. Height(m)	Volume(m³)
Ground floor	74.4 (1a)	x (2a)	2.6 = 193.44 (3a)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+....(1n)	74.4 (4)		
Dwelling volume		(3a)+(3b)+(3c)+(3d)+(3e)+....(3n) =	193.44 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total	m³ per hour	
Number of chimneys	0	+	0	+	0	x 40 = 0 (6a)
Number of open flues	0	+	0	+	0	x 20 = 0 (6b)
Number of intermittent fans					3	x 10 = 30 (7a)
Number of passive vents					0	x 10 = 0 (7b)
Number of flueless gas fires					0	x 40 = 0 (7c)

Air changes per hour

Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) = 30 ÷ (5) = 0.16 (8)

If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)

Number of storeys in the dwelling (ns)

Additional infiltration

Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction

if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35

If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0

If no draught lobby, enter 0.05, else enter 0

Percentage of windows and doors draught stripped

Window infiltration 0.25 - [0.2 x (14) ÷ 100] =

Infiltration rate (8) + (10) + (11) + (12) + (13) + (15) =

Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area

If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)

Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used

Number of sides sheltered

(20) = 1 - [0.075 x (19)] =

Infiltration rate incorporating shelter factor

(21) = (18) x (20) =

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

TER WorkSheet: New dwelling design stage

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

0.48	0.47	0.46	0.41	0.4	0.36	0.36	0.35	0.37	0.4	0.42	0.44
------	------	------	------	-----	------	------	------	------	-----	------	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) x Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) x [1 - (23c) ÷ 100]

(24a)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 x (23b), then (24c) = (23b); otherwise (24c) = (22b)m + 0.5 x (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0.61	0.61	0.61	0.58	0.58	0.56	0.56	0.56	0.57	0.58	0.59	0.6
---------	------	------	------	------	------	------	------	------	------	------	------	-----

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.61	0.61	0.61	0.58	0.58	0.56	0.56	0.56	0.57	0.58	0.59	0.6
--------	------	------	------	------	------	------	------	------	------	------	------	-----

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m ²)	Openings m ²	Net Area A ,m ²	U-value W/m ² K	A X U (W/K)	k-value kJ/m ² .K	A X k kJ/K
Windows Type 1			1.66	x1/[1/(1.4)+ 0.04] =	2.2		(27)
Windows Type 2			2.01	x1/[1/(1.4)+ 0.04] =	2.66		(27)
Windows Type 3			5	x1/[1/(1.4)+ 0.04] =	6.63		(27)
Windows Type 4			1.66	x1/[1/(1.4)+ 0.04] =	2.2		(27)
Windows Type 5			1.11	x1/[1/(1.4)+ 0.04] =	1.47		(27)
Windows Type 6			2.01	x1/[1/(1.4)+ 0.04] =	2.66		(27)
Windows Type 7			2.01	x1/[1/(1.4)+ 0.04] =	2.66		(27)
Windows Type 8			2.01	x1/[1/(1.4)+ 0.04] =	2.66		(27)
Windows Type 9			1.11	x1/[1/(1.4)+ 0.04] =	1.47		(27)
Walls	66.82	18.58	48.24	x 0.18 =	8.68		(29)
Roof	74.4	0	74.4	x 0.13 =	9.67		(30)
Total area of elements, m ²			141.22				(31)
Party wall			44.62	x 0 =	0		(32)

* for windows and roof windows, use effective window U-value calculated using formula $1/[(1/U\text{-value})+0.04]$ as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26)...(30) + (32) = 42.99 (33)

Heat capacity Cm = S(A x k) ((28)...(30) + (32) + (32a)...(32e) = 0 (34)

Thermal mass parameter (TMP = Cm ÷ TFA) in kJ/m²K Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : S (L x Y) calculated using Appendix K 8.05 (36)

TER WorkSheet: New dwelling design stage

if details of thermal bridging are not known (36) = 0.05 x (31)

Total fabric heat loss

$$(33) + (36) =$$

51.04

(37)

Ventilation heat loss calculated monthly

$$(38)m = 0.33 \times (25)m \times (5)$$

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(38)m= 39.2	38.92	38.64	37.34	37.1	35.96	35.96	35.75	36.4	37.1	37.59	38.1

(38)

Heat transfer coefficient, W/K

$$(39)m = (37) + (38)m$$

(39)m= 90.24	89.96	89.68	88.38	88.14	87	87	86.79	87.44	88.14	88.63	89.14
<i>Average = Sum(39)_{1...12} /12=</i>											88.38

(39)

Heat loss parameter (HLP), W/m²K

$$(40)m = (39)m \div (4)$$

(40)m= 1.21	1.21	1.21	1.19	1.18	1.17	1.17	1.17	1.18	1.18	1.19	1.2
<i>Average = Sum(40)_{1...12} /12=</i>											1.19

(40)

Number of days in month (Table 1a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(41)m= 31	28	31	30	31	30	31	31	30	31	30	31

(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

2.35

(42)

$$\text{if TFA} > 13.9, N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (\text{TFA} - 13.9)^2)] + 0.0013 \times (\text{TFA} - 13.9)$$

$$\text{if TFA} \leq 13.9, N = 1$$

Annual average hot water usage in litres per day Vd,average = (25 x N) + 36

89.97

(43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Hot water usage in litres per day for each month Vd,m = factor from Table 1c x (43)

(44)m= 98.96	95.36	91.77	88.17	84.57	80.97	80.97	84.57	88.17	91.77	95.36	98.96
<i>Total = Sum(44)_{1...12} =</i>											1079.59

(44)

Energy content of hot water used - calculated monthly = 4.190 x Vd,m x nm x DTm / 3600 kWh/month (see Tables 1b, 1c, 1d)

(45)m= 146.76	128.36	132.45	115.47	110.8	95.61	88.6	101.67	102.88	119.9	130.88	142.13
<i>Total = Sum(45)_{1...12} =</i>											1415.52

(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m= 22.01	19.25	19.87	17.32	16.62	14.34	13.29	15.25	15.43	17.99	19.63	21.32
--------------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(46)

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

150

(47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

1.39

(48)

Temperature factor from Table 2b

0.54

(49)

Energy lost from water storage, kWh/year

$$(48) \times (49) =$$

0.75

(50)

b) If manufacturer's declared cylinder loss factor is not known:

Hot water storage loss factor from Table 2 (kWh/litre/day)

0

(51)

If community heating see section 4.3

Volume factor from Table 2a

0

(52)

Temperature factor from Table 2b

0

(53)

Energy lost from water storage, kWh/year

$$(47) \times (51) \times (52) \times (53) =$$

0

(54)

Enter (50) or (54) in (55)

0.75

(55)

TER WorkSheet: New dwelling design stage

Water storage loss calculated for each month

$$((56)m = (55) \times (41)m)$$

(56)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	(56)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

If cylinder contains dedicated solar storage, (57)m = (56)m x [(50) – (H11)] ÷ (50), else (57)m = (56)m where (H11) is from Appendix H

(57)m=	23.33	21.07	23.33	22.58	23.33	22.58	23.33	23.33	22.58	23.33	22.58	23.33	(57)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month (59)m = (58) ÷ 365 x (41)m

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	23.26	21.01	23.26	22.51	23.26	22.51	23.26	23.26	22.51	23.26	22.51	23.26	(59)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Combi loss calculated for each month (61)m = (60) ÷ 365 x (41)m

(61)m=	0	0	0	0	0	0	0	0	0	0	0	0	(61)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Total heat required for water heating calculated for each month (62)m = 0.85 x (45)m + (46)m + (57)m + (59)m + (61)m

(62)m=	193.35	170.44	179.05	160.57	157.4	140.7	135.19	148.26	147.98	166.5	175.97	188.72	(62)
--------	--------	--------	--------	--------	-------	-------	--------	--------	--------	-------	--------	--------	------

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRS applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0	(63)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Output from water heater

(64)m=	193.35	170.44	179.05	160.57	157.4	140.7	135.19	148.26	147.98	166.5	175.97	188.72	Output from water heater (annual) 1...12	1964.13	(64)
--------	--------	--------	--------	--------	-------	-------	--------	--------	--------	-------	--------	--------	--	---------	------

Heat gains from water heating, kWh/month 0.25 [0.85 x (45)m + (61)m] + 0.8 x [(46)m + (57)m + (59)m]

(65)m=	86.07	76.35	81.32	74.47	74.12	67.86	66.74	71.08	70.28	77.14	79.59	84.53	(65)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(66)m=	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	117.4	(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	18.48	16.42	13.35	10.11	7.56	6.38	6.89	8.96	12.03	15.27	17.82	19	(67)
--------	-------	-------	-------	-------	------	------	------	------	-------	-------	-------	----	------

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	207.34	209.49	204.07	192.53	177.96	164.26	155.12	152.96	158.39	169.93	184.5	198.19	(68)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	-------	--------	------

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	34.74	(69)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Pumps and fans gains (Table 5a)

(70)m=	3	3	3	3	3	3	3	3	3	3	3	3	(70)
--------	---	---	---	---	---	---	---	---	---	---	---	---	------

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	-93.92	(71)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

Water heating gains (Table 5)

(72)m=	115.69	113.61	109.3	103.43	99.62	94.26	89.7	95.54	97.61	103.69	110.54	113.62	(72)
--------	--------	--------	-------	--------	-------	-------	------	-------	-------	--------	--------	--------	------

Total internal gains = (66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m

(73)m=	402.74	400.74	387.94	367.29	346.35	326.12	312.93	318.68	329.25	350.11	374.08	392.03	(73)
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	------

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

TER WorkSheet: New dwelling design stage

Orientation:	Access Factor Table 6d	Area m ²	Flux Table 6a	g Table 6b	FF Table 6c	Gains (W)
North	0.9x 0.77	x 1.66	x 10.63	x 0.63	x 0.7	= 5.39 (74)
North	0.9x 0.77	x 2.01	x 10.63	x 0.63	x 0.7	= 6.53 (74)
North	0.9x 0.77	x 1.11	x 10.63	x 0.63	x 0.7	= 3.61 (74)
North	0.9x 0.77	x 1.66	x 20.32	x 0.63	x 0.7	= 10.31 (74)
North	0.9x 0.77	x 2.01	x 20.32	x 0.63	x 0.7	= 12.48 (74)
North	0.9x 0.77	x 1.11	x 20.32	x 0.63	x 0.7	= 6.89 (74)
North	0.9x 0.77	x 1.66	x 34.53	x 0.63	x 0.7	= 17.52 (74)
North	0.9x 0.77	x 2.01	x 34.53	x 0.63	x 0.7	= 21.21 (74)
North	0.9x 0.77	x 1.11	x 34.53	x 0.63	x 0.7	= 11.71 (74)
North	0.9x 0.77	x 1.66	x 55.46	x 0.63	x 0.7	= 28.14 (74)
North	0.9x 0.77	x 2.01	x 55.46	x 0.63	x 0.7	= 34.07 (74)
North	0.9x 0.77	x 1.11	x 55.46	x 0.63	x 0.7	= 18.82 (74)
North	0.9x 0.77	x 1.66	x 74.72	x 0.63	x 0.7	= 37.9 (74)
North	0.9x 0.77	x 2.01	x 74.72	x 0.63	x 0.7	= 45.9 (74)
North	0.9x 0.77	x 1.11	x 74.72	x 0.63	x 0.7	= 25.35 (74)
North	0.9x 0.77	x 1.66	x 79.99	x 0.63	x 0.7	= 40.58 (74)
North	0.9x 0.77	x 2.01	x 79.99	x 0.63	x 0.7	= 49.13 (74)
North	0.9x 0.77	x 1.11	x 79.99	x 0.63	x 0.7	= 27.13 (74)
North	0.9x 0.77	x 1.66	x 74.68	x 0.63	x 0.7	= 37.88 (74)
North	0.9x 0.77	x 2.01	x 74.68	x 0.63	x 0.7	= 45.87 (74)
North	0.9x 0.77	x 1.11	x 74.68	x 0.63	x 0.7	= 25.33 (74)
North	0.9x 0.77	x 1.66	x 59.25	x 0.63	x 0.7	= 30.06 (74)
North	0.9x 0.77	x 2.01	x 59.25	x 0.63	x 0.7	= 36.39 (74)
North	0.9x 0.77	x 1.11	x 59.25	x 0.63	x 0.7	= 20.1 (74)
North	0.9x 0.77	x 1.66	x 41.52	x 0.63	x 0.7	= 21.06 (74)
North	0.9x 0.77	x 2.01	x 41.52	x 0.63	x 0.7	= 25.5 (74)
North	0.9x 0.77	x 1.11	x 41.52	x 0.63	x 0.7	= 14.08 (74)
North	0.9x 0.77	x 1.66	x 24.19	x 0.63	x 0.7	= 12.27 (74)
North	0.9x 0.77	x 2.01	x 24.19	x 0.63	x 0.7	= 14.86 (74)
North	0.9x 0.77	x 1.11	x 24.19	x 0.63	x 0.7	= 8.21 (74)
North	0.9x 0.77	x 1.66	x 13.12	x 0.63	x 0.7	= 6.65 (74)
North	0.9x 0.77	x 2.01	x 13.12	x 0.63	x 0.7	= 8.06 (74)
North	0.9x 0.77	x 1.11	x 13.12	x 0.63	x 0.7	= 4.45 (74)
North	0.9x 0.77	x 1.66	x 8.86	x 0.63	x 0.7	= 4.5 (74)
North	0.9x 0.77	x 2.01	x 8.86	x 0.63	x 0.7	= 5.45 (74)
North	0.9x 0.77	x 1.11	x 8.86	x 0.63	x 0.7	= 3.01 (74)
East	0.9x 0.77	x 2.01	x 19.64	x 0.63	x 0.7	= 12.06 (76)
East	0.9x 0.77	x 5	x 19.64	x 0.63	x 0.7	= 30.01 (76)
East	0.9x 0.77	x 2.01	x 19.64	x 0.63	x 0.7	= 12.06 (76)

TER WorkSheet: New dwelling design stage

East	0.9x	0.77	x	2.01	x	38.42	x	0.63	x	0.7	=	23.6	(76)
East	0.9x	0.77	x	5	x	38.42	x	0.63	x	0.7	=	58.71	(76)
East	0.9x	0.77	x	2.01	x	38.42	x	0.63	x	0.7	=	23.6	(76)
East	0.9x	0.77	x	2.01	x	63.27	x	0.63	x	0.7	=	38.87	(76)
East	0.9x	0.77	x	5	x	63.27	x	0.63	x	0.7	=	96.69	(76)
East	0.9x	0.77	x	2.01	x	63.27	x	0.63	x	0.7	=	38.87	(76)
East	0.9x	0.77	x	2.01	x	92.28	x	0.63	x	0.7	=	56.69	(76)
East	0.9x	0.77	x	5	x	92.28	x	0.63	x	0.7	=	141.01	(76)
East	0.9x	0.77	x	2.01	x	92.28	x	0.63	x	0.7	=	56.69	(76)
East	0.9x	0.77	x	2.01	x	113.09	x	0.63	x	0.7	=	69.47	(76)
East	0.9x	0.77	x	5	x	113.09	x	0.63	x	0.7	=	172.81	(76)
East	0.9x	0.77	x	2.01	x	113.09	x	0.63	x	0.7	=	69.47	(76)
East	0.9x	0.77	x	2.01	x	115.77	x	0.63	x	0.7	=	71.12	(76)
East	0.9x	0.77	x	5	x	115.77	x	0.63	x	0.7	=	176.9	(76)
East	0.9x	0.77	x	2.01	x	115.77	x	0.63	x	0.7	=	71.12	(76)
East	0.9x	0.77	x	2.01	x	110.22	x	0.63	x	0.7	=	67.71	(76)
East	0.9x	0.77	x	5	x	110.22	x	0.63	x	0.7	=	168.42	(76)
East	0.9x	0.77	x	2.01	x	110.22	x	0.63	x	0.7	=	67.71	(76)
East	0.9x	0.77	x	2.01	x	94.68	x	0.63	x	0.7	=	58.16	(76)
East	0.9x	0.77	x	5	x	94.68	x	0.63	x	0.7	=	144.67	(76)
East	0.9x	0.77	x	2.01	x	94.68	x	0.63	x	0.7	=	58.16	(76)
East	0.9x	0.77	x	2.01	x	73.59	x	0.63	x	0.7	=	45.2	(76)
East	0.9x	0.77	x	5	x	73.59	x	0.63	x	0.7	=	112.45	(76)
East	0.9x	0.77	x	2.01	x	73.59	x	0.63	x	0.7	=	45.2	(76)
East	0.9x	0.77	x	2.01	x	45.59	x	0.63	x	0.7	=	28	(76)
East	0.9x	0.77	x	5	x	45.59	x	0.63	x	0.7	=	69.66	(76)
East	0.9x	0.77	x	2.01	x	45.59	x	0.63	x	0.7	=	28	(76)
East	0.9x	0.77	x	2.01	x	24.49	x	0.63	x	0.7	=	15.04	(76)
East	0.9x	0.77	x	5	x	24.49	x	0.63	x	0.7	=	37.42	(76)
East	0.9x	0.77	x	2.01	x	24.49	x	0.63	x	0.7	=	15.04	(76)
East	0.9x	0.77	x	2.01	x	16.15	x	0.63	x	0.7	=	9.92	(76)
East	0.9x	0.77	x	5	x	16.15	x	0.63	x	0.7	=	24.68	(76)
East	0.9x	0.77	x	2.01	x	16.15	x	0.63	x	0.7	=	9.92	(76)
South	0.9x	0.77	x	1.66	x	46.75	x	0.63	x	0.7	=	23.72	(78)
South	0.9x	0.77	x	1.11	x	46.75	x	0.63	x	0.7	=	15.86	(78)
South	0.9x	0.77	x	2.01	x	46.75	x	0.63	x	0.7	=	28.72	(78)
South	0.9x	0.77	x	1.66	x	76.57	x	0.63	x	0.7	=	38.84	(78)
South	0.9x	0.77	x	1.11	x	76.57	x	0.63	x	0.7	=	25.97	(78)
South	0.9x	0.77	x	2.01	x	76.57	x	0.63	x	0.7	=	47.03	(78)
South	0.9x	0.77	x	1.66	x	97.53	x	0.63	x	0.7	=	49.48	(78)
South	0.9x	0.77	x	1.11	x	97.53	x	0.63	x	0.7	=	33.09	(78)

TER WorkSheet: New dwelling design stage

South	0.9x	0.77	x	2.01	x	97.53	x	0.63	x	0.7	=	59.91	(78)
South	0.9x	0.77	x	1.66	x	110.23	x	0.63	x	0.7	=	55.92	(78)
South	0.9x	0.77	x	1.11	x	110.23	x	0.63	x	0.7	=	37.39	(78)
South	0.9x	0.77	x	2.01	x	110.23	x	0.63	x	0.7	=	67.72	(78)
South	0.9x	0.77	x	1.66	x	114.87	x	0.63	x	0.7	=	58.28	(78)
South	0.9x	0.77	x	1.11	x	114.87	x	0.63	x	0.7	=	38.97	(78)
South	0.9x	0.77	x	2.01	x	114.87	x	0.63	x	0.7	=	70.56	(78)
South	0.9x	0.77	x	1.66	x	110.55	x	0.63	x	0.7	=	56.08	(78)
South	0.9x	0.77	x	1.11	x	110.55	x	0.63	x	0.7	=	37.5	(78)
South	0.9x	0.77	x	2.01	x	110.55	x	0.63	x	0.7	=	67.91	(78)
South	0.9x	0.77	x	1.66	x	108.01	x	0.63	x	0.7	=	54.8	(78)
South	0.9x	0.77	x	1.11	x	108.01	x	0.63	x	0.7	=	36.64	(78)
South	0.9x	0.77	x	2.01	x	108.01	x	0.63	x	0.7	=	66.35	(78)
South	0.9x	0.77	x	1.66	x	104.89	x	0.63	x	0.7	=	53.21	(78)
South	0.9x	0.77	x	1.11	x	104.89	x	0.63	x	0.7	=	35.58	(78)
South	0.9x	0.77	x	2.01	x	104.89	x	0.63	x	0.7	=	64.43	(78)
South	0.9x	0.77	x	1.66	x	101.89	x	0.63	x	0.7	=	51.69	(78)
South	0.9x	0.77	x	1.11	x	101.89	x	0.63	x	0.7	=	34.56	(78)
South	0.9x	0.77	x	2.01	x	101.89	x	0.63	x	0.7	=	62.59	(78)
South	0.9x	0.77	x	1.66	x	82.59	x	0.63	x	0.7	=	41.9	(78)
South	0.9x	0.77	x	1.11	x	82.59	x	0.63	x	0.7	=	28.02	(78)
South	0.9x	0.77	x	2.01	x	82.59	x	0.63	x	0.7	=	50.73	(78)
South	0.9x	0.77	x	1.66	x	55.42	x	0.63	x	0.7	=	28.11	(78)
South	0.9x	0.77	x	1.11	x	55.42	x	0.63	x	0.7	=	18.8	(78)
South	0.9x	0.77	x	2.01	x	55.42	x	0.63	x	0.7	=	34.04	(78)
South	0.9x	0.77	x	1.66	x	40.4	x	0.63	x	0.7	=	20.49	(78)
South	0.9x	0.77	x	1.11	x	40.4	x	0.63	x	0.7	=	13.7	(78)
South	0.9x	0.77	x	2.01	x	40.4	x	0.63	x	0.7	=	24.82	(78)

Solar gains in watts, calculated for each month

$$(83)m = \text{Sum}(74)m \dots (82)m$$

$$(83)m = 137.97 \quad 247.45 \quad 367.34 \quad 496.44 \quad 588.71 \quad 597.47 \quad 570.71 \quad 500.77 \quad 412.34 \quad 281.65 \quad 167.63 \quad 116.49 \quad (83)$$

Total gains – internal and solar $(84)m = (73)m + (83)m$, watts

$$(84)m = 540.71 \quad 648.19 \quad 755.28 \quad 863.73 \quad 935.06 \quad 923.59 \quad 883.63 \quad 819.45 \quad 741.59 \quad 631.76 \quad 541.71 \quad 508.52 \quad (84)$$

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 ($^{\circ}\text{C}$)

21 (85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		(86)
(86)m= 1	0.99	0.97	0.91	0.77	0.58	0.43	0.48	0.74	0.94	0.99	1		(86)

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

$$(87)m = 19.79 \quad 19.99 \quad 20.29 \quad 20.64 \quad 20.88 \quad 20.98 \quad 21 \quad 20.99 \quad 20.93 \quad 20.6 \quad 20.13 \quad 19.76 \quad (87)$$

Temperature during heating periods in rest of dwelling from Table 9, Th2 ($^{\circ}\text{C}$)

$$(88)m = 19.91 \quad 19.91 \quad 19.92 \quad 19.93 \quad 19.93 \quad 19.94 \quad 19.94 \quad 19.95 \quad 19.94 \quad 19.93 \quad 19.93 \quad 19.92 \quad (88)$$

TER WorkSheet: New dwelling design stage

Utilisation factor for gains for rest of dwelling, h_{2,m} (see Table 9a)

(89)m=	0.99	0.98	0.96	0.88	0.71	0.49	0.33	0.37	0.65	0.92	0.99	1	(89)
--------	------	------	------	------	------	------	------	------	------	------	------	---	------

Mean internal temperature in the rest of dwelling T₂ (follow steps 3 to 7 in Table 9c)

(90)m=	18.32	18.61	19.04	19.53	19.82	19.93	19.94	19.94	19.89	19.49	18.82	18.28	(90)
$fLA = \text{Living area} \div (4) =$											0.4	(91)	

Mean internal temperature (for the whole dwelling) = f_{LA} × T₁ + (1 – f_{LA}) × T₂

(92)m=	18.91	19.17	19.54	19.98	20.25	20.35	20.37	20.37	20.31	19.94	19.35	18.88	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	18.91	19.17	19.54	19.98	20.25	20.35	20.37	20.37	20.31	19.94	19.35	18.88	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set T_i to the mean internal temperature obtained at step 11 of Table 9b, so that T_{i,m}=(76)m and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, h_m:

(94)m=	0.99	0.98	0.95	0.88	0.73	0.53	0.37	0.42	0.68	0.92	0.98	0.99	(94)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

Useful gains, h_mG_m, W = (94)m × (84)m

(95)m=	536.33	636.12	720.38	758.35	683.1	489.27	326.39	341.71	505.91	581.03	532.47	505.37	(95)
--------	--------	--------	--------	--------	-------	--------	--------	--------	--------	--------	--------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, L_m, W = [(39)m × [(93)m – (96)m]]

(97)m=	1318.75	1283.63	1169.84	979.16	753.44	500.56	327.91	344.42	542.87	822.97	1085.69	1308.57	(97)
--------	---------	---------	---------	--------	--------	--------	--------	--------	--------	--------	---------	---------	------

Space heating requirement for each month, kWh/month = 0.024 × [(97)m – (95)m] × (41)m

(98)m=	582.12	435.12	334.39	158.99	52.33	0	0	0	0	180	398.32	597.58	
--------	--------	--------	--------	--------	-------	---	---	---	---	-----	--------	--------	--

Total per year (kWh/year) = Sum(98)_{1...5,9...12} = 2738.86 (98)

Space heating requirement in kWh/m²/year

36.81 (99)

9a. Energy requirements – Individual heating systems including micro-CHP

Space heating:

Fraction of space heat from secondary/supplementary system

0 (201)

Fraction of space heat from main system(s) (202) = 1 – (201) = 1 (202)

Fraction of total heating from main system 1 (204) = (202) × [1 – (203)] = 1 (204)

Efficiency of main space heating system 1 93.5 (206)

Efficiency of secondary/supplementary heating system, % 0 (208)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

582.12	435.12	334.39	158.99	52.33	0	0	0	0	180	398.32	597.58
--------	--------	--------	--------	-------	---	---	---	---	-----	--------	--------

(211)m = {[(98)m × (204)] } × 100 ÷ (206) 2929.26 (211)

622.59	465.37	357.64	170.04	55.97	0	0	0	0	192.52	426.01	639.12
--------	--------	--------	--------	-------	---	---	---	---	--------	--------	--------

Total (kWh/year) = Sum(211)_{1...5,10...12} = 2929.26 (211)

Space heating fuel (secondary), kWh/month

= {[(98)m × (201)] } × 100 ÷ (208) 0 (215)

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

Total (kWh/year) = Sum(215)_{1...5,10...12} = 0 (215)

TER WorkSheet: New dwelling design stage

Water heating

Output from water heater (calculated above)

193.35	170.44	179.05	160.57	157.4	140.7	135.19	148.26	147.98	166.5	175.97	188.72
--------	--------	--------	--------	-------	-------	--------	--------	--------	-------	--------	--------

Efficiency of water heater

79.8

(216)

(217)m=

87.57	87.21	86.46	84.79	82.23	79.8	79.8	79.8	85.02	86.93	87.68
-------	-------	-------	-------	-------	------	------	------	-------	-------	-------

(217)

Fuel for water heating, kWh/month

(219)m = $(64)m \times 100 \div (217)m$

220.79	195.44	207.09	189.38	191.42	176.32	169.42	185.79	185.43	195.83	202.43	215.24
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

Total = Sum(219a)_{1...12} =

2334.59

(219)

Annual totals

Space heating fuel used, main system 1

kWh/year

kWh/year

2929.26

Water heating fuel used

2334.59

Electricity for pumps, fans and electric keep-hot

central heating pump:

30

(230c)

boiler with a fan-assisted flue

45

(230e)

Total electricity for the above, kWh/year

sum of (230a)...(230g) =

75

(231)

Electricity for lighting

326.44

(232)

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating (main system 1)	(211) x	0.216	= 632.72
Space heating (secondary)	(215) x	0.519	= 0
Water heating	(219) x	0.216	= 504.27
Space and water heating	(261) + (262) + (263) + (264) =		1136.99
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	= 38.93
Electricity for lighting	(232) x	0.519	= 169.42
Total CO2, kg/year		sum of (265)...(271) =	1345.34
TER =			18.08