

55 Cumberland Terrace London

Environmental Noise Survey and Plant Noise Assessment Report

27769/PNA1

24 July 2020

For:
Antonella Noto
Millbridge Project Management Limited
16 Watermark Way
Foxholes Business Park
Hertford
Herts
SG13 7TZ



Hann Tucker Associates

Consultants in Acoustics Noise & Vibration

Head Office: Duke House, 1-2 Duke Street, Woking, Surrey, GU21 5BA (t) +44 (0) 1483 770 595
Manchester Office: First Floor, 346 Deansgate, Manchester, M3 4LY (t) +44 (0) 161 832 7041
(w) hanntucker.co.uk (e) enquiries@hanntucker.co.uk



Environmental Noise Survey Report 27769/PNA1

Document Control

Rev	Date	Comment	Prepared & Authorised by Authorised by	
0	24/07/2020	-		
			James Hardacre Technical Assistant	Andrew Fermer Director BSc(Hons), MIOA

This report has been prepared by Hann Tucker Associates Limited (HTA) with all reasonable skill, care and diligence in accordance with generally accepted acoustic consultancy principles and the purposes and terms agreed between HTA and our Client. Any information provided by third parties and referred to herein may not have been checked or verified by HTA unless expressly stated otherwise. This document contains confidential and commercially sensitive information and shall not be disclosed to third parties. Any third party relies upon this document at their own risk.



Environmental Noise Survey Report 27769/PNA1

Contents	Page
1.0 Introduction	1
2.0 Objectives	1
3.0 Site Description	1
4.0 Acoustic Terminology	3
5.0 Methodology	3
6.0 Results	6
7.0 Discussion Of Noise Climate	6
8.0 Local Authority Requirements	6
9.0 Relevant Planning Policies and Guidance	8
10.0 Plant Noise Emission Criteria	12
11.0 Plant Noise Impact Assessment	13
12.0 Conclusions	15

Attachments

Appendix A – Acoustic Terminology

Time History Graph 27144/TH1



1.0 Introduction

It has been proposed to install new plant on the premise of 55 Cumberland Terrace.

Hann Tucker Associates have therefore been commissioned to undertake a detailed environmental noise survey and noise impact assessment in order to determine the currently prevailing noise climate around the site and propose suitable plant noise emission criteria based on Local Authority requirements.

This report presents the methodology and findings of our noise survey.

2.0 Objectives

To inspect the site to familiarise ourselves with its layout and surroundings in order to identify suitable accessible locations for environmental noise measurements.

To establish by means of an unmanned 24 hour survey the existing L_{Amax}, L_{Aeq} and L_{A90} environmental road, rail and air traffic noise levels at 3No. secure and accessible on-site position, using fully computerised noise monitoring equipment.

To assess the noise emissions from the proposed plant, based upon data with which we are provided, and comment upon the acceptability.


To advise on noise control measures if required with reference to the requirements of the Local Authority.

To present our methodology and findings in a detailed Environmental Noise Survey and Plant Noise Impact Assessment Report to accompany the planning application.

3.0 Site Description

3.1 Location

The site is located at 55 Cumberland Terrace in London. The location is shown in the Location Map below.



Location Map (Map Data © 2020 Google)


The site falls within the jurisdiction of Camden Council.

3.2 Description

The site is a ground plus 3 storey and 1 basement residential unit.

The site boundary is neighboured by Cumberland Terrace to the west, residential units to the north and south and Albany Street to the east. The surrounding area is characterised by residential use.

See Site Plan below.



Site Plan (Bluesky, CNES/Airbus, Getmapping plc, Inforterra Ltd & Bluesky, Maxar technologies, The Geoinformation Group, Map Data © 2020 Google)

4.0 Acoustic Terminology

For an explanation of the acoustic terminology used in this report please refer to Appendix A enclosed.

5.0 Methodology

The survey was undertaken by James Hardacre.

5.1 Unmanned Survey

5.1.1 Procedure

Fully automated environmental noise monitoring was undertaken from approximately 13:30 hours on Monday 6 July 2020 to 13:45 hours on Tuesday 7 July 2020.

Owing to the nature of the survey, i.e. unmanned, it is not possible to accurately comment on the weather conditions throughout the entire survey period. However at the beginning and end of the survey period the wind conditions were calm. The sky was generally clear. We understand that generally throughout the survey period the weather conditions were similar to this.


Measurements were taken continuously of the A-weighted (dBA) L_{90} , L_{eq} and L_{max} sound pressure levels over 15 minute periods.



5.1.2 Measurement Positions

The noise level measurements were undertaken at 3 positions as described in the table below.

Position No	Description
1	The microphone was placed on the front balcony directly above the front lightwell approximately 6m above ground level and at least 1.5m from the nearest reflecting surface
2	The microphone was placed out of a top floor rear window directly below the roof level at least 1.5m from the nearest reflecting surface
3	The microphone was placed out of a lower floor window at the rear of the property at least 1.5m from the nearest reflecting surface



Site Plan Showing Unmanned Measurement Positions (The GeoInformation Group, Map data © 2019 Google)



5.2 Instrumentation

The instrumentation used during the survey is presented in the table below:

Description	Manufacturer	Type	Serial Number	Calibration
Position 1 Type 1 ½" Condenser Microphone	ACO Pacific	7052E	75560	Calibration on 31/10/2019
Position 1 Preamp	Svantek	SV18	83547	Calibration on 31/10/2019
Position 1 Type 1 Data Logging Sound Level Meter	Svantek	971	87087	Calibration on 31/10/2019
Position 2 Type 1 ½" Condenser Microphone	ACO Pacific	7052E	52450	Calibration on 08/03/2019
Position 2 Preamp	Svantek	SV12L	30424	Calibration on 08/03/2019
Position 2 Type 1 Data Logging Sound Level Meter	Svantek	957	28035	Calibration on 08/03/2019
Position 3 Type 1 ½" Condenser Microphone	ACO Pacific	7052E	67983	Calibration on 06/02/2019
Position 3 Preamp	Svantek	SV18	71464	Calibration on 06/02/2019
Position 3 Type 1 Data Logging Sound Level Meter	Svantek	971	80233	Calibration on 06/02/2019

Each sound level meter, including the extension cable, was calibrated prior to and on completion of the surveys. No significant changes were found to have occurred (no more than 0.1 dB).

Each sound level meter was located in an environmental case with the microphone connected to the sound level meter via an extension cable.



Each microphone was fitted with a manufacturer windshield.

6.0 Results

The results have been plotted on the Time History Graphs 27931/TH1.1-1.3 enclosed presenting the 15 minute A-weighted (dBA) L_{90} , L_{eq} and L_{max} levels at the measurement position throughout the duration of the survey.

6.1 Measured L_{eq} Noise Levels

The measured daytime $L_{Aeq(16-hour)}$ and night-time $L_{Aeq(8-hour)}$ noise levels for each position are presented in the table below.

Position	Lowest Measured $L_{Aeq(15min)}$ Background Noise Level (dB re 2×10^{-5} Pa)	
	Daytime (07:00 – 23:00) Hours	Night-Time (23:00 – 07:00) Hours
1	61dBA	54dBA
2	63dBA	60dBA
3	59dBA	55dBA

6.2 Lowest Measured L_{90} Noise Levels

The following table presents the lowest measured L_{A90} background noise levels during the survey:

Position	Lowest Measured $L_{A90(15min)}$ Background Noise Level (dB re 2×10^{-5} Pa)	
	Daytime (07:00 – 23:00) Hours	Night-Time (23:00 – 07:00) Hours
1	46dBA	31dBA
2	46dBA	43dBA
3	44dBA	38dBA

7.0 Discussion Of Noise Climate

Due to the nature of the survey, i.e. unmanned, it is not possible to accurately describe the dominant noise sources, or specific noise events throughout the entire survey period. However at the beginning and end of the survey period the dominant noise sources were noted to be road traffic from the road network.

8.0 Local Authority Requirements

The site lies within London Borough of Camden's jurisdiction. Their advice regarding criteria for



atmospheric noise emissions from building service plant is contained within their Local Plan, version June 2017 as follows:

Industrial and Commercial Noise Sources

A relevant standard or guidance document should be referenced when determining values for LOAEL and SOAEL for non-anonymous noise. Where appropriate and within the scope of the document it is expected that British Standard 4142:2014 'Methods for rating and assessing industrial and commercial sound' (BS 4142) will be used. For such cases a 'Rating Level' of 10 dB below background (15dB if tonal components are present) should be considered as the design criterion).

Table C: Noise levels applicable to proposed industrial and commercial developments (including plant and machinery)

Existing Noise sensitive receptor	Assessment Location	Design Period	LOAEL (Green)	LOAEL to SOAEL (Amber)	SOAL (Red)
Dwellings**	Garden used for main amenity (free field) and Outside living or dining or bedroom window (façade)	Day	'Rating level' 10dB* below background	'Rating level' between 9dB below and 5dB above background	'Rating level' greater than 5dB above background
Dwellings**	Outside bedroom window (façade)	Night	'Rating level' 10dB* below background and no events exceeding 57dB _{L_{max}}	'Rating level' between 9dB below and 5dB above background or noise events between 57dB and 88dB L _{max}	'Rating level' greater than 5dB above background and/or events exceeding 88dB _{L_{max}}



*10dB should be increased to 15dB if the noise contains audible tonal elements (day and night). However, if it can be demonstrated that there is no significant difference in the character of the residual background noise and the specific noise from the proposed development then this reduction may not be required. In addition, a frequency analysis (to include, the use of Noise Rating (NR) curves or other criteria curves) for the assessment of tonal or low frequency noise may be required.

**levels given are for dwellings, however, levels are use specific and different levels will apply dependent on the use of the premises.

The periods in Table C correspond to 0700 hours to 2300 hours for the day and 2300 hours to 0700 hours for the night. The Council will take into account the likely times of occupation for types of development and will be amended according to the times of operation of the establishment under consideration.

There are certain smaller pieces of equipment on commercial premises, such as extract ventilation, air conditioning units and condensers, where achievement of the rating levels (ordinarily determined by a BS:4142 assessment) may not afford the necessary protection. In these cases, the Council will generally also require a NR curve specification of NR35 or below, dependant on the room (based upon measured or predicted Leq,5mins noise levels in octave bands) 1 metre from the façade of affected premises, where the noise sensitive premise is located in a quiet background area.

On 26 June 2016 London Borough of Camden sent us an email confirming the following windows should be considered noise sensitive, *“housing, schools, hospitals, offices, workshops”*.

9.0 Relevant Planning Policies and Guidance

9.1 Noise Policy Statement for England

The Noise Policy Statement for England (NPSE) was published in March 2010. The NPSE is the overarching statement of noise policy for England and applies to all forms of noise other than occupational noise, setting out the long term vision of Government noise policy which is to:

“Promote good health and a good quality of life through the effective management of noise within the context of Government policy on sustainable development.”

That vision is supported by the following aims which are reflected in three of the four aims for planning policies and decisions in paragraph 123 of the NPPF (see paragraph 8.2 (b) below):

“Through the effective management and control of environmental, neighbour and neighbourhood noise within the context of Government policy on sustainable development:

- *avoid significant adverse impacts on health and quality of life;*



- *mitigate and minimise adverse impacts on health and quality of life; and*
- *where possible, contribute to the improvement of health and quality of life.”*

The Explanatory Note to the NPSE has three concepts for the assessment of noise in this country:

NOEL – No Observed Effect Level

This is the level below which no effect can be detected and below which there is no detectable effect on health and quality of life due to noise.

LOAEL – Lowest Observable Adverse Effect Level

This is the level above which adverse effects on health and quality of life can be detected.

SOAEL – Significant Observed Adverse Effect Level

This is the level above which significant adverse effects on health and quality of life occur.

None of these three levels are defined numerically and for the SOAEL the NPSE makes it clear that the noise level is likely to vary depending upon the noise source, the receptor and the time of day/day of the week, etc. The need for more research to investigate what may represent an SOAEL for noise is acknowledged in the NPSE and the NPSE asserts that not stating specific SOAEL levels provides policy flexibility in the period until there is further evidence and guidance.

The NPSE concludes by explaining in a little more detail how the LOAEL and SOAEL relate to the three aims listed in paragraph (b) above. It starts with the aim of avoiding significant adverse effects on health and quality of life, then addresses the situation where the noise impact falls between the LOAEL and the SOAEL when *“all reasonable steps should be taken to mitigate and minimise adverse effects on health and quality of life while also taking into account the guiding principles of sustainable development.”* The final aim envisages pro-active management of noise to improve health and quality of life, again taking into account the guiding principles of sustainable development which include the need to minimise travel distance between housing and employment uses in an area.

9.2 National Planning Policy Framework (NPPF)

The National Planning Policy Framework (NPPF) was published in March 2012 and replaced the previous national planning guidance document Planning Policy Guidance 24: *Planning and Noise* (PPG24).

The main reference to noise within the NPPF is at paragraph 123, reproduced below:



“123. Planning policies and decisions should aim to:

- Avoid noise from giving rise to significant adverse impacts²⁷ on health and quality of life as a result of new development;*
- Mitigate and reduce to a minimum other adverse impacts²⁷ on health and quality of life arising from noise from new development, including through the use of conditions;*
- Recognise that development will often create some noise and existing businesses wanting to develop in continuance of their business should not have unreasonable restrictions put on them because of changes in nearby land uses since they were established;²⁸ and*
- Identify and protect areas of tranquillity which have remained relatively undisturbed by noise and are prized for their recreational and amenity value for this reason.”*

The reference numbers 27 and 28 point respectively to the Explanatory Note to the NPSE and the provisions of the Environmental Protection Act 1990 *“and other relevant law”*.

The spirit of the Localism Act and the NPPF would suggest that of the guidelines cited, it is guidelines adopted as policy by the Local Planning Authority (if such exist) that should prevail, at least until the Government publishes relevant technical guidance under the NPPF.

9.3 Planning Practice Guidance on Noise

Planning Practice Guidance (PPG) under the NPPF has been published by the Government as a web based resource at <http://planningguidance.planningportal.gov.uk/blog/guidance/>. This includes specific guidance on Noise although, like the NPPF and NPSE the PPG does not provide any quantitative advice. It seeks to illustrate a range of effect levels in terms of examples of outcomes as set out in the following table:



Perception	Examples of Outcomes	Increasing effect level	Action
Not noticeable	No effect	No Observed Effect	No specific measures required
Noticeable and not intrusive	Noise can be heard, but does not cause any change in behaviour or attitude. Can slightly affect the acoustic character of the area but not such that there is a perceived change in the quality of life.		
		Lowest Observed Adverse Effect Level	
Noticeable and intrusive	Noise can be heard and causes small changes in behaviour and/or attitude, e.g. turning up volume of television; speaking more loudly; where there is no alternative ventilation, having to close windows for some of the time because of the noise. Potential for some reported sleep disturbance.	Observed Adverse Effect	Mitigate and reduce to a minimum
		Significant Observed Adverse Effect Level	
Noticeable and disruptive	The noise causes a material change in behaviour and/or attitude, e.g. avoiding certain activities during periods of intrusion; where there is no alternative ventilation, having to keep windows closed most of the time because of the noise. Potential for sleep disturbance resulting in difficulty in getting to sleep, premature awakening and difficulty in getting back to sleep. Quality of life diminished due to change in acoustic character of the area.		Avoid
Noticeable and very disruptive	Extensive and regular changes in behaviour and/or an inability to mitigate effect of noise leading to psychological stress or physiological effects, e.g. regular sleep deprivation/awakening; loss of appetite, significant, medically definable hard, e.g. auditory and non-auditory.		Prevent

9.4 World Health Organisation Guidelines on Community Noise

BS8233:2014 is based upon the current World Health Organisation (WHO) guidance “Guidelines on Community Noise”. A summary of the noise guidelines relevant to the proposed development is presented in the table below.



Residential Environment	Critical Health Effect(s)	L _{Aeq}	L _{AFmax}	Time Base
Outdoor living area	Serious annoyance, daytime and evening	55	-	07:00-23:00
	Moderate annoyance, daytime and evening	50	-	07:00-23:00
Dwelling, indoors	Speech intelligibility and moderate annoyance, daytime and evening	35	-	07:00-23:00
Inside bedrooms	Sleep disturbance, night-time	30	45	23:00-07:00
Outside bedrooms	Sleep disturbance, window open (outdoor values)	45	60	23:00-07:00

These WHO guidelines are based, in almost all cases, on the lower threshold below which the occurrence rates of any particular effect can be assumed to be negligible.

The internal and external noise level criteria presented in BS8233:2014 for residential dwelling are generally consistent with the WHO guidelines, although some differences are apparent. For instance the WHO guidelines refer to research that suggests *“For a good sleep, it is believed that indoor sound pressure levels should not exceed approximately 45 dB L_{AFmax} more than 10-15 times per night.”* (Vallet & Vernet, 1991). The current version of BS8233 does not identify a specific L_{AFmax} level although it suggests that a guideline value may be set using that parameter depending on the character and number of individual noise events per night.

10.0 Plant Noise Emission Criteria

On the basis of the aforementioned acoustic standards and guidance, together with the results of the environmental noise survey, we propose that the following plant noise emission criteria be achieved at in the nearest garden ‘used for main amenity’ or at 1 metre from the nearest living room, dining room, or bedroom in the daytime, and at 1 metre from the nearest bedroom window at night-time with all plant operating simultaneously.

Position	Plant Noise Emission Criteria (dB re 2x10 ⁻⁵ Pa)	
	Daytime (07:00 – 23:00 hours)	Night-time (23:00 – 07:00 hours)
1	36dBA / NR35*	28dBA / NR35*

*NR35 criterion applies to ‘smaller pieces of equipment on commercial premises, such as extract ventilation, air conditioning units, and condensers....where noise sensitive premises are located in a quiet background area’ as per Camden’s Local Plan.

If plant contains tonal or impulsive characteristics the external design criteria should be reduced by 5dBA.



The above criteria are based on a level of 10dB below background in order to fall into Camden's 'Green' criteria for **dwelling**s. Whilst we understand that Camden considers other uses noise sensitive, the Local plan states that the criteria is use dependent but does not define criteria that correspond to 'Green', 'Amber', or 'Red' for these other uses. We request that Camden clarify their policy in this respect. The criteria could be relaxed by 5dB in line with the 'Amber' criteria in Camden's Local Plan, which may be acceptable to Camden depending on 'the context of other merits of the development'.

It should be noted that the above are subject to the final approval of the Local Authority.

11.0 Plant Noise Impact Assessment


We understand the proposed plant comprises 1No. Mitsubishi PUMY-SP140VKM Air Conditioning Unit and 3No. Mitsubishi PUMY-P200YKM2 heat pumps.

11.1 Plant Noise Data

Plant Description	Sound Pressure Level at 1m (dB re 2×10^{-5} Pa) at Octave Band Centre Frequency (Hz)								dBA
	63	125	250	500	1k	2k	4k	8k	
PUMY – SP140VKM at 1m	62.3	57.8	56.1	53.1	51.8	46.7	40.3	33.2	56.0
PUMY – P200YKM2 at 1m	63	61	60	58	57	51.5	48.5	41	61

11.2 Location of Plant

The plan below shows the location of the proposed plant and approximate distance to nearest noise sensitive window.



Proposed Plant Location (Bluesky, CNES/Airbus, Getmapping plc, Infoterra Ltd & Bluesky, Maxar technologies, The Geoinformation Group, Map Data © 2020 Google)

11.3 Plant Noise Impact Assessment

We understand that the proposed units could be operational during daytime and night-time hours.

The following tables summarise our predictions of atmospheric noise emissions from the plant to the nearest noise sensitive window.

	Sound Pressure Level (dB re 2 x 10 ⁻⁵ Pa) at Octave Band Centre Frequency (Hz)								dBA
	63	125	250	500	1k	2k	4k	8k	
PUMY – SP140VKM at 1m	62.3	57.8	56.1	53.1	51.8	46.7	40.3	33.2	56.0
Distance Correction (12m)	-22	-22	-22	-22	-22	-22	-22	-22	
Environ Acoustic Enclosure	-14	-16	-23	-30	-37	-39	-38	-39	
Calculated Noise Level at Receptor	26	20	11	1	-7	-14	-20	-28	8



	Sound Pressure Level (dB re 2 x 10 ⁻⁵ Pa) at Octave Band Centre Frequency (Hz)								dBA
	63	125	250	500	1k	2k	4k	8k	
PUMY – P200YKM2 at 1m	63	61	60	58	57	51.5	48.5	41	61
Distance Correction (12m)	-22	-22	-22	-22	-22	-22	-22	-22	
Environ Acoustic Enclosure	-14	-16	-23	-30	-37	-39	-38	-39	
Calculated Noise Level at Receptor	27	23	15	6	-2	-9	-11	-20	11

	Sound Pressure Level at Octave Band Centre Frequency (Hz)								dBA
	63	125	250	500	1k	2k	4k	8k	
Calculated Total Cumulative Noise Level at Receptor	33	28	20	11	3	-4	-6	-15	17

12.0 Conclusions

A detailed 24 hour daytime and night-time fully automated environmental noise survey has been undertaken in order to establish the currently prevailing environmental noise climate around the site. The results are presented herein.

Plant noise emission criteria have been recommended and a preliminary plant noise emission limit has been set with reference to BS 4142:2014 and Local Authority requirements.

An assessment has been carried out to determine the plant noise emissions at the nearest noise sensitive window.

The assessment indicates that the proposed plant should be capable of achieving the proposed environmental noise criteria at the nearest noise sensitive residential window.

Appendix A

The acoustic terms used in this report are defined as follows:

dB Decibel - Used as a measurement of sound level. Decibels are not an absolute unit of measurement but an expression of ratio between two quantities expressed in logarithmic form. The relationships between Decibel levels do not work in the same way that non-logarithmic (linear) numbers work (e.g. 30dB + 30dB = 33dB, not 60dB).

dBA The human ear is more susceptible to mid-frequency noise than the high and low frequencies. The 'A'-weighting scale approximates this response and allows sound levels to be expressed as an overall single figure value in dBA. The _A subscript is applied to an acoustical parameter to indicate the stated noise level is A-weighted

It should be noted that levels in dBA do not have a linear relationship to each other; for similar noises, a change in noise level of 10dBA represents a doubling or halving of subjective loudness. A change of 3dBA is just perceptible.

L_{90,T} L₉₀ is the noise level exceeded for 90% of the period *T* (i.e. the quietest 10% of the measurement) and is often used to describe the background noise level.

L_{eq,T} L_{eq,T} is the equivalent continuous sound pressure level. It is an average of the total sound energy measured over a specified time period, *T*.

L_{max} L_{max} is the maximum sound pressure level recorded over the period stated. L_{max} is sometimes used in assessing environmental noise where occasional loud noises occur, which may have little effect on the L_{eq} noise level.

L_p Sound Pressure Level (SPL) is the sound pressure relative to a standard reference pressure of 2×10^{-5} Pa. This level varies for a given source according to a number of factors (including but not limited to: distance from the source; positioning; screening and meteorological effects).

L_w Sound Power Level (SWL) is the total amount of sound energy inherent in a particular sound source, independent of its environment. It is a logarithmic measure of the sound power in comparison to a specified reference level (usually 10^{-12} W).