
Ducting route from the canopy onto the flat roof and into the void space above the kitchen.

The internal void area will be utilized for extraction plant to minimize outside noise levels.



NOTES:

All dimensions must be checked on site and not scaled from this drawing.

To comply with BS-6173-2009 mandatory interlocks are required between the gas supply and the mechanical kitchen ventilation system (extract and make-up air).

DO NOT SCALE

ALL DIMENSIONS TO BE CHECKED ON SITE

REVISION NOTES

REV	DATE	REVISION			
-					

© Copyright 2019

'CESCO'

The Catering Equipment Supply Co Ltd

135 Margate Road Herne Bay, Kent. CT6 7AB

Tel: 01227 742999 Fax: 01227 742699

GENERAL NOTES

- Electrical contractor to supply & fix all sockets outlets, plugs, starters, isolators & main fuses.
 General contractors to provide suitable
- isolating cocks for gas & water risers, each appliance to be locally valved for maintenance.
- General contractors to provide all waste traps. The appropriate stop valve/isolators to be positioned in accordance to this drawing. (If required, cut off solenoid by others)
- Plumbing contractor to check incoming water supplies, drainage & gas pipe supplies to ensure pipes are able to cope with the kitcher equipment.
- Water softener required for dishwasher / glasswasher & steamers if hardness exceeds 7 degrees Clarke.

Mobile: 07768 200424 Email: <u>cescoltd@aol.com</u> Company No. 3109662 VAT No. 661 8291 21 <u>www.cescolimited.co.uk</u>



CLIENT

The Magdala, Hampstead					
TITLE	2A S Hill Park, Hampstead, London, NW3 2SB				
Proposed New Extraction Route Kitchen Plan View					
SCALE	NTS	PAPER SIZE	A3		
DATE	20 - 05 - 2019	DRAWN BY	BH		
DRAWING NUMBER 19 - 138 D1					