



Statement for – Aircon Condensers for 2020/4441/NEW

Dear Jack,

The proposed elevation reflects 4 condensers on the drg, we are going to include Aircon with Hot & cold function for the ground floor and the basement too as we are doing refit works to basement section too.

We are also supplying fresh and ventilation for the basement section so the 3 condensers would cover the ground and basement for Aircon and 1 condenser to cover the ventilation for the basement section.

I hope the above information covers the idea behind the 4 units into the rear and trust all in order.

Thanks,
Sabir Dosani