







7ABC Bayham Street, Camden

Energy Statement

Client Name:	Camden Lifestyle (UK) Ltd
Document Reference:	17-E090-032
Project Number:	17-E090

Quality Assurance Approval Status

This document has been prepared and checked in accordance with Ensphere Group Ltd's Quality Management System.

Issue:	Version:	Prepared by:	Reviewed by:	Date:
Final	V1	Pete Jeavons	Pete Jeavons	November 2020

Sustainability Energy Climate Change Socio	-Economic
--	-----------



Contents

1.	Executive Summary	1
2.	Introduction	2
3.	Assessment Methodology	3
4.	Planning Context	4
5.	Baseline Emissions	8
6.	Demand Reduction (Be Lean)	9
7.	Heating Infrastructure (Be Clean)	12
8.	Renewable Energy (Be Green)	14
9.	Summary	16

Appendices

Α.	Site Plans	19
В.	Key Local Planning Policy Requirements	21
C.	GLA Carbon Emissions Reporting Spreadsheet	27
D.	Indicative Energy Model Outputs (Be Lean)	30
E.	Indicative Energy Model Outputs (Be Green)	43
F.	General Notes	56



1. Executive Summary

- 1.1 This Energy Statement presents the energy strategy for a proposed scheme at 7ABC Bayham Street, Camden.
- 1.2 Planning consent has been granted for the *"Full Planning Application for the demolition of existing buildings (B1a Use Class) and erection of a part 3, part 4, part 5 storey building (with two basement levels), comprising co-working office floorspace (B1a Use Class), hotel accommodation (C1 Use Class) and an ancillary café/bar and fitness facilities; works to the existing access and associated works." Variations are being sought as part of a Section 73 Application.*
- 1.3 Consideration has primarily been given to the planning policy context and other requirements prior to establishing a strategy based upon the energy hierarchy; with a priority given to energy reduction and efficiency. Renewable and low carbon technologies have also been considered in the context of their technical feasibility and financial viability.
- 1.4 The following is therefore proposed:
 - High performance building fabric and energy efficient lighting, services and equipment;
 - Passive design measures to reduce energy demand for heating, cooling, ventilation and lighting;
 - Air Source Heat Pumps to provide space heating and hot water.
 - Photovoltaics (PV) at roof level to offset the site's electricity demand
- 1.5 In line with Policy 5.2 of the London Plan and the Council policy, an on-site carbon saving of ≥35% has been targeted for the entire development relative to Part L 2013 (equivalent to a 40% carbon saving relative to the 2010 version of Part L).



Introduction 2.

2.1 Ensphere Group Ltd was commissioned to produce an Energy Statement for a proposed development at 7ABC Bayham Street, Camden.

Site and Surroundings

Site

- 2.2 The site is located in central London in the London Borough of Camden, to the southern end and western side of Bayham Street. Bayham Street is a wide one-way route which runs parallel to the east of Camden High Street (A400).
- 2.3 The site has a regular shape and currently comprises three existing buildings 7A, 7B and 7C and the lawful planning use of these buildings is Offices (Class B1a). The site is contained on three sides, with access only being achievable from Bayham Street.

Surroundings

- 2.4 The character of the area is mixed but is categorised as commercial by the Conservation Area Appraisal "Sub Area 1 ('Commercial')".
- 2.5 The site is approximately 100m northeast of Mornington Crescent underground station, 400m south of Camden underground station and 900m north of both Euston and King's Cross/St Pancras National Rail stations. In addition, nine high frequency bus routes operate in the area.

Consented Scheme

2.6 Full Planning Application for the demolition of existing buildings (B1a Use Class) and erection of a part 3, part 4, part 5 storey building (with two basement levels), comprising co-working office floorspace (B1a Use Class), hotel accommodation (C1 Use Class) and an ancillary café/bar and fitness facilities; works to the existing access and associated works.

Section 73

2.7 A Section 73 Application is now being submitted to accommodate variations.

Report Objective

2.8 The objective of the Energy Statement is to outline how energy efficiency, low carbon and renewable technologies have been considered as part of the energy strategy.



Assessment Methodology 3.

- 3.1 The assessment methodology follows the Energy Hierarchy, on the basis that it is preferable to firstly minimise carbon dioxide emissions through reduced energy demand; prior to considering low carbon and renewable energy supply options.
- 3.2 The tiers of the Energy Hierarchy are:
 - Be Lean **Demand Reduction** •
 - Be Clean Use Energy More Efficiently
 - Be Green Use Renewable Energy
- 3.3 Where opportunities to improve the efficiency of the design have been maximised, consideration is then given to the second principle whereby priority is given to the efficient use of energy. This is on the basis that low carbon technologies can be cost-effective and provide significant carbon savings when compared to conventional technologies.
- 3.4 The third principle of the hierarchy promotes the use of renewable technologies. Whilst these technologies can be relatively expensive to install, they do offer the potential to significantly reduce carbon emissions.
- 3.5 The following sections of the report review the planning policy requirements prior to establishing a baseline from which the principles of the Energy Hierarchy are applied.



4. Planning Context

4.1 Local planning policy relevant to sustainable development is considered below:

National Context

National Planning Policy Framework (2019)

4.2 The National Planning Policy Framework (NPPF) was updated in February 2019. Paragraph 7 of the revised NPPF states that:

"the purpose of the planning system is to contribute to the achievement of sustainable development"

4.3 Chapter 14 of the NPPF includes consideration of climate change and the use and supply of renewable and low carbon energy. Paragraph 148 states:



"The planning system should support the transition to a low carbon future in a changing climate, taking full account of flood risk and coastal change. It should help to: shape places in ways that contribute to radical reductions in greenhouse gas emissions, minimise vulnerability and improve resilience; encourage the reuse of existing resources, including the conversion of existing buildings; and support renewable and low carbon energy and associated infrastructure."

Planning Practice Guidance (2016; updated 2018)

- Climate Change Advises how planning can identify suitable mitigation and adaption measures in plan-making and the application process to address the potential for climate change.
- Renewable and Low Carbon Energy The guidance is intended to assist local councils in developing policies for renewable energy in local plans, and identifies the planning considerations for a range of renewable sources.

London Context

The London Plan Consolidated with Alterations Since 2011 (2016)

- 4.4 The London Plan was further updated in March 2016. The Plan is the overall strategic plan for London. Chapter five of the Plan details London's Response to Climate Change. The following policies are considered pertinent to this Statement:
 - Policy 5.2 (*Minimising Carbon Dioxide Emissions*) includes:



Chapter: Planning Context



- An Energy Hierarchy: Be Lean; Be Clean; Be Green;
- Carbon reduction targets for major developments; including a "zero carbon" target for Ο 2019:
- Sets out the information requirements for energy assessments. 0
- Policy 5.3 (Sustainable Design & Construction) encourages consideration of sustainability as part of the design and construction;
- Policy 5.5 (Decentralised Energy Networks) requires planning authorities to require developers prioritise connection to existing or planned decentralised energy networks where feasible;
- Policy 5.6 (Decentralised Energy in Development Proposals) encourages development to establish or connect to energy networks;
- Policy 5.7 (Renewable Energy) within the framework of the Energy Hierarchy, major • development proposals should provide a reduction in expected carbon dioxide through the use of on-site renewable energy generation, where feasible;
- Policy 5.9 (Overheating and Cooling) major development proposals should reduce potential overheating and reliance on air conditioning systems in accordance with a Cooling Hierarchy;

Energy Assessment Guidance (2018)

4.5 This guidance document explains how to prepare an energy assessment to accompany strategic planning applications referred to the Mayor as set out in London Plan Policy 5.2. It states that the purpose of an energy assessment is to demonstrate that the proposed climate change mitigation measures comply with London Plan energy policies, including the energy hierarchy.



4.6 Although primarily aimed at strategic planning applications, London boroughs are encouraged to apply the same structure for energy

assessments related to non-referable applications and adapt it for relevant scales of development.



Emerging London Plan (2019)

4.7 The draft New London Plan is a broad plan to shape the way London develops over the next 20-25 years. Energy issues are discussed in Chapter 3 (Design), Chapter 8 (Green Infrastructure and Natural Environment) and Chapter 9 (Sustainable Infrastructure). The following draft policies are considered important to this report:



- Draft Policy D1 (London's Form and Characteristics) Development should aim for high sustainability standards (with reference to the policies within London Plan Chapter's 8 and 9);
- Draft Policy SI1 (Improving Air Quality) Development should not lead to further deterioration of existing poor air quality;
- Draft Policy SI2 (*Minimising GHG Emissions*) Encourages major development to be zerocarbon and minimise annual and peak energy demand in accordance to 'Be Lean, Be Clean, Be Green, Be Seen' energy hierarchy.
- Draft Policy SI3 (Energy Infrastructure) Major development proposals in Heat Network Priority Areas should have a communal low-temperatures heating system and the heating source should be selected in accordance to the Heating Hierarchy;
- Draft Policy SI4 (Managing Heat Risk) Encourages development to minimise adverse impacts on the urban heat island and to assess the risk of internal overheating and reduce reliance on air conditioning.

Local Context

Camden Local Plan (June 2017)

- 4.8 The Local Plan sets out the planning policies, site allocations and land designations Borough-wide and is the central document in the Borough's Development Plan.
- 4.9 The following policies are considered relevant to this report:
 - Policy CC1 (*Climate Change Mitigation*) promotes zero carbon development, consideration of the Energy Hierarchy (encouraging connection to District Energy Networks), reduced reliance on transport by car and resource efficiency;



 Policy CC2 (Adapting to Climate Change) – requires consideration of overheating risks, encourages the use of the Home Quality Mark and Passivhaus Standards along with BREEAM "excellent" for non-domestic and refurbishment developments >500sqm; Chapter: Planning Context



Camden Planning Guidance – Energy Efficiency & Adaptation (March 2019)

- 4.10 This guidance provides information on key energy and resource issues within the borough and supports Local Plan Policies CC1 Climate change mitigation and CC2 Adapting to climate change.
- 4.11 Includes requirements concerning credits under certain BREEAM categories (60% energy, 60% water and 40% materials); and reference the 20% renewables target.





5. Baseline Emissions

- 5.1 This section establishes the baseline position from which carbon savings are to be achieved. For the purposes of this assessment, and in line with GLA and local authority policies and guidance, the baseline position equates to regulated carbon dioxide emissions, assuming compliance with Part L 2013 of the Building Regulations, as calculated using approved compliance software.
- 5.2 When determining this baseline, it has been assumed that heating would be provided by gas boilers (irrespective of the design proposals) and that any active cooling system would be provided by electrically powered equipment. This is to ensure consistency with the requirements of the GLA guidance.
- 5.3 Regulated emissions are emissions which are covered by the Building Regulations and include the energy consumed in the operation of the space heating / cooling and hot-water systems, ventilation and internal lighting.
- 5.4 Unregulated emissions (i.e. those associated with cooking and all electrical appliances and other small power) have been separately calculated.
- 5.5 All emissions have been assessed using the SAP10 carbon factors. Non-domestic unregulated emissions have been taken from the unregulated emissions values generated by the SBEM models.

able 5.1 Carbon Diox	de Emissions (SAP10) -	- Baseline (Non-Domestic)
----------------------	------------------------	---------------------------

Step	Carbon Dioxide Emissions (Tonnes CO ₂ per annum)	
	Regulated	Unregulated
Baseline: Part L 2013	147.7	17.9



Demand Reduction (Be Lean) 6.

6.1 This section considers features of the proposed design (including indicative performance levels) relevant to passive design and energy efficiencies.

Passive Design

6.2 Passive design seeks to maximise the use of natural sources of heating, cooling and ventilation to maintain thermal comfort levels within the building.

Building Massing & Orientation

- 6.3 The building comprises a single block of ground plus upper storeys and is orientated on the northwest-southeast axis of the site.
- 6.4 The limited extent of south-facing surfaces will help reduce the direct solar gain and potential for overheating.
- 6.5 It is intended that windows will be set back slightly to provide a degree of shading from the sun. It is intended that the building will have the potential to be naturally ventilated (via openable window / vent), with ventilation rates calculated to ensure sufficient air chances per hour to maintain temperatures within a comfortable range.

Daylighting

6.6 The design of the glazed areas will seek to offer good access to natural daylight to reduce consumption of energy for artificial lighting. Overall, a balance shall be sought between achieving daylighting levels and winter solar gains, whilst minimising summer heat gains and cooling loads.

Fabric Efficiency

6.7 Fabric efficiency concerns the thermal properties associated with the building fabric and construction.

Insulation

- 6.8 Heat Transfer Coefficients, otherwise referred to as U-Values, are a measure of the rate of heat transfer through a building element over a given area, under standardised conditions (i.e. the rate at which heat is lost or gained through a fabric).
- 6.9 It is intended that the performance of the building fabric will incorporate relatively low U-Values to reduce the rate at which the buildings lose heat, preserving the heat within the space and reducing the requirement for mechanical heating.



Fabric Element	Part L2A (W/m ² K)	Proposed (W/m ² K)
External Wall	0.35	0.14-0.15
Roof	0.25	0.12
Ground Floor	0.25	0.12-0.13
Windows	2.2 (including frame)	1.4 (double glazed)

Table 6.1 Proposed Building Fabric U-Values (Non-Domestic)

Air Tightness

6.10 A high level of air tightness is proposed and a level below 3m³/h/m² is targeted, meaning that air infiltration between the internal and the external environment will be largely controlled and space heating demand further reduced.

Thermal Bridging

- 6.11 Thermal bridging is the penetration of the insulation layer by a highly conductive non-insulating material allowing rapid heat transfer from an interior to exterior environment (and vice versa). In well insulated buildings, as much as 30% of heat loss can occur through thermal bridges.
- 6.12 The building fabric shall be constructed so that there are no reasonably avoidable thermal bridges in the insulation layers caused by gaps within the various elements.

System Efficiencies

Heating Systems

6.13 It is proposed to incorporate low carbon and renewable technologies as the basis of the heating strategy (see sections below).

Ventilation / Cooling Systems

6.14 Mechanical Ventilation Heat Recovery (MVHR) will be included to ensure that heat losses are minimised. Mechanical cooling will be included on the basis that this is anticipated to be an expectation of end-users in a high-end hotel.

Extract Fans

6.15 It is anticipated that extract fans will be employed in WC and kitchen areas. The specific fan power (SFP) for these systems will be efficient and target a power consumption rate of 0.3W/l/s.

Controls

6.16 Time and temperature controls by suitable arrangement will be installed within occupied area in order to maximise the efficiency of the heating system.



6.17 The major energy uses shall be monitored via separate energy meters and a Building Energy Management System (BEMS) will be installed, which will allow for optimum operational control and performance of complex building services in the development.

Lighting Efficiency

- 6.18 Lighting design is intended to be highly efficient and in excess of Building Standards requirements. In the domestic components it is intended that lighting efficacy shall be in excess of 80 lumens/circuit Watt (likely predominantly LED).
- 6.19 External lighting shall be highly efficient and employ controls to avoid energy wastage from unnecessary operation during daytime.

Domestic Appliances

6.20 Within the dwellings, domestic appliances such as fridges, hairdryers etc. may be included. It is proposed that the EU energy label of these appliances shall be A+ or greater.



7. Heating Infrastructure (Be Clean)

District Energy Networks (DEN)

- 7.1 The term "district energy" applies to the energy distribution network, rather than the origins of the energy and the extent of any carbon savings will be largely determined by the energy source and heat losses on the network.
- 7.2 The London Heat Map is a tool provided by the Mayor of London to identify opportunities for decentralised energy projects in London and it builds on the 2005 London Community Heating Development Study.



Figure 7.1 Extract from the London Heat Map

- 7.3 The above extract from The London Heat Map shows the site located in an area of modest heat density. The wider area, as with much of central London, is defined as being a Heat Network Priority Area. However, the Site is not within a zone defined as Heat Mapping Decentralised Energy Potential.
- 7.4 No existing District Energy Networks (DEN) have been identified in close proximity to the site. The nearest potential network runs along the southern end of Charlton Street, taking heat off Euston Road (orange lines on the above image), circa 700m to the south.

District Energy Appraisal

7.5 In the absence of a DEN in close proximity to the Site, it is not proposed to accommodate DEN as part of the energy strategy.



Combined Heat & Power (CHP)

7.6 Combined Heat & Power (CHP) systems generate electrical energy and provide the waste heat from the process to be used on site. They are typically gas-fired but can be run off alternative fuel sources. CHP has been considered an efficient means of supplying heat in developments, providing significant carbon savings and wider environmental benefits (the power generation has historically been lower carbon emitting compared to grid electricity from the average UK power station). Savings from CHP are; however, reducing on the basis that grid electricity is decarbonising; meaning that carbon reductions associated with not using grid electricity are becoming marginal (or non-existent).

CHP Appraisal

- 7.7 Whilst the site has a heating demand, it is modest and likely subject to daily / weekly / yearly fluctuation due to occupancy patterns. At this scale, it is generally not economic to install CHP as smaller CHPs tend to have lower electrical efficiencies and therefore higher carbon emissions. CHP also tends to emit higher levels of NO_x than other heating systems; potentially adversely impacting local air quality.
- 7.8 A centralised CHP plant would create complex managerial arrangements and the administrative burden of managing CHP electricity sales to grid when the power is not required on site; combined with the relatively low unit price for small volumes of exported CHP electricity can create incentives for the CHP to be installed but not operated. CHP is therefore not proposed.



8. Renewable Energy (Be Green)

8.1 Renewable technologies are those which take their energy from sources which are considered to be inexhaustible (e.g. sunlight, wind etc.). Emissions associated with renewables are generally considered to be negligible and the technologies are frequently referred to as "zero carbon".

Biomass Systems

8.2 Biomass systems are heating systems that use agricultural, forest, urban and industrial residues and waste to produce heat and (depending on the system) electricity. At the building scale, biomass boilers using wood pellets or woodchips are the norm. Biomass should be sourced locally to limit "embodied carbon" associated with transport and ideally be derived from waste wood products to limit the take-up of agricultural land for fuel crops.

Biomass Appraisal

- 8.3 Whilst technically feasible, the site is in an urban setting and the absence of a readily available and diverse local fuel source creates risk associated with security of fuel supply. This has implications for operational viability.
- 8.4 Carbon emissions associated with cultivation, processing and transport of biomass are not normally considered in the context of planning or Building Regulations meaning that total carbon emissions are likely to be significantly higher than estimated. Biomass is also likely to cause other air quality impacts (e.g. particulates), which have implications for local air quality.
- 8.5 Biomass is therefore not a preferred technology for the scheme.

Heat Pumps

- 8.6 Heat pumps draw thermal energy from the air, water or ground ("source") and upgrade it to be used as useful heat at another location ("sink"). Heat pumps require electricity to operate (or gas in the case of Gas Absorption Heat Pumps) as mechanical input is required to convert harvested energy to useful heat and complete its transport to the "sink".
- 8.7 Heat pumps are generally considered as renewable (despite an electrical or gas requirement) because the source of the heat is the ambient temperature in the exterior environment, which is ultimately heated via the sun.
- 8.8 Reversible systems can provide air conditioning comfort cooling; however, when in cooling mode, the system is not considered renewable as it is not taking advantage of a renewable source of energy.



Heat Pump Appraisal

- 8.9 The absence of nearby water body and relatively small footprint of the site rule out the options of Water Source and Ground Source Heat Pumps.
- 8.10 There is potential to include Air Source Heat Pumps (ASHPs); and it is proposed to use this technology to provide space and hot water heating.

Micro Hydro Power

8.11 Micro hydro power systems harness energy from flowing water by using height differences (called "head"); the minimum allowable head is 1.5m and ideally not lower than 10m.

Micro Hydro Appraisal

8.12 No surface water courses are located in close proximity to the site. Micro hydro is therefore not considered an option.

Micro Wind Power

8.13 Wind turbines are used to generate electricity; with power production determined by the rotation of the blades and being proportionate to the speed of their rotation. The technology is most efficient for constant, low turbulence wind profiles.

Micro Wind Appraisal

8.14 Given the central London location and uncertainty over performance, the fact that any contribution will likely be quite minor, and that the application type (change of use) and heritage considerations would prohibit any external plant, wind turbines are rejected as an option.

Solar Systems

8.15 Both solar thermal and photovoltaic (PV) systems convert energy from the sun into a form which can be applied within the building. Solar thermal generates energy for heating (usually for hot water) and PV generates electricity. Hybrid photovoltaic / solar thermal collectors are also available and co-generate heat and power.

Solar System Appraisal

8.16 An extent of PV is proposed for the roof area. It is anticipated that these will be allocated to serve the demands for the hotel space.



9. Summary

- 9.1 This Energy Statement provides an overview of the energy strategy in consideration of the site context, anticipated energy requirements and local priorities and initiatives.
- 9.2 A review of Camden Council's planning policies has identified a number of requirements relating to energy. Of these, Local Plan policy CC1 (*Climate Change Mitigation*) is considered most pertinent along with Camden Planning Guidance *Energy Efficiency and Adaptation*. Consideration has also been given to the NPPF and GLA's London Plan and the targets contained therein.
- 9.3 The approach follows the Energy Hierarchy, with priority given to efficient design on the basis that it is preferable to reduce carbon emissions by reducing energy demand than through the use of low and/or zero carbon technologies.
- 9.4 The building's fabric shall be constructed to a high performance standard, achieving high levels of thermal insulation and low air permeability. Energy efficient lighting and appropriate controls shall be employed throughout the development.
- 9.5 A centralised Air Source Heat Pump (ASHP) shall be used to supply the heating for hot water. The system will also be future proofed with plant room space reserved to enable connection to any future district energy network, subject to this source of energy being available at commercially viable rates and with a lower associated carbon emissions than on-site systems.
- 9.6 Following the application of energy efficiency measures, space heating has been reduced to represent a relatively small proportion of the overall heating requirements and, due to the nature of the spaces and occupation, will be required to operate intermittently. A reversible ASHP is therefore proposed for space heating on the basis that it will allow for a significant degree of control (i.e. only applying heating when and where needed), will reduce the risk of uncontrolled and wasteful heat losses in the building (e.g. distribution losses) and can be coupled with mechanical cooling relatively simply (anticipated to be an expectation of end-users in a high-end hotel).
- 9.7 It is proposed to install an extent of photovoltaics (PV) at roof level which would assist in further reducing the carbon emissions.

Carbon Savings

9.8 Energy modelling has been undertaken using SBEM and the carbon savings delivered by each of the three steps of the Energy Hierarchy have been estimated (indicative outputs are included in the appendices).



Table 9.1 CO₂ Emissions after Each Stage of the Energy Hierarchy (SAP10)

Step	Carbon Dioxide Emissions (Tonnes CO ₂ per annum)	
	Regulated	Unregulated
Baseline	147.7	17.9
After energy demand reduction	143.4	17.9
After CHP	143.4	17.9
After renewable energy	47.0	17.9

Table 9.2 Regulated CO ₂ Savings from Each Stage of the Energy Hierarchy						
	Table 9.2	Regulated CO ₂	Savings from	Each Stage of	of the Energy	Hierarchy

	Regulated Carbon Dioxide Savings	
	(Tonnes CO ₂ per annum)	%
Savings from energy demand reduction	4.3	3%
Savings from CHP	0.0	0%
Savings from renewable energy	96.4	65%
Total Cumulative Savings	100.7	68%

- 9.9 A copy of the GLA Carbon Emission Reporting Spreadsheet is appended to this report outlining the savings at each stage of the Energy Hierarchy.
- 9.10 Overall, the proposed energy strategy is considered consistent with the National Planning Policy Framework, London Plan and policies of the Council. When implemented, the scheme will provide an efficient and low carbon development.



Appendices



A. Site Plans







B. Key Local Planning Policy Requirements



London Planning Policy Framework

Key London Plan planning policy is detailed below:

The London Plan as Altered (2016)

The London Plan is the overall strategic plan for London. Chapter five details London's Response to Climate Change and includes a number of policies that set the overarching principles for reducing carbon emissions in the built environment:

Policy 5.2 – Minimising Carbon Dioxide Emissions

Planning Decisions

- A) Development proposals should make the fullest contribution to minimising carbon dioxide emissions in accordance with the following energy hierarchy:
 - 1) Be lean: use less energy;
 - 2) Be clean: supply energy efficiently;
 - 3) Be green: use renewable energy.
- B) The Mayor will work with boroughs and developers to ensure that major developments meet the following targets for carbon dioxide emissions reduction in buildings. These targets are expressed as minimum improvements over the Target Emission Rate (TER) outlined in the national Building Regulations leading to zero carbon residential buildings from 2016 and zero carbon non-domestic buildings from 2019.

Residential Buildings:

Year	Improvement in 2010 Building Regs
2010-2013	25% (Code Level 4)
2013-2016	40%
2016-2031	Zero Carbon

Non-Residential Buildings:

Year	Improvement in 2010 Building Regs
2010-2013	25%
2013-2016	40%
2016-2019	As per building regulations requirements
2019-2031	Zero Carbon

- C) Major development proposals should include a detailed energy assessment to demonstrate how the targets for carbon dioxide emission reduction outlined above are to be met within the framework of the energy hierarchy.
- D) As a minimum, energy assessments should include the following details:
 - a) Calculations of the energy demand and carbon dioxide emissions covered by the Building Regulations and, separately, the energy demand and carbon dioxide emissions from any other part of the development, including



plant or equipment, that are not covered by the Building Regulations (see paragraph 5.22) at each stage of the hierarchy;

- b) Proposals to reduce carbon dioxide emissions through the energy efficient design of the site, buildings and services;
- c) Proposals to reduce carbon dioxide emissions through the use of decentralised energy where feasible, such as district heating and cooling and combined heat and power (CHP);
- d) Proposals to further reduce carbon dioxide emissions through the use of on-site renewable energy technologies.

The carbon dioxide reduction targets should be met on-site. Where it is clearly demonstrated that the specific targets cannot be fully achieved on-site, any shortfall may be provided off-site or through a cash in lieu contribution to the relevant borough to be ring fenced to secure delivery of carbon dioxide savings elsewhere.

Policy 5.3 – Sustainable Design & Construction [extract]

Planning Decisions

- B) Development proposals should demonstrate that sustainable design standards are integral to the proposals, including its construction and operation, and ensure that they are considered at the beginning of the design process.
- C) Major development proposals should meet the minimum standards outlined in the Mayor's supplementary planning guidance and this should be clearly demonstrated within a design and access statement. The standards include measures to achieve other policies in this Plan and the following sustainable design principles apply:
 - Minimising carbon dioxide emissions across the site, including the building and services (such as heating and cooling systems);
 - b) Avoiding internal overheating and contributing to the urban heat island effect;
 - c) Efficient use of natural resources (including water), including making the most of natural systems both within and around buildings;
 - d) Minimising pollution (including noise, air and urban run-off);

Policy 5.5 – Decentralised Energy Networks

Strategic

A) The Mayor expects 25 per cent of the heat and power used in London to be generated through the use of localised decentralised energy systems by 2025. In order to achieve this target the Mayor prioritises the development of decentralised heating and cooling networks at the development and area wide levels, including larger scale heat transmission networks.

LDF Preparation

- B) Within LDFs boroughs should developer policies and proposals to identify and establish decentralised energy network opportunities. Boroughs may choose to develop this as a supplementary planning document and work jointly with neighbouring boroughs to realise wider decentralised energy network opportunities. As a minimum, boroughs should:
 - a) Identify and safeguard existing heating and cooling networks;



- Identify opportunities for expanding existing networks and establishing new networks. Boroughs should use the London Heat Map tool and consider any new developments, planned major infrastructure works and energy supply opportunities which may arise;
- c) Developer energy master plans for specific decentralised energy opportunities which identify;
 - Major heat loads (including anchor heat loads, with particular reference to sites such as universities, hospitals and social housing);
 - Major heat supply plant;
 - Possible opportunities to utilise energy from waste;
 - Possible heating and cooling network routes;
 - Implementation options for delivering feasible projects, considering issues of procurement, finding and risk in the role of the public sector.

Require developers to prioritise connection to existing or planned decentralised energy networks where feasible.

Policy 5.6 – Decentralised Energy in Development Proposals

Planning Decisions

- A) Development proposals should evaluate the feasibility of Combined Heat and Power (CHP) systems, and where a new CHP system is appropriate also examine opportunities to extend the system beyond the site boundary to adjacent sites.
- B) Major development proposals should select energy systems in accordance with the following hierarchy:
 - 1) Connection to existing heating or cooling networks;
 - 2) Site wide CHP network;
 - 3) Communal heating and cooling.

Potential opportunities to meet the first priority in this hierarchy are outlined in the London Heat Map tool. Where future network opportunities are identified, proposals should be designed to connect to these networks.

Policy 5.7 – Renewable Energy

Strategic

A) The Mayor seeks to increase the proportion of energy generated from renewable sources, and expects that the projections for installed renewable energy capacity outlined in the Climate Change Mitigation and Energy Strategy and in supplementary planning guidance will be achieved in London.

Planning Decisions

B) Within the framework of the energy hierarchy (see Policy 5.2), major development proposals should provide a reduction in expected carbon dioxide through the use of on-site renewable energy generation, where feasible.

LDF Preparation

C) Within LDFs boroughs should, and other agencies may wish to development more detailed policies and proposals to support the development of renewable energy in London – in particular, to identify broad areas where specific renewable



All renewable energy systems should be located and designed to minimise any potential adverse impacts on biodiversity, the natural environment and historical assets, and to avoid any adverse impacts on air quality.

Policy 5.9 – Overheating and Cooling

ensphere

Strategic

A) The Mayor seeks to reduce the impact of the urban heat island effect in London and encourages the design of places and spaces to avoid overheating and excessive heat generation, and to reduce overheating due to the impacts of climate change and the urban heat island effect on an area wide basis.

Planning Decisions

- B) Major development proposals should reduce potential overheating and reliance on air conditioning systems and demonstrate this is in accordance with the following cooling hierarchy:
 - 1) Minimise internal heat generation through energy efficient design;
 - 2) Reduce the amount of heat entering a building in summer through orientation, shading, albedo, fenestration, insulation and green roofs and walls;
 - 3) Manage the heat within the building through exposed internal thermal mass and high ceilings;
 - 4) Passive ventilation;
 - 5) Mechanical ventilation;
 - 6) Active cooling.
- C) Major development proposals should demonstrate how the design, materials, construction and operation of the development would minimise overheating and also meet its cooling needs. New development in London should also be designed to avoid the need for energy intensive air conditioning systems as much as possible. Further details and guidance regarding overheating and cooling are outlined in the London Climate Change Adaptation Strategy.

LDF Preparations

Within LDFs boroughs should develop more detailed policies and proposals to support the avoidance of overheating and to support the cooling hierarchy.

Local Planning Policy Framework

Camden Local Plan (June 2017)

The Local Plan was adopted by Council on 3 July 2017 and has replaced the Core Strategy and Camden Development Policies documents as the basis for planning decisions and future development in the borough. Policies relevant to this report are presented below:

Policy CC1 Climate Change Mitigation

The Council will require all development to minimise the effects of climate change and encourage all developments to meet the highest feasible environmental standards that are financially viable during construction and occupation.

We will:

- a) Promote zero carbon development and require all development to reduce carbon dioxide emissions through following the steps in the energy hierarchy;
- b) Require all major development to demonstrate how London Plan targets for carbon dioxide have been met;
- c) Ensure that the location of the development and mix of land uses minimise the need to travel by car and help to support decentralised energy networks;
- d) Support and encourage sensitive energy efficiency improvements to existing buildings;
- e) Require all proposals that involve substantial demolition to demonstrate that it is not possible to retain and improve the existing building; and
- f) Expect all developments to optimise resource efficiency.

For decentralised energy networks, we will promote decentralised energy by:

- g) Working with local organisations and developers to implement decentralised energy networks in the parts of Camden most likely to support them;
- h) Protecting existing decentralised energy networks (e.g. at Gower Street Bloomsbury, Kings Cross, Gospel Oak, and Somers Town) and safeguarding potential network routes; and
- i) Requiring all major developments to assess the feasibility of connecting to an existing decentralised energy network, or where this is not possible establishing a new network.

To ensure that the Council can monitor the effectiveness of renewable and low carbon technologies, major developments will be required to install appropriate monitoring equipment.

Policy CC2 Adapting to Climate Change [extract] The Council will require development to be resilient to climate change.

All development should adopt appropriate climate change adaptation measures such as:

[...]

a) Measures to reduce the impact of urban and dwelling overheating, including application of the cooling hierarchy.

[...]



C. GLA Carbon Emissions Reporting Spreadsheet



Non-domestic

Table 3: Carbon Dioxide Emissions after each stage of the Energy Hierarchy for non-domestic buildings

	Carbon Dioxide Emissions for non-domestic buildings (Tonnes CO ₂ per annum)					
	Regulated	Unregulated				
Baseline: Part L 2013 of the Building Regulations Compliant Development	189.2					
After energy demand reduction (be lean)	175.8					
After heat network connection (be clean)	175.8					
After renewable energy (be green)	104.6					

Table 4: Regulated Carbon Dioxide savings from each stage of the Energy Hierarchy for non-domestic buildings

	Regulated non-domestic	carbon dioxide savings
	(Tonnes CO ₂ per annum)	(%)
Be lean: savings from energy demand reduction	13.4	7%
Be clean: savings from heat network	0.0	0%
Be green: savings from renewable energy	71.2	38%
Total Cumulative Savings	84.6	45%

Table 3: Carbon Dioxide Emissions after each stage of the Energy Hierarchy for non-domestic buildings

	Carbon Dioxide Emissions for non-domestic buildings (Tonnes CO ₂ per annum)					
	Regulated	Unregulated				
Baseline: Part L 2013 of the Building Regulations Compliant Development	147.7	17.9				
After energy demand reduction (be lean)	143.4	17.9				
After heat network connection (be clean)	143.4	17.9				
After renewable energy (be green)	47.0	17.9				

Table 4: Regulated Carbon Dioxide savings from each stage of the Energy Hierarchy for non-domestic buildings

	Regulated non-domestic carbon dioxide savings					
	(Tonnes CO ₂ per annum)	(%)				
Be lean: savings from energy demand reduction	4.3	3%				
Be clean: savings from heat network	0.0	0%				
Be green: savings from renewable energy	96.4	65%				
Total Cumulative Savings	100.7	68%				



SITE-WIDE

	Total regulated emissions (Tonnes CO ₂ / year)	CO ₂ savings (Tonnes CO ₂ / year)	Percentage savings (%)
Part L 2013 baseline	189.2		
Be lean	175.8	13.4	7%
Be clean	175.8	0.0	0%
Be green	104.6	71.2	38%
Total Savings	-	84.6	45%
	-	CO ₂ savings off-set (Tonnes CO ₂)	-
Off-set	-	3,138.2	-

	Total regulated emissions (Tonnes CO ₂ / year)	CO ₂ savings (Tonnes CO ₂ / year)	Percentage savings (%)
Part L 2013 baseline	147.7		
Be lean	143.4	4.3	3%
Be clean	143.4	0.0	0%
Be green	47.0	96.4	65%
Total Savings	-	100.7	68%
	-	CO ₂ savings off-set (Tonnes CO ₂)	-
Off-set	-	1,408.9	-







D. Indicative Energy Model Outputs (Be Lean)

Project name					
Bayam Street Hotel	Be	Lea	in		As designed
Date: Fri Aug 07 18:50:35 2020		-			
Administrative information					
Building Details Address: ,		0	wner D lame:	etails	
Certification tool Calculation engine: Apache		A	elephon Address:	e number:	
Calculation engine version: 7.0.12 Interface to calculation engine: IES Virtual Interface to calculation engine version: 7.0 BRUKL compliance check version: v5.6.a.	Environme).12 1	Certifier details Name: Telephone number: Address: , ,			
CO ₂ emission rate from the notional build Target CO ₂ emission rate (TER), kgCO ₂ /	ling, kgC(m².annum	O₂/m².an	num		70.5
Building CO2 emission rate (BER), kgCO	/m².annu	im			70.5 67.2
Building CO: emission rate (BER), kgCO Are emissions from the building less than Are as built details the same as used in t	/m².annu n or equal he BER c	im I to the t alculatio	arget? ons?		70.5 67.2 BER =< TER Separate submission
Building CO. emission rate (BER), kgCO Are emissions from the building less than Are as built details the same as used in the Criterion 2: The performance of the achieve reasonable overall stand Values which do not achieve the standards displayed in red. Building fabric	/m².annu or equal he BER o ne build ards of in the No	im I to the t calculation ling fa energ n-Domes	arget? ons? bric ar y effic stic Build	nd fixed iency ding Servic	70.5 67.2 BER =< TER Separate submission building services should es Compliance Guide and Part L are
Building CO. emission rate (BER), kgCO Are emissions from the building less than Are as built details the same as used in the Criterion 2: The performance of the achieve reasonable overall stand Values which do not achieve the standards displayed in red. Building fabric Element	./m².annu n or equal he BER o ne build ards of in the No	I to the t calculation ling fa energy n-Domes	arget? ons? bric ar y effic stic Built	nd fixed iency ding Servic Surface	70.5 67.2 BER =< TER Separate submission building services should es Compliance Guide and Part L are where the maximum value occurs*
Building CO. emission rate (BER), kgCO Are emissions from the building less than Are as built details the same as used in the Criterion 2: The performance of the achieve reasonable overall stand Values which do not achieve the standards displayed in red. Building fabric Element Wall**	./m².annu norequal he BER c ne build ards of in the No Un-Limit 0.35	ling fa energ n-Domes 0.14	arget? ons? bric at y effic stic Build Ui-Calc 0.4	nd fixed iency ding Servic Surface BS0000	70.5 67.2 BER =< TER Separate submission building services should es Compliance Guide and Part L are where the maximum value occurs* DC:Sur[9]
Building CO. emission rate (BER), kgCO Are emissions from the building less than Are as built details the same as used in the Criterion 2: The performance of the achieve reasonable overall stand Values which do not achieve the standards displayed in red. Building fabric Element Wall** Floor	//m².annu norequal he BER c he build ards of in the No 0.35 0.25	Lito the t calculation ling fa energy n-Domes 0.14 0.14	arget? ons? bric all y effic stic Build Ui-Calc 0.4 0.4 0.4	nd fixed iency ling Servic Surface BS0000 BS0000	70.5 67.2 BER =< TER Separate submission building services should es Compliance Guide and Part L are where the maximum value occurs* DC:Surf[9] DC:Surf[6] DC:Surf[6]
Building CO. emission rate (BER), kgCO Are emissions from the building less than Are as built details the same as used in the Criterion 2: The performance of the achieve reasonable overall stand Values which do not achieve the standards displayed in red. Building fabric Element Wall** Floor Roof	/m³.annu norequal he BER c he build ards of in the No 0.35 0.25 0.25	Uscale 0.14 0.13 0.12	arget? ons? bric al y effic stic Built 0.4 0.36 0.12	nd fixed iency ling Servic Surface BS0000 GR0000 GR0000	70.5 67.2 BER =< TER Separate submission building services should es Compliance Guide and Part L are where the maximum value occurs* DC:Surf[9] DC:Surf[0] 02:Surf[0] 02:Surf[0]
Building CO. emission rate (BER), kgCO Are emissions from the building less than Are as built details the same as used in the Criterion 2: The performance of the achieve reasonable overall stand Values which do not achieve the standards displayed in red. Building fabric Element Wall** Floor Roof Windows***, roof windows, and rooflights Descence doors	/m³.annu no requal he BER c ne build ards of in the No 0.35 0.25 0.25 5 2.2	Uscale Uscale Uscale Uscale 0.14 0.13 0.12 1.4	arget? ons? bric all y effic stic Build 0.4 0.36 0.12 1.4	nd fixed jency ling Servic BS0000 GR0000 GR0000 GR0000	70.5 67.2 BER =< TER Separate submission building services should es Compliance Guide and Part L are where the maximum value occurs* DC:Surf[9] DC:Surf[0] 02:Surf[0] 04:Surf[3] 02:Surf[1]
Building CO. emission rate (BER), kgCO Are emissions from the building less than Are as built details the same as used in the Criterion 2: The performance of the achieve reasonable overall stand Values which do not achieve the standards displayed in red. Building fabric Element Wall** Floor Roof Windows***, roof windows, and rooflights Personnel doors	/m².annu n or equal he BER c ne build ards of in the No Un.Limit 0.35 0.25 0.25 5 2.2 2.2 1.5	Uacalc 0.14 0.13 0.12 1.4 1.65	arget? ons? bric all y effic stic Build 0.4 0.36 0.12 1.4 1.65	d fixed iency Surface BS0000 GR0000 GR0000 GR0000 Dia Vici	70.5 67.2 BER =< TER Separate submission building services should es Compliance Guide and Part L are where the maximum value occurs* DC:Surf[9] DC:Surf[9] D0:Surf[1] de senere deere in building
Building CO. emission rate (BER), kgCO Are emissions from the building less than Are as built details the same as used in the Criterion 2: The performance of the achieve reasonable overall stand Values which do not achieve the standards displayed in red. Building fabric Element Wall** Floor Roof Windows***, roof windows, and rooflights Personnel doors Vehicle access & similar large doors	/m².annu n or equal he BER c ne build ards of in the No Un.Limit 0.35 0.25 0.25 5 2.2 2.2 1.5 3.5	Ito the t calculation ing fa energy n-Domes Us-Calc 0.14 0.13 0.12 1.4 1.65 -	arget? ons? bric all y effic stic Build 0.4 0.36 0.12 1.4 1.65 -	nd fixed iency Surface BS0000 GR0000 GR0000 GR0000 GR0000 No Vehin	70.5 67.2 BER =< TER Separate submission building services should es Compliance Guide and Part L are where the maximum value occurs* DC:Surf[9] DC:Surf[9] DC:Surf[1] DC:Surf[3] DC:Surf[1] cle access doors in building ueans entrange doors in building
Building CO. emission rate (BER), kgCO Are emissions from the building less than Are as built details the same as used in the Criterion 2: The performance of the achieve reasonable overall stand Values which do not achieve the standards displayed in red. Building fabric Element Wall** Floor Roof Windows***, roof windows, and rooflights Personnel doors Vehicle access & similar large doors High usage entrance doors Upane Elming rate weighted average Uvalues Upane Challender than one surface where the * Automatc Uvalue check by the tod does not a ** Deplay windows and similar gare weighted WB. Neither moly whildreds (inc. sunkey vents) no High uncoversion of ventilations of the surface were the * Automatc Uvalue check by the tod does not a ** Deplay windows and similar gare weighted HB. Neither moly whildreds (inc. sunkey vents) no	/m*.annu nor equal he BER of ards of in the No Ualimit 0.35 0.25 0.25 0.25 0.25 0.25 0.25 0.25 0.2	Ling fa energy n-Domes 0.14 0.13 0.12 1.4 1.65 - - - - - - - - - - - - -	arget? ons? bric all y effic U.cae 0.4 0.36 0.12 1.4 1.65 - - U.cae entrol to see the set of the	Ind fixed iency surface BS0000 GR0000 GR0000 GR0000 GR0000 No Vehin No High Salculated min g standard i delied or che	70.5 67.2 BER =< TER
Building CO. emission rate (BER), kgCO Are emissions from the building less than Are as built details the same as used in the Criterion 2: The performance of the achieve reasonable overall stand Values which do not achieve the standards displayed in red. Building fabric Element Wall** Floor Roof Windows***, roof windows, and rooflights Personnel doors Vehicle access & similar large doors High usage entrance doors Uncer = Catalabled area weighted average U-values Uncer = Catalabled area weighted average U-values New Hother roof ventiliters (inc. smoke vertip	/m ² .annu he BER c he build ards of in the No Ualimit 0.25 0.25 0.25 5 2.2 1.5 3.5 3.5 W/(mR) maximum t gyl to curta s (W/(mR))	Ling fa energy n-Domes Uscate 0.14 0.12 1.4 1.65 - - - - - - - - - - - -	arget? ons? bric all y effic 0.4 0.36 0.12 1.4 1.65 - - U-care = (- - - - - - - - - - - - -	Ind fixed iency Surface BS0000 GR000 GR0000 GR0000 GR0000 GR0000 GR0000 GR000 GR000 GR000 GR000 GR000 GR000 GR000 GR000 GR000 GR000 GR000 GR00 GR00 GR00 GR00 GR00 GR00 GR00 GR00 GR00 GR00 GR00 GR00 GR00 GR00 GR00 GR0 GR	70.5 67.2 BER =< TER

Building services

The standard values listed below are minimum values for efficiencies and maximum values for SFPs. Refer to the Non-Domestic Building Services Compliance Guide for details.

 Whole building lighting automatic monitoring & targeting with alarms for out-of-range values
 YES

 Whole building electric power factor achieved by power factor correction
 <0.9</td>

1- Heating Cooling

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(I/s)]	HR efficiency	
This system	0.96	5,82	0	1.3	0.85	
Standard value	0.91*	32	N/A	1.6^	0.5	
Automatic mon	itoring & targeting w	ith alarms for out-of	-range values for th	is HVAC syste	m YES	
* Standard shown is efficiency is 0.86 For	for gas single boller system any individual boller in a n	rs <=2 MW output. For sinc nuth-boiler system limiting	le bollor systems ≥2 MW c efficiency is 0.82	r multi-boilar system	ns, (overail) itmitting	

* Landing SFP may be indended by the annual's specified in the Non-Domestic Bailding Service's Compliance Guide if the system includes additional components as fished in the Guide.

2- Heating- (Baseline)

	Heating efficiency	Radiant efficiency	SFP [W/(I/s)]	HR efficiency			
This system	system 0.96 -		0.2	D	0.85		
Standard value	0.91*	N/A	N/A	N/A	0.5		
Automatic moni	itoring & targeting w	ith alarms for out-ol	f-range values for th	is HVAC system	m YES		
For online of the intervention of the statement of the							

1- DHW (Baseline)

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	0.96	-
Standard value	0.8	N/A

Local mechanical ventilation, exhaust, and terminal units

ID	System type in Non-domestic Building Services Compliance Guide											
A	Local supply or extract ventilation	n unit	s serv	ing a s	ingle	area						
в	Zonal supply system where the	fan is	remot	e from	the zo	ne						
C	Zonal extract system where the	fan is	remot	e from	the zo	one						
D	Zonal supply and extract ventila	tion u	nits se	rving a	singli	e roon	or zo	ne wit	h heat	ing ar	nd heat re	ecovery
E	Local supply and extract ventila	tion sy	stem	serving	a sin	gle an	sa with	heati	ng and	heat	recovery	1
F	Other local ventilation units							_				
G	Fan-assisted terminal VAV unit											
н	Fan coil units											
Ê.	Zonal extract system where the	where the fan is remote from the zone with grease filter										
Zon	ne name	-			S	P [W	(Vs)]				1	
-	ID of system type	A	B	C	D	E	F	G	H	15	HRE	efficiency
	Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
Stat	ff Change	S	-	-2	-	0.11	-	-	10.3	-	- C	N/A
Con	nms	8	-	8	-	÷	-	•	0.3	-		N/A
Staf	ff Breakout	÷.,	-	4.	÷.:	100	-	1	0.3	1.		N/A
Circ	sulation	6.0	-	×	×	5	-		0.4	-		N/A
Circ	ulation			÷1.1	•	*		+	0.4	1.0	-	N/A
	Kitchen		-	12	1		1.	1	70.3	1	1.	6.128

Oensphere

A 0.3	B 1.1	C 0.5	D	E	F	G	H	1	nr.	niciency
0.3	1.1	0.5	10						-	
3			1.9	1.6	0.5	1.1	0.5	1	Zone	Standar
	-	1	-	27	-	1	0.4	-	-	N/A
7	-	÷.,	-	20	-	10	0,4		~	N/A
-	-	-		-	•	-	0.3	10		N/A
-	-	-	•	1		-	0.4	51	•	N/A
-	-		-	•	-	-	0.3		-	N/A
-	-		-	•	•	-	0.3		-	N/A
-	-		-	-	-	-	0.4	•		N/A
-	+		÷	-	-	-	0.4	10		N/A
-	-		-	•	-	-	0.3		-	N/A
-	-	-	-	21	-	2	D.4	27	-	N/A
-	-	· .	-	10	-	-	0.3	~	5	N/A
÷1.	-	•	× .	-7	-	-	0.3		· ·	N/A
-	-		< :	-0.	-	-	0.4		-	N/A
-	-	-	5	-	-	-	0.3	•	-	N/A
1	4	÷.	-	-	-	-	0.4	+	*	N/A
-	-	+	-	÷	-	-	0.3	÷τ.		N/A
-	•		-	=	-	-	0.4			N/A
+	+	-	-	-	+	+	0.4	-1	-	N/A
-	-	-	÷		•	-	0.3	1	÷	N/A
-	-	-	-	÷	•	-	0.4	-		N/A
-	-		-	-	-	-	E.0	÷.	-	N/A
12	-	4	-	-	-	-	0,4	4	-	N/A
-	-	1	-	1	-	-	0.3	100	-	N/A
-	-	-		-		-	0.3		-	N/A
-	-	-	-	- 2		-	0.4	-	-	N/A
-	-	-	-	-	-	-	0.4	-	~	N/A
-	-	1	-	-	-	-	0.3	-	-	N/A
10	-	-	-	-	-	100	0.3	100	-	N/A
-	-	+	-	2.0	-	-	0.4	+1	-	N/A
-1	-		-			-	0.4			N/A
-			-	-	-	-	0.3			N/A
- (-		-		-	-	0.4		-	N/A
-	-		-	-			03		-	N/A
-	-	2	-	40	-	1.	0.3	4	-	N/A
4	-	-	12.1	1.0	-	-	0.4		~	N/A
1.5	-		-	1.	-	2	0.4	1.	-	N/A
1.2	-		-		-	-	0.3		-	N/A
1.		-	-	-		-	0.3		-	N/A
-	1.		-	-		-	0.4		-	N/A
1.	1.	-	-	-		1.	0.3	1.	1.	N/A
1	1		-	-		-	0.4		-	N/A
	1.				1.		04			N/A
1.	1.	1.	1.		1.		0.4		1.	N/A
		- - - -		NNN		NN <t< td=""><td>NNN<tr< td=""><td>- - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.4 - - - - 0.4 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.4 - -</td><td>- - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - -</td><td>- - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - 0.3 - - 0.3 - - - - 0.4 - - - 0.4 - - - - - 0.3 - - - 0.3 - - - - - - 0.3 - - - - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - -</td></tr<></td></t<>	NNN <tr< td=""><td>- - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.4 - - - - 0.4 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.4 - -</td><td>- - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - -</td><td>- - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - 0.3 - - 0.3 - - - - 0.4 - - - 0.4 - - - - - 0.3 - - - 0.3 - - - - - - 0.3 - - - - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - -</td></tr<>	- - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.4 - - - - 0.4 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.4 - -	- - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - -	- - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - 0.3 - - 0.3 - - - - 0.4 - - - 0.4 - - - - - 0.3 - - - 0.3 - - - - - - 0.3 - - - - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - -

Zone name	1	SFP [W/(I/s)]									an
ID of system type	A	в	C	D	E	F	G	H	1	HRE	mciency
Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
en suite 08	8	-	-	-	-	-	1	0.4	-	-	N/A
Suestroom 08	7	-	÷	-	10	-	-	0,3		×	N/A
Suestroom 04	-	-	-		-	-	-	0.3	10		N/A
en suite 04	÷	-	-	•	1.1		-	0.4	-		N/A
Guestroom 05	-	-		-		-	-	0.3		-	N/A
an suite 05	- E -	-		-	÷	•		0.4			N/A
en sulte 07	÷.	-		-	-	-	-	0.4	÷		N/A
Guestroom 07		+		÷	-		-	0.3			N/A
Circulation	-			-	•		-	0.4	-	-	N/A
Suestroom 09	-	-	2	-	21	-	2	0.3	27	2	N/A
Guestroom 01	-	-	÷	-	4	-	-	0.3	~	4	N/A
en suite 01		-	-	-	-	-	-	0.4		-	N/A
Guestroom 02	-	-		-	->	-	-	0.3	•	-	N/A
en suite 02	-	-	-	-	-	-	-	0.4	-	-	N/A
Guestroom 05	÷	4	÷	-	-	-	-	0.3	1.0	*	N/A
en suite 05	÷	-	÷	-	÷	4.1	-	0.4	÷1	-	N/A
en suite 06	÷., .	•	e .	-	e1 -	-	-	0.4			N/A
Suestroom 06	+	+	-	-	-	+	+	0.3	-1	-	N/A
en suite 07		-	2	*			-	0.4	14		N/A
Guestroom 07	-	-	÷	-	÷	•	1.0	6.0	-		N/A
Guestroom 08	1	-		-	-	-	14	E.0	÷.	-	N/A
en suite 08	2	-	4	-	**	-	-	0,4	4	-	N/A
Suestroom 09	-	-	1.	-	10	-	-	0.3	100	-	N/A
en suite 09	-	-	-		· · ·		-	0.4	-	4	N/A
en suite 10	-	-	-	-	-2		-	0.4	•	÷	N/A
Suestroom 10	-	-	÷	-	· • .	-	-	0.3	-	*	N/A
en suite 12	-	-	÷	· ·	-		-	0.4	1	-	N/A
Suestroom 12	0	-	100	-	10	-	100	0.3	÷C	-	N/A
Suestroom 13	+.II	-	÷	-	÷	-	-	0.3	÷τ		N/A
en suite 13	-1	-				-	-	0.4			N/A
en suite 14	1	+		-	-	-	-	0.4	-	-	N/A
Suestroom 14	+	-	-				-	0.3	-	-	N/A
Guestroom 15	-	-	-	-	-	-	-	0.3		-	N/A
an suite 15	-0	-	2	-	60	-	2	0.4	4	-	N/A
an suite 16	4	-	-	-	÷.	-	÷	0.4		1	N/A
Suestroom 16	-	-	-	÷	÷	-	2	0.3	1.	-	N/A
en suite 19	÷	-		-	•	-	-	0.4	-	×.	N/A
Guestroom 19	1	-	-	-	-	-	-	0.3	-	-	N/A
Suestroom 18	-	-		-	-	-	-	0.3	-	-	N/A
en suite 18	8		-	-	-	-	-	0.4	-	-	N/A
en suite 17	20	-	+	-	-	-	Ļ. I	0.4	-	-	N/A
Guestroom 17	-			-	-		-	0.3			N/A
Guestroom 03	-	-		-				0.3			N/A
Suestroom 19 Suestroom 18 en suite 18 en suite 17 Guestroom 17 Guestroom 03						•		0.3 0.3 0.4 0.4 0.3 0.3			N/A N/A N/A N/A N/A

Oensphere

Zone name	1		_	S	FP [W	/(I/s)]			-	UD.	
ID of system type	A	в	C	D	E	F	G	н	1	HR	mciency
Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standar
en suite 03	31	-	1	-	20	-	1	0.4	-	2	N/A
en suite 04	~	-	÷.,	-	1	-	-	0,4		1	N/A
Guestroom 04	-	•	-		-		-	0.3	10		N/A
Guestroom 11	-	-	-		1		-	0.3	51		N/A
en suite 11	-	-		-	•	-	-	0.4			N/A
Circulation	-	-	•	-	•		-	0.4			N/A
Circulation	1	-	-	-	-	-	-	0.4	÷.		N/A
Guestroom 01	-	-	-	÷	-	-	-	0.3			N/A
en suite 01	-	-		-	•	-	-	0,4		-	N/A
Guestroom 02	-	-	-	-	21	-	2	0.3	1		N/A
en suite 02	-	-	÷	1	44	-	-	0.4	~	14-	N/A
Guestroom 03	-1	-	•	-	-7	-	-	0.3		÷	N/A
en suite 03	-	-		< :	•	-	-	0.4		-	N/A
Guestroom 04	-	-	-	5	-		-	0.3	-	-	N/A
en suite 04	-	4	÷	-	100	-	-	0,4	10	*	N/A
en suite 05	4	-	+	-	-	-	-	0.4	÷.	-	N/A
Guestroom 05	÷.,		-	-		-	-	0.3			N/A
Guestroom 07	-		-	-	-1	+	+	0.3	-1		N/A
en suite 07	-	-	2	2	-	-	-	0.4	14	÷	N/A
en suite 08	-			-			-	0.4	1.0		N/A
Guestroom 08	-	-		-	-	-	-	E.0	1.0	2	N/A
en suite09	2	-	1.	-	-	-	-	0.4		-	N/A
en suite 10	-		12	-	20		-	0.4	1	-	N/A
Guestroom 10	-	-		-	-		-	0.3		4	N/A
Guestroom 11	-	-		-		1.	-	0.3	-	6	N/A
en suite 11	-	-	1.	-	-	-	-	0.4	-	2	N/A
en suite 12	-		1.2	-	-		-	0.4		-	N/A
Guestroom 12	1	-	-	-	-	-	-	0.3	-	-	N/A
Guestroom 13	-		-	-	1.0		-	0.3	1.		N/A
en suite 13						1.		0.4			N/A
Guestroom 14				-				0.3			N/A
en suite 14	-	-		-				0.4	1.	1.	N/A
Guestroom 15		1.		12				0.3			N/A
an suite 15	1.0	1.	1.		1.0		1.	0.4	12	-	N/A
en suite 16	1	1.			1.1			0.4	1	1.	N/A
Guestroom 15	12	1	1	1.	12	1	2	0.3	1	12	N/A
en quite 08	10-	1	1	1	1	1	1	0.4	1	10	N/A
Cuertrees 08	1-	-	-	-	-	-	-	0.4	-	-	NUA
Guestioom 17	13-	1	-	-	-	-	-	0.3	1	1	NUA
Guestroom 17	-	-	-	-	-	-	-	0.3	-	-	NUA
an outeal?	1	-	-	-	1		-	0.3	-	1	NUA
en suite //	-	-	-	-	-		-	0.4	1	-	NUA
circulation	-		1	-	-		1	0.4			N/A
circulation	1.	-	1.	1.5	5		1.1	0.4		1.	N/A

Zone name	1			S	FP [W	//(l/s)]			_		
ID of system type	A	в	С	D	E	F	G	H	1	HRe	fficiency
Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
circulation	8	-	-	-	-	100	-	0.4	-	-	N/A
Guestroom 03	۳.	-	÷		10		-	0.3	-	-	N/A
en suite 03	-0	-	٠.		÷.	•	-	0.4	-		N/A
en suite 06		-			1		-	0.4	-		N/A
Guestroom 01	-	-		-				0.3		-	N/A
Guestroom 01	÷	-			+			0.3		-	N/A
Guestroom 02	1	-	+				-	0.3	-		N/A
Guestroom 02	4.1		4	-	-		-	0.3		-	N/A
Guestroom 06			*		-		-	0.3	-	-	N/A
circulation	-	-	2	-	2.1	-	2	D,4	-	2.00	N/A
Circulation	1	-		-	14	1.		0.4	-	-	N/A
en suite 1	-	-		-	-7	-	-	0.4		-	N/A
Guestroom 1	-	-		-	-0	-	-	0.3	-	-	N/A
en suite 2	-	-		-	-		-	0.4		-	N/A
Guestroom 2	5	-	÷.	-	10		-	0.3	4	-	N/A
Guestroom 3	4			-	-	1	-	0,3	÷ 1	÷	N/A
en suite 3			-	-	-1	1.	-	0.4		4	N/A
en suite 4	-			-	-		-	0.4	-		N/A
Guestroom 4	-		2	-	1.			03	1.		N/A
Guestroom 5	-	1.	-	-			1.1	03	1.		N/A
Guestroom 5	1			-	1.1		2.	0.3			N/A
Guestroom 6	2			-	-	1.		0.3		1	N/A
en suite 6	-			-	1.1	1.		0.4		1.	N/A
Guestroom 7	-			-	-	1.		03		-	N/A
en suite 7	-			1.		1.	-	0.4	-		N/A
Guestroom 8	-	-	1	1	1	1.		03	-	-	N/A
en suite 8	-		12	-	12	1.	-	0.4		1.	N/A
Guestroom 9			-		1	1.	1	0.3			N/A
en suite 9	-			-	1	1.	-	0.4	-	-	N/A
Guestroom 10		1		1		1.	1	0.3		-	NUA
an suite 10		1				1.	1	0.4		-	N/A
en suite 10				-	17	1-	10	1.0.4	1	1	196
General lighting and display lighti	ng		-	Lu	mino	us effic	acy [m/W]			
Zone name			1	umina	ire	Lamp	Disp	play la	mp	General I	ighting (W
St	andai	d valu	e E	60	-	60	22	_	-		
Staff Change	_				-	100	-		-	125	
Comms	_		1	00	-	·	171		1	49	
Staff Breakout				-	-	100	<u>.</u>			62	
Circulation	_		-	_	-	100	100		-	29	
Circulation				-	_	100	2			53	
Stairwell				-	_	100		_		38	
Kitchen			-		_	100	-			465	
Acc WC			-	C		100	15			30	
<u>NUC 110</u>			1			100	13			100	

ensphere General lighting and display lighting Luminous efficacy [Im/W] Zone name Luminaire Lamp Display lamp General lighting [W] Standard value 60 60 22 Circulation 100 46 Staff Cycle 100 10 ÷ . 100 Admin 162 100 Goods In 15 Restaurant & Bar 100 60 839 Reception 100 60 200 Circulation 100 -60 en suite 02 100 12 Guestroom 02 100 -27 en suite 03 100 9 29 Guestroom 03 100 100 24 Guestroom 06 en suite 01 100 12 Guestroom 01 100 22 en suite 06 100 11 28 Stairwell 100 Guestroom 10 100 26 100 11 en suite 10 100 -13 en suite 11 100 28 Guestroom 11 100 13 en suite 12 100 33 Guestroom 12 100 en suite 15 9 100 26 Guestroom 15 Guestroom 16 100 -27 en suite 16 100 -10 en suite 19 100 -11 Guestroom 19 100 -29 Guestroom 18 100 -26 en suite 18 100 + 10 en suite 17 100 -10 Guestroom 17 100 -26 en suite 13 100 -10 26 Guestroom 13 100 -26 Guestroom 14 100 en suite 14 100 -10 en suite 20 100 -12 Guestroom 20 100 -31 Guestroom 22 100 -27 en suite 22 100 -10 Guestroom 21 25 100 en suite 21 100 -10 Circulation 100 -72

Page 7 of 17

Zone name	Luminaire	Lame	Display land	General listeine fue
Standard value	60	60	22	Seneral lighting [VV]
an suite 09		100		11
en suite 08		100	2	10
Guestroom 08	<u> </u>	100		28
Guestroom 04		100	2	25
an enite 04		100	2	10
Guestroom 05		100		26
en sulta 05	-	100	2	10
en suite 07		100		10
Guertroom 07	-	100	6	20
Oresulation		100	-	104
Customer 00	-	100	-	29
Guestroom 09	-	100	7	20
Guestroom 01	-	100	0	10
en suite u i	-	100	2	10
Guestroom 02	-	100	2	20
en suite uz	1	100	5	10
Guestroom 05	1	100	2	31
en suite up	-	100	5	10
en suite U6	-	100	-	12
Guestroom 05	•	100		26
en suite 07	-	100	<u>.</u>	10
Guestroom 07	*	100	-	26
Guestroom 08	*	100	2	28
en suite 08	-	100	5	14
Guestroom 09	^	100	-	33
en suite us	-	100	1	14
en suite 10	· .	100	-	10
Guestroom 10	*	100	-	27
en suite 12	1	100	2	10
Guestroom 12	•	100	2	27
Guestroom 13	•	100	*	27
en suite 13	-	100	-	10
en suite 14	•	100		10
Guestroom 14	-	100	-	26
Guestroom 15	•	100	2	27
en suite 15	1	100	÷	10
en suite 16	~	100	~	11
Guestroom 16	-	100	5	30
Stairwell	-	100	÷	28
en suite 19	1	100	2	10
Guestroom 19	1	100	ž	29
Guestroom 18	-	100	-	25
en suite 18	*	100	÷.	10
en suite 17		100	e	13

ensphere General lighting and display lighting Luminous efficacy [Im/W] Zone name Luminaire Lamp Display lamp General lighting [W] Standard value 60 60 22 Guestroom 17 100 31 Guestroom 03 100 24 en suite 03 100 9 100 en suite 04 10 100 -Guestroom 04 32 100 Guestroom 11 26 en suite 11 100 10 Circulation 100 104 Circulation 100 46 stairwell 100 27 23 Guestroom 01 100 100 11 en suite 01 Guestroom 02 100 25 en suite 02 100 11 Guestroom 03 100 23 en suite 03 100 9 31 Guestroom 04 100 100 en suite 04 9 100 -10 en suite 05 100 31 Guestroom 05 100 28 Guestroom 07 en suite 07 100 11 100 16 en suite 08 100 29 Guestroom 08 en suite09 100 -16 en suite 10 100 -10 Guestroom 10 100 -27 Guestroom 11 100 -27 en suite 11 100 -10 en suite 12 100 + 10 Guestroom 12 100 -26 Guestroom 13 100 -26 en suite 13 100 -10 Guestroom 14 100 -26 en suite 14 10 100 -Guestroom 15 100 -26 en suite 15 100 -10 en suite 16 100 -11 27 Guestroom 16 100 en suite 06 100 -13 30 Guestroom 06 100 Guestroom 17 34 100 -Guestroom 09 100 -35

General lighting and display lighting	Lumine	ous effic	acy [im/W]	
Zone name	Luminaire	Lamp	Display lamp	General lighting [W]
Standard value	60	60	22	
en suite17	2	100	-	14
circulation	-	100	2	46
circulation	- C	100	-	108
circulation		100	2000 A	57
Guestroom 03	•	100	÷	39
en suite 03	•	100		21
en suite 06	-	100	-	26
Guestroom 01	·	100	×	20
Guestroom 01	•	100	÷	37
Guestroom 02	-	100	2	44
Guestroom 02	2	100	+	22
stairwell	*	100	5	27
Guestroom 06	~	100	L	65
circulation	-	100	8	96
Circulation	-	100	e	79
en suite 1	-	100	-	23
Guestroom 1	-	100	e	57
en suite 2	-	100		14
Guestroom 2	÷	100	-	35
Guestroom 3	-	100	<u>k</u> .	32
en suite 3	+	100 -	÷.	14
en suite 4	~	100	*	14
Guestroom 4	2	100	i i	33
Guestroom 5	*	100	-	33
Guestroom 5	-	100	-	14
Guestroom 6	×.	100	2	30
en suite 6	÷	100	2	22
Guestroom 7	-	100	2	28
en suite 7	-	100	÷	18
Guestroom 8	•	100		52
en suite 8	-	100	-	13
Guestroom 9	÷	100	-	39
en suite 9		100	÷	14
Guestroom 10	× .	100	×	40
en suite 10	×	100	÷	15

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
Staff Change	N/A	N/A
Commis	N/A.	N/A
Staff Breakout	N/A.	N/A
Circulation	N/A	NIA
Circulation	N/A	N/A

Page 9 of 17

Page 10 of 17

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
Kitchen	N/A	N/A
Acc WC	N/A.	N/A
Circulation	N/A.	N/A
Admin	N/A.	N/A
Goods In	N/A.	N/A
Restaurant & Bar	NO(+63%)	NO
Reception	N/A	N/A
Circulation	N/A.	N/A
en suite 02	N/A.	N/A
Guestroom 02	NO (-68.4%)	NO
en suite 03	N/A.	N/A
Guestroom 03	N/A.	N/A
Guestroom 06	NO (-58%)	NO
en suite 01	N/A.	N/A
Guestroom 01	NO (-60.6%)	NO
en suite 06	N/A	N/A
Guestroom 10	NO (+64:2%)	NO
en suite 10	N/A.	N/A
en suite 11	N/A	N/A
Guestroom 11	NO (+65.2%)	NO
en suite 12	N/A	N/A
Guestroom 12	NO (-34.1%)	NO
en suite 15	N/A	N/A
Guestroom 15	NO (-13.4%)	NO
Guestroom 16	NO (-13.8%)	NO
en suite 16	N/A	N/A
en suite 19	NO (-10,236)	NO
Guestroom 19	NO (-22.3%)	NO
Guestroom 18	NO /-12%/	NO
en suite 18	N/A	N/A
en suite 17	N/A.	N/A
Guestroom 17	NO (+10.8%)	NO
en suite 13	N/A	N/A
Guestroom 13	NO (-9.9%)	NO
Guestroom 14	NO (-11,5%)	NO
en suite 14	N/A	N/A
en suite 20	N/A	N/A
Guestroom 20	NO (-66.6%)	NO
Guestroom 22	NO (-74.7%)	NO
en suite 22	N/A	N/A
Guestroom 21	NO [-61,2%]	NO
en suite 21	N/A	N/A
Circulation	N/A	N/A
an cuite 00	N/A	N/A
an quite 08	N/A	N/A
Guestroom 08	NO (-76.9%)	NO
Guestroom 04	NO 170.0 ml	NO
Substitutin u4	NUA	N/A
Cuestiener OF	N/A	NO
Guestiooffi US	LACI L-OCTAUD1	NO

ensphere

Zone	Solar gain limit exceeded? (%)	Internal blinds used
en suite 05	N/A.	N/A
en suite 07	N/A	N/A
Guestroom 07	NO (-65/2%)	NO
Circulation	N/A.	N/A
Guestroom 09	NO (-68.7%)	NO
Guestroom 01	NO((+80.9%)	NO
en suite 01	N/A.	N/A
Guestroom 02	NO((+83:7%))	NO
en suite 02	N/A.	N/A
Guestroom 05	NO (-86.8%)	NO
en suite 05	N/A.	N/A
en suite 06	N/A.	N/A
Guestroom 06	NO (-77.3%)	NO
en suite 07	N/A.	N/A
Guestroom 07	NO (-63%)	NO
Guestroom 08	NO (-64.7%)	NO
en suite 08	N/A.	N/A
Guestroom 09	NO (-47.4%)	NO
en suite 09	N/A.	N/A
en suite 10	N/A.	N/A
Guestroom 10	NO (-31.4%)	NO
en suite 12	N/A	N/A
Guestroom 12	NO (-32/2%)	NO
Guestroom 13	NO (-32.8%)	NO
en suite 13	N/A	N/A
en suite 14	N/A	N/A
Guestroom 14	NO 6-29,7%X	NO
Guestroom 15	NO 1-31 5%)	NO
en suite 15	NIA	NIA
en suite 16	N/A	NIA
Guestroom 16	NO LAD BOL	NO
an quite 10	N/A	N/A
Guestman 19	NO CTR AND	NO
Guestroom 19	100 (710 4 m)	NO
en cuite 19	N/A	N/A
en suite 17	N/A	N/A
Guestreen 17	NOV 68 3WY	NO
Guestroom 17	NO (26 200)	NO
en aute 03	N/A	NUA
en suite 0.	NUO.	hua.
Cuesties of	NOT BT BNI	NG
Guestroom 11	NO (-97,6 %)	NO
Guessoom 11	NO (-30,37m)	MIA
Classification	N/A.	N/A
Circulation	N/A.	N/A
Girculation	N/A.	N/A
Guestroom UT	NO (-83 AM)	110
en suite 01	N/A	N/A
Guestroom 02	NO (-84 1%)	NO
en suite 02	N/A.	N/A

Zone	Solar gain limit exceeded? (%)	Internal blinds used
Guestroom 03	NO (-75.6%)	NO
en suite 03	N/A	N/A
Guestroom 04	NO (-67.7%)	NO
en sulte 04	N/A.	N/A
en suite 05	N/A.	N/A
Guestroom 05	NO (-87.7%)	NO
Guestroom 07	NO (+66:7%)	NO
en suite 07	N/A.	N/A
en suite 08	N/A.	N/A
Guestroom 08	NO (-66.4%)	NO
en suite09	N/A.	N/A
en suite 10	N/A.	N/A
Guestroom 10	NO (-32%)	NO
Guestroom 11	NO (-30.6%)	NO
en suite 11	N/A.	N/A
en suite 12	N/A.	N/A
Guestroom 12	NO (-30%)	NO
Guestroom 13	NO (-29.3%)	NO
en suite 13	N/A.	N/A
Guestroom 14	NO (-29.6%)	NO
en suite 14	N/A.	N/A
Guestroom 15	NO (-30.3%)	NO
en suite 15	N/A.	N/A
en suite 16	N/A.	N/A
Guestroom 16	NO (-33%)	NO
en suite 06	N/A	N/A
Guestroom 06	NO (-82.5%)	NO
Guestroom 17	NO (-80.3%)	NO
Guestroom 09	NO (-50,3%)	NO
en suite17	N/A.	N/A
circulation	N/A	N/A
circulation	NO (+52:1%)	NO
circulation	N/A.	N/A
Guestroom 03	NO (-29.8%)	NO
en suite 03	N/A.	N/A
en suite 06	N/A	N/A
Guestroom 01	NO (-14%)	NO
Guestroom 01	NO (-23.6%)	NO
Guestroom 02	NO (-35.2%)	NO
Guestroom 02	NO (-25.9%)	NO
Guestroom 06	YES (+18.6%)	NO
circulation	N/A	N/A
Circulation	N/A.	N/A
en suite 1	N/A.	N/A
Guestroom 1	NO (+95.1%)	NO
en suite 2	N/A.	N/A
Guestroom 2	NO (-83,2%)	NO
Guestroom 3	N/A	N/A
en suite 3	N/A.	N/A

ensphere

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
en suite 4	N/A.	N/A
Guestroom 4	NO (-77%)	NO
Guestroom 5	NO (-84.8%)	NO
Guestroom 5	N/A.	N/A
Guestroom 6	NO (-72.2%)	NQ
en suite 6	N/A.	N/A
Guestroom 7	NO((-83.3%))	NO
en suite 7	N/A.	N/A
Guestroom 8	N/A.	N/A
en suite 8	N/A	N/A
Guestroom 9	N/A.	N/A
en suite 9	N/A.	N/A
Guestroom 10	N/A.	N/A
en suite 10	N/A.	N/A

Criterion 4: The performance of the building, as built, should be consistent with the calculated BER

Separate submission

Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place

Separate submission

EPBD (Recast): Consideration of alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	VES
Is evidence of such assessment available as a separate submission?	YES
Are any such measures included in the proposed design?	YES

Peers 14 of 1/

Building Global P	arameters	;	Buil	ding Use
	Actual	Notional	% Are	ea Building Type
Area [m²]	2362	2362		A1/A2 Retail/Financial and Professional services
External area [m ²]	3278.6	3102.2		A3/A4/A5 Restaurants and Cafes/Drinking Est/Takeaways
Veather	LON	LON		B1 Offices and workshop businesses B2 to B7 General Industrial and Special Industrial Groups
nfiltration [m³/hm²@ 50Pa	3	3		B8 Storage or Distribution
Average conductance [W/A	() 653.95	900.91	100	C1 Hotels
Average U-value [W/m ³ K]	0.2	0.29		C2 Residential Institutions: Hospitals and Care Homes
Npha value* [%]	10.96	10		C2 Residential Institutions: Residential schools C2 Residential Institutions: Universities and colleges
				D1 Non-residential Institutions: Education D1 Non-residential Institutions: Education D1 Non-residential Institutions: Primary Health Care Building D1 Non-residential Institutions: Crown and County Counts D2 General Assembly and Leisure, Night Clubs, and Theatres Others: Enseigner terminals Others: Enseigner terminals Others: Care Parks 24th activities Others: Care Parks 24th activities
Energy Consump leating coling uxiliary ighting let unter	tion by Er Actual 10.03 2.16 24.59 9.28 214.7	Notional 14.78 3.81 25.7 16.66 202.41	n²]	Contrata, onand aona aony taoka
Energy Consump teating cooling uxiliary ighting tot water suipment*	tion by Er Actual 10.03 2.16 24.59 9.28 214.7 23.65	d Use [kWh/r Notional 14.78 3.81 25.7 16.66 203.41 23.65	n²]	
Energy Consump leating cooling wxiliary ighting tot water iquipment* roTAL**	tion by Er Actual 10.03 2.16 24.59 9.28 214.7 23.65 260.76	d Use [kWh/r Notional 14.78 3.81 25.7 16.66 203.41 23.65 264.36	n²]	contra otario aone any aoos
Energy Consump leating cooling uxillary ighting lot water Equipment* OTAL** Energy Productio	tion by Er Actual 10.03 2.16 24.59 9.28 214.7 23.65 260.76 teach be total for control by CPP parent by CPP parent Actual	d Use [kWh/n Notional 14.78 3.81 25.7 16.66 203.41 23.65 264.36 commention or arCalatty et nology [kWh/ Notional	n²]	
Energy Consump leating cooling wxiliary ighting tot water coupment* OTAL** Energy Productio Photovoltaic systems	tion by Er Actual 10.03 2.16 24.59 9.28 214.7 23.65 260.76 It bands the lotal for 260.76 It bands the lotal for Actual 0	d Use [kWh/r Notional 14.78 3.81 25.7 16.66 203.41 23.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 20.55 20.65 20.65 20.5	n²] tissiors. m²]	
Energy Consump Heating Cooling Auxiliary ighting Hot water cotAL** COTAL** Energy electrate energ day Energy Productio Photovoltaic systems Wind turbines	tion by Er Actual 10.03 2.16 24.59 9.28 214.7 23.65 260.76 beach be total for control by CPG particular by CPG particula	Id Use [kWh/r Notional 14.78 3.81 25.7 16.66 203.41 23.65 264.36 comundo or calcularge en , e agaication nology [kWh/ Notional 0 0	n²]	
Energy Consump leating cooling taxillary ighting idot water cotal +** Cotal +** Energy Productio Photovoltaic systems Wind turbines CHP generators	tion by Er Actual 10.03 2.16 24.59 9.28 214.7 23.65 260.76 Heaveds the total for cost by CPO present Actual 0 0 0	Id Use [kWh/n Notional 14.78 3.81 25.7 16.66 203.41 23.65 264.36 consumedon or calcularly en nology [kWh/ Notional 0 0 0	n°]	
Energy Consump leating cooling uxiliary ighting iot water caujoment* OTAL** Emergy Production Photovoltaic systems Wind turbines HP generators icolar thermal systems	tion by Er Actual 10.03 2.16 24.59 9.28 214.7 23.65 260.76 Teachte total for teachte total for teachte total for teachte total for Actual 0 0 0	d Use [kWh/r Notional 14.78 3.81 25.7 16.66 203.41 23.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 20.75 20.65 20.75 20	n²]	
Energy Consump leating Cooling wxillary ighting idot water Squipment* OTAL** Energy Production Photovoltaic systems Wind turbines HP generators icolar thermal systems Energy & CO ₂ Em	tion by Er Actual 10.03 2.16 24.59 9.28 214.7 23.65 260.76 x00.76 n by Tech Actual 0 0 0 0 0	Id Use [kWh/n Notional 14.78 3.81 25.7 16.66 203.41 23.65 264.36 consumption or calculating we nology [kWh/n Notional 0 0 0 0	n*]	
Energy Consump leating cooling wollary lighting tot water Equipment* OTAL** Energy Production Photovoltaic systems Wind turbines CHP generators Solar thermal systems Energy & CO ₂ Em	tion by Er Actual 10.03 2.16 24.59 9.28 260.76 260.76 260.76 260.76 10.02 20.75 260.76 260.76 20.75 20	Id Use (kWh/r Notional 14.78 3.81 25.7 16.66 203.41 23.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 203.41 20.65 20.55	n°] mesons. m°]	
Energy Consump Heating Cooling Auxiliary Lighting Hot water Equipment* FOTAL** Emergy electronic energy debit Energy Productio Photovoltaic systems Mind turbines DHP generators Solar thermal systems Energy & CO ₂ Emergy & CO ₂ Emergy Heating + cooling demand	tion by Er Actual 10.03 2.16 24.59 9.28 214.7 23.65 260.76 To be data for a control of the form of the form the bid a for a control of the form of the form a control of the form a	Id Use (kWh/r Notional 14.78 3.81 25.7 16.66 203.41 23.65 264.36 264.36 00 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	n*]	
Energy Consump Heating Cooling Auxiliary Lighting Hot water Cooling Co	tion by Er Actual 10.03 2.16 24.59 9.28 214.7 23.65 260.76 It search te that for the that for th	Id Use [kWh/r Notional 14.78 3.81 25.7 16.66 203.41 23.65 264.36 commercial or calcularity er nology [kWh/ Notional 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	n*] mssiors. [m2] otional 7.85 04.39	

Page 15 of 17

Sy	stem Type	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Cool con kWh/m2	Aux con kWh/m2	Heat SSEEF	Cool SSEER	Heat gen SEFF	Cool gen SEER
[\$1	T] Central h	eating using	y water: rad	iators, [HS]	LTHW boi	ler, [HFT] N	atural Gas,	[CFT] Elect	tricity	
	Actual	68.4	0	21.1	0	2	0.9	0	0.96	0
	Notional	63.7	0	20.5	0	2.8	0.86	0		
[\$1	T] Fan coil s	ystems, [H	5] LTHW bo	iler, [HFT]	Natural Gas	, [CFT] Ele	ctricity			
	Actual	30.1	38.2	9.7	2.2	25.5	0.86	4.73	0.96	5.82
	Notional	45.4	54	14.6	4	26.6	0.86	3.79		
[\$]	T] No Heatin	g or Coolin	g							
	Actual	0	0	0	0	0	0	0	0	0
	Notional	0	0	0	0	0	0	0		

Key to terms	
Heat dem [MJ/m2]	= Heating energy demand
Cool dem [MJ/m2]	= Cooling energy demand
Heat con [kWh/m2]	= Heating energy consumption
Cool con [kWh/m2]	= Cooling energy consumption
Aux con [kWh/m2]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HET	= Heating fuel type
CFT	= Cooling fuel type

Page 16 of 17

Wall 0.23 0.04 FR00000F:Surf[5] Floor 0.2 0.02 FF000001:Surf[5] Roof 0.15 0.12 GR000002:Surf[6] Windows, not windows, and rooflights 1.5 1.4 GR000002:Surf[6] Personnel doors 1.5 1.4 GR000002:Surf[6] Vehicle access & similar large doors 1.5 No Vehicle access doors in building High usage entrance doors in building 1.5 No Vehicle access doors in building Usage Trance doors 1.5 No Vehicle access doors in building Usage Trance doors 1.5 No High usage entrance doors in building Usage Trance flair one surface Writer the minimum U-willoe coors. No High usage entrance doors in building There might be more flair one surface Writer the minimum U-willoe coors. This building Mr/(ht.m/) at 50 Pa 5 3	Element	1	Uityp	Uiten	Surface where the	he minimum value occu	r5*
Floor 0.2 0.02 FF000001:Surf[5] Roof 0.15 0.12 GR000002:Surf[0] Windows, roof windows, and rooflights 1.5 1.4 GR0000002:Surf[1] Personnel doors 1.5 1.4 GR000002:Surf[1] Vehidle access & similar large doors 1.5 - No Vehidle access doors in building High usage entrance doors 1.5 - No High usage entrance doors in building Urge= Typical individual element U-values (W(mK)) Ubus = Minima individual element U-values (W(mK)) - Three might be more than one surface where the minimum U-value occus - This building Air Permeability Typical value This building 3	Wali	(0.23	0.04	FR00000F:Surf[5	1	
Roof 0.15 0.12 GR000002:Surf[0] Windows, nod voidigwts 1.5 1.4 GR000002:Surf[1] Personnel doors 1.5 1.85 GR000002:Surf[1] Vehicle access & similar large doors 1.5 - No Vehicle access doors in building High usage entrance doors 1.5 - No Vehicle access doors in building Ur. ₉ = Typical individuat istemort U-values (W(trrK)) Us = Mirmum individual element U-values (W(trrK)) * There might be more than one surface where the minimum U-value occurs This building Air Permeability Typical value This building mv(th.m;/) at 50 Pa. 5 3	Floor	(0.2	0.02	FF000001 Surf[5]	1	
Windows, roof windows, and rooflights 1.5 1.4 GR000004:Surf[3] Personnel doors 1.5 1.85 GR000000:Surf[1]. Vehicle access & similar large doors 1.5 2 No Vehicle access doors in building High usage entrance doors 1.5 - No High usage entrance doors in building Ur_ps= Typical individual element U-values (W(mR)) Ur_w = High usage entrance doors in building * There might be more than one surface Where the minimum U-value coors: This building Air Permeability Typical value This building mv/(h.m./) at 50 Pa 5 3	Roof		0.15	0.12	GR000002:Surf[0	0]	
Personnel doors 1.5 1.65 GR00000C:Surf[1]. Vehicle access & similar large doors 1.5 - No Vehicle access doors in building High usage entrance doors 1.5 - No High usage entrance doors in building Usas = Typical individual alternant U-values (W(mK)) Usas = Minimum individual alternant U-values (W(mK)) * There might be more than one surface Where the minimum U-value coccus.	Windows, roof windows, and roof	flights	1.5	1.4	GR000004:Surf[3	5]	
Vehicle access & similar large doors 1.5 - No Vehicle access doors in building High usage entrance doors 1.5 - No High usage entrance doors in building Urbar-Typical individual element Urbainse (WirrRI) Urbar-Sterman individual element Urbainse (WirrRI) Urbar-Sterman individual element Urbainse (WirrRI) * There might be more than one surface where the minimum Urballic coors: This building This building * Air Permeability Typical value This building This building mv(th.mr) at 50 Pa 5 3 3	Personnel doors		1.5	1:65	GR00000C:Surf[1]	
High usage entrance doors 1.5 - No High usage entrance doors in building Urge = Typical material diverse them to the surface where the manuful U-willee coors. Urge = Typical individual element U-willee (W(mK)) Urge = Typical element U-willee coors.	Vehicle access & similar large do	oors	1.5	2	No Vehicle acces	s doors in building	
Use_= Typical individual defense II Uvalues (W(mR)) Use_= Minmum individual defense II Uvalues (W(mR)) * There might be more than one surface where the minmum Uvalue occurs. This building Air Permeability Typical value This building mv(th.m/) at 50 Pa 5 3	High usage entrance doors		1.5	÷	No High usage en	ntrance doors in building	· · · · · ·
Air Permeability Typical value This building mr/(h.mr) at 50 Pa 5 3	 Units = Typical individual element U-value There might be more than one surface. 	es (W/(m ⁻ K)) Where the min	imüm t	U-vitilie oo	U.a. = Minimum indev xrs	dual element U-values [W/(m/K	n
m/(h.m/) at 50 Pa	Air Permeability	Typica	al valu	Je	This b	uilding	
	m//(h.m/) at 50 Pa	5	-		3		

Oensphere

roject name					
Bayam Street Offi	ce Be	Lea	n		As designed
ate: Fri Aug 07 18:12:59 2020					
dministrative information					
uilding Details	-	0	wher D	ataile	
Address:		N	lame:	cialis	
	1	elephone	e number:		
ertification tool	fication tool				
Calculation engine: Apache					
Calculation engine version: 7.0.12		Ce	ertifier (details	
Interface to calculation engine: IES Vint	al Environm	ent N	lame:		
Interface to calculation engine version:	7.0.12	1	elephone	e number:	
BRUKL compliance check version: v5.6	5.a.1		duress.	17	
Building CO ₂ emission rate (BER), kg0 Are emissions from the building less th	CO ₂ /m ² .anni han or equa	im I to the t	arget?	_	28.2 BER =< TER
Building CO ₂ emission rate (BER), kg(Are emissions from the building less the Are as built details the same as used in the same as used in th	COJ/m ² ,annu han or equa in the BER o	im I to the t calculatio	arget? ons?		28.2 BER =< TER Separate submission
Building CO, emission rate (BER), kg(Are emissions from the building less the Are as built details the same as used in friterion 2: The performance of chieve reasonable overall star Values which do not achieve the standar displayed in red.	COJM, annu han or equa in the BER of f the build ndards of nds in the No	im I to the t calculation ding fa energ n-Domes	arget? ons? bric an y effici stic Build	nd fixed ency ling Service	28.2 BER =< TER Separate submission building services should es Compliance Guide and Part Lare
Building CO, emission rate (BER), kg(Are emissions from the building less ti Are as built details the same as used i ritterion 2: The performance of chieve reasonable overall star Values which do not achieve the standar displayed in red. Building fabric Element	COJMT.annu han or equa in the BER of f the build indards of rds in the No	In to the t calculation ding far energ in-Domes	arget? ons? bric an y effici stic Build Ui-cak	nd fixed ency ling Service Surface	28.2 BER =< TER Separate submission building services should es Compliance Guide and Part L are where the maximum value occurs*
Building CO, emission rate (BER), kg Are emissions from the building less th Are as built details the same as used i riterion 2: The performance of chieve reasonable overall star Values which do not achieve the standa displayed in red. Building fabric: Element Wall**	COJMT.annu han or equa in the BER of f the build ndards of rds in the No Ustant 0.35	In to the t calculation ding far energy m-Domest 0.12	bric an y effici ulcak 0.15	nd fixed ency ling Service Surface GR00000	28.2 BER =< TER Separate submission building services should es Compliance Guide and Part L are where the maximum value occurs* 03:Surf[2]
Building CO, emission rate (BER), kg(Are emissions from the building less ti Are as built details the same as used i riterion 2: The performance of chieve reasonable overall star Values which do not achieve the standar displayed in red. Building fabric: Element Wall** Floor	COJMT.annu han or equa in the BER of fithe build ndards of rds in the No Ustant 0.35 0.25	I to the t calculation ding fa energ m-Domes 0.12 0.12	bric an y effici stic Build Uicate 0.15 0.12	nd fixed ency Surface GR0000 LW0000	28.2 BER =< TER Separate submission building services should es Compliance Guide and Part L are where the maximum value occurs* 03:Surf[2] 01:Surf[0]
Building CO, emission rate (BER), kgt Are emissions from the building less ti Are as built details the same as used i riterion 2: The performance of chieve reasonable overall star Values which do not achieve the standar displayed in red. Building fabric: Element Walt** Filoar Roof	COJM ² annu han or equa in the BER of fithe build indards of rds in the No 0.35 0.25 0.25	I to the t calculation ding fa energ m-Domes 0,12 0,12 0,12	bric an y effici ons? Utcak 0.15 0.12 0.12	Id fixed ency ling Service Surface GR0000 LW0000 LW0000	28.2 BER =< TER Separate submission building services should es Compliance Guide and Part Lare where the maximum value occurs* 03:Surf[2] 01:Surf[0] 01:Surf[7]
Building CO, emission rate (BER), kg/ Are emissions from the building less th Are as built details the same as used i riterion 2: The performance of chieve reasonable overall star Values which do not achieve the standar displayed in red. Building fabric: Element Wall** Floor Roof Windows***, roof windows, and rooflig	COJM ² annu han or equa in the BER of f the build rdards of rds in the No Ustum 0.35 0.25 0.25 0.25	Unit of the transformed of transformed of the trans	arget? ons? bric an y effici stic Build ULCMC 0.15 0.12 0.12 0.12 1.4	Id fixed ency ling Service Surface GR0000 LW0000 LW0000 LW0000	28.2 BER ⇒< TER Separate submission building services should es Compliance Guide and Part L are where the maximum value occurs* 03:Surf[2] 01:Surf[0] 01:Surf[7] 01:Surf[1]
Building CO, emission rate (BER), kg/ Are emissions from the building less to Are as built details the same as used i riterion 2: The performance of chieve reasonable overall star Values which do not achieve the standar displayed in red. Building fabric Element Walt** Floor Roof Windows***, roof windows, and rooflig Personnel doors	COJMF.annu han or equa in the BER of f the build idlards of idlards of idlard	Uncore 0.12 0.12 0.12 0.12 1.4 1.65	arget? ons? bric an y effici stic Build ULOM: 0.15 0.12 0.12 0.12 1.4 1.65	d fixed ency Surface GR0000 LW0000 LW0000 GR0000	28.2 BER ⇒< TER Separate submission building services should as Compliance Guide and Part L are where the maximum value occurs* 03:Surf[2] 01:Surf[0] 01:Surf[1] 03:Surf[3]
Building CO, emission rate (BER), kg/ Are emissions from the building less to Are as built details the same as used i ritterion 2: The performance of chieve reasonable overall star Values which do not achieve the standar displayed in red. Building fabric Element Wall** Floor Roof Windows***, roof windows, and rooflig Personnel doors Vehicle access & similar large doors	COJMF.annu han or equa in the BER of f the build idards of rds in the No 0.35 0.25 0.25 0.25 0.25 1.5	Into the t calculation ding fa energy m-Domes 0.12 0.12 0.12 0.12 1.4 1.65 -	arget? ons? bric an y effici stic Build 0.15 0.12 0.12 0.12 1.4 1.65 -	d fixed ency Surface GR0000 LW0000 LW0000 LW0000 GR0000 No Vehic	28.2 BER =< TER Separate submission building services should es Compliance Guide and Part L are where the maximum value occurs* 03:Surf[2] 01:Surf[0] 01:Surf[7] 01:S
Building CO, emission rate (BER), kg(Are emissions from the building less ti Are as built details the same as used i Friterion 2: The performance of chieve reasonable overall star Values which do not achieve the standa displayed in red. Building fabric: Element Wall** Floor Roof Roof Windows**, roof windows, and rooflig Personnel doors Vehicle access & similar large doors High usage entrance doors	COJMF.ann. han or equa in the BER of fthe build ndards of nds in the No 0.35 0.25 0.25 0.25 0.25 1.5 1.5 3.0 2.2 1.5 3.0 2.5 1.5 3.5 3.0 2.5 1.5 3.5 3.0 2.5 1.5 3.5 3.5 3.5 3.5 3.5 3.5 3.5 3.5 3.5 3	I to the t calculation ding fa energy m-Domes 0.12 0.12 0.12 0.12 1.4 1.65 - -	arget? bric an y effici stic Build U.cae 0.15 0.12 0.12 1.4 1.65 - -	d fixed ency ling Service GR0000 LW0000 LW0000 CW0000 GR0000 No Vehic No Vehic	28.2 BER =< TER Separate submission building services should es Compliance Guide and Part L are where the maximum value occurs* 03:Surf[2] 01:Surf[7] 01:Surf[7] 01:Surf[11] 03:Surf[3] de access doors in building usage entrance doors in building
Building CO, emission rate (BER), kg(Are emissions from the building less ti Are as built details the same as used i riterion 2: The performance of chieve reasonable overall star Values which do not achieve the standar displayed in red. Building fabric Element Wall** Floor Roof Windows**, roof windows, and rooflig Personnel doors Vehicle access & similar large doors High usage entrance doors Dates 1 Union grave weighted average U-wild Union Caticulated ama-seqtiled average U-wild There might be more than one suthoar wider ** Automatic University of which of which are one ** Display wedows and senting glazing are eet 18. (reatine of vehicles for any device)	COJMF.ann. han or equa in the BER of fittle build ndards of nds in the No Usum 0.35 0.25 0.25 0.25 0.25 0.25 0.25 0.25 0.2	In the the transmission of transmission of the transmission of transmissio	arget? ons? bric an y effici ons. 0.15 0.12 0.1	Ind fixed ency ling Service Surface GR0000 LW0000 LW0000 LW0000 No Vehic No High alculated inc gscandard is surface	28.2 BER =< TER Separate submission building Services should es Compliance Guide and Part Lare where the maximum value occurs* 03:Surf[2] 01:Surf[7] 01:Surf[7] 01:Surf[11] 03:Surf[3] de access cloors in building usage entrance doors in building asmum individual element U values [W(m/K)] as similar to the for windows. Stod against the limiting ittending it the took.
Building CO, emission rate (BER), kg/ Are emissions from the building less to Are as built details the same as used i Priterion 2: The performance of chieve reasonable overall star Values which do not achieve the standar displayed in red. Building fabric Element Wall** Floor Roof Windows**, noof windows, and rooflig Personnel doors Vehicle access & similar large doors High usage entrance doors Dates 1 turing area werging to wind " There might be more than one suthor wind " Automatic turium chark by mit tool does no " Briege wendows and entire glazm are cert It B. feature root ventilatos (inc. smake vents)	COJMF.ann. han or equa in the BER of fittle build ndards of nds in the No Usum 0.35 0.25 0.25 0.25 0.25 0.25 0.25 0.25 0.2	In the test of	arget? bric anns? bric anny effici tic Build 0.15 0.15 0.12 0.12 0.12 0.12 0.4 1.65 - - Ucose = C Cose innonnees is a ano mod	Ing Service Surface GR00000 LW0000 LW0000 LW00000 No Vehic No High Alculated inc gracoou Sandard is Noid of choo	28.2 BER =< TER Separate submission building Services should es Compliance Guide and Part Lare where the maximum value occurs* 03:Surf[2] 01:Surf[7] 01:Surf[7] 01:Surf[11] 03:Surf[3] de access cloors in building usage entrance doors in building asmum individual element U values [W(m/K)] a similar to that for windows. Stud against the limiting itandards by the tool.



ID of system type Standard value Office WC Showers Workspace/Office Cale General lighting and display lights Zone name Stu	A 0.3 -	8			L. Du	(((s))				11 March 11	A
Standard value Office WC Showers Workspace/Office Cafe General lighting and display lights Zone name Sto	0.3	0	C	D	E	F	G	H	1	HRe	miclency
Office WC Showers Workspace/Office Cafe General lighting and display lights Zone name Sto	-	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
Workspace/Office Cafe General lighting and display lighta Zone name Sto		51	04	÷	-	÷	-	+	-	÷	N/A
General lighting and display lightin Zone name Sta		÷ .	•	£17.		- e	-	6.0			N/A
General lighting and display lighti Zone name Sta											
Zone name Str	ng		Г	Lu	nino	us effic	acy [m/W]	-	1.1	
St			1	umina	ire	Lamp	Disp	lay la	mp	General I	ighting [W
	andar	d value	. 6	0		60	22	-	1.1	11.00	
Work space/ Offices			11	00		÷				2430	
Female WC	_		1.			100	-			102	
Stairwell			T	-		100	2			37	
Circulation			1.	C = 1		100	-			45	
Male WC			1.	-		100	-			111	
UA WC			13	ē		100	~			33	
Office WC Showers	_					100	-		-	57	
Office Cycle			11	0.0		~	~			19	
Workspace/Office Cafe			1	00		÷	2		1	351	
riterion 3: The spaces in the b limit solar gains Zone Work space/ Offices Workspace/Office Cate			S N N	olarga ol[-81 ol[-8%	in lin 1%)	nit exce	eded	? (%)	In N N	ternal blir O O	nds used?
riterion 3: The spaces in the b limit solar gains Zone Work space/Offices Workspace/Office Cate riterion 4: The performance of alculated BER	f the	build	N N N	olarga O(-81 O(-8% Asbi	in lin 1%))	nit exce	eded d be	? (%) cons	In N N	ternal blin O O Pont with	nds used? The
riterion 3: The spaces in the b Ilmit solar gains Zone Work space/ Offices Workspace/Office Cate Riterion 4: The performance of alculated BER Separate submission riterion 5: The necessary prov uilding should be in place	f the	build ns for	S NN	olar ga O(-81 O(-81% (-81%) (-	in lin 1%)) uilt, s	shoul	d be	? (%) cons	In N Iste	ternal blin O O ent with 1	nds used? the
riterion 3: The spaces in the b I limit solar gains Zone Work space/ Offices Workspace/Office Cate riterion 4: The performance of alculated BER isparate submission riterion 5: The necessary provuilding should be in place isparate submission PBD (Recast): Consideration	f the visio	build ns for	sing, ing, tive	olar ga 0 (-81 0 (-8%) as b as b	uin lim 1%) uilt, s	shoul ergy-e	d be	? (%) cons	In N N isto	ternal blin O O ent with 1 ation of 1	nds used? the
riterion 3: The spaces in the b limit solar gains Zone Work space/ Offices Workspace/Office Cate riterion 4: The performance of alculated BER separate submission riterion 5: The necessary prov uilding should be in place separate submission PBD (Recast): Consideration Were alternative energy systems of	f the vision	build ns for ternat	Sing N ing ing	olar ga o (.81 o (.8% as bi abling energ	in lim 1%)) uilt, :) ene gy sy	shoul ergy-e	d be fficie	r (%) cons	In N N iste	ternal blin O O ent with ation of 1 ess?	the the YES
riterion 3: The spaces in the b I limit solar gains Zone Work space/ Offices Workspace/Office Cate riterion 4: The performance of alculated BER isparate submission riterion 5: The necessary prov uilding should be in place isparate submission PBD (Recast): Consideration of Were alternative energy systems of Is evidence of such assessment availa	f the vision of alt	build ns for ternat	Ing.	as bi as bi as bi abling energ	in lim 1%)) uilt, :) ene) y sy d as p ission	shoul shoul stem stem	d be fficie	cons ent op	In N isto	ternal blir 0 0 ent with t ation of 1 ess?	the YES YES

Building Global P	arame	ters	Build	ing Use
	Actu	al Notional	% Area	Building Type
Area [m ²]	601.9	601.9		A1/A2 Retail/Financial and Professional services
External area [m ²]	587.4	786.8		A3/A4/A5 Restaurants and Cafes/Drinking Est/Takeaways
Weather	LON	LON	100	B1 Offices and Workshop businesses B2 to B7 General Industrial and Special Industrial Groups
nfiltration [m³/hm²@ 50Pa]	3	3		B8 Storage or Distribution
Average conductance [W/k	(] 123.4	34 202.42		C1 Hotels
Average U-value [W/m ² K]	0.21	0.26		C2 Residential Institutions: Hospitals and Care Homes
Alpha value* [%]	10.3	10		C2 Residential Institutions: Pasidential schools C2 Residential Institutions: Universities and colleges
Energy Consump Heating Cooling Auxiliary Lighting Hot water Equipment* TOTAL** Creary uned by reagneet does not court	tion by Actual 3.6 4.62 9.44 12.93 62.06 34.76 34.76 baards the	Y End Use (kW Notion 7.67 5.12 9.68 25.53 58.79 34.76 106.79 34.76	(h/m ²) al	Prosoftinal spaces D1 Non-residential Institutions: Community/Day Centre D1 Non-residential Institutions: Libraries, Museums, and Galleri D1 Non-residential Institutions: Education D1 Non-residential Institutions: Primary Health Care Building D1 Non-residential Institutions: Crown and County Courts D2 General Assembly and Leisure, Night Clubs, and Theatres Others: Passenger terminals Others: Energiency services Others: Miscellaneous 24th ractivities Others: Stand alone utility block
Energy Productio	n by T	echnology [k)	Wh/m²]	
Dia tanàna mandritra dia ma	Actual	Notion	al	
Photovoltaic systems	0	0		
Wind turbines	0	0		
Crim generators	0	0		
	•	0		
Energy & CO ₂ Em	ISSION	Actual	Notional	
	[MJ/m ²]	90.1	93.68	
Heating + cooling demand	funouut 1	162.98	201.81	
Heating + cooling demand Primary energy* [kWb/m ²]				
Heating + cooling demand Primary energy* [kWh/m ²] Total emissions [kg/m ²]		28.2	34.8	

Page 4 of 6

System Type	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Cool con kWh/m2	Aux con kWh/m2	Heat SSEEF	Cool SSEER	Heat gen SEFF	Cool gen SEER
[ST] Central h	eating using	y water: rad	liators, [HS] LTHW boi	ler, [HFT] N	latural Gas	s, [CFT] Ele	ctricity	
Actual	34	0	10.5	0	9	0.9	0	0.96	0
Notional	65.6	0	21.2	0	9	0.86	0		
[ST] Fan coil :	systems, [HS] LTHW bo	iler, [HFT]	Natural Gas	, [CFT] Ele	ctricity			
Actual	5.7	103.9	1.8	6.1	10	0.86	4.73	0.96	5.82
Notional	13.3	92.4	4.3	6.8	10.3	0.86	3.79		
[ST] No Heatin	ng or Coolin	g							
Actual	0	0	0	0	0	0	0	0	0
Notional	0	0	0	0	0	0	0		

Key to terms	
Heat dem [MJ/m2]	= Heating energy demand
Cool dem [MJ/m2]	= Cooling energy demand
Heat con [kWh/m2]	= Heating energy consumption
Cool con [kWh/m2]	= Cooling energy consumption
Aux con [kWh/m2]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type

)ensphere **Key Features** The Building Control Body is advised to give particular attention to items whose specifications are better than typically expected. **Building fabric** Element Ulityp Uliten Surface where the minimum value occurs* 0.23 0.11 LW000001:Sun[1] 0.2 0.12 LW000001:Sun[0] Wall Floor Roof 0.15 0.12 LW000001:Surt[7] Windows, roof windows, and rooflights 1.5 1.4 LW000001:Surt[11] 1.5 1.85 GR000003;Surf[3] 1.5 No Vehicle access doors in building Personnel doors Vehicle access & similar large doors 1.5 -High usage entrance doors No High usage entrance doors in building Unon = Typical individual element U-values (W/(mR)) U.u. = Minimum individual element U-values [W/(m/K)] * There might be more than one surface where the minimum U-villue occurs Air Permeability Typical value This building m4/(h.m4) at 50 Pa 5 3 Page 6 of 6



E. Indicative Energy Model Outputs (Be Green)

				oran	
Project name					
Bayam Street Hotel I	Be (Gree	en		As designed
Date: Fri Aug 07 17:39:30 2020					
dministrative information					
Building Details		O	wner De	etails	
Address: ,		Name:			
			elephone	e number:	
Certification tool		A	ddress:	i.e	
Calculation engine: Apache					
Calculation engine version: 7.0.12		Ce	ertifier	details	
Interface to calculation engine: IES Virtual En	vironme	nt N	lame:		
Interface to calculation engine version: 7.0.1	2	1	ddress.	- number:	
BRUKL compliance check version: v5.6.a.1					
Building CO, emission rate (BER), kgCO/m	n².annu	m	_		38.2
Are emissions from the building less than o	or equal	to the t	arget?		BER =< TER
Are emissions from the building less than o Are as built details the same as used in the	BER c	to the talculation	arget? ons?	dfixed	BER =< TER Separate submission
Are emissions from the building less than o Are as built details the same as used in the Criterion 2: The performance of the chieve reasonable overall standard Values which do not achieve the standards in displayed in red. Building fabric	build build ds of the Nor	to the t alculation ing fai energy n-Domes	arget? ons? bric an y effici stic Build	d fixed ency ing Service	BER =< TER Separate submission building services should as Compliance Guide and Part L are
Are emissions from the building less than o Are as built details the same as used in the Criterion 2: The performance of the chieve reasonable overall standard Values which do not achieve the standards in displayed in red. Building fabric Element	e build buil	to the t alculation ing fal energy n-Domes Ua-Calc	arget? ons? bric an y effici stic Build Ui-Calc	d fixed ency ing Service Surface	BER =< TER Separate submission building services should as Compliance Guide and Part L are where the maximum value occurs*
Are emissions from the building less than o Are as built details the same as used in the criterion 2: The performance of the chieve reasonable overall standard Values which do not achieve the standards in displayed in red. Building fabric Element Wall**	e build build ds of the Nor UnLimit	to the tr alculation ing fal energy n-Domes Ua-Calc 0.14	bric an y effici stic Build	d fixed ency ing Service Surface BS00000	BER =< TER Separate submission building services should as Compliance Guide and Part L are where the maximum value occurs* CC.Surt[0]
Are emissions from the building less than o Are as built details the same as used in the criterion 2: The performance of the chieve reasonable overall standard Values which do not achieve the standards in displayed in red. Building fabric Element Wall** Floor	build build ds of the Nor Un-Limit 0.35 0.25	to the to alculation ing fai energy n-Domes Ua-Calc 0.14 0.13	bric an y effici tic Build ULCalc 0.4 0.36	d fixed ency ing Service Surface BS00000 BS00000	BER =< TER Separate submission building services should es Compliance Guide and Part L are where the maximum value occurs ⁴ IC:Surf[9] IC:Surf[6]
Are emissions from the building less than o Are as built details the same as used in the criterion 2: The performance of the chieve reasonable overall standar Values which do not achieve the standards in displayed in red. Building fabric Element Wall** Floor Roof	build build	to the t alculation ing fal energy n-Domes 0.14 0.13 0.12	bric an y effici stic Build Ui-Calc 0.4 0.36 0.12	d fixed ency ing Service Surface BS00000 GR00000 GR00000	BER =< TER Separate submission building services should es Compliance Guide and Part L are where the maximum value occurs* IC:Surf[6] IC:Surf[6] ID:Surf[6]
Are emissions from the building less than o Are as built details the same as used in the Criterion 2: The performance of the chieve reasonable overall standar Values which do not achieve the standards in displayed in red. Building fabric Element Wall** Floor Roof Windows***, roof windows, and rooflights	build build build ds of the Nor U_a-Limit 0.35 0.25 2.2 2.2	to the b alculation ing fai energy n-Domes Us-Calc 0.14 0.13 0.12 1.4	ULCalc 0.36 0.12	d fixed ency ing Service Surface BS00000 GR00000 GR00000	BER =< TER Separate submission building services should as Compliance Guide and Part L are where the maximum value occurs* IC:Surf[9] IC:Surf[0] ID:Surf[0] ID:Surf[0] ID:Surf[1]
Are emissions from the building less than o Are as built details the same as used in the Criterion 2: The performance of the Chieve reasonable overall standard Values which do not achieve the standards in displayed in red. Building fabric Element Wall** Floor Roof Windows***, roof windows, and rooflights Personnel doors	build build ds of the Nor UnLimit 0.35 0.25 0.25 2.2 2.2 1.5	uacale 0.14 0.13 0.12 1.4 1.65	arget? ons? bric an y effici stic Build Ui-Calc 0.4 0.36 0.12 1.4 1.65	d fixed ency ing Service Surface BS00000 GR00000 GR00000 GR00000	BER =< TER Separate submission building services should as Compliance Guide and Part L are where the maximum value occurs* DC:Surf[9] DC:Surf[9] D2:Surf[0] D4:Surf[3] DC:Surf[1]
Are emissions from the building less than o Are as built details the same as used in the Criterion 2: The performance of the chieve reasonable overall standard Values which do not achieve the standards in displayed in red. Building fabric Element Wall** Floor Roof Windows***, roof windows, and rooflights Personnel doors Vehicle access & similar large doors	build build ds of the Nor UnLimit 0.35 0.25 2.2 2.2 1.5 3.5	to the b alculation ing fai energy n-Domes 0.14 0.13 0.12 1.4 1.65 -	arget? ons? bric an y effici stic Build Ui.calc 0.4 0.36 0.12 1.4 1.65 -	d fixed ency ing Service BS00000 GR00000 GR00000 GR00000 No Vehic	BER =< TER Separate submission building services should as Compliance Guide and Part L are where the maximum value occurs* DC:Surf[0] DC:Surf[0] D4:Surf[3] DC:Surf[1] le access doors in building usage entrance drops in building
Are emissions from the building less than o Are as built details the same as used in the Criterion 2: The performance of the Chieve reasonable overall standar Values which do not achieve the standards in displayed in red. Building fabric Element Wall** Floor Roof Windows***, roof windows, and rooflights Personnel doors Vehicle access & similar large doors High usage entrance doors High usage entrance doors High usage entrance doors	requal BER c build bouild ds of the Nor 0.35 0.25 0.25 2.2 2.2 1.5 3.5 (\mmk)) (\mmk))	to the b alculation ing fai energy n-Domes Uscale 0.14 0.13 0.12 1.4 1.65 - -	arget? pric an y effici stic Build Ui-Calc 0.4 0.36 0.12 1.4 1.65 - - U-calc U-calc 0.4 0.55 -	d fixed ency ing Service Surface BS00000 GR00000 GR00000 GR00000 No Vehic No High alculaled ma	BER =< TER Separate submission building services should as Compliance Guide and Part L are where the maximum value occurs* DC:Surf[9] DC:Surf[9] DC:Surf[1] DC:Surf[1] Lise access doors in building usage entrance doors in building usage entrance doors in building
Are emissions from the building less than o Are as built details the same as used in the Chiceve reasonable overall standar Values which do not achieve the standards in displayed in red. Building fabric Element Wall* Floor Roof Windows**, roof windows, and rooflights Personnel doors Vehicle access & similar large doors High usage entrance doors Used a cress & similar large doors High usage entrance doors Used = Calculated area weighted average Uvalues fW Used = Calculated area weighted average uvalues fW	build build build build build build ds of using u	to the b alculation ing fai energy Uscale 0.14 0.13 0.12 1.4 1.65 - - - - - - - - - - - - - - - - - - -	UirCan 0.4 0.36 0.12 1.4 1.65 -	d fixed ency ing Service BS00000 GR00000 GR00000 GR00000 No Vehic No High alculated me g standard el alled or ches	BER =< TER
Are emissions from the building less than o Are as built details the same as used in the Criterion 2: The performance of the Chiceve reasonable overall standard Values which do not achieve the standards in displayed in red. Building fabric Element Wall** Floor Roof Windows**, roof windows, and rooflights Personnel doors Vehicle access & similar large doors High usage entrance doors Usawe 5 Limburg arrow explicit evenge U values (W Usawe 5 Limburg arrow explicit evenge U values (W Leave 5 Calculated area-weighted evenge U values (W ** Automatic Uvalue check by the lood does not apply ** Deplay windows and similar giazing are excluded NB. Neither roof vehiliators (inc. simoke vinis) for sy Air Permaphility.	build build build build using build using	to the b alculation ing fai energy h-Domes 0.14 0.13 0.12 1.4 1.65 - - - - - - - - - - - - - - - - - - -	bric an y effici stic Build Ui-Calc 0.4 0.36 0.12 1.4 1.65 - - U-cose = C cors, iose limitin hock, tandard	d fixed ency ing Service BS00000 BS00000 GR00000 GR00000 No Vehic No High alculated me g standard si alted or chee	BER =< TER Separate submission building services should as Compliance Guide and Part L are where the maximum value occurs* DC:Surf[6] D2:Surf[6] D2:Surf[6] D2:Surf[1] de access doors in building usage entrance doors in building wamum individual element U-values [W!(mFK)] as similar to that for windows sked against the limiting standards by the tool. uilding

Building services

The standard values listed below are minimum values for efficiencies and maximum values for SFPs. Refer to the Non-Domestic Building Services Compliance Guide for details.

 Whole building lighting automatic monitoring & targeting with elarms for out-of-range values
 YES

 Whole building electric power factor achieved by power factor correction
 <0.9</td>

1- Heating Cooling - Heat Pump (MVHR)

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(I/s)]	HR efficiency
This system	3,8	3.32	0	0	0.8
Standard value	2.5*	3.2	N/A	N/A	0.5
Automatic mon	itoring & targeting w	ith alarms for out-of	-range values for th	is HVAC system	m YES
* Standard shown is for limiting standards	for all types >12 kW output	except absorption and ga	s engine heat pumps. For t	ypes <=12 kW outp	ult, refer to EN 14625

1- DHW - Heat pump

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	3.58	0.004
Standard value	1	N/A

ID	System type in Non-domestic	Build	ling S	ervice	s Con	plian	ce Gu	ide				
A	Local supply or extract ventilation	n unit	s serv	ing a s	single a	area						
в	Zonal supply system where the	fan is	remot	e from	the zo	one						
С	Zonal extract system where the	fan is	remot	e from	the zo	one						
D	Zonal supply and extract ventila	tion u	nits se	rving a	s single	e roon	or zo	ne wit	h heat	ing an	d heat re	covery
Е	Local supply and extract ventila	tion sy	/stem	servin	g a sin	gle an	ea with	heati	ng and	i heat	recovery	1
F	Other local ventilation units											
G	Fan-assisted terminal VAV unit											
н	Fan coil units											
1	Zonal extract system where the	fan is	remot	e from	the z	one wi	th grea	ase filt	er		_	_
Zor	ne name			-	SI	P IW	(Vs)]	-		-	1	
	ID of system type	A	B	C	D	E	F	G	H	01	HRE	miciency
	Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
Sta	ff Change		-	10	0.3	÷	-		•0.0			N/A
Cor	TIM5	•	-	e	0.3		-	-			+	N/A
Sta	ff Breakout		-	-	0.3	*	-					N/A
Circ	culation	÷		0.4	-	·	-	-	-		*	N/A
Cire	culation	4	-	0.4	1	2	-	4	-	2.1	-	N/A
Kito	hen	4	2	0.4	~	2	-	ē	20	41		N/A
Acc	WC	÷.,	÷.	0.4	8	2	*	÷	*			N/A
-	sulation	2	-	0.4	× .	-	-		2		-	N/A
Circ							_					
Circ	ករក	-	-	-	0.3		-		-		-	N/A

ID of system type	A	B	C	D	E	F	G	H	11	HR eniciency	
Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
Staff Change		-	10	0.3	÷						N/A
Comms		-		0.3	-	-	-				N/A
Staff Breakout		-	-	£.0	*	-					N/A
Circulation	÷		0.4	-	100	-		-	1.0	*	N/A
Circulation	4	-	0,4	1	<u>}</u>	-	4	-	2.0	-	N/A
Kitchen	×	2	0.4	~	3-11	-	÷	2	1.		N/A
Acc.WC	÷.,	÷.	0.4	8	2	*		*			N/A
Circulation	-	-	0.4	× .	-	-		-		-	N/A
Admin	-	-		0.3	- C	-		-			N/A
Goods In	-	-	0.4	1	100	-	-	-	-		N/A
Restaurant & Bar	1	-	10	0.3	÷	-	-		•	-	N/A
Reception	-		1	0.3	1	1.00	τ.		70	*	N/A
Circulation	-	-	0.4	-	+	-	4	w	-	×	N/A
en suite 02		-	100	0.4		1.0	÷	÷	+0		N/A
Guestroom 02		-	4.	0.3	÷.		÷ .	4.3	+1		N/A

ensphere

Zone name		1			S	FP [W	/(l/s)]				UD.	Hisianau
	D of system type	A	в	C	D	E	F	G	н	1	nk .	successy
	Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standar
en suite 03		-	-	-	0.4	19	-	5	151	10	-	N/A
Guestroom 03		٣	-	100	0.3		-	+	-	+	-	N/A
Guestroom 06		-	-	100	0.3	5		-	-	7 C		N/A
en suite 01		-	-		0.4			1		*C	-	N/A
Guestroom 01		-	-		0.3	•	-	-	-			N/A
en suite 06		-	-		0.4		-	1.	-	+	-	N/A
Guestroom 10		*	-		0.3		•	1.	-	+	-	N/A
en suite 10		÷.	-	-	0.4		-	÷.	-	*	-	N/A
en suite 11		-	-		0.4	÷	-	-	-	2.1	-	N/A
Guestroom 11		-	-	1	0.3	×	-	2	-	1.0	-	N/A
en suite 12		-	· .	92	0.4	-		÷ .	100	è.	-	N/A
Guestroom 12		-	-	-	0.3	->	-	-	-	-	-	N/A
en suite 15			-		0.4	•	-	-2	1		-	N/A
Guestroom 15		-	-	-	0.3	->	-	-	× 1			N/A
Guestroom 16		-	-	×	0,3	×	-	÷	× .	-	÷	N/A
en suite 16		÷	-	1	0.4	10	4	0	5.1	÷1.	-	N/A
en suite 19		÷	-	÷.	0.4	-	1	-	+ 1	-	*	N/A
Guestroom 19		e (-	1.	0.3	÷.,	+		÷ .	-	-	N/A
Guestroom 18	100 million (1997)	-3	1	÷.	0.3	-	+	211	- 1	11	-	N/A
en suite 18		4	-	÷	0.4	÷.		÷.	+	10		N/A
en suite 17		-	-		0.4	2.		÷	1.1	1	-	N/A
Guestroom 17		-	-		0.3	1	-	-	2.1		-	N/A
en suite 13		-	-	-	0.4	-		1	2	20	-	N/A
Guestroom 13		4	4	-	0.3	-		-	~ -			N/A
Guestroom 14		14	-	-	0.5	-	-			1	-	N/A
en suite 14		-	~	12	0.4	-	-	2.	14.1	1	-	N/A
en sulte 20		-	-	-	0.4	-		-	-		-	N/A
Guestroom 20		1	-	1.1	0.3	-	-	5.00	-		~	N/A
Guestroom 22		100	-	-	0.3	-	-	-	-	-	-	N/A
en suite 22					0.4				-			N/A
Guestroom 21					0.3				-		-	N/A
en suite 21			-		0.4	-	-		-	-	-	N/A
Circulation		-		04	-		-		1.			N/A
en suite 09		5	-	-	0.4	-	-	2	-	1.	-	N/A
en suite 08		-	-	-	0.4	1	-	1	-	1	-	N/A
Guestroom 08		-	-		03	-			2	1	-	N/A
Guestroom 04				1	0.3		1.	-			-	N/A
en suite 04					nd	1	1.	1.			1.	N/A
Guestroom 05					0.3	-		-			1.	N/A
en suite 05					0.4		1.	1			-	N/A
en suite 07		2	1	-	0.0	-		0		1	-	N/A
Guestroom 07					0.3						1	N/A
Circulation			-	D.d	0.0	1						NVA
Circulation		-	-	0.4	21	<i>t</i> :	1	5.	2	22	-	N/A

1		_	S	P [W	(l/s)]				1 100	
A	в	C	D	E	F	G	н	1	HRe	fliciency
0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
-	-	6.7	0.3	5	-	e'	1.1	20	-	N/A
۳.	-	2	0.3	-	-	+	-	+	-	N/A
-	-	-	0.4	-		+	÷	- C		N/A
-	•		0.3		·	100	$\tau = 1$	÷C.		N/A
-	-		0.4			÷			-	N/A
			0.3				-	F -	-	N/A
+	-		0.4			+	-	+	-	N/A
÷.	-		0.4	***	-	-	-	2	-	N/A
-		•	E,0			-	-	2.0	-	N/A
-	-	1	0.4	× .	-	а.	-	1.0	2	N/A
-	· .	Q	0.3	2		÷	< :	20	-	N/A
- 1	-	-	0.3	->	-	-	-	÷.	-	N/A
-	-	•	0.4	•×	-	-	< 1		-	N/A
-	-	-	0.3		-	-	-		-	N/A
-	-	×.	0.4	~	-	÷	4	-	*	N/A
÷	-	-	0.4	1	1	-	5.1	÷1	-	N/A
-	-	-	0.3	-	1	-	- 1		-	N/A
e (-		0.4	-			-	10	-	N/A
-3		-	0.3	-		211	- 1	1.	1.000	N/A
-	-		E.0			-	-	1.0		N/A
÷.	-		0.4			÷	1.1	10	-	N/A
-	-		0.4	-		4	2.1	1	-	N/A
-	-	÷	0.3	~		×	2	20	-	N/A
1	2	-	0.3	-		-	2		- C	N/A
2	-	-	0.4	-	-	-		1	-	N/A
-	~	12	0.4	-		2	× 1	1	-	N/A
+	~	21	0.3	-		÷.	~	•	-	N/A
1	-	1.1	0.4	-		5.00	-		-	N/A
1.0	-	-	0.3	-	-	+	-	-	-	N/A
			0.3				-			N/A
		-	0.4				-		-	N/A
+ (-		0.4	-	-	-	-	-	-	N/A
-	-		E.0		-	-	-	1.1		N/A
47	-	-	E.0	-	-	2	-	1.	-	N/A
4	-	-	0.4	1	-	7	~	20	-	N/A
6	-		0.4	1	-		2	1	~	N/A
-	-		0.3		-	-	-		-	N/A
-	-	-	0.3	-	1.	-	-	-	-	N/A
-	-	-	0.4	-	1.		1		-	N/A
-		0.4	-	-		C	1		-	N/A
2.1	-	0.4	-	-	-	2	-	2	-	N/A
-			0.3	-				-	-	N/A
-			0.4				-		-	N/A
		A B 0.3 1.1 - - - -	A B C 0.3 1.1 0.5 - - - - - -	A B C D 0.3 1.1 0.5 1.9 - - - 0.3 - - - 0.3 - - - 0.3 - - 0.4 - 0.3 - - 0.4 - 0.3 - - 0.4 - 0.4 - - 0.4 - 0.4 - - 0.4 - 0.4 - - 0.4 - 0.4 - - 0.4 - 0.4 - - 0.4 - 0.4 - - 0.4 - 0.3 - - - 0.4 - 0.4 - - - 0.3 - 0.4 - - - 0.3 - - 0.4 - - - <td>A B C D E 0.3 1.1 0.5 1.9 1.6 - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.4 - - - - 0.4 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3<td>A B C D E P 0.3 1.1 0.5 1.9 1.6 0.5 - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.4 - - - - 0.4 - - - - 0.4 - - - - 0.4 - - - - 0.4 - - - - 0.4 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - -<td>A B C D E P G 0.3 1.1 0.5 1.9 1.6 0.5 1.7 - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - 0.04 - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - -</td><td>A B C D E P G H 0.3 1.1 0.5 1.9 1.6 0.5 1.1 0.5 - - - 0.3 - - - - - - 0.3 - - - - - - - 0.4 - - - - - - - 0.4 - - - - - - - 0.4 - - - - - - - 0.4 -</td><td>A B C D E P G H I 0.3 1.1 0.5 1.9 1.6 0.5 1.1 0.5 1 - - - 0.3 -</td><td>A B C D E P G H I 0.3 1.1 0.5 1.9 1.6 0.5 1.1 0.5 1 Zone - - 0.3 - - - - - - - - - 0.3 - - - - - - - - - 0.3 -<!--</td--></td></td></td>	A B C D E 0.3 1.1 0.5 1.9 1.6 - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.4 - - - - 0.4 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 <td>A B C D E P 0.3 1.1 0.5 1.9 1.6 0.5 - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.4 - - - - 0.4 - - - - 0.4 - - - - 0.4 - - - - 0.4 - - - - 0.4 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - -<td>A B C D E P G 0.3 1.1 0.5 1.9 1.6 0.5 1.7 - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - 0.04 - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - -</td><td>A B C D E P G H 0.3 1.1 0.5 1.9 1.6 0.5 1.1 0.5 - - - 0.3 - - - - - - 0.3 - - - - - - - 0.4 - - - - - - - 0.4 - - - - - - - 0.4 - - - - - - - 0.4 -</td><td>A B C D E P G H I 0.3 1.1 0.5 1.9 1.6 0.5 1.1 0.5 1 - - - 0.3 -</td><td>A B C D E P G H I 0.3 1.1 0.5 1.9 1.6 0.5 1.1 0.5 1 Zone - - 0.3 - - - - - - - - - 0.3 - - - - - - - - - 0.3 -<!--</td--></td></td>	A B C D E P 0.3 1.1 0.5 1.9 1.6 0.5 - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.4 - - - - 0.4 - - - - 0.4 - - - - 0.4 - - - - 0.4 - - - - 0.4 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - - 0.3 - - - <td>A B C D E P G 0.3 1.1 0.5 1.9 1.6 0.5 1.7 - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - 0.04 - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - -</td> <td>A B C D E P G H 0.3 1.1 0.5 1.9 1.6 0.5 1.1 0.5 - - - 0.3 - - - - - - 0.3 - - - - - - - 0.4 - - - - - - - 0.4 - - - - - - - 0.4 - - - - - - - 0.4 -</td> <td>A B C D E P G H I 0.3 1.1 0.5 1.9 1.6 0.5 1.1 0.5 1 - - - 0.3 -</td> <td>A B C D E P G H I 0.3 1.1 0.5 1.9 1.6 0.5 1.1 0.5 1 Zone - - 0.3 - - - - - - - - - 0.3 - - - - - - - - - 0.3 -<!--</td--></td>	A B C D E P G 0.3 1.1 0.5 1.9 1.6 0.5 1.7 - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - - 0.3 - - - - 0.04 - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - - 0.3 - - - - - -	A B C D E P G H 0.3 1.1 0.5 1.9 1.6 0.5 1.1 0.5 - - - 0.3 - - - - - - 0.3 - - - - - - - 0.4 - - - - - - - 0.4 - - - - - - - 0.4 - - - - - - - 0.4 -	A B C D E P G H I 0.3 1.1 0.5 1.9 1.6 0.5 1.1 0.5 1 - - - 0.3 -	A B C D E P G H I 0.3 1.1 0.5 1.9 1.6 0.5 1.1 0.5 1 Zone - - 0.3 - - - - - - - - - 0.3 - - - - - - - - - 0.3 - </td

ensphere

Zone name	-1-			S	FP [W	(l/s)]		_		UD .	Hisioney
ID of system to	ype A	в	C	D	E	F	G	н	1	nic e	inclusion
Standard va	lue 0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standar
Guestroom 02	-	-	-	0.3	19	-	5	51		-	N/A
en suite 02	۲.	-	1	0.4		-	+	-	+	-	N/A
Guestroom 03	-	-	100	0.3	5		-	-	7 C		N/A
en suite 03		-		0.4			1		<	-	N/A
Guestroom 04	-	-		0.3	•	-	F 1	-			N/A
en suite 04		-		0.4		-		-	٠	-	N/A
en suite 05	-	-		0.4	•	-	(*) ·	-	+	-	N/A
Guestroom 05		-	1	0.3	1	-	÷		*	-	N/A
Guestroom 07	-	-		0.3	÷ -	-	2	4	2.1	-	N/A
en suite 07	-	-	100	0.4	×	-	2	-	1.0	-	N/A
en suite 08	-	÷	3	0.4	2	-	1. C	< :	÷c.	-	N/A
Guestroom 08	- 1	-	2	0.3	->	-	-	-	÷<.	-	N/A
en suite09	-	-	1	0.4	•)	-	-	5.1	*	-	N/A
en suite 10	-	-		0.4		-	-	1		~	N/A
Guestroom 10	-	-	×	0,3	×.	-	÷	× 1	-		N/A
Guestroom 11	÷.	-	1.1	0.3	100	4	e	S. 1	÷1.	-	N/A
en suite 11	-	-		0.4	-	1	-	-		-	N/A
en suite 12	- (- (-	-	0.4	4.	+	-	÷ .	-	-	N/A
Guestroom 12		-	-	0.3	-	-	211	- 1	1.	1.000	N/A
Guestroom 13	-	-		0.3			-	-	1.0	-	N/A
en suite 13		-		0.4					-	-	N/A
Guestroom 14	-	-		0.3	-		-	2.1		-	N/A
en suite 14	-	-	-	0.4	-		-	~ 1	20	-	N/A
Guestroom 15	1	1.	-	0.3	-			2.		4	N/A
en suite 15	12	-	-	0.4	-	-	-		-	-	N/A
en suite 16	-	-	1.	0.4	~		2	1	-	-	N/A
Guestroom 16	-	-	-	0.3	-		-	-		-	N/A
en suite 06		-	1.1	0.4	-	-	5.00	-		~	N/A
Guestroom 06	-	-		0.3	-	-	-	-	-	-	N/A
Guestroom 17				0.3				-			N/A
Guestroom 09				0.3				-		-	N/A
en suite17	-			0.4				-		-	N/A
sirculation			04	-	-			-			N/A
proviation	1.5		0.4	-	1.0		1	1.	14		N/A
circulation	1.5	-	04	-	-		1	-	2	-	N/A
Guestroom 03	-	-	10.7	03	-		1	2	1	1	N/A
en suite 03	-		1	0.4			-			-	N/A
en suite 06	-	1.		0.4	1	1.	1.	1.	1.	-	N/A
Guestroom 01		1	-	0.4	1	1	1	1	1	10	N/A
Guestroom 01	-	15	1	0.3	1	1	10-	1		12	N/A
Guestroom 02		1	1	0.3		1	0	0		15	N/A
Guestroom 02		1.	1.	0.2		1.			1	1	NIZ
Guestroom 06		1	1	0.3	1		1		1	-	NVA
Guestioom de			15	0.5	1.5	1.	1.5	12	1.5	1-	19/24

Zone name	1		_	S	P	(l/s)]		_	_	1.00	
ID of system type	A	в	С	D	E	F	G	н	1	HRE	mciency
Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
circulation	9.1	-	0.4	× 1	5	6	e)	181	${\bf s} \in$	-	N/A
Circulation	۲.	-	0.4	-	-	-	+	-	+	-	N/A
en suite 1	-	-	1	0.4	-		+	÷	1.5		N/A
Guestroom 1	-	•		0.3		·	-	$\tau = 0$	10		N/A
en suite 2		-	÷	0.4		-	$\tau_{\perp} =$				N/A
Guestroom 2	-	-	+	0.3			+	-	+	-	N/A
Guestroom 3	-	-	÷	0.3			+	-	+	-	N/A
en suite 3	÷.(.)	-	2	0.4	4.1	-	÷		-	-	N/A
en suite 4	-	-	2	0.4		-	-	-	2.4	-	N/A
Guestroom 4	-	-	1	0.3	×	-	2	-	1.1	-	N/A
Guestroom 5	-	÷	0 <u>.</u>	0.3	2		5	15	$\frac{1}{2}$	~	N/A
Guestroom 5			2	0.3	->	-	-	-		-	N/A
Guestroom 6	- 1	-	•	0.3	•)	-	-2-	≤ 1		12	N/A
en suite 6	-	-	-	0.4		-	-	-	-	-	N/A
Guestroom 7	-	4	1	0.3	1	4	÷	× .	-	-	N/A
en suite 7	÷	•	1	0.4	10	4	e	5	÷	÷	N/A
Guestroom 8	4.0	-	÷.	0.3	-	1.1	-	-		4	N/A
en suite 8	e (-	-	0.4		+	÷1.	÷	-	-	N/A
	-			1.0.00	1.1		2.00		12		NUA
Guestroom 9	-2	-		0.3	-	-	-				19/14
Guestroom 9 en suite 9	1	•	÷	0.3			121		-		N/A
Guestroom 9 en suite 9 Guestroom 10		•		0.3		•		•	1.1	-	N/A N/A
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light	- -	•		0.3 0.4 0.3 0.4	- -	- - -	acy [- - m/W]			N/A N/A N/A
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name	-	•	-	0.3 0.4 0.3 0.4 Lur	ninou	s effic	acy [l	- - m/W] play la	mp	- - - General I	N/A N/A N/A N/A
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Si	- - ing	- - -	- - L e 6	0.3 0.4 0.3 0.4 Lur umina 0	minou	- - - s effic Lamp 60	acy [l	- - m/W] play la	mp	- - - General I	N/A N/A N/A N/A
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Staff Change	- - ing	- - -	- - - -	0.3 0.4 0.3 0.4 Lur umina 0	ninou	- - - - - - - - - - - - - - - - - - -	- - - Dist 22	- - m/W] play la	mp	General I	N/A N/A N/A Ighting [W
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Staff Change Comms	- - ing	- - -	- - - - -	0.3 0.4 0.3 0.4 Lun umina 0	minou	- - - - - - - - - - - - - - - - - - -	- - Disp 22 -	- - m/W] play la	- - mp	General I 125 49	N/A N/A N/A
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Staff Change Comms Staff Breakout	ing	- - -	- - - - -	0.3 0.4 0.3 0.4 Lun umina 0	ninou	- - - - - - - - - - - - - - - - - - -	- acy [l Disp 22	- - m/W] play ta	mp	- - - - - - - - - - - - - - - - - - -	N/A N/A N/A N/A
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Staff Change Comms Staff Breakout Circulation	- - ing	- - -	- - - -	0.3 0.4 0.3 0.4 Lun umina 0	minou	- - - - - - - - - - - - - - - - - - -	- - - Dist 22 -	- - m/W] play la	mp	General I 125 49 62 29	N/A N/A N/A N/A
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Staff Change Comms Staff Breakout Circulation Circulation	ing	- - -	• • • • •	0.3 0.4 0.3 0.4 Lur umina 0	minou	- - - - - - - - - - - - - - - - - - -	- - - - - - - - -	- - - m/W] play la	mp		N/A N/A N/A
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Sistaff Change Comms Staff Breakout Circulation Stainwell	- - ing	- - -	- - - -	0.3 0.4 0.3 0.4 Lur umina 0	minou	- - - - - - - - - - - - - - - - - - -	- acy [l Disp 22 - -	- - m/W] olay la	mp	General I 125 49 62 29 53 38	N/A N/A N/A N/A
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Staff Change Comms Staff Breakout Circulation Circulation Stainwell Kitchen	- - ing tandar	- - -	- - - - - - -	0.3 0.4 0.3 0.4 Lur umina 0	ninou	- - - - - - - - - - - - - - - - - - -		- - m/W] olay la	mp	General I 125 49 62 29 53 38 465	N/A N/A N/A N/A
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Staff Change Comms Staff Breakout Circulation Circulation Stairwell Kitchen Ace WC	- - ing	- - -	- - - - - - - -	0.3 0.4 0.3 0.4 Lur umina 0 00	minou	- - - - - - - - - - - - - - - - - - -	acy [l Dist 22	- - m/W] play la	mp	General I 125 49 62 29 53 38 465 30	N/A N/A N/A N/A
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Staff Change Comms Staff Breakout Circulation Circulation Stainwell Kitchen Acc WC Circulation	ing	- - - d valu	- - - - - - - - -	0.3 0.4 0.3 0.4 Unina 0	minou	s effic Lamp 60 100 100 100 100 100 100 100		m/W]	mp	General 1 125 49 62 29 53 38 465 30 46	N/A N/A N/A N/A
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Sistaff Change Comms Staff Breakout Circulation Stainwell Kitchen Ace WC Circulation Staff Cycle	ing tandar	- - -	- - - - - - - - - - - - - - - - - - -	0.3 0.4 0.3 0.4 0.4 Lun umina 0 000	ninou	s efficience s	acy [l Disp 22	m/W)	mp	General I 125 49 62 29 53 38 465 30 46 10	IVA IVA IVA Ighting [W
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Staff Change Comms Staff Breakout Circulation Circulation Stainwell Kitchen Acc WC Circulation Staff Cycle Admin	ing	- - -	L e 6 - - - - - - - - - - - - - - - - - - -	0.3 0.4 0.3 0.4 0.4 Lun umina 0 0 00	ninou	s efficience s	acy [[Disp 22	m/W)	mp	General I 125 49 62 29 53 38 465 30 46 10 162	IVA IVA IVA Ighting [W
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Staff Change Comms Staff Breakout Circulation Circulation Circulation Stairwel Kitchen Ace WC Circulation Staff Cycle Admin Goods In	ing	- - -	L e 6 - - - - - - - - - - - - - - - - - - -	0.3 0.4 0.3 0.4 0.4 0.4 Lunumina 0 00 00	ninou jire	s effication s effication effication s effication effication s effication s effication s effication s effication s effication s effication	acy [[Disp 22	- - - - - - - - - - - - - - - - - - -	mp	General 1 125 49 62 29 53 38 465 30 46 10 162 15	N/A N/A N/A N/A
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Staff Change Comms Staff Breakout Circulation Circulation Stairwell Kitchen Acc WC Circulation Staff Cycle Admin Goods In Restaurant & Bar	ing	- - -	- - - - - - - - - - - - - - - - - - -	0.3 0.4 0.3 0.4 0.4 Lur umina 0 0 00 00	ninou	s efficience s efficience efficience s efficience s efficience effici	acy [l Disp 22	- - - - - - - - - - - - - - - - - - -	mp	General 1 125 49 62 29 53 38 465 30 46 10 162 15 839	NVA NVA NVA
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Si Staff Change Comms Staff Breakout Circulation Stainvell Kitchen Ace WC Circulation Staff Cycle Admin Goods In Restaurant & Bar Recoeption	ing tanda	- - -	- - - - - - - - - - - - - - - - - - -	0.3 0.4 0.3 0.4 0.4 Lur Lur 0 0 0 0 0 0	ninou	s effic Lamp 60 100 100 100 100 100 100 100 100	acy [l Disp 22	m/W) olay la	mp	General I 125 49 62 29 53 38 465 30 46 10 162 15 839 200	N/A N/A N/A N/A
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Staff Change Comms Staff Breakout Circulation Stainvell Kitchen Acc WC Circulation Staff Cycle Admin Goods In Restaurant & Bar Reception Circulation Circulation Circulation Circulation Circulation Circulation	ing	- - -	- - - - - - - - - - - - - - - - - - -	0.3 0.4 0.3 0.4 Lun umina 0 0 00	ninou	s effic Lamp 60 100 100 100 100 100 100 100 100 100	acy [[Disp 22	m/W) olay la	mp	General I 125 49 62 29 53 38 465 30 46 10 162 15 839 200 60	IVA IVA IVA Ighting [W
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Si Staff Change Comms Staff Breakout Circulation Circulation Stainwell Kitchen Acc WC Circulation Staff Cycle Admin Goods In Restaurant & Bar Recepton Circulation en suite 02	ing	- - -	- - - - - - - - - - - - - - - - - - -	0.3 0.4 0.3 0.4 Lun umina 0 0 00	minou ire i	s efficience Lamp 60 100 100 100 100 100 100 100 100 100	acy [[Disp 22	m/W] play la	mp	General I 125 49 62 29 53 38 465 30 46 10 162 15 839 200 60 12	N/A N/A N/A N/A
Guestroom 9 en suite 9 Guestroom 10 en suite 10 General lighting and display light Zone name Staff Change Comms Staff Breakout Circulation Circulation Stairwell Kitchen Ace WC Circulation Staff Cycle Admin Goods In Restaurant & Bar Reception Circulation en suite 02 Guestroom 02	ing	- - -		0.3 0.4 0.3 0.4 0.4 0.4 0 0 0 0 0 0 0 0 0 0	minou	s effic Lamp 60 100 100 100 100 100 100 100 100 100	acy [l Disp 22 - - - - - - - - - - - - - - - - - -	m/W]	mp	General I 125 49 62 29 53 38 465 30 465 30 465 30 465 30 465 30 465 30 465 30 465 30 465 15 839 200 60 12 27	IVA IVA IVA

())ensphere General lighting and display lighting Luminous efficacy [lm/W] Luminaire Lamp Display lamp General lighting [W] Zone name Standard value 60 60 22 en suite 03 100. 9 Guestroom 03 100 29 Guestroom 06 100 24 100 en suite 01 12 Guestroom 01 100 22 en suite 06 100 11 Stairwell 100 28 Guestroom 10 100 26 11 en suite 10 100 en suite 11 100 13 Guestroom 11 100 28 13 en suite 12 100 Guestroom 12 100 33 en suite 15 100 9 Guestroom 15 100 28 27 Guestroom 16 100 en suite 16 100 10 100 11 en suite 19 100 29 Guestroom 19 Guestroom 18 100 26 100 10 en suite 18 100 10 en suite 17 100 26 Guestroom 17 100 10 en suite 13 Guestroom 13 100 26 Guestroom 14 100 26 en suite 14 100 -10 en suite 20 100 12 Guestroom 20 100 31 Guestroom 22 100 -27 en suite 22 100 + 10 25 Guestroom 21 100 en suite 21 100 10 72 Circulation 100 11 en suite 09 100 en suite 08 100 10 Guestroom 08 100 28 Guestroom 04 100 -25 en suite 04 100 10 Guestroom 05 100 26 10 en suite 05 100 en suite 07 100 10 Guestroom 07 100 -30 Page 7 of 17

	Lumino	ous effic	acy [Im/W]	A
Zone name	Luminaire	Lamp	Display lamp	General lighting [W]
Standard value	00	60	22	104
Circulation	~	100	-	104
Guestroom 09	×.	100	-	28
Guestroom 01	-	100	7	22
en suite 01		100	7	10
Guestroom U2	-	100	·	26
en suite U2	•	100		10
Guestroom 05	•	100	-	31
en suite 05	-	100	-	10
en sulte 06	-	100	-	12
Guestroom 06	-	100		26
en suite 07	×	100	5	10
Guestroom 07	~	100	5	26
Guestroom U8	~	100	2	28
en suite us	-	100	-	14
Guestroom 09	*	100	×	33
en suite 09	1	100	5	14
en suite 10	*	100	2	10
Guestroom 10	÷	100		2/
en suite 12	÷	100	-	10
Guestroom 12	*	100		27
Guestroom 13		100	<u>.</u>	27
en suite 13	-	100	-	10
en suite 14	-	100	-	10
Guestroom 14	-	100	-	26
Guestroom 15	~	100		27
en suite 15	~	100	r	10
en suite 16	-	100	ć.	11
Guestroom 16		100	2	30
Stairwell	-	100	7	28
en suite 19	•	100		10
Guestroom 19		100		29
Guestroom 18	•	100	-	25
en sulte 18	*	100	-	10
en suite 17	*	100	-	13
Guestroom 17	~	100	2	31
Guestroom 03	~	100	3	24
en suite 03	~	100	2	9
en suite 04		100	-	10
Guestroom 04	*	100	5	32
Guestroom 11	*	100	2	26
en suite 11	¥	100	-	10
Circulation	•	100	8	104
Circulation	1	100	e	46

Oensphere

1 1 1 1 1 1 1 1 2 1 1 2 2 1 2 2 4	Lama	Disalay lama	Constal Linksing DA
50	Ro	oispiay lamp	General lighting [*
00	100		27
12	100	3	23
1	100	120	11
1	100	2	25
1	100	5	11
1.	100	1	23
1.	100		9
	100	5	31
	100	-	9
-	100	-	10
1	100	1.	31
0	100	-	28
-	100	-	11
2	100	Ú	16
1.	100	2	29
-	100	-	16
-	100	-	10
-	100		27
1	100	2	27
	100	2	10
	100	2	10
1	100	4	26
	100	× 1	26
	100	2	10
~	100	-	26
~	100	2	10
2	100	2	26
12 1	100	1	10
-	100	<u>.</u>	11
	100	1	27
-0	100		13
	100		30
-	100	-	34
-	100	5	35
*	100	2	14
2	100	5	46
-	100	S	108
2	100		57
-	100	Q.	39
· .	100	6	21
lu l	100	C	26
	100	¥	20
	100		37
	 . .<	- 100 -	100. - 100. - - 100.

Luminaire 60		acy [inner]	
60	Lamp	Display lamp	General lighting [W]
	60	22	
×	100	-	44
-	100	2	22
·	100	-	27
	100	P	65
•	100	÷	96
•	100	•	79
	100	-	23
	100	×	57
	100	÷-	14
÷	100	2	35
2	100	÷	32
2	100	h	14
~	100	5	14
-	100	÷	33
- 1	100	8	33
+	100	-	14
-	100	e	30
+	100		22
÷	100		28
	100	<u>k</u> .	18
÷	100	£1	52
~	100	× .	13
2	100	ř.	39
¥.	100	-	14
-	100	8	40
<	100	-	15
		- 100 - 100	- 100 - - 100 -

	1,101,1		
Circulation	N/A	N/A	
Staff Cycle	N/A	N/A	_
Admin	N/A.	N/A	
Goods In	N/A.	N/A	
Restaurant & Bar	NO (-63%)	NO	
Reception	N/A	N/A	

Fage 10 of 17

Zone	Solar gain limit exceeded? (%)	Internal blinds used
Circulation	N/A	N/A
en suite 02	N/A	N/A
Guestroom 02	NO (-58.4%)	NO
en sulte 03	N/A.	N/A
Guestroom 03	N/A	N/A
Guestroom 06	NO(+56%)	NO
en suite 01	N/A.	N/A
Guestroom 01	NO (+60.6%)	NO
en suite 06	N/A.	N/A
Stairwell	N/A.	N/A
Guestroom 10	NO (-64,2%)	NO
en suite 10	N/A.	N/A
en suite 11	N/A.	N/A
Guestroom 11	NO (-65.2%)	NO
en suite 12	N/A	N/A
Guestroom 12	NO (-34,1%)	NO
en suite 15	N/A	N/A
Guestroom 15	NO (-13.4%)	NO
Guestroom 16	NO (+13.8%)	NO
en suite 16	N/A.	N/A
en suite 19	NO (-10.2%)	NO
Guestroom 19	NG (-22.3%)	NO
Guestroom 18	NO (+12%)	NO
en suite 18	N/A	N/A
an suite 17	N/A	N/A
Guestroom 17	NO (-10 896)	NO
an suite 13	N/A	N/A
Guestroom 13	NO 1-0-0901	NO
Guestion 13	MO (-3.3 (50))	NO
en suite 14	NIA	NIA
en suite 20	N/A	IN/A
Cuestaan 20	NO (REGRIN)	NO
Guestman 22	NG (*00.076)	NO
en quite 22	N/A	NUA
Cuestieren 21	NO. 2012	NO
Guestroom 21	1962 (10 1 2 m).	NO
en suite 21	N/A.	NA
orrouguon	DIG.	11/2
en suite 09	DV/A.	51/5
Custome 00	IN/A.	NO
Guestroom V8	NO (-Y0.9%)	NO
Guestroom 04	NO (-61.73b)	NU
en solle 04	N/A	NA
Guestroom 05	NO (+60.9%)	NU
en suite 05	N/A.	N/A
en suite 07	N/A.	N/A
Guestroom 07	NO (655,2%)	NO
Circulation	N/A	N/A
Guestroom 09	NO (-68/7%)	NO
Guestroom 01	NO (-80.9%)	NO

Oensphere

Zone	Solar gain limit exceeded? (%)	Internal blinds used
en suite 01	N/A	N/A
Guestroom 02	NO (-83.7%)	NO
en suite 02	N/A.	N/A
Guestroom 05	NO (-86.8%)	NO
en suite 05	N/A.	N/A
en suite 06	N/A.	N/A
Guestroom 06	NG (-77.3%)	NO
en suite 07	N/A.	N/A
Guestroom 07	NO (-63%)	NO
Guestroom 08	NO(-64.7%)	NO
en suite 08	N/A.	N/A
Guestroom 09	NO (-47.4%)	NO
en suite 09	N/A.	N/A
en suite 10	N/A.	N/A
Guestroom 10	NO (-31.4%)	NO
en suite 12	N/A.	N/A
Guestroom 12	NO (-32,2%)	NO
Guestroom 13	NO (-32.8%)	NO
en suite 13	N/A.	N/A
en suite 14	N/A.	N/A
Guestroom 14	NO (-29.7%)	NO
Guestroom 15	NO (-31.5%)	NO
en suite 15	N/A	N/A
en suite 16	NA	N/A
Guestroom 16	NO (-40 8%)	NO
Stairwell	N/A	N/A
en suite 19	N/A.	N/A
Guestroom 19	NO1-764%	NO
Guestroom 18	600 (FSCF M)	NO
en suite 19	N/A	NIA
en suite 17	N/A	NIA
Cupetrange 17	NO LEE SOLV	NO
Guestman 02	NG (100.3 m)	NO
es suite 03	N/A	NUA
en suite 03	N/A	N/A
Cuesties 04	NO. 07 0001	NA
Guestroom 04	NO (-67,610)	NO
Guestroom 11	NO [-30.5%)	NO
en suite 11	NVA.	IN/A
Circulation	N/A.	NIA
Girculation	N/A.	N/A
starwell	N/A.	N/A
Guestroom 01	NO (-83.4%)	NO
en suite 01	N/A	N/A
Guestroom 02	NO. (+84.17k)	NO
en suite 02	N/A.	N/A
Guestroom 03	NO (+75/8%)	NO
en suite 03	N/A	N/A
Guestroom 04	NO (-67.7%)	NO
en suite 04	N/A.	N/A

Zone	Solar gain limit exceeded? (%)	Internal blinds used
en suite 05	N/A	N/A
Guestroom 05	NO (-87 7%)	NO
Guestroom 07	NO (-56:7%)	NO
en sulte 07	N/A.	N/A
en suite 08	N/A	N/A
Guestroom 08	NO (466.4%)	NO
en suite09	N/A.	N/A
en suite 10	N/A.	N/A
Guestroom 10	NO (-32%)	NO
Guestroom 11	NO (-30.6%)	NO
en suite 11	N/A.	N/A
en suite 12	N/A.	N/A
Guestroom 12	NO (-30%)	NO
Guestroom 13	NO (-29.3%)	NO
en suite 13	N/A	N/A
Guestroom 14	NO (-29.6%)	NO
en suite 14	N/A.	N/A
Guestroom 15	NO (-30.3%)	NO
en suite 15	N/A	N/A
en suite 16	N/A.	N/A
Guestroom 16	NO (-33%)	NO
en suite 06	N/A.	N/A
Guestroom 06	NO (-82.5%)	NO
Guestroom 17	NO (-80.3%)	NO
Guestroom 09	NO (-50.3%)	NO
en suite17	N/A	N/A
circulation	N/A.	N/A
circulation	NO (-52.1%)	NO
circulation	N/A	N/A
Guestroom 03	NO (-29.8%)	NO
en suite 03	N/A.	N/A
en suite 06	N/A.	N/A
Guestroom 01	NO (-14%)	NO
Guestroom 01	NO (-23.6%)	NO
Guestroom 02	NO (-35,2%)	NO
Guestroom 02	NO (-25.9%)	NO
stairwell	N/A.	N/A
Guestroom 06	YES (+18.6%)	NO
circulation	N/A.	N/A
Circulation	N/A.	N/A
en suite 1	N/A.	N/A
Guestroom 1	NO (+95.1%)	NO
en suite 2	N/A.	N/A
Guestroom 2	NO (+83:2%)	NO
Guestroom 3	N/A.	N/A
en suite 3	N/A.	N/A
en suite 4	N/A.	N/A
Guestroom 4	NO (-77%)	NO
Guestroom 5	NO (-84.8%)	NO
Statement of the state of		

ensphere

Guestroom 5 N/A N/A Guestroom 6 N/A N/A en suite 6 N/A N/A Guestroom 7 N/A N/A Guestroom 8 N/A N/A en suite 7 N/A N/A Guestroom 8 N/A N/A en suite 3 N/A N/A Guestroom 9 N/A N/A en suite 3 N/A N/A Guestroom 9 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 10 N/A N/A Criterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission Separate submission Criterion 5: The necessary provisions for enabling energy-efficient operation of the suilding should be in place Separate submission Separate submission Criterion 5: Consideration of alternative energy systems YES PBD (Recast): Consideration of alternative energy systems YES Are any such measures included in the proposed design? YES Are any such measures included in the proposed design?<	Guestroom 5 N/A N/A Guestroom 6 N/A N/A en suite 6 N/A N/A Guestroom 7 N/A N/A en suite 7 N/A N/A Guestroom 8 N/A N/A en suite 7 N/A N/A Guestroom 8 N/A N/A en suite 8 N/A N/A Guestroom 9 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 10 N/A N/A Criterion 4: The performance of the building, as built, should be consistent with the calculated BER Separate submission Separate submission Criterion 5: The necessary provisions for enabling energy-efficient operation of the puilding should be in place Separate submission Separate submission EPBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Are any such measures included in the proposed design? YES	Guestroom 5 N/A N/A Guestroom 6 N/A N/A en suite 6 N/A N/A Guestroom 7 N/Q (-83,3%) N/O en suite 7 N/A N/A Guestroom 7 N/A N/A Guestroom 7 N/A N/A Guestroom 8 N/A N/A Guestroom 8 N/A N/A Guestroom 9 N/A N/A en suite 8 N/A N/A Guestroom 10 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 10 N/A N/A Criterion 4: The performance of the building, as built, should be consistent with the talculated BER Separate submission Separate submission Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place Separate submission Separate submission EPBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Are any such measures included in the proposed design?<	Zone	Solar gain limit exceeded? (%)	Internal blinds used
Guestroom 6 NO (-72.2%) NO en suite 6 N/A N/A Guestroom 7 NO (-83.3%) NO en suite 7 N/A N/A Guestroom 8 N/A N/A en suite 8 N/A N/A Guestroom 9 N/A N/A Guestroom 9 N/A N/A Guestroom 10 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 10 N/A N/A Criterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission Separate submission Criterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission Separate submission CPBD (Recast): Consideration of alternative energy systems YES Vere alternative energy systems considered and analysed as part of the design process? <td>Guestroom 6 NO (-72.2%) NO en suite 6 N/A N/A Guestroom 7 NO (-83.3%) NO en suite 7 NA N/A Guestroom 8 N/A N/A en suite 7 NA N/A Guestroom 8 N/A N/A en suite 8 N/A N/A guestroom 9 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 10 N/A N/A Criterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission Separate submission Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place Separate submission Separate submission Criterion 5: Consideration of alternative energy systems Separate submission Separate submission Separate submission Separate submission? YES Is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design?</td> <td>Guestroom 6 NO (-72.2%) NO ensulte 6 N/A N/A Guestroom 7 N/A N/A ensulte 7 N/A N/A Guestroom 8 N/A N/A ensulte 7 N/A N/A Guestroom 8 N/A N/A ensulte 8 N/A N/A Guestroom 9 N/A N/A ensulte 9 N/A N/A Guestroom 10 N/A N/A ensulte 10 N/A N/A Friterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission Separate submission Priterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission Separate submission PEPD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Are any such measures included in the proposed design? YES</td> <td>Guestroom 5</td> <td>N/A.</td> <td>1N/A</td>	Guestroom 6 NO (-72.2%) NO en suite 6 N/A N/A Guestroom 7 NO (-83.3%) NO en suite 7 NA N/A Guestroom 8 N/A N/A en suite 7 NA N/A Guestroom 8 N/A N/A en suite 8 N/A N/A guestroom 9 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 10 N/A N/A Criterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission Separate submission Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place Separate submission Separate submission Criterion 5: Consideration of alternative energy systems Separate submission Separate submission Separate submission Separate submission? YES Is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design?	Guestroom 6 NO (-72.2%) NO ensulte 6 N/A N/A Guestroom 7 N/A N/A ensulte 7 N/A N/A Guestroom 8 N/A N/A ensulte 7 N/A N/A Guestroom 8 N/A N/A ensulte 8 N/A N/A Guestroom 9 N/A N/A ensulte 9 N/A N/A Guestroom 10 N/A N/A ensulte 10 N/A N/A Friterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission Separate submission Priterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission Separate submission PEPD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Are any such measures included in the proposed design? YES	Guestroom 5	N/A.	1N/A
en suite 6 N/A N/A N/A Guestroom 7 N/A Guestroom 7 N/A N/A Guestroom 7 N/A N/A N/A Guestroom 8 N/A N/A N/A Guestroom 8 N/A N/A N/A en suite 8 N/A N/A N/A Guestroom 9 N/A N/A N/A Guestroom 9 N/A N/A N/A Guestroom 10 N/A N/A N/A Guestroom 10 N/A N/A N/A Guestroom 10 N/A N/A M/A Guestroom 10 N/A N/A M/A Guestroom 10 N/A N/A Guestroom 10 N/A N/A M/A Guestroom 5 M/A N/A M/A Guestroom 5 M/A N/A M/A Guestroom 10 N/A N/A M/A Guestroom 10 N/A N/A M/A Guestroom 10 N/A M/A M/A Guestroom 5 M/A M/A M/A Guestroom 5 M/A M/A M/A Guestroom 5 M/A M/A M/A Guestroom 10 N/A M/A M/A Guestroom 10 N/A M/A M/A M/A Guestroom 5 M/A M/A M/A M/A Guestroom 5 M/A M/A M/A M/A Guestroom 10 N/A M/A M/A Guestroom 5 M/A M/A M/A M/A M/A Guestroom 5 M/A M/A M/A M/A M/A Guestroom 5 M/A	en suite 6 N/A N/A N/A Guestroom 7 N/A Guestroom 7 N/A N/A N/A O O O O O O O O O O O O O O O O O O O	en suite 6 N/A N/A N/A Guestroom 7 N/A (193,3%)) N/C en suite 7 N/A (193,3%)) N/C en suite 7 N/A (194,4) N/A (194,	Guestroom 6	NO (-72-2%)	NO
Guestroom 7 NQ (-93,3%) NQ en suite 7 N/A N/A Guestroom 8 N/A N/A en suite 8 N/A N/A Guestroom 9 N/A N/A en suite 8 N/A N/A Guestroom 9 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 10 N/A N/A riterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of altérnative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Sevidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design? YES	Guestroom 7 NQ (-93,3%) NQ ensuite 7 N/A N/A Guestroom 8 N/A N/A ensuite 8 N/A N/A Guestroom 9 N/A N/A ensuite 9 N/A N/A Guestroom 9 N/A N/A ensuite 9 N/A N/A Guestroom 10 N/A N/A ensuite 10 N/A N/A riterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Are any such measures included in the proposed design? YES	Guestroom 7 NQL (33,3%) NO en suite 7 N/A N/A Guestroom 8 N/A N/A en suite 8 N/A N/A Guestroom 9 N/A N/A en suite 8 N/A N/A Guestroom 9 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 10 N/A N/A riterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design? YES	en suite 6	N/A.	N/A
en suite 7 N/A N/A Guestroom 8 N/A N/A N/A en suite 8 N/A N/A N/A en suite 9 N/A N/A N/A Guestroom 9 N/A N/A N/A en suite 9 N/A N/A N/A Guestroom 10 N/A N/A N/A en suite 10 N/A N/A riterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? Separate submission? YES Is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design? YES	en suite 7 N/A N/A A Guestroom 8 N/A N/A A A A A A A A A A A A A A A A A	en suite 7 N/A N/A Guestroom 8 N/A N/A en suite 8 N/A N/A en suite 9 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 10 N/A N/A en suite 10 N/A N/A riterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? VES is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design? YES	Guestroom 7	NQ (-83,3%)	NO
Guestroom 8 N/A N/A en suite 8 N/A N/A Guestroom 9 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 10 N/A N/A riterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Are any such measures included in the proposed design? YES	Guestroom 8 N/A N/A en suite 8 N/A N/A Guestroom 9 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 10 N/A N/A riterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Are any such measures included in the proposed design? YES	Guestroom 8 N/A N/A en suite 8 N/A N/A Guestroom 9 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 10 N/A N/A riterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Ware alternative energy systems considered and analysed as part of the design process? YES Are any such measures included in the proposed design? YES	en suite 7	N/A	N/A
en suite 8 N/A N/A Guestroom 9 N/A N/A Guestroom 9 N/A N/A en suite 10 N/	en suite 8 N/A N/A Guestroom 9 N/A N/A Guestroom 9 N/A N/A Or A N/A Guestroom 10 N/A N/A Or A N/A Guestroom 10 N/A N/A N/A Or A N/A Or A N/A Or A N/A Or A N/A N/A Or A N/A OR	en suite 8 N/A N/A Guestroom 9 N/A N/A A A A A A A A A A A A A A A A A	Guestroom 8	N/A.	N/A
Guestroom 9 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 10 N/A N/A riterion 4: The performance of the building, as built, should be consistent with the alculated BER separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES sevidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design?	Guestroom 9 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 10 N/A N/A riterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Are any such measures included in the proposed design?	Guestroom 9 N/A N/A en suite 9 N/A N/A Guestroom 10 N/A N/A en suite 10 N/A N/A riterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Deparate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Are any such measures included in the proposed design?	en suite 8	N/A.	N/A
en suite 9 NA N/A Guestroom 10 N/A N/A Guestroom 10 N/A N/A en suite 10 N/A N/A ritterion 4: The performance of the building, as built, should be consistent with the alculated BER separate submission ritterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design?	en suite 9. NA. N/A Guestroom 10 N/A N/A en suite 10 N/A N/A riterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design? YES	en suite 9 NA NA Guestroom 10 N/A Guestroom 10 N/A	Guestroom 9	N/A.	N/A
Guestroom 10 N/A N/A en suite 10 N/A N/A riterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Are any such measures included in the proposed design? YES	Guestroom 10 N/A N/A en suite 10 N/A N/A ritterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission ritterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? Is evidence of such assessment available as a separate submission? Are any such measures included in the proposed design?	Guestroom 10 N/A N/A en suite 10 N/A N/A ritterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission ritterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Are any such measures included in the proposed design?	en suite 9	N/A.	N/A
en suite 10 N/A N/A interior 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design? YES	en suite 10 N/A N/A interior 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design? YES	en suite 10 N/A N/A interior 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission interior 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design? YES	Guestroom 10	N/A	N/A
riterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design? YES	riterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Are any such measures included in the proposed design? YES	riterion 4: The performance of the building, as built, should be consistent with the alculated BER Separate submission riterion 5: The necessary provisions for enabling energy-efficient operation of the uilding should be in place Separate submission PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Are any such measures included in the proposed design? YES	en suite 10	N/A	N/A
PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design? YES	PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design? YES	PBD (Recast): Consideration of alternative energy systems Were alternative energy systems considered and analysed as part of the design process? YES Is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design? YES	uilding should be in place Separate submission		
Is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design? YES	Is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design? YES	Is evidence of such assessment available as a separate submission? YES Are any such measures included in the proposed design? YES	Were alternative energy systems c	of alternative energy systems onsidered and analysed as part of the design p	rocess? YES
Are any such measures included in the proposed design? YES	Are any such measures included in the proposed design? YES	Are any such measures included in the proposed design? YES	to avidence of such organized avail	ahle as a senarate submission?	1400
			is evidence of such assessment avail Are any such measures included in th	eare as sciperation submits on r	YES
			is evidence of such assessment avail Are any such measures included in th	early as a scylattic submitsion r	YES
			Are any such measures included in th	eare as expenses advinibility of the proposed design?	YES
			Are any such measures included in th	eare as expenses advised advised average of the proposed design?	YES
			Are any such measures included in th	eare as a separate submitsion : te proposed design?	YES
			Are any such measures included in th	eare as a separate submitsion : te proposed design?	YES

Area [m²]	ananner	ers	Building Use
Area [m ²]	Actu	al Notional	% Area Building Type
	2362	2362	A1/A2 Retail/Financial and Professional services
External area [m ²]	3278.	6 3102.2	A3/A4/A5 Restaurants and Cafes/Drinking Est/Takeaways
Weather	LON	LON	B1 Offices and Workshop businesses B2 to B7 General Industrial and Special Industrial Groups
Infiltration [m ³ /hm ² @ 50P	a] 3	3	B8 Storage or Distribution
Average conductance [W	/K] 653.9	5 900.91	100 C1 Hotels
Average U-value [W/m ² K	0.2	0.29	C2 Residential Institutions: Hospitals and Care Homes
Alpha value* [%]	10.96	10	C2 Residential Institutions: Universities and colleges
Energy Consum Heating Cooling Auxiliary Lighting Hot water	Actual 3.42 2.22 6.74 9.28 54.39 22.05	End Use [kWh Notional 6.8 3.29 8.16 16.66 68.55 9.265	D1 Non-residential institutions: CommunityDay Centre D1 Non-residential Institutions: Libraries, Museums, and Galleri D1 Non-residential Institutions: Education D1 Non-residential Institutions: Crown and County Courts D2 General Assembly and Leisure, Night Clubs, and Theatres Others: Energency services Others: Energency services Others: Car Parks 24 hrs Others: Stand alone utility block
Equipment	23.65	23.65	
equipment ⁻	76.05	103.46	
Equipment* TOTAL** Energy used by equipment does not co * Total is net of any electrical energy dis	int towards the to placed by CHP ge	merators, if applicable.	
Equipment TOTAL** Energy and by equipment does not co T dat is not of any electrical energy de Energy Production Photovoltaic systems Wind turbines CHP generators Scilar themas excesses	on by Te on by CHP gr Actual 2.41 0 0	echnology [kW Notional 0 0 0	h/m²]
Equipment: TOTAL:* Energy and by equipment does not co Trata is not of any electrical energy de Energy Producti Photovoltaic systems Wind turbines CHP generators Solar thermal systems Energy & CO ₂ En	ant lowards the to placed by CHP go on by Te Actual 2.41 0 0 0 1 issions	echnology [kW Notional 0 0 0 0 0 0 Summary	h/m²]
Equipment: TOTAL** Energy equipment does not co T dat is not of any electrical energy de Energy Producti Photovoltaic systems Wind turbines CHP generators Solar thermal systems Energy & CO ₂ En	ant lowards the Ic placed by CHP gr Actual 2.41 0 0 0 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	Actual	h/m ²]
Equipment: TOTAL** Total a net drag vesticitat energy de Trada is net drag vesticitat energy de Energy Productia Wind turbines CHP generators Solar thermal systems Energy & CO ₂ En Heating + cooling deman	and lowards the to placed by CHP gr on by TC Actual 2.41 0 0 0 1issions d [MJ/m ²]	Actual 83.29	h/m ²] Notional 107.48
Equipment: ToTAL** Emergy used by easigned does not co Total a not of any vectorial womey do Energy Production Photovoltaic systems Wind turbines CHP generators Solar thermal systems Energy & CO ₂ En Heating + cooling deman Primary energy' (kWh/m	and lowards the to bloced by CHP gr on by TC Actual 2.41 0 0 0 0 nissions d [MJ/m ²]	Actual 83.29 83.29 83.29 83.29	Notional 107.48 535.24

Page 15 of 17

System 1	Гуре	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Cool con kWh/m2	Aux con kWh/m2	Heat SSEEF	Cool SSEER	Heat gen SEFF	Cool gen SEER
[ST] Spli	t or m	ulti-split sy	stem, [HS]	Heat pump	(electric): a	ir source,	[HFT] Electr	icity, [CFT]	Electricity	
Actu	al	45.9	37.4	3.4	2.2	5.6	3.73	4.68	3.8	6.26
Notic	onal	62.6	44.8	6.8	3.3	8.2	2.56	3.79		
[ST] No I	leatin	g or Coolin	g							
Actu	al	0	0	0	0	0	0	0	0	0
Notic	onal	0	0	0	0	0	0	0		

Key to terms

= Heating energy demand
= Cooling energy demand
= Heating energy consumption
= Cooling energy consumption
= Auxiliary energy consumption
= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
= Cooling system seasonal energy efficiency ratio
= Heating generator seasonal efficiency
= Cooling generator seasonal energy efficiency ratio
= System type
= Heat source
= Heating fuel type
= Cooling fuel type

Page 16 of 17

Element		U.tm	UM	Surface	where the minimum value occu	r5*
Wall		0.23	0.04	FR00000	F:Surf[5]	
Floor		0.2	0.02	FF00000	1:Surf[5]	
Roof		0.15	0.12	GR00000	02;Surf[0]	
Windows, roof windows, and	rooflights	1.5	1.4	GR0000	04:Suf[3]	
Personnel doors	_	1.5	1:65	GR0000	DC:Surf[1]	
Vehicle access & similar larg	ge doors	1.5	2	No Vehic	de access doors in building	
High usage entrance doors		1.5	-	No High	usage entrance doors in building	
 There might be more than one sur 	values (W/(m/k	9) minimulinn (U-villue oc	Oran = Mind Ours	umu iogwonni eieuseur n-Annes I.M.(ui.K.	N
Air Permeability	Typ	ical valu	ie		This building	1
m//(h.m/) at 50 Pa	5				3	

Oensphere

roject name				
Bayam Street Office	Be	Gre	en	As designed
Date: Fri Aug 07 18:21:17 2020				
dministrative information				
uilding Details Address: . certification tool		0	wner De Name: Felephone Address:	number:
Calculation engine: Apache Calculation engine version: 7.0.12 Interface to calculation engine: IES Virtual 6 Interface to calculation engine version: 7.0 BRUKL compliance check version: v5.6.s.1	inviranme 12	Cr int 1	ertifier d Name: Telephone Address:	letails number:
CO ₂ emission rate from the notional build Target CO ₂ emission rate (TER), kgCO ₂ /m Building CO ₂ emission rate (BER), kgCO ₂ / Are emissions from the building less than	28.6 28.6 23.8 BER == TER			
Are an built details the name an used in th	Dian -> 1 an			
Are as out details the same as used in th	e den c	alculati	ohs?	Separate submission
Are as doit details the same as used in the same as used in the chieve reasonable overall standards displayed in red. Building fabric Element Wall** Floor Roof	e build rds of n the No 0.35 0.25 0.25	Uncate 0.12 0.12	bric any y efficio stic Buildi U.cat 0.15 0.12 0.12	Separate submission d fixed building services should ency ng Services Compliance Guide and Part L are Surface where the maximum value occurs* GR000003;Surf[2] LW00001:Surf[7]
Are as doit details the same as used in the same as used in the chieve reasonable overall standard values which do not achieve the standards displayed in red. Building fabric Element Wail** Filoar Roof Windows***, roof windows, and rooflights	e build rds of n the No 0.35 0.25 0.25 2.2	Uncore 0.12 0.12 0.12	bric any y efficio stic Build 0.15 0.12 0.12 1.4	Separate submission d fixed building services should ency ng Services Compliance Guide and Part L are Surface where the maximum value occurs* GR0000003:Surf[2] LW000001:Surf[7] LW000001:Surf[7] LW000001:Surf[7]
Are as don't denaits the same as used in the riterion 2: The performance of the chieve reasonable overall standards displayed in red. Building fabric Element Wall** Floor Roof Windows***, roof windows, and rooflights Personnel doors	e build rds of n the No 0.35 0.25 0.25 2.2 2.2	U. Calc 0.12 0.12 0.12 1.4 1.85	bric an y efficit stic Build U.cat. 0.15 0.12 0.12 1.4 1.65	Separate submission d fixed building services should ency ng Services Compliance Guide and Part L are Surface where the maximum value occurs* GR000001:Surf[2] LW000001:Surf[7] LW000001:Surf[7] LW000001:Surf[7] LW000001:Surf[7] LW000001:Surf[7]
riterion 2: The performance of th chieve reasonable overall standa Values which do not achieve the standards displayed in red. Building fabric Element Walt** Floor Roof Windows***, roof windows, and rooflights Personnel doors Vehicle access & similar large doors	e build rds of n the No 0.35 0.25 2.2 2.2 1.5 2.5	U. Calc 0.12 0.12 0.12 0.12 0.12 0.12 0.12 0.12	bric an y efficit stic Build U.cat. 0.15 0.12 0.12 1.4 1.65 -	Separate submission d fixed building services should ency ng Services Compliance Guide and Part L are Surface where the maximum value occurs* GR000003:Surf[2] LW000001:Surf[0] LW000001:Surf[7] LW000001:Surf[11] GR000003:Surf[3] No Vehicle access doors in building No Vehicle access doors in building
Are as built details the same as used in the chieve reasonable overall standar displayed in red. Building fabric Element Wall** Floor Roof Windows***, roof windows, and rooflights Personnel doors Vehicle access & similar large doors High usage entrance doors Usame 1 inform gene weighter overage U where fit Usame 2 inform gene weighter overage U where fit " Anomed Varias charts by the lost open one over " Anomed Varias charts by the lost open one over " Anomed Varias charts by the lost open one over " Anomed Control over the rene surface when the re- " Anomed Control over the rene surface when the re- " Anomed Control over the rene surface when the re- " Anomed Control over the rene surface when the re- " Anomed Control over the rene surface when the re- " Depty wordows and semile glazag are excluded the forther mody with the of open overthis not fits the the rendom overthis not fits motifie mody words on the re-	e build rds of n the No 0.25 0.25 0.25 0.25 0.25 0.25 0.25 0.25	Uscale 0.12 0.12 0.12 0.12 0.12 0.12 0.12 0.12	Uicae 0.15 0.12 1.4 1.65 - Uicae = Cr curs nace inniting nace inniting	Separate submission d fixed building services should ency ng Services Compliance Guide and Part L are Surface where the maximum value occurs* GR000003:Surf[2] LW000001:Surf[0] LW000001:Surf[1] GR000003:Surf[3] No Vehicle access doors in building No High usage entrance doors in building setulated maximum volvelue element (U-values) [W(m/K)] g iterutant is similar for thirt for windows aliod or checked against the limiting standards by the tool.
The as build details the same as used in the Criterion 2: The performance of the Chieve reasonable overall standar Values which do not achieve the standards displayed in red. Building fabric Element Wall** Floor Roof Windows***, roof windows, and rooflights Personnel doors Vehicle access & similar large doors High usage entrance doors Usars = Lindrag area-weighted exempt 0 waters (Usars = Calculated eners weighted exempt 0 waters (Usars = Calculated eners weighted exempt 0 waters (" Antomote Uwale check by the lost doors not eners" ** Deplay windows and similar glazing are exclude tils to the root windows in a mote weighted exempt 0 waters (** Antomote Uwale check by the lost doors not eners ** Deplay windows and similar glazing are excluded ** The method windows and similar glazing are excluded ***********************************	e build rdS of n the No 0.35 0.25 0.25 0.25 2.2 2.2 1.5 3.5 V/mmKij V/mrKij Aborn the assertion the	ling fa energ n-Oome: 0.12 0.12 0.12 0.12 0.12 0.12 0.12 0.12	bric any y efficio stic Buildi U.cae 0.15 0.12 0.12 0.12 0.12 1.4 1.65 - - - - - - - - - - - - - - - - - -	Separate submission d fixed building services should ency ng Services Compliance Guide and Part L are Surface where the maximum value occurs* GR000003:Surf[2] LW000001:Surf[0] LW000001:Surf[1] GR000003:Surf[1] GR000003:Surf[3] No Vehicle access doors in building No Vehicle access doors in building No Vehicle access doors in building skedaled maximum individual element U-values [W(in/K)] g skendard is similar to mit for windows alid or checked against the limiting standards by the tool. This building



General lighting and display lighting	Lumine	ous effic		
Zone name	Luminaire	Lamp	Display lamp	General lighting [W]
Standard value	60	60	22	
Circulation	3	100	4	45
Male WC	2	100	2	111
UA WC	×	100		33
Office WC Showers	-	100	Access of the second se	57
Office Cycle	1001			19
Workspace/Office Cale	100			351

Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
Work space/ Offices	NOX (-81,7%)	NO
Female WC	N/A.	N/A
Staitwell	N/A	N/A
Circulation	N/A.	14/A
Male WC	N/A.	MA
UA WC	N/A	NIA
Office WC Showers	N/A	N/A
Workspace/Office Cafe	NE(1-8%)	NO

Criterion 4: The performance of the building, as built, should be consistent with the calculated BER

Separate submission

Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place

Separate submission

EPBD (Recast): Consideration of alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	YES
Is evidence of such assessment available as a separate submission?	YES
Are any such measures included in the proposed design?	YES

19ape 2-of 6-

Building Global Pa	arame	ters	Building Use
	Actu	al Notional	% Area Building Type
Area [m ²]	601.9	601.9	A1/A2 Retail/Financial and Professional services
External area [m ²]	587.4	786.8	A3/A4/A5 Restaurants and Cafes/Drinking Est/Takeaways
Weather	LON	LON	100 B1 Offices and Workshop businesses B2 to B7 General Industrial and Special Industrial Groups
Infiltration [m³/hm²@ 50Pa]	3	3	B8 Storage or Distribution
Average conductance [W/K] 123.8	202.42	C1 Hotels
Average U-value [W/m ² K]	0.21	0.26	C2 Residential Institutions: Hospitals and Care Homes
Alpha value* [%]	10.3	10	C2 Residential Institutions: Residential Schools C2 Residential Institutions: Universities and colleges
Energy Consumpt Heating Cooling Auxiliary Lighting Hot water Equipment* TOTAL**	tion by Actual 0.86 4.76 6.75 12.93 20.58 34.76 45.88	Pend Use [kWl Notiona 2.59 5.26 3.25 25.53 19.82 34.76 56.43	
** Total is net of any electrical energy display	ed by CHP g	enerators, il applicable.	
Energy Production	n by T	echnology [kW	/h/m²]
	Actual	Notiona	
Photovoltaic susteme	0	0	
Photovoltaic systems	0 0		
Photovoltaic systems Wind turbines	0	0	
Photovoltaic systems Wind turbines CHP generators Solar thermal systems	0	0	
Photovoltaic systems Wind turbines CHP generators Solar thermal systems	0 0 ssion	0 0 Summary	
Photovoitaic systems Wind turbines CHP generators Solar thermal systems Energy & CO ₂ Emi	o o ssion:	0 0 s Summary Actual	Notional
Photovoltaic systems Wind turbines CHP generators Solar thermal systems Energy & CO ₂ Emi Heating + cooling demand	0 0 ssion:	0 0 s Summary Actual 91.7	Notional 95.53
Photovoltaic systems Wind turbines CHP generators Solar thermal systems Energy & CO ₂ Emi Heating + cooling demand Primary energy" (WW/m ²)	0 0 ssion: [MJ/m ²]	0 0 s Summary Actual 91.7 206.68	Notional 95.53 235.99
Photovoltaic systems Wind turbines CHP generators Solar thermal systems Energy & CO ₂ Emi Heating + cooling demand Primary energy' [kWh/m ²] Total emission Rk/m ²]	0 0 ssion: [MJ/m ²]	0 0 s Summary Actual 91.7 206.68 23.8	Notional 95.53 235.99 28.6

Page 4 of 6

HVAC Systems Performance											
Sys	stem Type	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Cool con kWh/m2	Aux con kWh/m2	Heat SSEEF	Cool SSEER	Heat gen SEFF	Cool gen SEER	
ST] Split or multi-split system, [HS] Heat pump (electric): air source, [HFT] Electricity, [CFT] Electricity											
	Actual	11.9	83	0.9	4.9	2.3	3.73	4.68	3.8	6.26	
	Notional	24.7	74.2	2.7	5.4	3.4	2.56	3.79			
ST] No Heating or Cooling											
	Actual	0	0	0	0	0	0	0	0	0	
	Notional	0	0	0	0	0	0	0			

Key to terms

Γ

= Heating energy demand
= Cooling energy demand
= Heating energy consumption
= Cooling energy consumption
= Auxiliary energy consumption
= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
= Cooling system seasonal energy efficiency ratio
= Heating generator seasonal efficiency
= Cooling generator seasonal energy efficiency ratio
= System type
= Heat source
= Heating fuel type
= Cooling fuel type

Page 5 of 6

)ensphere **Key Features** The Building Control Body is advised to give particular attention to items whose specifications are better than typically expected. **Building fabric** Element Ulityp Uliten Surface where the minimum value occurs* 0.23 0.11 LW000001:Sun[1] 0.2 0.12 LW000001:Sun[0] Wall Floor Roof 0.12 0.12 LW000001:Sun[7] Windows, roof windows, and rooflights 1.5 1.4 LW000001:Sun[7] Windows, roof windows, and rooflights 1.5 1.4 LW000001:Sun[1] Personnel doors 1.5 1.65 GR000003:Sun[3] Vehicle access & similar large doors 1.5 No Vehicle access doors in building High usage entrance doors 1.5 No High usage entrance doors in building Loc = Totic Indextwite Intervent Liveitors Wittervett Disc. = Stermen intervent Liveitors Wittervett Disc. = Stermen intervent Liveitors Wittervett Unon = Typical individual element U-values (W/(mR)) U.w. = Minimum individual element U-values [W/(m%)] * There might be more than one surface where the minimum U-villue occurs Air Permeability Typical value This building m4/(h.m4) at 50 Pa 5 3 Page 6 of 6



F. General Notes

ensphere

The report is based on information available at the time of the writing and discussions with the client during any project meetings. Where any data supplied by the client or from other sources have been used it has been assumed that the information is correct. No responsibility can be accepted by Ensphere Group Ltd for inaccuracies in the data supplied by any other party.

The review of planning policy and other requirements does not constitute a detailed review. Its purpose is as a guide to provide the context for the development and to determine the likely requirements of the Local Authority.

No site visits have been carried out, unless otherwise specified.

This report is prepared and written in the context of an agreed scope of work and should not be used in a different context. Furthermore, new information, improved practices and changes in guidance may necessitate a re-interpretation of the report in whole or in part after its original submission.

The copyright in the written materials shall remain the property of Ensphere Group Ltd but with a royalty-free perpetual licence to the client deemed to be granted on payment in full to Ensphere Group Ltd by the client of the outstanding amounts.

The report is provided for sole use by the Client and is confidential to them and their professional advisors. No responsibility whatsoever for the contents of the report will be accepted to any person other than the client, unless otherwise agreed.

These terms apply in addition to the Ensphere Group Ltd "Standard Terms of Business" (or in addition to another written contract which may be in place instead thereof) unless specifically agreed in writing. (In the event of a conflict between these terms and the said Standard Terms of Business the said Standard Terms of Business shall prevail.). In the absence of such a written contract the Standard Terms of Business will apply.



Ensphere Group Ltd 52 Grosvenor Gardens London, SW1W 0AU +44 (0) 20 7846 9040 www.enspheregroup.com