

GENERAL NOTES.

- THE CONTRACTOR WILL FULLY COMPLY WITH ALL RELEVANT BRITISH STANDARDS, REGULATIONS, STANDARD CODES OF PRACTICE, METHODS OF WORKING, AND GOOD PRACTICE.
- THE MECHANICAL CONTRACTOR IS RESPONSIBLE FOR FINAL CO-ORDINATION AND INSTALLATION OF ALL MECHANICAL SERVICES WITH ALL OTHER SERVICES AND THE BUILDING STRUCTURE.
- ALL SERVICES WILL BE IDENTIFIED IN ACCORDANCE WITH BS 1710 AND GOOD ENGINEERING PRACTICE. PIPEWORK TO BE RAL 6003.
- ALL PIPEWORK TO BE PRESSURE TESTED PRIOR TO APPLICATION OF INSULATION.
- ALL PIPEWORK IN PLANTROOM, RISERS, RECESSED AREAS, BOXING IN OR CEILING VOIDS SHALL BE THERMALLY INSULATED THROUGHOUT USING THE MATERIALS IN ACCORDANCE WITH THE M&E SPECIFICATION.
- DRAIN COCKS SHALL BE PROVIDED TO ALL LOW POINTS ON THE SYSTEM.
- AUTOMATIC AIR VENTS SHALL BE PROVIDED TO ALL HIGH POINTS ON THE SYSTEM.
- THE MECHANICAL CONTRACTOR SHALL ALLOW ALL ANCILLARIES NECESSARY TO DEAL WITH EXPANSION/CONTRACTION.
- THE CONTRACTOR SHALL ENSURE THE DESIGN AND INSTALLATION OF ALL GAS APPLIANCES, PIPEWORK, FLUES, ETC. ARE IN COMPLIANCE WITH THE GAS SAFETY REGULATIONS, THE CLEAN AIR ACT, AND RELEVANT BRITISH STANDARDS.
- THE CONTRACTOR SHALL ENSURE ALL PIPEWORK PENETRATING A CAVITY BARRIER OR FIRE COMPARTMENT WALL/SLAB SHALL BE FIRE STOPPED AT THE POINT OF PENETRATION IN ORDER TO MAINTAIN THE INTEGRITY AND REQUIRED FIRE RESISTANCE OF THE FIRE COMPARTMENT.

ALL DIMENSIONS, LEVELS AND CLEARANCES TO BE CHECKED ON SITE PRIOR TO WORKS COMMENCING

THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH ALL OTHER PROJECT RELATED DRAWINGS, SPECIFICATIONS AND DOCUMENTS AS PART OF A SINGLE PROJECT PACKAGE.

ANY DISCREPANCY BETWEEN THIS DRAWING, OTHER DRAWINGS FORMING PART OF THIS CONTRACT, OR THE SPECIFICATION / BILLS OF QUANTITIES MUST BE CLARIFIED BEFORE COMMENCEMENT OF ANY WORK OR ORDERING OF ANY MATERIALS.

PLEASE CONSULT THE AUTHOR OR PROJECT MANAGER SHOULD THE READER REQUIRE CLARIFICATION ON ANY PART OF THIS DRAWING.

THE COPYRIGHT OF THE DRAWING AND DESIGN IS THE PROPERTY OF THE COMPANY. THIS INFORMATION HAS BEEN ISSUED UNDER SPECIFIC TERMS FOR THIS PROJECT AND MAY ONLY BE USED AND REPRODUCED ACCORDINGLY.

NOTES

- ALL PIPEWORK ROUTES SHOWN ARE INDICATIVE & SUBJECT TO VALIDATION BY THE CONTRACTOR.
- FOR PIPE SIZES REFER TO DWG No. 227637-FCG-MB-SC-DR-M-5600 & 227637-FCG-MB-SC-DR-M-5601

LEGEND:


- PIPE DROPPING TO BELOW
- PIPE RISING TO ABOVE
- - - - - PIPEWORK BELOW FLOOR
- — — — — PIPEWORK AT LOW LEVEL
- — — — — PIPEWORK AT HIGH LEVEL
- - - - - PIPEWORK WITHIN CEILING VOID SPACE
- ⊗ PROPOSED RADIATOR
- T ROOM THERMOSTAT

ABBREVIATIONS:

- HTG-F - HEATING FLOW
- HTG-R - HEATING RETURN
- F.A. - FROM ABOVE
- F.B. - FROM BELOW
- T.A. - TO ABOVE
- T.B. - TO BELOW
- DTLL - DROP TO LOW LEVEL
- H/L - HIGH LEVEL
- L/L - LOW LEVEL
- C/V - CEILING VOID

Rev	Date	By	CHK	APP	Comment
C01	02.10.20	MRS SH	AM		Tender Issue

BRADING IDEAS POLITE



FRANKHAM

Frankham Consultancy Group Limited
E: enquire@frankham.com
www.frankham.com

SIDCUP OFFICE Irene House Five Arches Business Park Medstone Road Sidcup, Kent DA14 5AE T: 020 8309 7777	OXFORD OFFICE Woodton Business Park Beesley Road Woodton, Abingdon Oxfordshire OX13 6FD T: 01865 322500
LONDON OFFICE Third Floor Bard House 15-17 St Cross Street London EC1N 8JW T: 020 7651 0790	STEVENAGE OFFICE Suite 237, Second Floor Kings Court Business Centre London Road, Stevenage Hertfordshire SG1 2NG T: 020 3748 7063

Client:



LFB
LONDON FIRE BRIGADE

Project Title:

LFB - Euston Fire Station - Heating Replacement

Drawing Title:

**Mechanical Services
Third Floor
Proposed Heating Layout**

Status:

TENDER ISSUE

Drawn By:	Designed By:	Checked By:	Approved By:
BD	MR	SH	AM
Original Issue Date:	Scale @ A1:		
02/10/2020	1:50		

Job No/ File Ref	Originator	Zone	Level
227637	FCG	MB	03
Type	Discipline	Number	Suitability
DR	M	5606	D2
			Revision
			C01