

15-20 Woodfield Road Welwyn Garden City Hertfordshire AL7 1JQ

01707 372 858 · info@chapmanventilation.co.uk · www.chapmanventilation.co.uk

Rosa's Thai Café 26 Earlham Street, Seven Dials, London WC2H 9LX

15th December, 2020

Ref: Rosa's Earlham St London – Odour Assessment

Dear Mac Plumpton

As requested please find below our assessment of the potential for nuisance Odour arising from the cooking processed carried out at the above site. This assessment has been carried out using Annex C: Risk assessment for Odour from DEFRA document – "Guidance on the control of Odour and Noise from Commercial Kitchen Exhaust Systems "- January 2005

Dispersion

The kitchen extract ductwork is to rise from within the lightwell up the external riser through to high level and discharge at the pitched roof and will be level with the roof ridge. We are designing the extract flow rate to achieve a velocity of 16m/s at the outlet. This criteria gives the system a good level of dispersion. Assessment score of 5.

Proximity of Receptors

Due to the location of the building, the height of the kitchen extract outlet and the extract air velocity the nearest sensitive receptor form the outlet location is approximately 15 meters from the outlet location. Assessment score of 10.

Size of Kitchen

The premises will have 45 covers so is therefore regarded as a medium size kitchen. Assessment score of 3

Cooking Type (odour and grease loading)

The type of foods cooked at Rosa's has a very high grease content and odour loading, taking from the figures stated on the DEFRA document and an overall figure of the two combined to an assessment score of 10

Total Assessment Score = 28

Registered Office No: 627 3275 VAT No: 809371324





01707 372 858 · info@chapmanventilation.co.uk · www.chapmanventilation.co.uk

Based on the above, a **high** level of odour control will be installing high efficiency grease baffle filters within the kitchen canopy along with internally located ESP filters and UV-0 treatment in accordance with the DEFRA guidelines for this score rating.

System Operation

The system has been designed to achieve an extract rate of 2.2m3/s @ 800 Pascal's through a duct sized at 600x600 with an efflux velocity at a speed of 16 meters per second at the outlet.

Maintenance

The washable stainless steel grease filters will be cleaned daily as part of the Rosa's cleaning regime. Maintenance to the fan unit and filtration units will be as per the manufacturer's recommendations and a service contract will be entered in to.

The ductwork cleaning will be in accordance with TR19 as published by the HVCA.

We hope that you find this proposal to your satisfaction, please contact us with any queries.

Yours Sincerely

Michael De Souza

Mr. Michael De Souza

