

Application ref: 2020/4399/P
Contact: Charlotte Meynell
Tel: 020 7974 2598
Email: Charlotte.Meynell@camden.gov.uk
Date: 5 January 2021

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE

Phone: 020 7974 4444

planning@camden.gov.uk
www.camden.gov.uk/planning

Rolfe Judd Planning
Old Church Court
Claylands Road
Oval
London
SW8 1NZ

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted

Address:
3 Shorts Gardens
London
WC2H 9AT

Proposal: Installation of replacement internal extract duct and associated new external access hatches to north-western side elevation, and replacement plant enclosure on main roof.

Drawing Nos: 25020 SLP-01; 25020 101; 25020 102; 25020 103; 25020 104; 25020 105; 25020 106; 25020 107; 25020 201; 25020 202; 25020 203; 25020 204; 25020 205; 25020 206; 25020 207; Cover Letter (prepared by Rolfe Judd, dated 25/09/2020); Environmental Noise Survey and Plant Noise Assessment Report (prepared by Hann Tucker Associates, dated 23/09/2020).

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policies D1 and D2 of the London Borough of Camden Local Plan 2017.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans: 25020 SLP-01; 25020 101; 25020 102; 25020 103; 25020 104; 25020 105; 25020 106; 25020 107; 25020 201; 25020 202; 25020 203; 25020 204; 25020 205; 25020 206; 25020 207; Cover Letter (prepared by Rolfe Judd, dated 25/09/2020); Environmental Noise Survey and Plant Noise Assessment Report (prepared by Hann Tucker Associates, dated 23/09/2020).

Reason: For the avoidance of doubt and in the interest of proper planning.

- 4 Prior to use of the extraction equipment, details shall be submitted to and approved in writing by the Council, of the external noise level emitted from equipment and mitigation measures as appropriate. The measures shall ensure that the external noise level emitted from equipment will be lower than the typical background noise level by at least 10dBA, by 15dBA where the source is tonal, as assessed according to BS4142:1997 at the nearest and/or most affected noise sensitive premises, with all machinery operating together at maximum capacity. A post installation noise assessment shall be carried out where required to confirm compliance with the noise criteria and additional steps to mitigate noise shall be taken, as necessary. Approved details shall be implemented prior to first use of the extraction equipment and thereafter be permanently retained.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017

- 5 Plant or equipment and ducting at the development shall be mounted with proprietary anti-vibration isolators and fan motors shall be vibration isolated from the casing and adequately silenced. All such measures shall thereafter be retained and maintained in accordance with the manufacturers' recommendations.

Reason: To ensure that the amenity of occupiers of the development site and surrounding premises is not adversely affected by vibration in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and

emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).

- 2 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant licence from the Council's Streetworks Authorisations & Compliance Team London Borough of Camden 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444) . Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106 agreement), no licence or authorisation will be granted until the Construction Management Plan is approved by the Council.
- 3 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website at <https://beta.camden.gov.uk/documents/20142/1269042/Camden+Minimum+Requirements+%281%29.pdf/bb2cd0a2-88b1-aa6d-61f9-525ca0f71319> or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these hours.

- 4 Your attention is drawn to the need for compliance with the requirements of the Environmental Health regulations, Compliance and Enforcement team, [Regulatory Services] Camden Town Hall, Argyle Street, WC1H 8EQ, (tel: 020 7974 4444) particularly in respect of arrangements for ventilation and the extraction of cooking fumes and smells.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2019.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully

A handwritten signature in black ink, appearing to read 'DPope', is positioned above the printed name.

Daniel Pope
Chief Planning Officer