



Notes:

- 1) This drawing is not to be scaled, only dimensions to be used.
- 2) Final location of MVHR unit to be agreed, as location needs to match ceiling access hatch.
- 3) MVHR to include Electric heater for fresh air to raise temperature from 14° to 24°.
- 4) Flexible ducts to be kept to minimum length, no more than 500mm.

Revisions

- 1 - 17/12/20 - Grilles aligned to RCP, Layout updated.
- 2 - 18/12/20 - duct moved from over wall, drying grille added.

Client

Peldon Rose

Project title

Heals Building
Torrington Place
London

Drawing title

Basement Showers
Ventilation Layout

Drawing No: C-xxx-B-V-001

Revision: 2

Date: 14/12/20

Scale: 1:50

Drawn: MJL

Checked: ---



53 High Street, Ewell, Surrey
KT17 1RZ
E: accounts@mistrallondon.com
T: 020 8786 8754