



Notes:

- 1) This drawing is not to be scaled, only dimensions to be used.
- 2) Final location of MVHR unit to be agreed, as location needs to match ceiling access hatch.
- 3) MVHR to include Electric heater for fresh air to raise temperature from 14° to 24°.
- 4) Flexible ducts to be kept to minimum length, no more than 500mm.

Revisions

Client

Peldon Rose

Project title

Heals Building
Torrington Place
London

Drawing title

Basement Showers
Ventilation Layout

Drawing No: C-xxx-B-V-001

Revision: ----

Date: 14/12/20

Scale: 1:50

Drawn: MJL

Checked: ----



MISTRAL

53 High Street, Ewell, Surrey
KT17 1RZ
E: accounts@mistrallondon.com
T:020 8786 8754