

7 Greenaway Gardens London



Planning Compliance Report
Report 21713.PCR.01

SHH ARCHITECTURE & INTERIOR DESIGN
1 Vencourt Place
London
W6 9NU

| Report 21713.PCR.01 | | |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------|--------------------------------------------------------|
| Revision History | | |
| First Issue Date: 15/01/2021 | | |
| A | 19/01/2021 Revision of plant units venting to atmosphere. Mitigation measures refined. | D |
| B | 19/01/2021 Correction of site plan. | E |
| C | | F |
| Written by: | Checked by: | Approved by: |
| Duncan Arkley MIOA Senior Acoustic Consultant | Kyriakos Papanagiotou MIOA Managing Director | Kyriakos Papanagiotou MIOA Managing Director |
| <p>Disclaimer KP Acoustics Ltd. has used reasonable skill and care to complete this technical document, within the terms of its brief and contract with the resources devoted to it by agreement with the client. We disclaim any responsibility to the client and others in respect of any matters outside the stated scope. This report is confidential to the client and we accept no responsibility to third parties to whom this report, or any part thereof, is made known. KP Acoustics Ltd. accepts no responsibility for data provided by other bodies and no legal liability arising from the use by other persons of data or opinions contained in this report. KP Acoustics Ltd. 2021</p> | | |

Contents

| | | |
|-----|------------------------------------------------------------------------------------------------|----|
| 1.0 | INTRODUCTION..... | 1 |
| 2.0 | SITE SURVEYS | 1 |
| 2.1 | Site Description..... | 1 |
| 2.2 | Environmental Noise Survey Procedure | 2 |
| 2.3 | Equipment..... | 3 |
| 3.0 | RESULTS..... | 3 |
| 4.0 | NOISE ASSESSMENT GUIDANCE..... | 4 |
| 4.1 | BS4142: 2014 ' <i>Methods for rating and assessing industrial and commercial sound</i> ' | 4 |
| 4.2 | Local Authority Guidance..... | 5 |
| 4.3 | Proposed Noise Emissions Criteria | 6 |
| 5.0 | NOISE IMPACT ASSESSMENT | 6 |
| 5.1 | Proposed Plant Installations | 6 |
| 5.2 | Closest Noise Sensitive Receiver..... | 9 |
| 5.3 | Calculations..... | 9 |
| 6.0 | NOISE CONTROL MEASURES..... | 10 |
| 6.1 | AHU and Extract/Supply Fan Silencers..... | 10 |
| 6.2 | Condenser Units in Light Well..... | 10 |
| 6.3 | Light Well Absorptive Lining | 11 |
| 6.4 | Anti-Vibration Mounting Strategy | 11 |
| 7.0 | CONCLUSION..... | 11 |

List of Attachments

| | |
|-----------------------|---------------------------------------------------------------------|
| 21713.TH1 | Environmental Noise Time History |
| 21713.Daytime.LA90 | Statistical analysis for representative daytime L _{A90} |
| 21713.Night-time.LA90 | Statistical analysis for representative night-time L _{A90} |
| Appendix A | Glossary of Acoustics Terminology |
| Appendix B-3 | Acoustic Calculations |
| Appendix C | Anti-Vibration Mounting Specification Reference Document |

1.0 INTRODUCTION

KP Acoustics Ltd has been commissioned by SHH Architecture & Interior Design, 1 Vencourt Place, London, W6 9NU, to undertake a noise impact assessment of a proposed plant unit installation serving the building at 7 Greenaway Gardens, London.

A 24 hour environmental noise survey has been undertaken on site in order to prepare a noise impact assessment in accordance with BS4142:2014 ‘Method for rating and assessing industrial and commercial sound’ as part of the planning requirements of the London Borough of Camden.

This report presents the methodology and results from the environmental survey, followed by calculations in accordance with BS4142 to provide an indication as to the likelihood of the noise emissions from the proposed plant unit installation having an adverse impact on the closest noise sensitive receiver. Mitigation measures will be outlined as appropriate.

2.0 SITE SURVEYS

2.1 Site Description

As shown in Figure 2.1, the site is bounded by Greenaway Gardens to the North East, and residential properties to all cardinal directions.



Figure 2.1 Site Location Plan (Image Source: Google Maps)

Initial inspection of the site revealed that the background noise profile at the monitoring location was typical of a suburban environment, with the dominant source being road traffic noise from the surrounding roads.

2.2 Environmental Noise Survey Procedure

Continuous automated monitoring was undertaken for the duration of the noise survey between 08/01/2021 and 11/01/2021.

The environmental noise measurement position, proposed plant installation locations, and the closest noise sensitive receiver relative to the plant installations are described within Table 2.1 and shown within Figure 2.2.




| Icon | Descriptor | Location Description |
|-------------------------------------------------------------------------------------|---------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|  | Noise Measurement Position | The meter was installed on a window on the ground floor of the South West façade, as shown in figure 2.2. A correction of 3dB has been applied to account for non-free field conditions |
|  | Closest Noise Sensitive Receiver | Residential windows of neighbouring properties discussed in section 5. |
|  | Proposed Plant Installation Locations | Proposed plant installations are outlined in Section 5 |

Table 2.1 Measurement position and description




Figure 2.2 Site measurement position, identified receivers and proposed plant unit installations (Image Source: Google Maps)

The choice of the position was based both on accessibility and on collecting representative noise data in relation to the nearest noise sensitive receiver relative to the proposed plant installation.

Weather conditions were generally dry with light winds and therefore suitable for the measurement of environmental noise. The measurement procedure complied with ISO 1996-2:2017 Acoustics ‘Description, measurement and assessment of environmental noise - Part 2: Determination of environmental noise levels’.

2.3 Equipment

The equipment calibration was verified before and after use and no abnormalities were observed. The equipment used is described within Table 2.3.

| Measurement instrumentation | | Serial no. | Date | Cert no. |
|----------------------------------------|--------------------------------------------|------------|------------|----------|
| Noise Kit 5 | Svantek Type 977 Class 1 Sound Level Meter | 46459 | 9/05/2019 | 14012954 |
| | Free-field microphone Aco Pacific 7052H | 43114 | | |
| | Preamp Svantek 2v12L | 18929 | | |
| | Svantek External windshield | - | - | - |
| Larson Davis CAL200 Class 1 Calibrator | | 17148 | 07/02/2020 | 04615/1 |

Table 2.3 Measurement instrumentation

3.0 RESULTS

The $L_{Aeq: 5min}$, $L_{Amax: 5min}$, $L_{A10: 5min}$ and $L_{A90: 5min}$ acoustic parameters were measured throughout the duration of the survey. Measured levels are shown as a time history in Figure 21713.TH1.

Representative background noise levels are shown in Table 3.1 for daytime and night-time.

It should be noted that the representative background noise level has been derived from the most commonly occurring $L_{A90,5 min}$ levels measured during the environmental noise survey undertaken on site, as shown in 21713.Daytime.LA90 and 21713.Night-time.LA90 attached.

| Time Period | Representative background noise level L_{A90} dB(A) |
|--------------------------|-------------------------------------------------------|
| Daytime (07:00-23:00) | 30 |
| Night-time (23:00-07:00) | 23 |

Table 3.1 Representative background noise levels

4.0 NOISE ASSESSMENT GUIDANCE

4.1 BS4142: 2014 *'Methods for rating and assessing industrial and commercial sound'*

British Standard BS4142:2014 *'Methods for rating and assessing industrial and commercial sound'* describes a method for rating and assessing sound of an industrial and/or commercial nature, which includes:

- Sound from industrial and manufacturing processes
- Sound from fixed installations which comprise mechanical and electrical plant and equipment
- Sound from the loading and unloading of goods and materials at industrial and/or commercial premises, and
- Sound from mobile plant and vehicles that is an intrinsic part of the overall sound emanating from premises or processes.

This Standard compares the Rating Level due to the noise source/s under assessment for a one-hour period during the daytime (07:00 – 23:00 hours) and a fifteen-minute period during the night-time (23:00 – 07:00 hours) with the existing background noise level in terms of an L_{A90} when the noise source is not operating.

It should be noted that the Rating Level is the Specific Sound Level in question ($L_{Aeq, Tt}$), including any relevant acoustic feature corrections, as follows:

- **Tonality** – *'For sound ranging from not tonal to prominently tonal the Joint Nordic Method gives a correction of between 0dB and +6dB for tonality. Subjectively, this can be converted to a penalty of 2dB for a tone which is just perceptible at the noise receptor, 4dB where it is clearly perceptible, and 6dB where it is highly perceptible'*
- **Impulsivity** – *'A correction of up to +9dB can be applied for sound that is highly impulsive, considering both the rapidity of the change in sound level and the overall change in sound level. Subjectively, this can be converted to a penalty of 3dB for impulsivity which is just perceptible at the noise receptor, 6dB where it is clearly perceptible, and 9dB where it is highly perceptible'*
- **Intermittency** – *'If the intermittency is readily distinctive against the residual acoustic environment, a penalty of 3dB can be applied'*

- **Other sound characteristics** – *‘Where the specific sound features characteristics that are neither tonal nor impulsive, though otherwise are readily distinctive against the residual acoustic environment, a penalty of 3dB can be applied’*

Once the Rating Level has been obtained, the representative background sound level is subtracted from the Rating Level to obtain an initial estimate of the impact, as follows:

- Typically, the greater this difference, the greater the magnitude of the impact
- A difference of around +10 dB or more is likely to be an indication of a significant adverse impact, depending on the context
- A difference of around +5 dB could be an indication of an adverse impact, depending on the context
- The lower the rating level is relative to the measured background sound level, the less likely it is that there will be an adverse impact or significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound having a low impact, depending on the context

NOTE: Adverse impacts may include but not be limited to annoyance and sleep disturbance. Not all adverse impacts will lead to complaints and not every complaint is proof of an adverse impact.

The initial estimate of the impact may then be modified by taking consideration of the context in which the sound occurs.

4.2 Local Authority Guidance

The guidance provided by The London Borough of Camden for noise emissions of new plant in this instance is as follows:

The noise criteria, as per the Local Plan 2017 of London Borough of Camden, British Standard 4142:2014 ‘Methods for rating and assessing industrial and commercial sound’ should be considered as the main reference document for the assessment. The resultant ‘Rating Level’ would be considered as follows:

| Period | Assessment Location | Rating Level Acceptability Range | | |
|-------------------------|---------------------------------------------------------------------------------------------------|---------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------|
| | | Green: noise is considered to be at an acceptable level | Amber: noise is observed to have an adverse effect level, but which may be considered acceptable when assessed in the context of other merits of the development | Red: noise is observed to have a significant adverse effect. |
| Daytime (7:00-23:00) | Garden used for main amenity (free field) and Outside living or dining or Bedroom window (façade) | 10dB below background | 9 dB below and 5dB above background | 5dB above background |
| Night-time (23:00-7:00) | Outside bedroom window (façade) | 10dB below background and no events exceeding 57dB L_{Amax} | 9db below and 5dB above background or noise events between 57dB and 88dB L_{Amax} | 5dB above background and/or events exceeding 88dB L_{Amax} |

Table 4.1 Camden noise criteria for plant and machinery

4.3 Proposed Noise Emissions Criteria

As the measured noise level on site would be considered objectively low, a suitable noise emissions criteria in this case, based on both experience of noise control and the guidance from Camden Borough Council, would be not to exceed the measured representative background noise level. At this level, no negative impact would be expected at the nearest noise sensitive receivers.

| Time Period | Representative background noise level L_{A90} dB(A) |
|--------------------------|-------------------------------------------------------|
| Daytime (07:00-23:00) | 30 |
| Night-time (23:00-07:00) | 23 |

Table 4.1 Proposed noise emissions criteria

5.0 NOISE IMPACT ASSESSMENT

5.1 Proposed Plant Installations

It is understood that the proposed external plant installation is separated into groups, consisting of the following units:

Group 1 – Swimming Pool Units – Basement level to South West

Pool plant room LG.21:

- Type 18 AHU – Manufacturer undefined – data supplied by project architect
- Supply fan – Nuaire DS4HA-ES
- Extract fan – Nuaire DE4HA-ES
- MVHR unit – Zehnder ComfoAir Q 600

The proposed installation location for this plant group will be to the South West, in the basement level plant room, as shown in Figure 2.2 above.

The noise emission levels as provided by the manufacturer for the units are shown in Table 5.1.

| Unit | Descriptor | Octave Frequency Band (Hz) | | | | | | | | Overall (dBA) |
|---------------------------------|------------|----------------------------|-----|-----|-----|----|----|----|----|---------------|
| | | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| Type 18 AHU Supply | SWL (dB) | 81 | 81 | 78 | 75 | 74 | 71 | 66 | 61 | 79 |
| Type 18 AHU Exhaust | SWL (dB) | 81 | 81 | 79 | 75 | 74 | 72 | 66 | 61 | 79 |
| Nuaire DS4HA-ES Supply Fan | SWL (dB) | 83 | 78 | 70 | 74 | 69 | 68 | 64 | 66 | 76 |
| Nuaire DE4HA-ES Extract Fan | SWL (dB) | 91 | 91 | 76 | 76 | 73 | 71 | 65 | 66 | 80 |
| MVHR units Supply/Exhaust @ 80% | SWL (dB) | 71* | 71 | 76 | 72 | 65 | 63 | 63 | 57 | 73 |
| MVHR units Extract/Inlet @ 80% | SWL (dB) | 66* | 66 | 64 | 59 | 47 | 40 | 40 | 28 | 60 |

Table 5.1 Plant Units Noise Emission Levels as provided by the manufacturer

Group 2 – Units terminating at North East Light Well

Plant room LG.17 (adjacent to cinema):

- Supply fan – Nuaire DS4HA-ES
- Extract fan – Nuaire DE3A-ES
- 2 no. MVHR unit – Zehnder ComfoAir Q 600

Lightwell condensers:

- Calorex WA1234BC - data supplied by project M&E
- Marstair CKC 50 outdoor unit
- PUZ-ZM71VHA

The proposed installation location for the above plant will be at the lower ground level, with all duct terminations exiting at the light well, alongside the condenser units, as shown in Figure 2.2 above.

The noise emission levels as provided by the manufacturer for the units are shown in Table 5.1.

| Unit | Descriptor | Octave Frequency Band (Hz) | | | | | | | | Overall (dBA) |
|---------------------------------|------------|----------------------------|-----|-----|-----|----|----|----|-----|---------------|
| | | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| Nuaire DS4HA-ES Supply Fan | SWL (dB) | 83 | 78 | 70 | 74 | 69 | 68 | 64 | 66 | 76 |
| Nuaire DE3A-ES Extract Fan | SWL (dB) | 85 | 77 | 61 | 50 | 50 | 54 | 53 | 52 | 65 |
| Calorex WA1234BC | SPL@3m | - | - | - | - | - | - | - | - | 65 |
| Marstair CKC 50 | SWL (dB) | 74* | 74 | 68 | 67 | 66 | 61 | 54 | 54* | 70 |
| PUZ-ZM71VHA | SPL@1m | 53 | 52 | 53 | 44 | 43 | 39 | 34 | 37 | 49 |
| MVHR units Supply/Exhaust @ 80% | SWL (dB) | 71* | 71 | 76 | 72 | 65 | 63 | 63 | 57 | 73 |
| MVHR units Extract/Inlet @ 80% | SWL (dB) | 66* | 66 | 64 | 59 | 47 | 40 | 40 | 28 | 60 |

Table 5.1 Plant Units Noise Emission Levels as provided by the manufacturer

***no data, sound power level assumed from neighbouring frequency band**

Group 3 – Units terminating at South West Garden Space

GSHP plant room UC.02:

- Supply fan – Vectaire MBOX 200/2 DC
- Extract fan – Vectaire MBOX 200/2 DC

- MVHR unit – Zehnder ComfoAir Q 600

The proposed installation location for the above units will be to the rear of the basement level extension to rear, with all units ducted and terminating at ground level, as shown in Figure 2.2.

The noise emission levels as provided by the manufacturer for the units are shown in Table 5.1.

| Unit | Descriptor | Octave Frequency Band (Hz) | | | | | | | | Overall (dBA) |
|---------------------------------------------|------------|----------------------------|-----|-----|-----|----|----|----|----|---------------|
| | | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| Vectaire MBOX 200/2 DC Supply/Exhaust @ 80% | SWL (dB) | 58 | 60 | 64 | 61 | 62 | 60 | 55 | 53 | 67 |
| Vectaire MBOX 200/2 DC Extract/Inlet @ 80% | SWL (dB) | 53 | 55 | 59 | 56 | 57 | 55 | 50 | 48 | 62 |
| MVHR units Supply/Exhaust @ 80% | SWL (dB) | 71* | 71 | 76 | 72 | 65 | 63 | 63 | 57 | 73 |
| MVHR units Extract/Inlet @ 80% | SWL (dB) | 66* | 66 | 64 | 59 | 47 | 40 | 40 | 28 | 60 |

Table 5.1 Plant Units Noise Emission Levels as provided by the manufacturer

*no data, sound power level assumed from neighbouring frequency band

5.2 Closest Noise Sensitive Receiver

The closest noise sensitive receivers to the proposed installation locations have been identified as being the windows of the neighbouring properties to the North West and South East from the proposed plant installation location, as shown in Figure 2.2.

5.3 Calculations

The ‘Rating Level’ of each plant unit installation has been calculated at 1m from the closest receiver using the noise levels shown in Table 5.1, and corrected due to different acoustic propagation features such as distance, reflective surfaces, screening elements, etc.

Acoustic feature corrections as per BS4142 have been considered. In this instance as the units are expected to operate for extended periods of time, with no impulsive or tonal components, it is determined that no further penalties need be applied.

Detailed calculations for each plant unit installation are shown in Appendix B1-3.

| Receiver | Criterion | Noise Level at 1m From the Closest Noise Sensitive Window |
|------------------------------------------------------------------|-----------|-----------------------------------------------------------|
| Receiver to Group 1, Rear window of South East Neighbour at 13m | 23dB(A) | 23dB(A) |
| Receiver to Group 2, Front window of South East Neighbour at 10m | 23dB(A) | 23dB(A) |
| Receiver to Group 3, Rear window of North West Neighbour at 23m | 23dB(A) | 21dB(A) |

Table 5.2 Predicted noise level and criterion at nearest noise sensitive location

As shown in Appendix B and Table 5.2, transmission of noise to the nearest sensitive windows due to the effects of the various external plant unit installations satisfies the emissions criterion of proposed, providing that the mitigation measures outlined in Section 6 are implemented.

6.0 NOISE CONTROL MEASURES

In order to achieve the specific sound level and subsequent rating level shown in the assessment above, the following noise control strategy should be adopted.

6.1 AHU and Extract/Supply Fan Silencers

In order to control the noise emissions from the AHU and fan duct work, silencers should be installed providing the minimum insertion loss values outlined in Table 6.1 below. This is modelled from a sample generic silencer with 40% free area, and 1200mm length.

| Unit | Insertion Loss Levels (dB) in each Octave Frequency Band | | | | | | | |
|------------------------------------------------------|----------------------------------------------------------|-------|-------|-------|------|------|------|------|
| | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz |
| Silencers for pool plant room ducted units (group 1) | 4 | 9 | 17 | 21 | 20 | 20 | 20 | 20 |
| Silencers for lightwell ducted units (group 2) | 4 | 9 | 15 | 16 | 15 | 14 | 12 | 12 |
| Silencers for GSHP plant room ducted units (group 3) | 4 | 8 | 12 | 12 | 12 | 10 | 8 | 6 |

Table 6.1 Insertion loss figures to be provided by acoustic silencers

6.2 Condenser Units in Light Well

In order to control the noise emissions from condenser units, we would recommend that a plant enclosure is installed around each unit, or around groups of units, which should provide

the minimum insertion loss levels shown in Table 6.2. This is modelled on the performance for a generic enclosure provided by Environ.

| Unit | Insertion Loss Levels (dB) in each Octave Frequency Band | | | | | | | |
|------------------------------------------------------------------------|----------------------------------------------------------|-------|-------|-------|------|------|------|------|
| | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz |
| Louvres of acoustic enclosure – Generic for Calorex and Marstair units | -12 | -13 | -20 | -29 | -36 | -37 | -39 | -39 |
| Bespoke for PUZ-ZM71VHA | -6 | -10 | -10 | -10 | -10 | -10 | -6 | -6 |

Table 6.2 Insertion loss figures to be provided by acoustic enclosure

We would recommend the following suppliers of the aforementioned enclosure/silencer:

- Environmental Equipment Corporation
- Environ
- Allaway Acoustics
- Wakefield Acoustics

6.3 Light Well Absorptive Lining

In addition to the above, the condenser unit lightwell to the East corner of the property should have its walls lined with an environmental absorptive lining, such as AcoustiLine panels from EEC, CMS-Danskin proprietary plantroom panels, or any similar material.

6.4 Anti-Vibration Mounting Strategy

In the case of all plant units, appropriate anti-vibration mounts should be installed in order to ensure that vibrations do not give rise to structure-borne noise. Appendix C outlines detailed advice in order to ensure that the system installer selects the appropriate anti-vibration mount for the installation.

It is the supplier's responsibility to ensure that all mountings offered are suitable for the loads, operating and environmental conditions which will prevail.

7.0 CONCLUSION

An environmental noise survey has been undertaken at 7 Greenaway Gardens, London, by KP Acoustics Ltd between 08/01/2021 and 11/01/2021. The results of the survey have enabled a representative background noise level to be set.

Manufacturer's noise data of proposed plant units has been used to obtain Specific and Rated Noise Level at the nearest noise sensitive receiver in accordance with British Standard BS4142:2014 for compliance with Local Authority requirements.

The rating level was compared with the representative background noise level to assess the likelihood of impact considering the environmental noise context of the area as per the requirements of BS4142:2014.

It has been concluded that noise emissions from the proposed plant units would not have an adverse impact on the nearest residential receivers provided that the noise control strategy presented in Section 6 is followed.

7 Greenaway Gardens, London
Environmental Noise Time History
From 08 January 2021 To 11 January 2021




Figure 21713.TH1

7 Greenaway Gardens, London
Representative Daytime Background Noise Level
From 08 January 2021 To 11 January 2021




Figure 21713.L90

7 Greenaway Gardens, London
Representative Night-time Background Noise Level
From 08 January 2021 To 11 January 2021




Figure 21713.L90

GENERAL ACOUSTIC TERMINOLOGY

Decibel scale - dB

In practice, when sound intensity or sound pressure is measured, a logarithmic scale is used in which the unit is the 'decibel', dB. This is derived from the human auditory system, where the dynamic range of human hearing is so large, in the order of 10^{13} units, that only a logarithmic scale is the sensible solution for displaying such a range.

Decibel scale, 'A' weighted - dB(A)

The human ear is less sensitive at frequency extremes, below 125Hz and above 16Khz. A sound level meter models the ears variable sensitivity to sound at different frequencies. This is achieved by building a filter into the Sound Level Meter with a similar frequency response to that of the ear, an A-weighted filter where the unit is dB(A).

L_{eq}

The sound from noise sources often fluctuates widely during a given period of time. An average value can be measured, the equivalent sound pressure level L_{eq} . The L_{eq} is the equivalent sound level which would deliver the same sound energy as the actual fluctuating sound measured in the same time period.

L_{10}

This is the level exceeded for no more than 10% of the time. This parameter is often used as a "not to exceed" criterion for noise.

L_{90}

This is the level exceeded for no more than 90% of the time. This parameter is often used as a descriptor of "background noise" for environmental impact studies.

L_{max}

This is the maximum sound pressure level that has been measured over a period.

Octave Bands

In order to completely determine the composition of a sound it is necessary to determine the sound level at each frequency individually. Usually, values are stated in octave bands. The audible frequency region is divided into 11 such octave bands whose centre frequencies are defined in accordance with international standards. These centre frequencies are: 16, 31.5, 63, 125, 250, 500, 1000, 2000, 4000, 8000 and 16000 Hertz.

Environmental noise terms are defined in BS7445, *Description and Measurement of Environmental Noise*.

APPLIED ACOUSTIC TERMINOLOGY

Addition of noise from several sources

Noise from different sound sources combines to produce a sound level higher than that from any individual source. Two equally intense sound sources operating together produce a sound level which is 3dB higher than a single source and 4 sources produce a 6dB higher sound level.

Attenuation by distance

Sound which propagates from a point source in free air attenuates by 6dB for each doubling of distance from the noise source. Sound energy from line sources (e.g. stream of cars) drops off by 3dB for each doubling of distance.

Subjective impression of noise

Hearing perception is highly individualised. Sensitivity to noise also depends on frequency content, time of occurrence, duration of sound and psychological factors such as emotion and expectations. The following table is a guide to explain increases or decreases in sound levels for many scenarios.

| Change in sound level (dB) | Change in perceived loudness |
|----------------------------|------------------------------|
| 1 | Imperceptible |
| 3 | Just barely perceptible |
| 6 | Clearly noticeable |
| 10 | About twice as loud |

Transmission path(s)

The transmission path is the path the sound takes from the source to the receiver. Where multiple paths exist in parallel, the reduction in each path should be calculated and summed at the receiving point. Outdoor barriers can block transmission paths, for example traffic noise. The effectiveness of barriers is dependent on factors such as its distance from the noise source and the receiver, its height and construction.

Ground-borne vibration

In addition to airborne noise levels caused by transportation, construction, and industrial sources there is also the generation of ground-borne vibration to consider. This can lead to structure-borne noise, perceptible vibration, or in rare cases, building damage.

Sound insulation - Absorption within porous materials

Upon encountering a porous material, sound energy is absorbed. Porous materials which are intended to absorb sound are known as absorbers, and usually absorb 50 to 90% of the energy and are frequency dependent. Some are designed to absorb low frequencies, some for high frequencies and more exotic designs being able to absorb very wide ranges of frequencies. The energy is converted into both mechanical movement and heat within the material; both the stiffness and mass of panels affect the sound insulation performance.

APPENDIX B1

7 Greenaway Gardens, London

PLANT NOISE EMISSIONS CALCULATIONS

| Source: Group 1 Plant Units Receiver: Neighbour to South East | Frequency, Hz | | | | | | | | dB(A) |
|----------------------------------------------------------------------------|---------------|-----|-----|-----|-----|-----|-----|-----|-------|
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| Air Handling Unit - Noise Emissions from Air Exhaust Outlet | | | | | | | | | |
| Type 18 AHU (Sound Power Level) | 81 | 81 | 79 | 75 | 74 | 72 | 66 | 61 | 79 |
| Attenuation due to duct length (3m), dB | -3 | -2 | -1 | -1 | -1 | -1 | -1 | -1 | |
| Correction due to duct end reflection, dB | -8 | -4 | -1 | 0 | 0 | 0 | 0 | 0 | |
| Conversion to SPL@1m | -11 | -11 | -11 | -11 | -11 | -11 | -11 | -11 | |
| Correction due to surface reflections (1), dB | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | |
| Directivity correction, dB | 1 | -1 | -4 | -4 | -11 | -11 | -11 | -11 | |
| Minimum attenuation provided by the building envelope, dB | -10 | -10 | -10 | -10 | -10 | -10 | -10 | -10 | |
| Minimum attenuation provided by distance (13m), dB | -22 | -22 | -22 | -22 | -22 | -22 | -22 | -22 | |
| Minimum attenuation required from silencer, dB (40% 1200mm) | -4 | -9 | -17 | -20 | -20 | -20 | -20 | -20 | |
| Total Noise Emissions from Air Handling Unit Air Exhaust Outlet, dB | 27 | 25 | 16 | 10 | 2 | 0 | -6 | -11 | 14 |
| Air Handling Unit - Noise Emissions from Air Supply Inlet | | | | | | | | | |
| Type 18 AHU (Sound Power Level) | 81 | 81 | 78 | 75 | 74 | 71 | 66 | 61 | 79 |
| Attenuation due to duct length (3m), dB | -3 | -2 | -1 | -1 | -1 | -1 | -1 | -1 | |
| Correction due to duct end reflection, dB | -8 | -4 | -1 | 0 | 0 | 0 | 0 | 0 | |
| Conversion to SPL@1m | -11 | -11 | -11 | -11 | -11 | -11 | -11 | -11 | |
| Correction due to surface reflections (1), dB | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | |
| Directivity correction, dB | 1 | -1 | -4 | -4 | -11 | -11 | -11 | -11 | |
| Minimum attenuation provided by the building envelope, dB | -10 | -10 | -10 | -10 | -10 | -10 | -10 | -10 | |
| Minimum attenuation provided by distance (13m), dB | -22 | -22 | -22 | -22 | -22 | -22 | -22 | -22 | |
| Minimum attenuation required from silencer, dB (40% 1200mm) | -4 | -9 | -17 | -20 | -20 | -20 | -20 | -20 | |
| Total Noise Emissions from Air Handling Unit Air Supply Inlet, dB | 27 | 25 | 15 | 10 | 2 | -1 | -6 | -11 | 13 |
| MVHR units Supply/Exhaust @ 80% (Sound Power Level) | | | | | | | | | |
| MVHR units Supply/Exhaust @ 80% (Sound Power Level) | 71 | 71 | 76 | 72 | 65 | 63 | 63 | 57 | 73 |
| Attenuation due to duct length (3m), dB | -3 | -2 | -1 | -1 | -1 | -1 | -1 | -1 | |
| Correction due to duct end reflection, dB | -8 | -4 | -1 | 0 | 0 | 0 | 0 | 0 | |
| Conversion to SPL@1m | -11 | -11 | -11 | -11 | -11 | -11 | -11 | -11 | |
| Correction due to surface reflections (1), dB | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | |
| Directivity correction, dB | 1 | -1 | -4 | -4 | -11 | -11 | -11 | -11 | |
| Minimum attenuation provided by distance (13m), dB | -22 | -22 | -22 | -22 | -22 | -22 | -22 | -22 | |
| Minimum attenuation required from silencer, dB (40% 1200mm) | -4 | -9 | -17 | -21 | -20 | -20 | -20 | -20 | |
| Total Noise Emissions from Extract Fan Exhaust Outlet, dB | 27 | 25 | 23 | 16 | 3 | 1 | 1 | -5 | 18 |
| MVHR units Extract/Inlet @ 80% (Sound Power Level) | | | | | | | | | |
| MVHR units Extract/Inlet @ 80% (Sound Power Level) | 66 | 66 | 64 | 59 | 47 | 40 | 40 | 28 | 60 |
| Attenuation due to duct length (3m), dB | -3 | -2 | -1 | -1 | -1 | -1 | -1 | -1 | |
| Correction due to duct end reflection, dB | -8 | -4 | -1 | 0 | 0 | 0 | 0 | 0 | |
| Conversion to SPL@1m | -11 | -11 | -11 | -11 | -11 | -11 | -11 | -11 | |
| Correction due to surface reflections (1), dB | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | |
| Directivity correction, dB | 1 | -1 | -4 | -4 | -11 | -11 | -11 | -11 | |
| Minimum attenuation provided by distance (13m), dB | -22 | -22 | -22 | -22 | -22 | -22 | -22 | -22 | |
| Minimum attenuation required from silencer, dB (40% 1200mm) | -4 | -9 | -17 | -21 | -20 | -20 | -20 | -20 | |
| Total Noise Emissions from Supply Fan Inlet, dB | 22 | 20 | 11 | 3 | -15 | -22 | -22 | -34 | 8 |
| Nuaire DE4HA-ES Extract Fan (Sound Power Level) | | | | | | | | | |
| Nuaire DE4HA-ES Extract Fan (Sound Power Level) | 91 | 91 | 76 | 76 | 73 | 71 | 65 | 66 | 80 |
| Attenuation due to duct length (3m), dB | -3 | -2 | -1 | -1 | -1 | -1 | -1 | -1 | |
| Correction due to duct end reflection, dB | -8 | -4 | -1 | 0 | 0 | 0 | 0 | 0 | |
| Conversion to SPL@1m | -11 | -11 | -11 | -11 | -11 | -11 | -11 | -11 | |
| Correction due to surface reflections (1), dB | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | |
| Directivity correction, dB | 1 | -1 | -4 | -4 | -11 | -11 | -11 | -11 | |
| Minimum attenuation provided by the building envelope, dB | -10 | -10 | -10 | -10 | -10 | -10 | -10 | -10 | |
| Minimum attenuation provided by distance (13m), dB | -22 | -22 | -22 | -22 | -22 | -22 | -22 | -22 | |
| Minimum attenuation required from silencer, dB (40% 1200mm) | -4 | -9 | -17 | -21 | -20 | -20 | -20 | -20 | |
| Total Noise Emissions from Extract Fan Exhaust Outlet, dB | 37 | 35 | 13 | 10 | 1 | -1 | -7 | -6 | 20 |
| Nuaire DS4HA-ES Supply Fan (Sound Power Level) | | | | | | | | | |
| Nuaire DS4HA-ES Supply Fan (Sound Power Level) | 83 | 78 | 70 | 74 | 69 | 68 | 64 | 66 | 76 |
| Attenuation due to duct length (3m), dB | -3 | -2 | -1 | -1 | -1 | -1 | -1 | -1 | |
| Correction due to duct end reflection, dB | -8 | -4 | -1 | 0 | 0 | 0 | 0 | 0 | |
| Conversion to SPL@1m | -11 | -11 | -11 | -11 | -11 | -11 | -11 | -11 | |
| Correction due to surface reflections (1), dB | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | |
| Directivity correction, dB | 1 | -1 | -4 | -4 | -11 | -11 | -11 | -11 | |

| | | | | | | | | | |
|----------------------------------------------------------------------|-----------|-----------|-----------|-----------|----------|----------|----------|----------|-----------|
| Minimum attenuation provided by the building envelope, dB | -10 | -10 | -10 | -10 | -10 | -10 | -10 | -10 | |
| Minimum attenuation provided by distance (13m), dB | -22 | -22 | -22 | -22 | -22 | -22 | -22 | -22 | |
| Minimum attenuation required from silencer, dB (40% 1200mm) | -4 | -9 | -17 | -21 | -20 | -20 | -20 | -20 | |
| Total Noise Emissions from Supply Fan Inlet, dB | 29 | 22 | 7 | 8 | -3 | -4 | -8 | -6 | 10 |
| Sound Pressure Level at Receiver due to Duct Terminations, dB | 39 | 36 | 25 | 19 | 8 | 6 | 3 | 0 | 23 |

| | |
|-------------------------|-----------|
| Design Criterion | 23 |
|-------------------------|-----------|

APPENDIX B2

7 Greenaway Gardens, London

PLANT NOISE EMISSIONS CALCULATIONS

| Source: Group 2 Plant Units Receiver: Neighbour to South East | Frequency, Hz | | | | | | | | dB(A) |
|------------------------------------------------------------------|---------------|-----|-----|-----|-----|-----|-----|-----|-------|
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| Calorex WA1234BC (Sound Pressure Level @3m) | | | | | | | | | 65 |
| Correction due to surface reflections (3), dB | | | | | | | | | 9 |
| Minimum attenuation due to building envelope, dB | | | | | | | | | -10 |
| Minimum attenuation provided by distance (10m), dB | | | | | | | | | -11 |
| Treatment of 2 no. reflections | | | | | | | | | -6 |
| Attenuation required by proposed acoustic enclosure, dB | -12 | -13 | -20 | -29 | -36 | -37 | -39 | -39 | -27 |
| Total Noise Emissions from unit, dB | | | | | | | | | 20 |
| Marstair CKC 50 (Sound Power Level) | 74 | 74 | 68 | 67 | 66 | 61 | 54 | 54 | 70 |
| Conversion to SPL@1m | -11 | -11 | -11 | -11 | -11 | -11 | -11 | -11 | |
| Correction due to surface reflections (3), dB | 9 | 9 | 9 | 9 | 9 | 9 | 9 | 9 | |
| Minimum attenuation due to building envelope, dB | -10 | -10 | -10 | -10 | -10 | -10 | -10 | -10 | |
| Minimum attenuation provided by distance (10m), dB | -20 | -20 | -20 | -20 | -20 | -20 | -20 | -20 | |
| Treatment of 2 no. reflections | -6 | -6 | -6 | -6 | -6 | -6 | -6 | -6 | |
| Attenuation required by proposed acoustic enclosure, dB | -12 | -13 | -20 | -29 | -36 | -37 | -39 | -39 | |
| Total Noise Emissions from Extract Fan Exhaust Outlet, dB | 24 | 23 | 10 | 0 | -8 | -14 | -23 | -23 | 9 |
| PUZ-ZM71VHA (Sound Pressure Level @1m) | 53 | 52 | 53 | 44 | 43 | 39 | 34 | 37 | 49 |
| Correction due to surface reflections (3), dB | 9 | 9 | 9 | 9 | 9 | 9 | 9 | 9 | |
| Minimum attenuation due to building envelope, dB | -10 | -10 | -10 | -10 | -10 | -10 | -10 | -10 | |
| Minimum attenuation provided by distance (10m), dB | -20 | -20 | -20 | -20 | -20 | -20 | -20 | -20 | |
| Treatment of 2 no. reflections | -6 | -6 | -6 | -6 | -6 | -6 | -6 | -6 | |
| Attenuation required by proposed acoustic enclosure, dB | -6 | -10 | -10 | -10 | -10 | -10 | -6 | -6 | |
| Total Noise Emissions from Extract Fan Exhaust Outlet, dB | 20 | 15 | 16 | 7 | 6 | 2 | 1 | 4 | 13 |
| MVHR units Supply/Exhaust @ 80% (Sound Power Level) | 71 | 71 | 76 | 72 | 65 | 63 | 63 | 57 | 73 |
| Correction for number of units (2 no.) | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | |
| Attenuation due to duct length (3m), dB | -3 | -2 | -1 | -1 | -1 | -1 | -1 | -1 | |
| Correction due to duct end reflection, dB | -8 | -4 | -1 | 0 | 0 | 0 | 0 | 0 | |
| Conversion to SPL@1m | -11 | -11 | -11 | -11 | -11 | -11 | -11 | -11 | |
| Correction due to surface reflections (3), dB | 9 | 9 | 9 | 9 | 9 | 9 | 9 | 9 | |
| Directivity correction, dB | 1 | -1 | -4 | -4 | -11 | -11 | -11 | -11 | |
| Minimum attenuation provided by the building envelope, dB | -10 | -10 | -10 | -10 | -10 | -10 | -10 | -10 | |
| Minimum attenuation provided by distance (10m), dB | -20 | -20 | -20 | -20 | -20 | -20 | -20 | -20 | |
| Treatment of 2 no. reflections | -6 | -6 | -6 | -6 | -6 | -6 | -6 | -6 | |
| Minimum attenuation required from silencer, dB | -4 | -9 | -15 | -16 | -15 | -14 | -12 | -12 | |
| Total Noise Emissions from Supply Fan Inlet, dB | 22 | 20 | 20 | 16 | 3 | 2 | 4 | -2 | 16 |
| MVHR units Extract/Inlet @ 80% (Sound Power Level) | 66 | 66 | 64 | 59 | 47 | 40 | 40 | 28 | 60 |
| Correction for number of units (2 no.) | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | |
| Attenuation due to duct length (3m), dB | -3 | -2 | -1 | -1 | -1 | -1 | -1 | -1 | |
| Correction due to duct end reflection, dB | -8 | -4 | -1 | 0 | 0 | 0 | 0 | 0 | |
| Conversion to SPL@1m | -11 | -11 | -11 | -11 | -11 | -11 | -11 | -11 | |
| Correction due to surface reflections (3), dB | 9 | 9 | 9 | 9 | 9 | 9 | 9 | 9 | |
| Directivity correction, dB | 1 | -1 | -4 | -4 | -11 | -11 | -11 | -11 | |
| Minimum attenuation provided by the building envelope, dB | -10 | -10 | -10 | -10 | -10 | -10 | -10 | -10 | |
| Minimum attenuation provided by distance (10m), dB | -20 | -20 | -20 | -20 | -20 | -20 | -20 | -20 | |
| Treatment of 2 no. reflections | -6 | -6 | -6 | -6 | -6 | -6 | -6 | -6 | |
| Minimum attenuation required from silencer, dB | -4 | -9 | -15 | -16 | -15 | -14 | -12 | -12 | |
| Total Noise Emissions from Supply Fan Inlet, dB | 17 | 15 | 8 | 3 | -15 | -21 | -19 | -31 | 4 |
| Nuair DE3A-ES Extract Fan (Sound Power Level) | 85 | 77 | 61 | 50 | 50 | 54 | 53 | 52 | 65 |
| Attenuation due to duct length (3m), dB | -3 | -2 | -1 | -1 | -1 | -1 | -1 | -1 | |
| Correction due to duct end reflection, dB | -8 | -4 | -1 | 0 | 0 | 0 | 0 | 0 | |
| Conversion to SPL@1m | -11 | -11 | -11 | -11 | -11 | -11 | -11 | -11 | |
| Correction due to surface reflections (3), dB | 9 | 9 | 9 | 9 | 9 | 9 | 9 | 9 | |
| Directivity correction, dB | 1 | -1 | -4 | -4 | -11 | -11 | -11 | -11 | |
| Minimum attenuation provided by the building envelope, dB | -10 | -10 | -10 | -10 | -10 | -10 | -10 | -10 | |
| Minimum attenuation provided by distance (10m), dB | -20 | -20 | -20 | -20 | -20 | -20 | -20 | -20 | |
| Treatment of 2 no. reflections | -6 | -6 | -6 | -6 | -6 | -6 | -6 | -6 | |
| Minimum attenuation required from silencer, dB | -4 | -9 | -15 | -16 | -15 | -14 | -12 | -12 | |

| | | | | | | | | | |
|----------------------------------------------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----------|
| Total Noise Emissions from Extract Fan Exhaust Outlet, dB | 33 | 23 | 2 | -9 | -15 | -10 | -9 | -10 | 10 |
| Nuaire DS4HA-ES Supply Fan (Sound Power Level) | 83 | 78 | 70 | 74 | 69 | 68 | 64 | 66 | 76 |
| Attenuation due to duct length (3m), dB | -3 | -2 | -1 | -1 | -1 | -1 | -1 | -1 | |
| Correction due to duct end reflection, dB | -8 | -4 | -1 | 0 | 0 | 0 | 0 | 0 | |
| Conversion to SPL@1m | -11 | -11 | -11 | -11 | -11 | -11 | -11 | -11 | |
| Correction due to surface reflections (3), dB | 9 | 9 | 9 | 9 | 9 | 9 | 9 | 9 | |
| Directivity correction, dB | 1 | -1 | -4 | -4 | -11 | -11 | -11 | -11 | |
| Minimum attenuation provided by the building envelope, dB | -10 | -10 | -10 | -10 | -10 | -10 | -10 | -10 | |
| Minimum attenuation provided by distance (10m), dB | -20 | -20 | -20 | -20 | -20 | -20 | -20 | -20 | |
| Treatment of 2 no. reflections | -6 | -6 | -6 | -6 | -6 | -6 | -6 | -6 | |
| Minimum attenuation required from silencer, dB | -4 | -9 | -15 | -16 | -15 | -14 | -12 | -12 | |
| Total Noise Emissions from Supply Fan Inlet, dB | 31 | 24 | 11 | 15 | 4 | 4 | 2 | 4 | 16 |
| Sound Pressure Level at Receiver due to Duct Terminations, dB | | | | | | | | | 23 |

| | |
|-------------------------|-----------|
| Design Criterion | 23 |
|-------------------------|-----------|

APPENDIX B3

7 Greenaway Gardens, London

PLANT NOISE EMISSIONS CALCULATIONS

| Source: Group 3 Plant Units Receiver: Neighbour to North West | Frequency, Hz | | | | | | | | dB(A) |
|----------------------------------------------------------------------|---------------|-----------|-----------|-----------|------------|------------|------------|------------|-----------|
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| Vectaire MBOX 200/2 DC Supply/Exhaust @ 80% (Sound Power Level) | 58 | 60 | 64 | 61 | 62 | 60 | 55 | 53 | 67 |
| Attenuation due to duct length (3m), dB | -3 | -2 | -1 | -1 | -1 | -1 | -1 | -1 | |
| Correction due to duct end reflection, dB | -8 | -4 | -1 | 0 | 0 | 0 | 0 | 0 | |
| Conversion to SPL@1m | -11 | -11 | -11 | -11 | -11 | -11 | -11 | -11 | |
| Correction due to surface reflections (1), dB | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | |
| Directivity correction, dB | 1 | -1 | -4 | -4 | -11 | -11 | -11 | -11 | |
| Minimum attenuation provided by distance (23m), dB | -27 | -27 | -27 | -27 | -27 | -27 | -27 | -27 | |
| Minimum attenuation required from silencer, dB | -4 | -8 | -12 | -12 | -12 | -10 | -8 | -6 | |
| Total Noise Emissions from Extract Fan Exhaust Outlet, dB | 9 | 10 | 11 | 9 | 3 | 3 | 0 | 0 | |
| Vectaire MBOX 200/2 DC Supply/Exhaust @ 80% (Sound Power Level) | 53 | 55 | 59 | 56 | 57 | 55 | 50 | 48 | |
| Attenuation due to duct length (3m), dB | -3 | -2 | -1 | -1 | -1 | -1 | -1 | -1 | |
| Correction due to duct end reflection, dB | -8 | -4 | -1 | 0 | 0 | 0 | 0 | 0 | |
| Conversion to SPL@1m | -11 | -11 | -11 | -11 | -11 | -11 | -11 | -11 | |
| Correction due to surface reflections (1), dB | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | |
| Directivity correction, dB | 1 | -1 | -4 | -4 | -11 | -11 | -11 | -11 | |
| Minimum attenuation provided by distance (23m), dB | -27 | -27 | -27 | -27 | -27 | -27 | -27 | -27 | |
| Minimum attenuation required from silencer, dB | -4 | -8 | -12 | -12 | -12 | -10 | -8 | -6 | |
| Total Noise Emissions from Extract Fan Exhaust Outlet, dB | 4 | 5 | 6 | 4 | -2 | -2 | -5 | -5 | |
| MVHR units Supply/Exhaust @ 80% (Sound Power Level) | 71 | 71 | 76 | 72 | 65 | 63 | 63 | 57 | 73 |
| Attenuation due to duct length (3m), dB | -3 | -2 | -1 | -1 | -1 | -1 | -1 | -1 | |
| Correction due to duct end reflection, dB | -8 | -4 | -1 | 0 | 0 | 0 | 0 | 0 | |
| Conversion to SPL@1m | -11 | -11 | -11 | -11 | -11 | -11 | -11 | -11 | |
| Correction due to surface reflections (1), dB | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | |
| Directivity correction, dB | 1 | -1 | -4 | -4 | -11 | -11 | -11 | -11 | |
| Minimum attenuation provided by distance (23m), dB | -27 | -27 | -27 | -27 | -27 | -27 | -27 | -27 | |
| Minimum attenuation required from silencer, dB | -4 | -8 | -12 | -12 | -12 | -10 | -8 | -6 | |
| Total Noise Emissions from Extract Fan Exhaust Outlet, dB | 22 | 21 | 23 | 20 | 6 | 6 | 8 | 4 | |
| MVHR units Extract/Inlet @ 80% (Sound Power Level) | 66 | 66 | 64 | 59 | 47 | 40 | 40 | 28 | |
| Attenuation due to duct length (3m), dB | -3 | -2 | -1 | -1 | -1 | -1 | -1 | -1 | |
| Correction due to duct end reflection, dB | -8 | -4 | -1 | 0 | 0 | 0 | 0 | 0 | |
| Conversion to SPL@1m | -11 | -11 | -11 | -11 | -11 | -11 | -11 | -11 | |
| Correction due to surface reflections (1), dB | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | |
| Directivity correction, dB | 1 | -1 | -4 | -4 | -11 | -11 | -11 | -11 | |
| Minimum attenuation provided by distance (23m), dB | -27 | -27 | -27 | -27 | -27 | -27 | -27 | -27 | |
| Minimum attenuation required from silencer, dB | -4 | -8 | -12 | -12 | -12 | -10 | -8 | -6 | |
| Total Noise Emissions from Supply Fan Inlet, dB | 17 | 16 | 11 | 7 | -12 | -17 | -15 | -25 | |
| Sound Pressure Level at Receiver due to Duct Terminations, dB | 23 | 23 | 24 | 21 | 8 | 8 | 9 | 6 | 21 |

| | |
|-------------------------|-----------|
| Design Criterion | 23 |
|-------------------------|-----------|

ANTI-VIBRATION MOUNTING SPECIFICATION REFERENCE DOCUMENT

1.0 General

- 1.1 All mountings shall provide the static deflection, under the equipment weight, shown in the schedules. Mounting selection should allow for any eccentric load distribution or torque reaction, so that the design deflection is achieved on all mountings under the equipment, under operating conditions.
- 1.2 It is the supplier's responsibility to ensure that all mountings offered are suitable for the loads, operating and environmental conditions which will prevail. Particular attention should be paid to mountings which will be exposed to atmospheric conditions to prevent corrosion.
- 1.3 All mountings shall be colour coded, or otherwise marked, to indicate their load capacity, to facilitate identification during installation.

Where use of resilient supports allows omission of pipe flexible connections for vibration/noise isolation, it shall be the Mechanical Service Consultant's or Contractor's responsibility to decide whether such devices are required to compensate for misalignment or thermal strain.

2.1 Type A Mounting (Caged Spring Type)

- 2.1.1 Each mounting shall consist of cast or fabricated telescopic top and bottom housings enclosing one or more helical steel springs as the principle isolation elements, and shall incorporate a built-in levelling device. The housing should be designed to permit visual inspection of the springs after installation, i.e. the spring must not be totally enclosed.
- 2.1.2 The springs shall have an outside diameter of not less than 75% of the operating height, and be selected to have at least 50% overload capacity before becoming coil-bound.
- 2.1.3 The bottom plate of each mounting shall have bonded to it a rubber/neoprene pad designed to attenuate any high frequency energy transmitted by the springs.
- 2.1.4 Mountings incorporating snubbers or restraining devices shall be designed so that the snubbing, damping or restraining mechanism is capable of being adjusted to have no significant effect during the normal running of the isolated machine.
- 2.1.5 All nuts, bolts or other elements used for adjustment of a mounting shall incorporate locking mechanisms to prevent the isolator going out of adjustment as a result of vibration or accidental or unauthorised tampering.

2.2 Type B Mounting (Open Spring Type)

- 2.2.1 Each mounting shall consist of one or more helical steel springs as the principal isolation elements, and shall incorporate a built-in levelling device.
- 2.2.2 The springs shall be fixed or otherwise securely located to cast or fabricated top and bottom plates, shall have an outside diameter of not less than 75% of the operating height, and shall be selected to have at least 50% overload capacity before becoming coil-bound.
- 2.2.3 The bottom plate shall have bonded to it a rubber/ neoprene pad designed to attenuate any high frequency energy transmitted by the springs.

2.3 Type C Mounting (Rubber/Neoprene Type)

Each mounting shall consist of a steel top plate and base plate completely embedded in oil resistant rubber/neoprene. Each mounting shall be capable of being fitted with a levelling device, and should have bolt holes in the base plate and a threaded metal insert in the top plate so that they can be bolted to the floor and equipment where required.

3.0 Plant Bases

3.1 Type A Bases (A.V. Rails)

An A.V. Rail shall comprise a steel beam with two or more height-saving brackets. The steel sections must be sufficiently rigid to prevent undue strain in the equipment and if necessary should be checked by the Structural Engineer.

3.2 Type B Bases (Steel Plant Bases)

Steel plant bases shall comprise an all-welded steel framework of sufficient rigidity to provide adequate support for the equipment, and fitted with isolator height saving brackets. The frame depth shall be approximately 1/10 of the longest dimension of the equipment with a minimum of 150 mm. This form of base may be used as a composite A.V. rail system.

3.3 Type C Bases (Concrete Inertia Base: for use with steel springs)

These shall consist of an all-welded steel pouring frame-work with height saving brackets, and a frame depth of approximately 1/12 of the longest dimension of the equipment, with a minimum of 100 mm. The bottom of the pouring frame should be blanked off, and concrete (2300 kg/m³) poured in over steel reinforcing rods positioned 35 mm above the bottom. The inertia base should be sufficiently large to provide support for all parts of the equipment, including any components which over-hang the equipment base, such as suction and discharge elbows on centrifugal pumps.