



CONSERVATION AREA ADVISORY COMMITTEE

-----  
Advisory Committee: Camden Town

Application ref: 2021/0040/P

Address: 107 Camden High Street London NW1 7JN Planning Officer: Josh Lawlor Comments by: 09 Mar 2021

Proposal: Relocation of AC plant from roof to rear wall, all as application 2020/3294/P informative item 6

Comment: Yes

Observations: Whilst, in principle, the CTCAAC does not object to this proposed move of A/C units we are concerned to ensure that occupiers of adjacent properties will not have their amenity impacted, specifically as there is no mention of acoustic hoods for the units. It appears that mounting them on the rear wall of the house could result in substantial noise at the rear facades above and adjacent and an acoustic report should be provided along with mitigation required to ensure that amenity is not negatively impacted.

DOCUMENTS ATTACHED

-----  
No details entered

ABOUT THIS FORM

-----  
Issued by: Contact Camden

5 Pancras Square

London N1C 4AG

Form reference: 21662179