



mechanical and electrical  
consulting engineers

## STEPHENSON HOUSE – MITSUBISHI CONDENSER NOISE RATINGS

Floor	Condenser Type	Noise – SPL dBA		
		Fan Speed 100%	Fan Speed 85%	Fan Speed 70%
Lower Ground 01A	PURY-P600	70.0	62.5	
Lower Ground 01B	PURY-P800	72.0	64.0	
Lower Ground 02	PURY-P1100	73.0	65.0	
Ground G01A	PURY-P1000	67.5	65.0	
Ground G01B	PURY-P1050	73.0	64.7	
Ground G02	PURY-P800	72.0	64.0	
First 01 - 01	PURY-P850	72.5	65.8	
First 01 - 02	PURY-P800	72.0	64.0	
First 01 - 03	PURY-P850	72.5	65.8	
First 01 - 04	PURY-P800	72.0	64.0	
Second 02 - 01	PURY-P850	72.5	65.8	
Second 02 - 02	PURY-P600	70.0	62.5	
Second 02 - 03	PURY-P850	72.5	65.8	
Second 02 - 04	PURY-P500	64	62.0	
Second 02 - 05	PURY-P550	68	63.5	

Floor	Condenser Type	Noise – SPL dBA		
		Fan Speed 100%	Fan Speed 85%	Fan Speed 70%
Third 03 - 01	PURY-P700	67	65	
Third 03 – 02	PURY-P700	67	65	
Third 03 - 03	PURY-P700	67	65	
Third 03 - 04	PURY-P250	61	57	
Fourth 04 – 01	PURY-P500	64	62	
Fourth 04 – 02	PURY-P650	69	63.9	
Fourth 04 – 03	PURY-P800	72.0	64	
Fifth 05 – 01	PURY-P500	64	62	
Fifth 05 – 02	PURY-P600	70.0	62.5	
Fifth 05 – 03	PURY-P850	72.5	65.8	
Sixth 06 – 01	PURY-P250	61	57	
Sixth 06 – 02	PURY-P400	69	61	
Sixth 06 – 03	PURY-P550	68	63.5	
Seventh – 07 - 01	PURY-P200	59	55.5	
Seventh – 07 - 02	PURY-P300	67	59.5	
Seventh – 07 - 03	PURY-P450	70	64	
Seventh – 07 - 03	PURY-P400	69	61	

Floor	Condenser Type	Noise – SPL dBA		
		Fan Speed 100%	Fan Speed 85%	Fan Speed 70%
AHU	PUHZ – 3ZP250YKA3	62		
AHU	PUHZ – 3ZP250YKA3	62		
AHU	PUHZ – 3ZP250YKA3	62		
AHU	PUHZ – 3ZP250YKA3	62		