



2-6 Boundary Row
London SE1 8HP
T 020 3714 4090

www.chpsurveyors.com

Our Ref: 2523-21-0312

12th March, 2021

Dr. R Orrell
14 Tobin Close
London
NW3 3DY

Dear Dr Orrell,

Proposed Works at 14 Tobin Close, London, NW3 3DY

In accordance with our instructions, we have considered the potential effects the proposed additional floor to 14 Tobin Close could have on the neighbouring residential properties' daylight and sunlight.


In accordance with the London Borough of Camden's Local Plan, our review has been carried out with reference to the Building Research Establishment's publication "*Site Layout Planning for Daylight and Sunlight. A guide to good practice.*" (BRE guidelines).

Paragraph 2.2.5 of the BRE guidelines states; "*First, draw a section in a plane perpendicular to each affected main window wall of the existing building. Measure the angle to the horizontal subtended by the new development at the level of the centre of the lowest window. If this angle is less than 25° for the whole of the development then it is unlikely to have a substantial effect on the diffuse skylight enjoyed by the existing building.*"

As indicated on the attached drawing, the proposals fall well below the 25° line.

We would therefore confirm that the BRE guidelines are achieved and the proposed additional floor to 14 Tobin Close will not have a substantial effect on the daylight and sunlight enjoyed by the neighbouring residential properties.

Yours sincerely,



Encl.

