

Application ref: 2020/3896/P
Contact: Tony Young
Tel: 020 7974 2687
Email: Tony.Young@camden.gov.uk
Date: 16 March 2021

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE

Phone: 020 7974 4444

planning@camden.gov.uk
www.camden.gov.uk/planning

Schneider Designers
Lower Ground Unit
15 Eldon Grove
London
NW3 5PT

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted

Address:

**33 Primrose Hill Road
London
NW3 3DG**

Proposal:

Installation of air conditioning unit located on flat roof to residential dwelling, including installation of mansafe anchor system fixed to roof and glazed roof hatch to replace skylight.

Drawing Nos: A-100 rev 00 to A-107 rev 00 (inclusive); Noise Impact Assessment from Venta Acoustics (ref. VA3401/201007/NIA) dated 08/10/2020; Energy Efficiency and Adaption Justification email from Schneider Designers dated 30/09/2020; Design and Access Statement and email from Schneider Designers dated 26/08/2020 and 10/02/2021 respectively.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 of the London Borough of Camden Local Plan 2017.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans: A-100 rev 00 to A-107 rev 00 (inclusive); Noise Impact Assessment from Venta Acoustics (ref. VA3401/201007/NIA) dated 08/10/2020; Energy Efficiency and Adaption Justification email from Schneider Designers dated 30/09/2020; Design and Access Statement and email from Schneider Designers dated 26/08/2020 and 10/02/2021 respectively.

Reason:

For the avoidance of doubt and in the interest of proper planning.

- 4 The external noise level emitted from plant, machinery or equipment at the development hereby approved shall be lower than the typical background noise level by at least 10dBA, by 15dBA where the source is tonal, as assessed according to BS4142:2014 at the nearest and/or most affected noise sensitive premises, with all machinery operating together at maximum capacity.

Reason: To safeguard the amenities of neighbouring noise sensitive receptors in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 5 Prior to first use, all approved machinery, plant or equipment shall be provided with acoustic isolation and anti-vibration measures as necessary, and in accordance with the scheme hereby approved, and thereafter shall be permanently retained and maintained in accordance with the manufacturers' recommendations.

Reason: To prevent the transmission of noise and vibration throughout the building and or into any neighbouring premises, thus safeguarding the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 6 The approved roof hatch shall provide access out onto a flat roof area for maintenance purposes only.

Reason: In order to prevent any overlooking of the neighbouring occupiers in accordance with the requirements of policy A1 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations

and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).

- 2 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant licence from the Council's Streetworks Authorisations & Compliance Team London Borough of Camden 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444) . Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106 agreement), no licence or authorisation will be granted until the Construction Management Plan is approved by the Council.
- 3 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website at <https://beta.camden.gov.uk/documents/20142/1269042/Camden+Minimum+Requirements+%281%29.pdf/bb2cd0a2-88b1-aa6d-61f9-525ca0f71319> or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444).

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these hours.

- 4 The applicant's attention is drawn to the need to remove the air conditioning unit hereby approved from the roof of the building as soon as reasonably practicable when no longer required in order to minimize the impact on the appearance of the building and local environment.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2019.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully

A handwritten signature in black ink, appearing to read 'DPope', is positioned above the printed name.

Daniel Pope
Chief Planning Officer