

CERTIFICATE OF IDENTIFICATION FOR ASBESTOS FIBRES

Certificate No. J004679

Page: 1 of 1


Client:	AA Woods (Woods Building Services Ltd) (Head Office)	Report Date:	22 Nov 2016
Client Address:	Woods House, River Way, Harlow, Essex, CM20 2DP	Site Address:	99 Charlotte Street, London, W1
Sample(s) received:	22 Nov 2016	Sampled by:	Client
Sample(s) analysed:	22 Nov 2016	No. of sample(s):	5

All analysis is conducted in accordance with Clearwater Environmental Limited documented in-house procedure PRO02 and HSG248 (Asbestos: The analysts' guide for sampling, analysis and clearance procedures). Clearwater Environmental Limited cannot be held responsible for interpretation, accuracy or competence of sampling of materials undertaken by any third party. Sampling of test items undertaken by the laboratory or associated inspection body is conducted utilising in-house Method PRO01 for which Clearwater Environmental Limited holds UKAS Accreditation. *Any reference to product types e.g. Cement or Insulation Board is an interpretation or opinion of the sampler at the time of conducting the sampling exercise. This certificate cannot confirm the density or classification of the product.

Ref No.	Client Ref No.	Sample Location	Asbestos Type(s) Present	Analysis Ref. No.
1	1	Debris from courtyard excavation	Chrysotile + Amosite	BS014320
2	2	Debris from courtyard excavation	Chrysotile	BS014321
3	3	Debris from courtyard excavation	Chrysotile + Amosite	BS014322
4	4	Debris from courtyard excavation	N.A.D.I.S	BS014323
5	5	Debris from courtyard excavation	Chrysotile + Amosite	BS014324
		----- End -----		

Notes, opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.
 NADIS = No Asbestos Detected in Sample. Sample retention period six (6) months.
 The results detailed on this certificate shall only be reproduced in full with the written approval of the Testing Laboratory.



Analysed by: Keir Daley
 Authorised by: Jess Smith
 Position: Laboratory Manager
 Authorised signature: 

First Floor
 99 Bridge Road East
 Welwyn Garden City
 Hertfordshire
 AL7 1GD
 Tel: 01707 294949
 Fax: 01707 294940
 lab@clearwater-environmental.com

