DESIGN NOTE

TEAM AND SUBJECT TO PLANNING.


DRAWING ISSUE FOR DESIGN INTENT DEVELOPMENT. FINAL LOCATION OF AIR VALVES VENTILATION END POSITIONS, IN PARTICULAR ILLUSTRATED AT THE EXTERNAL FACADES AND ROOF TO BE AGREED WITH PROJECT DESIGN

8 CEILING MOUNT IN-LINE EXTRACT FAN UNIT AS VECTAIRE'S MFIL100T COMPLETE WITH ADJUSTABLE OVER-RUN TIMER FROM 3 & 15 MINUTES OR EQUAL WITHIN JOINERY & REMOVABLE ACCESS PANEL



LEGEND

EXTRACT AIR VALVE





DUCTED COOKERHOOD



WITH THE CONSULTANT ENGINEER'S SPECIFICATION.

ALL DIMENSIONS TO BE VERIFIED ON SITE BEFORE

SETTING OUT OR MAKING ANY SHOP DRAWINGS. THIS DRAWING IS TO BE READ IN CONJUNCTION

\		

	ref./date	REVISIONS		
	PT 23.12.20	PRE-TENDER ISSUE		
	PT1 03.02.21	PRE-TENDER ISSUE		
	T 22.02.21	TENDER ISSUE, GA'S UPDATED		
	T1 15.03.21	TENDER ISSUE, GA'S UPDATED		

NOTES

- 1. FOR EXACT FLOOR FINISHES REFER TO INTERIOR DESIGNER/ARCHITECTS DRAWINGS.
- 2. FINAL LOCATIONS OF AIR VALVES TO BE AGREED WITH ARCHITECT.
- 3. FINAL LOCATION OF MVHR & MEV BOOST SWITCHES TO BE AGREED WITH ARCHITECT.
- 4. FIRE BREAK 2 HR AS SUPPLIED BY DOMUS OR EQUAL & APPROVED TO BE PROVIDED WHERE PASSING THROUGH FIRE RATED WALLS & FLOORS.
- 5. VENTILATION DUCTWORK SHALL BE INSTALLED WITH FIRE BREAK DUCT CONNECTOR WHERE PENETRATING THROUGH FLOORS & ROOF.

BWIC NOTE

- . USE OF EXISTING NOTCHES AND JOISTS TO BE USED WHERE PRACTICAL. ANY NEW NOTCH AND ENGINEER'S DETAILS.
- 2. ANY HOLES IN WALLS TO HAVE 'LETTER BOX' ARRANGEMENT TO BE AGREED WITH MBP.



HOLES WILL BE CARRIED OUT IN ACCORDANCE TO LISTED BUILDING REGULATIONS AND STRUCTURAL





ROOF MECHANICAL SERVICES VENTILATION

55 CUMBERLAND TERRACE CAMDEN, LONDON NW1 4HJ




	email: mai	l@czltd.co.uk			
xref	55CT - GA (21-03-03)				
Scale	A1@1:50	Drawn	SAS		
Date	Nov 2020	Checked			
Issue					

TENDER

M WS2-114 T1

ROOF



ROOF PLAN