

rev.	date	
A	05-10-20	Project title revised
B	29-10-20	Project title revised
C	05-02-21	Fixed glazed rooflight omitted
D	05-03-21	Openable rooflight revised to access hatch

Access hatch Bilco S-50TB CL for ladder access or equal approved, clear opening dimensions 760 x 915, or equal approved, fully insulated with solid insulated aluminium cover, thermally broken seals, compression spring operation, hold open arms, latch underside and top side, lockable internally by key, finish mill finish. Kerb to be suitable for application of asphalt skirting

Asphalt skirting 20 thick in 3 coats

Expanded metal lathing key to upstand

Sheathing felt separating membrane

25 WBP plywood deck on treated timber firrings laid to fall no shallower than 1 in 80.

PIR Insulation to upstands

Ventilated void

Twinned joists to structural engineer's details (steel beams to north & south sides of opening)

PIR Insulation to full depth of joists, between joists

Plaster skimmed foil backed plasterboard ceiling

150 min.

Plaster stop

Skimmed plasterboard lining

915 clear opening width (x 760)

client

JONATHAN & NATHALIE ESFANDI

property

55 CUMBERLAND TERRACE
LONDON NW1 4HJ

project

PROPOSED ALTERATIONS

drawing

MAIN ROOF -DETAILS AS PROPOSED
ROOFLIGHTS

scale

1 : 5 @ A3

drawn

MPP

drawing no.

11188-09

date

11-09-20

checked

revision

D



MILLBRIDGE

16 Watermark Way
Foxholes Business Park
Hertford
Hertfordshire SG13 7TZ
01992 300 301

Detail 1- main roof, section through fixed glazed rooflight- OMITTED

Detail 2- main roof, part section through openable rooflight