

**Sainsbury's**  
35 Hampstead High Street  
Hampstead  
NW3 1QE

**Plant Noise Impact Assessment**

On behalf of

**Sainsbury's**

Project Reference: 89759 | Revision: 00 | Date: 20<sup>th</sup> April 2021



## Document Information

**Project Name** : Sainsbury's, Hampstead High Street  
**Project Reference** : 89759  
**Report Title** : Plant Noise Impact Assessment  
**Doc Reference** : 89759/NIA  
**Date** : 20<sup>th</sup> April 2021

	Name	Qualifications	Initials	Date
<b>Prepared by:</b>	Dean Bowden	BSc(Hons), MIOA	DMB	20 <sup>th</sup> April 2021
<b>Reviewed and approved by:</b>	Jon Stump	BSc(Hons), MIOA	JS	20 <sup>th</sup> April 2021
<b>For and on behalf of Noise Solutions Ltd</b>				

Revision	Date	Description	Prepared	Reviewed/ Approved

Noise Solutions Ltd (NSL) disclaims any responsibility to the Client and others in respect of any matters outside the scope of this report. This report has been prepared with reasonable skill, care and diligence within the terms of the Contract with the Client and generally in accordance with the appropriate ACE Agreement and taking account of the manpower, resources, investigations and testing devoted to it by agreement with the Client. This report is confidential to the Client and NSL (Noise Solutions Ltd) accepts no responsibility of whatsoever nature to third parties to whom this report or any part thereof is made known. Any such party relies upon the report at their own risk.

© Noise Solutions Ltd (NSL) 2021

Reg no. 3483481 Trading office Unit 5, Oriol Court, Omega Park, Alton, Hampshire, GU34 2YT

**Contents**

**1.0 Introduction ..... 1**

**2.0 Details of development proposals..... 1**

**3.0 Nearest noise sensitive receptors ..... 1**

**4.0 Existing noise climate ..... 2**

    Covid-19 .....2

**5.0 Plant noise design criteria..... 4**

    London Borough of Camden.....4

    BS 4142:2014 Methods for rating and assessing industrial and commercial sound.....5

    Notes on BS 4142:2014 and Camden Local Plan Appendix 3 .....7

    Low background sound levels .....7

    Summary of requirements .....7

**6.0 Plant noise impact assessment..... 8**

    Uncertainties .....9

**7.0 Summary ..... 9**

**Appendices**

- Appendix A Acoustic terminology
- Appendix B Photograph and drawings of site showing areas of interest
- Appendix C Manufacturer noise data
- Appendix D Environmental sound survey
- Appendix E Noise level predictions

## 1.0 Introduction

- 1.1. Noise Solutions Ltd (NSL) has been commissioned by Sainsbury's to undertake a noise impact assessment for new internal and external plant serving a proposed Sainsbury's store at 35 Hampstead High Street.
- 1.2. An environmental sound survey has been undertaken to establish the prevailing background sound pressure levels at a location representative of the sound levels outside the nearest noise sensitive receptors to the site.
- 1.3. Cumulative plant noise emission levels for the proposed plant have been predicted at the most affected noise sensitive receptor and assessed using the typical requirements of London Borough of Camden.
- 1.4. A glossary of acoustic terminology is given in [Appendix A](#). An in-depth glossary of acoustic terms can be viewed online at [www.acoustic-glossary.co.uk](http://www.acoustic-glossary.co.uk).

## 2.0 Details of development proposals

- 2.1. New plant is to be installed to serve the Sainsbury's store at 35 Hampstead High Street.
- 2.2. A new refrigeration gas cooler is proposed within the external yard to the rear (north) of the site. Absorptive wall lining will be fitted to the store façade in the vicinity of the unit in order to minimise the effects of reflected sound.
- 2.3. A new VRF AC unit is to be located within an internal plant room on the first floor of the building. Airflow will be maintained to the plant room via a louvre on the north elevation. The plant room is to be fitted with suitable atmospheric-side attenuation internally.
- 2.4. The refrigeration plant will operate at all times, although generally at a lower duty at night when demands for cooling are reduced. The AC unit will operate only when the store is open.
- 2.5. [Appendix C](#) contains a table with the manufacturer's published sound pressure levels for the proposed plant.

## 3.0 Nearest noise sensitive receptors

- 3.1. The area surrounding the site is a mix of commercial and residential premises. The nearest noise-sensitive receptors (Receptor R1) to the new plant are on Spencer Walk, to the rear of the store, approximately 11m from the closest plant item.

- 3.2. It is understood there are no residential premises within the proposed Sainsbury's building.
- 3.3. The locations of the store, plant and receptor are shown in [Appendix B](#).


## 4.0 Existing noise climate

- 4.1. An environmental noise survey was undertaken to establish the typical background sound levels at a location representative of the noise climate outside the façades of the nearest noise sensitive receptors to the proposed plant area during the quietest times at which the plant will operate.
- 4.2. The results of the environmental sound survey are summarised in Table 1 below. The full set of measurement results and details of the survey methodology are presented in [Appendix D](#).

*Table 1 Summary of survey results*

Measurement period	Range of recorded sound pressure levels (dB)			
	L <sub>Aeq</sub> (15mins)	L <sub>Amax</sub> (15mins)	L <sub>A10</sub> (15mins)	L <sub>A90</sub> (15mins)
Daytime (07.00 – 23.00 hours)	56-66	68-93	60-68	38-56
Night (23.00 – 07.00 hours)	45-60	66-80	40-65	31-44

*Figure 1 Histogram of daytime L<sub>A90</sub> background sound pressure levels*




- 4.3. Further statistical analysis has been carried out on the data, and the mean and median values are shown in Table 2 below.

Table 2 Statistical analysis of  $L_{A90,15min}$  levels during the daytime period

dB, $L_{A90}$ daytime period	
<b>Mean</b>	49
<b>Mode</b>	52
<b>Median</b>	52

- 4.4. From the histogram analysis, 43dB has been selected to be a robust representation of the background noise level during the daytime period.

Figure 2 Histogram of night-time  $L_{A90}$  background sound pressure levels



- 4.5. Further statistical analysis has been carried out on the data and the mean and median values are shown in table 3 below.

Table 3 Statistical analysis of  $L_{A90,15min}$  levels during the night-time period

dB, $L_{A90}$ night-time period	
<b>Mean</b>	35
<b>Mode</b>	32
<b>Median</b>	34

- 4.6. Again, from the histogram analysis, 32dB has been chosen to be representative of the background sound level during the night-time period.

- 4.7. The following values are considered representative of the existing background sound pressure levels at nearby noise sensitive premises:

- 43dB  $L_{A90}$  during the daytime period; and
- 32dB  $L_{A90}$  during the night-time period.

## Covid-19

- 4.8. It should be noted that the environmental noise survey discussed in this report was undertaken in January 2021, at a time when the coronavirus pandemic was causing a disruption to typical working patterns and other activity. It is therefore likely that recorded sound levels are slightly lower than would otherwise be expected where dominated by road or air traffic. While the data should therefore be treated with an element of caution, where it has been used to establish background sound levels it is likely to understate the more-usual background sound levels and therefore result in a robust assessment.

## 5.0 Plant noise design criteria

### London Borough of Camden

- 5.1. Section 6 of the Camden Planning Guidance Amenity, published March 2018, gives guidance on noise and vibration.
- 5.2. Clause 6.8 refers to noise thresholds within Appendix 3 of the Local Plan and to the principles of No observed effect level (NOEL), Lowest observable adverse effect level (LOAEL) and Significant observed adverse effect level (SOAEL) and defines their meanings. Specifically, in the context of this report, LOAEL is defined as:

*The level above which changes in behaviour (e.g. closing windows for periods of the day) and adverse effects on health (e.g. sleep disturbance) and quality of life can be detected.*

- 5.3. SOEAL is defined as:

*The level above which adverse effects on health and quality of life occur. This could include psychological stress, regular sleep deprivation and loss of appetite.*

- 5.4. Clause 6.27 states that:

*Developments proposing plant, ventilation, air extraction or conditioning equipment and flues will need to provide the system's technical specifications to the council accompanying any acoustic report. "BS4142 Method for rating Industrial and Commercial Sound" contains guidance and standards which should also be considered within the acoustic report.*

- 5.5. Appendix 3 within the Camden Local Plan published 2017 states:

*"A relevant standard or guidance document should be referenced when determining values for LOAEL and SOAEL for non-anonymous noise. Where appropriate and within the scope of the document it is expected that British Standard 4142:2014 'Methods for rating and*

*assessing industrial and commercial sound' (BS 4142) will be used. For such cases a 'Rating Level' of 10 dB below background (15dB if tonal components are present) should be considered as the design criterion).*"

- 5.6. Table C of the appendix states the criteria at which development related noise levels will be acceptable:

*Table C: Noise levels applicable to proposed industrial and commercial development (including plant and machinery)*

Existing Noise sensitive receptor	Assessment Location	Design Period	LOAEL (green)	LOAEL to SOAEL (Amber)	SOAL (Red)
Dwellings**	Garden used for main amenity (free field) and Outside living or dining or bedroom window (façade)	Day	'Rating level' 10dB* below background	'Rating level' between 9dB below and 5dB above background	'Rating level' greater than 5dB above background
Dwellings**	Outside bedroom window (façade)	Night	'Rating level' 10dB* below background and no events exceeding 57dB <sub>L<sub>Amax</sub></sub>	'Rating level' between 9dB below and 5dB above background or noise events between 57dB and 88dB <sub>L<sub>Amax</sub></sub>	'Rating level' greater than 5dB above background and/or events exceeding 88dB <sub>L<sub>Amax</sub></sub>

*\*10dB should be increased to 15dB if the noise contains audible tonal elements. (day and night). However, if it can be demonstrated that there is no significant difference in the character of the residual background noise and the specific noise from the proposed development then this reduction may not be required. In addition, a frequency analysis (to include, the use of Noise Rating (NR) curves or other criteria curves) for the assessment of tonal or low frequency noise may be required.*

*\*\*levels given are for dwellings, however, levels are use specific and different levels will apply dependent on the use of the premises.*

### **BS 4142:2014 Methods for rating and assessing industrial and commercial sound**

- 5.7. BS 4142:2014 is intended to be used to assess the likely effects of sound on people residing in nearby dwellings. The scope of BS 4142:2014 includes "sound from fixed plant installations which comprise mechanical and electrical plant and equipment".



- 
- 5.8. The procedure contained in BS 4142:2014 is to quantify the "specific sound level", which is the measured or predicted level of sound from the source in question over a one hour period for the daytime and a 15 minute period for the night-time. Daytime is defined in the standard as 07.00 to 23.00 hours, and night-time as 23.00 to 07.00 hours.
- 5.9. The specific sound level is converted to a rating level by adding penalties on a sliding scale to account for either potentially tonal or impulsive elements. The standard sets out objective methods for determining the presence of tones or impulsive elements, but notes that it is acceptable to subjectively determine these effects.
- 5.10. The penalty for tonal elements is between 0dB and 6dB, and the standard notes: "Subjectively, this can be converted to a penalty of 2 dB for a tone which is just perceptible at the noise receptor, 4 dB where it is clearly perceptible, and 6 dB where it is highly perceptible."
- 5.11. The penalty for impulsive elements is between 0dB and 9dB, and the standard notes: "Subjectively, this can be converted to a penalty of 3 dB for impulsivity which is just perceptible at the noise receptor, 6 dB where it is clearly perceptible, and 9 dB where it is highly perceptible."
- 5.12. The assessment outcome results from a comparison of the rating level with the background sound level. The standard states:
- *Typically, the greater this difference, the greater the magnitude of the impact.*
  - *A difference of around +10 dB or more is likely to be an indication of a significant adverse impact, depending on the context;*
  - *A difference of around +5 dB is likely to be an indication of an adverse impact, depending on the context;*
  - *The lower the rating level is relative to the measured background sound level, the less likely it is that the specific sound source will have an adverse impact or a significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact, depending on the context.*
- 5.13. The standard does state that "adverse impacts include, but are not limited to, annoyance and sleep disturbance. Not all adverse impacts will lead to complaints and not every complaint is proof of an adverse impact."
- 5.14. The standard goes on to note that: "Where background sound levels and rating levels are low, absolute levels might be as, or more, relevant than the margin by which the rating level exceeds the background. This is especially true at night."

- 5.15. In addition to the margin by which the Rating Level of the specific sound source exceeds the Background Sound Level, the 2014 edition places emphasis upon an appreciation of the context, as follows:

*"An effective assessment cannot be conducted without an understanding of the reason(s) for the assessment and the context in which the sound occurs/will occur. When making assessments and arriving at decisions, therefore, it is essential to place the sound in context."*

- 5.16. BS 4142:2014 requires uncertainties in the assessment to be considered, and where the uncertainty is likely to affect the outcome of the assessment, steps should be taken to reduce the uncertainty.

### Notes on BS 4142:2014 and Camden Local Plan Appendix 3

- 5.17. It should be noted that a plant rating noise level equal to the background sound level would be considered to have a "low impact, depending on the context" using BS 4142, and would fall into the "Amber" category with the Camden Local Plan.

### Low background sound levels

- 5.18. As described in BS 4142:2014, where background noise levels are low it is appropriate to consider the absolute noise level. From guidance published by the World Health Organization<sup>1</sup> when windows are partially open for ventilation internal noise levels within dwellings are typically 15dBA lower than the noise level at the façade. Therefore, a plant noise level of 30dBA at the nearest residential window would result in internal noise levels of around 15-20dBA when windows are open, a level lower than that resulting from domestic refrigerators etc. within the dwellings.

### Summary of requirements

- 5.19. The local authority's usual requirement is that the plant noise level at the nearest noise-sensitive windows should be at least at least 10dB below the representative  $L_{A90}$  background sound level. However, due to the low background sound levels at night, and in accordance with advice in BS 4142:2014, it is proposed to set a lower plant noise limit of 30 dBA during the night-time period.

---

<sup>1</sup> World Health Organization Regional Office for Europe, *Environmental Noise Guidelines for the European Region*, 2018

5.20. A summary of the recommended plant noise limits is given in Table 4.

*Table 4 Proposed plant noise level at noise sensitive residential receptors*

Period	Cumulative plant noise level, dB(A)
Daytime (07.00 – 23.00 hours)	33
Night-time (23.00 – 07.00 hours)	30

5.21. These limits will result in a plant noise rating level at or below that at which a “low impact” would be expected, according to the method described in BS 4142:2014.

## 6.0 Plant noise impact assessment

6.1. The cumulative plant sound pressure level at the most affected noise sensitive receptor has been predicted based on manufacturer’s data for the proposed equipment.

6.2. For the gas cooler, the assessment has taken into consideration distance attenuation and the losses attributed to the proposed acoustic wall lining. Calculations of the VRF plant room have considered reverberation, aperture size, directivity and distance attenuation. The predictions are inclusive of the losses due to attenuators with the following acoustic performance:

*Table 5 Insertion losses(dB) for plantroom attenuators at octave band centre frequencies (Hz)*

Attenuator	63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz
<b>Intake</b>	13	26	40	45	45	45	45	45
<b>Discharge</b>	13	26	40	45	45	45	45	45

6.3. The predictions have been based on all plant operating at maximum duty during the daytime period, and the refrigeration plant only operating at maximum duty during the night-time period.

6.4. It should be noted that the proposed plant is not anticipated to exhibit any tonal or impulsive characteristics provided it is well maintained. All proposed plant will be inverter driven and, therefore, will gently ramp up and down depending on the demands on the various systems. However, a penalty of 3dB as described in BS 4142:2014 has been applied for the possible presence of “...characteristics that are neither tonal nor impulsive, though otherwise are readily distinctive against the residual acoustic environment...”.

6.5. Table 6, below, summarises the assessment of cumulative sound pressure levels of the proposed plant at the nearest noise-sensitive windows. All other nearby receptors benefit from increased distance/screening to the plant. The full set of calculations can be found in [Appendix E](#).

*Table 6 Assessment of noise levels at nearby receptor due to proposed plant*

Receptor	Period	Predicted plant noise rating level at receptor, $L_{Aeq}$ (dB)	Criterion, dB(A)	Difference (dB)
R1	Daytime period (07.00 – 23.00 hours)	32	33	-1
	Night-time period (23.00 – 07.00 hours)	30	30	0

6.6. The above assessment demonstrates that cumulative plant noise levels will be at or below the proposed noise limits at the nearest residential properties.

### Uncertainties

6.7. Where possible, uncertainty in the above assessments has been minimised by taking the following steps:

- The meter and calibrator used have a traceable laboratory calibration and the meter was field calibrated before and after the measurements.
- Uncertainty in the calculated impacts has been reduced by the use of a well-established calculation method.
- Care was taken to ensure that the measurement position was representative of the noise climate outside the nearby residential dwellings and not in a position where higher noise levels were present.

6.8. All reasonable steps have been taken to robustly assess noise from the proposed plant.

## 7.0 Summary

7.1. Noise Solutions Ltd (NSL) has been commissioned by Sainsbury's to undertake a noise impact assessment for new plant serving a proposed Sainsbury's Local store located at 35 Hampstead High Street.

7.2. An environmental sound survey has been undertaken to establish the prevailing background sound pressure levels at a location representative of the sound levels outside the nearest noise sensitive receptors to the site.

- 7.3. Cumulative plant noise emission levels for the proposed plant have been predicted at the most affected noise sensitive receptor and assessed using the typical requirements of the London Borough of Camden.
  
- 7.4. The assessment has demonstrated compliance with the proposed criteria. Therefore, noise from the proposals should not be a reason for refusal of planning permission.

## Appendix A Acoustic terminology


Parameter	Description
Ambient Noise Level	The totally encompassing sound in a given situation at a given time, usually composed of a sound from many sources both distant and near ( $L_{Aeq,T}$ ).
Decibel (dB)	A scale for comparing the ratios of two quantities, including sound pressure and sound power. The difference in level between two sounds $s_1$ and $s_2$ is given by $20 \log_{10} (s_1/s_2)$ . The decibel can also be used to measure absolute quantities by specifying a reference value that fixes one point on the scale. For sound pressure, the reference value is $20\mu\text{Pa}$ . The threshold of normal hearing is in the region of 0 dB and 140 dB is the threshold of pain. A change of 1 dB is only perceptible under controlled conditions.
dB(A), $L_{Ax}$	Decibels measured on a sound level meter incorporating a frequency weighting (A weighting) which differentiates between sounds of different frequency (pitch) in a similar way to the human ear. Measurements in dB(A) broadly agree with people's assessment of loudness. A change of 3 dB(A) is the minimum perceptible under normal conditions, and a change of 10 dB(A) corresponds roughly to halving or doubling the loudness of a sound. The background noise in a living room may be about 30 dB(A); normal conversation about 60 dB(A) at 1 metre; heavy road traffic about 80 dB(A) at 10 metres; the level near a pneumatic drill about 100 dB(A).
Fast Time Weighting	Setting on sound level meter, denoted by a subscript F, that determines the speed at which the instrument responds to changes in the amplitude of any measured signal. The fast time weighting can lead to higher values than the slow time weighting when rapidly changing signals are measured. The average time constant for the fast response setting is 0.125 (1/8) seconds.
Free-field	Sound pressure level measured outside, far away from reflecting surfaces (except the ground), usually taken to mean at least 3.5 metres
Façade	Sound pressure level measured at a distance of 1 metre in front of a large sound reflecting object such as a building façade.
$L_{Aeq,T}$	A noise level index called the equivalent continuous noise level over the time period T. This is the level of a notional steady sound that would contain the same amount of sound energy as the actual, possibly fluctuating, sound that was recorded.
$L_{max,T}$	A noise level index defined as the maximum noise level recorded during a noise event with a period T. $L_{max}$ is sometimes used for the assessment of occasional loud noises, which may have little effect on the overall $L_{eq}$ noise level but will still affect the noise environment. Unless described otherwise, it is measured using the 'fast' sound level meter response.
$L_{10,T}$	A noise level index. The noise level exceeded for 10% of the time over the period T. $L_{10}$ can be considered to be the "average maximum" noise level. Generally used to describe road traffic noise. $L_{A10,18h}$ is the A-weighted arithmetic average of the 18 hourly $L_{A10,1h}$ values from 06:00-24:00.
$L_{90,T}$	A noise level index. The noise level that is exceeded for 90% of the measurement time interval, T. It gives an indication of the lower levels of fluctuating noise. It is often used to describe the background noise level and can be considered to be the "average minimum" noise level and is a term used to describe the level to which non-specific noise falls during quiet spells, when there is lull in passing traffic for example.




## Appendix B Photograph and drawings of site showing areas of interest



DO NOT SCALE FROM THIS DRAWING - STATED DIMENSIONS REFER. CONTRACTORS TO BE RESPONSIBLE FOR THE CHECKING OF ALL STATED DIMENSIONS, WITH ANY ANOMALIES BEING IDENTIFIED TO THE ORIGINATOR PRIOR TO ANY CONSTRUCTION OR FABRICATION WORKS COMMENCING.



1 PROPOSED GROUND FLOOR PLAN  
1:200@A3



2 PROPOSED FIRST FLOOR PLAN  
1:200@A3

0 2 4 6 8 10m  
SCALE 1:200 @A3

B	12.04.21	Plant Area Amended	JN
A	24.03.21	Doors blocked	DH
-	23.03.21	First issue	JN
Rev.	Date	Description	

architects  
project managers  
cost consultants

1st Floor  
13 Essex Road  
Hampstead, London  
N11 1BA  
tel: 020 637 9993

Status

Project Title  
SAINSBURY'S LOCAL  
HAMPSTEAD, 35 HIGH STREET  
LONDON, NW3 1QE

Drawing Title  
EXISTING AND PROPOSED GROUND  
FLOOR PLAN

Project Number S-180082	Drawing Number P-180082-110	Revision B
Drawn JN	Checked VA	Scale 1:200@A3
Date 23.03.21		


All drawings are the property of the Company. No part of this drawing shall be reproduced or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written permission of the Company. The Company shall not be liable for any loss or damage arising from the use of this drawing.



DO NOT SCALE FROM THIS DRAWING - STATED DIMENSIONS REFER. CONTRACTORS SHALL BE RESPONSIBLE FOR THE CHECKING OF ALL STATED DIMENSIONS, WITH ANY ANOMALIES BEING IDENTIFIED TO THE ORIGINATOR PRIOR TO ANY CONSTRUCTION OR FABRICATION WORKS COMMENCING.



**01** EXISTING ELEVATION  
P186082205 1:200@A3




**03** EXISTING REAR ELEVATION  
P186082205 1:200@A3



**02** PROPOSED ELEVATION  
P186082205 1:200@A3

Notes:  
1. All dimensions are in millimetres unless otherwise stated.  
2. All dimensions are to the face of the work unless otherwise stated.  
3. All dimensions are to the centre of the work unless otherwise stated.  
4. All dimensions are to the finished surface unless otherwise stated.  
5. All dimensions are to the centre of the work unless otherwise stated.



**04** PROPOSED REAR ELEVATION  
P186082205 1:200@A3

0 2 4 6 8 10m  
SCALE 1:200 @A3

Rev.	Date	Description	By
B	18.04.21	General Amendments	JH
A	24.03.21	Rear elevation	DH
-	23.03.21	Final issue	JH

architects  
project managers  
cost consultants  
**jla**  
Jill Ross  
13 South Street  
Hampstead, London  
N6 5RS  
we work for you

Status

Project Title  
**SAINSBURY'S LOCAL  
HAMPSTEAD, 35 HIGH STREET  
LONDON, NW3 1QE**

Drawing Title  
**EXISTING AND PROPOSED  
ELEVATIONS**

Project Number	Drawing Number	Revision
S-186082	P-186082-205	B

Drawn	Checked	Scale	Date
JH	VA	1:200@A3	23.03.21

JLA Architects is a trading name of JLA Architects Limited, a company registered in England and Wales. Registered Office: 13 South Street, Hampstead, London, NW3 1QE. All responsibilities are shared and not limited to the architect's professional liability. The architect's professional liability is limited to the sum of £1,000,000. The architect's professional liability is limited to the sum of £1,000,000.

## Appendix C      Manufacturer noise data

Plant item	Make/Model	Quantity	Notes	dBA								dBA
				63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz	
AC	Mitsubishi / PURY-EM250YNW-A1	1	L <sub>w</sub>	88	82	81	79	73	69	70	63	80
Refrigeration gas cooler	Kelvion / GF-MA102G4/5684747	1	L <sub>p</sub> @ 10m	24	24	22	23	25	18	14	6	27
			L <sub>p</sub> @ 10m	24	24	22	23	25	18	14	6	27

## Appendix D Environmental sound survey

### Details of environmental sound survey

- D.1 Measurements of the existing background sound levels were undertaken from 15.45 hours on Tuesday 26<sup>th</sup> January to 12.30 hours on Wednesday 27<sup>th</sup> January 2021.
- D.2 The sound level meter was programmed to record the A-weighted  $L_{eq}$ ,  $L_{90}$ ,  $L_{10}$  and  $L_{max}$  noise indices for consecutive fifteen-minute sample periods for the duration of the survey.

### Measurement position

- D.3 The representative measurement position was located on a lamppost on Perrin's Court (location indicated on the site plan in [Appendix B](#)). In accordance with BS 7445-2:21991 '*Description and measurement of environmental noise – Part 2: Guide to the acquisition of data pertinent to land use*', the measurements were undertaken under free-field conditions.
- D.4 The survey location was selected to avoid the possible influence of plant at the rear of the store, serving other premises.

### Equipment

- D.5 Details of the equipment used during the survey are provided in the table below. The sound level meter was calibrated before and after the survey; no significant change (+/-0.2 dB) in the calibration level was noted.

Description	Model / serial no.	Calibration date	Calibration certificate no.
Class 1 Sound level meter	Rion NL-52 / 00654035	29/05/2019	UCRT19/1634
Condenser microphone	Rion UC-59 /08290		
Preamplifier	Rion NH-25 / 54080		
Calibrator	Rion NC-74 /34235932	20/08/2020	TCRT20/1469


- D.6 Weather conditions were determined both at the start and on completion of the survey. It is considered that the meteorological conditions were appropriate for environmental noise measurements. The table below presents the weather conditions recorded on site at the beginning and end of the survey.

Weather Conditions				
Measurement Location	Time/Date	Description	Beginning of Survey	End of Survey
As indicated on Appendix B	15.45 26 Jan – 12.30 27 Jan 2021	Temperature (°C)	6	8
<p><b>Cloud Cover</b></p> <p>Symbol    Scale in oktas (eighths)</p> <p>○    0    Sky completely clear</p> <p>◐    1</p> <p>◑    2</p> <p>◒    3</p> <p>◓    4    Sky half cloudy</p> <p>◔    5</p> <p>◕    6</p> <p>◖    7</p> <p>◗    8    Sky completely cloudy</p> <p>⊗    (9) Sky obstructed from view</p>		Precipitation:	Spitting	None
		Cloud cover (oktas – see guide)	8	8
		Presence of fog/snow/ice	No	No
		Presence of damp roads/wet ground	Damp	Wet
		Wind Speed (m/s)	1	Still
		Wind Direction	SW	-
		Conditions that may cause temperature inversion (i.e. calm nights with no cloud)	No	No

## Results

- D.7 The results of the survey are considered to be representative of the background sound pressure levels at the façades of the most affected noise sensitive receptors to the plant area during the quietest times at which the plant will operate. The noise climate at the measurement position was dominated by distant road traffic. The results of the survey are presented in a time history graph overleaf.

### Sainsbury's Hampstead Tuesday 26 - Wednesday 27 Jan 2021



## Appendix E Noise level predictions

Description	Notes	dB								dB(A)
		63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz	
<b>VRF intake</b>										
Reverberant level in plant room	Rev Lp	90	84	83	80	72	66	67	61	81
Opening area (m2)	3	4	4	4	4	4	4	4	4	
SRI of opening	I.L.	-13	-26	-40	-45	-45	-45	-45	-45	
Inside-outside correction		-6	-6	-6	-6	-6	-6	-6	-6	
Lw of opening	Lw	75	56	41	33	25	19	20	14	50
Directivity correction	0, 0	3	4	5	6	6	6	6	6	
Distance correction	13	-30	-30	-30	-30	-30	-30	-30	-30	
BS 4142:2014 correction		3	3	3	3	3	3	3	3	
Resultant at receptor	Lp @ R1	51	32	19	12	4	-2	-1	-7	25
<b>VRF discharge</b>										
Sound power level of fans	Lw	88	82	81	79	73	69	70	63	80
End reflection	3	-2	0	0	0	0	0	0	0	
SRI of opening	I.L.	-13	-26	-40	-45	-45	-45	-45	-45	
Lw of opening		73	56	41	34	28	24	25	18	48
Directivity correction	0, 0	3	4	5	6	6	6	6	6	
Distance correction	13	-30	-30	-30	-30	-30	-30	-30	-30	
BS 4142:2014 correction		3	3	3	3	3	3	3	3	
Resultant at receptor	Lp @ R1	48	32	18	12	7	2	3	-3	23
<b>Condenser (day)</b>										
Sound pressure level	Lp @ 10m	24	24	22	23	25	18	14	6	27
Distance correction	11	-1	-1	-1	-1	-1	-1	-1	-1	
Reflections*		0	0	0	0	0	0	0	0	
BS 4142:2014 correction		3	3	3	3	3	3	3	3	
Resultant at receptor	Lp @ R1	26	26	24	25	27	20	16	8	30
<b>Condenser (night)</b>										
Sound pressure level	Lp @ 10m	24	24	22	23	25	18	14	6	27
Distance correction	11	-1	-1	-1	-1	-1	-1	-1	-1	
Reflections*		0	0	0	0	0	0	0	0	
BS 4142:2014 correction		3	3	3	3	3	3	3	3	
Resultant at receptor	Lp @ R1	26	26	24	25	27	20	16	8	30
<b>Cumulative</b>										
Resultant at receptor (day)	Lp @ R1	53	35	26	26	27	20	16	9	32
Resultant at receptor (night)	Lp @ R1	26	26	24	25	27	20	16	8	30

\*reflections minimised through the installation of acoustic wall lining behind the plant.