

## Mark Chan

---

**From:** Michael Spraggon  
**Sent:** 19 April 2021 11:56  
**To:** Jack Greenard  
**Subject:** Noise from Lucy metered ring main units.

[External email]

---

Hi Jack,

Further to your phone enquiry regarding noise from Lucy ring main units with metering units, I can advise that there is no noise emission from these units.

The only instance where a sound would be heard would be if the circuit breaker was tripped due to a fault occurring downstream on the network.

Kind regards,

Michael Spraggon  
Contracts Engineer  
Lucy Electric Ltd



*engineering intelligent solutions*  
[www.lucyelectric.com](http://www.lucyelectric.com)



UK • China • India • Malaysia • Saudi Arabia • South Africa • Thailand • United Arab Emirates