



London Borough of Camden Our DTS Ref: 62024
Camden Town Hall Your Ref: 2021/0927/P- Updated
Argyle Street
Euston Road
London
WC1H 8EQ

19 May 2021

Dear Sir/Madam

Re: EASTMAN DENTAL HOSPITAL SITE, GRAY-S INN ROAD, LONDON, WC1X 8LD

Waste Comments

Thank you for consulting Thames Water for the discharge of matters relating to PILING. Thames Water are unable to support the discharge of this condition for the reasons outlined below.

Water Comments

.

Supplementary Comments

The documents submitted indicate that the developer is intending to carry out piling works within exclusion zones of Thames Water assets. The developer is required to contact the Thames Water Developer Services department and state that they have been referred to the Asset Protection team by the Development Planning team to discuss the requirements for an asset protection study (0800 009 3921 or by email at developer.services@thameswater.co.uk, FAO Asset Protection - Major Projects). Their case will be logged and a representative from the Asset Protection team will be in contact with them. The developer should provide cross sectional details with the TW assets marked up on them.

More details on the asset protection impact study process can be found in the guidance document "Working Near Our Assets" (available online at <https://developers.thameswater.co.uk/developing-a-large-site/planning-your-development/working-near-or-diverting-our-pipes>).

Please bear in mind that Thames Water will hold the developer and any relevant contractor/sub-contractor liable for any losses incurred or damage caused to Thames Water assets arising from construction works or subsequent use of the facility.

Plans of Thames Water apparatus can be obtained through our website at www.thameswater-propertysearches.co.uk. Please contact Developer Services if you wish to discuss further (0800 009 3921 or by email at developer.services@thameswater.co.uk with email subject FAO Asset Protection Team). Please use the following reference in all future correspondence: DTS 62024.

Yours faithfully
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ
Tel:020 3577 9998
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk
Visit us online www.thameswater.co.uk , follow us on twitter www.twitter.com/thameswater or find us on www.facebook.com/thameswater. We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.