

**From:** Hindle Emily

**Sent:** 20 May 2021 17:11

**To:** Tony Young

**Subject:** RE: Pavement on west side of Camden Road (2021/1594/P)

Hi Tony,

Thanks for the amended site plan. TfL's Streetscape Guidance recommends a footway clear zone of 2000mm. The amended proposed site plan indicates part of the footway will be less than 2000mm once the equipment is in place. Therefore the comments in my earlier email, dated 17<sup>th</sup> May, remain.

Kind regards,

Emily

**Emily Hindle | Assistant Planner (North)**

**Spatial Planning | City Planning**

Transport for London, 9<sup>th</sup> Floor, 5 Endeavour Square, London E20 1JN