

Protective fencing

To be erected prior to the commencement of all works on site, and retained in place throughout construction.

Default Specification: To comprise a 2.4m wooden site hoarding or a 2.3m high scaffolding framework comprising of vertical and horizontal framework, with bracing to resist impacts, with heights to be spaced at a maximum of 3.0m intervals and driven into the ground by a minimum of 600mm. On this, standard anti-climb welded mesh panels are to be secured fixed to each other with at least two scaffold clamps and to the scaffold framework with wire.

Alternative Specification: To comprise of 2m tall welded mesh panels on rubber or concrete feet. Panels are to be joined together using a minimum of two anti-tamper couplers, installed so that they can only be removed from inside the fence. The panels should be supported on the inner side by stabiliser spikes, which should be attached to a base plate and secured with ground pins.

All weather notices should be erected at regular intervals on the weld mesh panels with words such as "Construction exclusion zone - Keep out".

Trunk Protection

Protective trunk Wrappings

To be attached to the trunks of retained trees prior to the commencement of all works on site, and retained in place throughout construction. To comprise of a minimum of three wrapings of clear dry resin around the trunk from ground level up to 2.3m high and held in place using steel. Once the minimum of three wrappings of chestnut palling and it is to be held in place by 2.50mm mild steel galvanised wire in three locations and fixed into place using fencing staples fixed into the chestnut palling.

Ground boarding

New temporary ground protection should be capable of supporting any traffic entering or leaving the site without disturbing or causing compaction of underlying soil.

Note: The ground protection might comprise one of the following:

- for pedestrian movements only, a single thickness of scaffold boards placed either on top of a driven scaffold frame, or to form a suspended walkway, or on top of a compression-resistant layer (e.g. 100mm depth of woodchip), laid onto a geotextile membrane;
- for pedestrian-operated plant up to a gross weight of 2t, proprietary inter-leaf ground protection boards placed on top of a compression-resistant layer (e.g. 150mm depth of woodchip), laid onto a geotextile membrane;
- for wheeled or tracked construction traffic exceeding 2 t gross weight, an alternative system (e.g. proprietary system or pre-cast reinforced concrete slabs) to an engineering specification designed in consultation with arboricultural advice, to accommodate the likely loading to which it will be subjected.

For situations other than those described in a) to c), the ground boarding is to be designed by a suitably qualified person to an engineering specification in conjunction with arboricultural advice, to be able to support the expected loading to be placed upon it.

In all cases, the objective of the ground boarding is to avoid compaction of the soil beneath, so that tree root function remains unimpacted.

Supervised demolition

Hard surfacing: Removal of and/or replacement of hard surfacing situated either partially or completely within the RPA of retained trees shall be undertaken with care and under the direct on-site arboricultural supervision as these areas are likely to contain roots. Where this is necessary the working course will be broken up using a hand held pneumatic breaker, hand tools and a wheel barrow to break up and remove the surfacing. If it is necessary to remove the sub base this is to be undertaken using hand tools such as a fork to loosen the material and removed using wheelbarrows and wheelbarrows. In some situations and at the discretion of the arborist it may be possible to use an excavator to dig a hydraulic sized bootless grading bucket, if an excavator is to be used it must be situated outside of the RPA, on top of the hard surfacing working away from the RPA or from ground boarding. Which ever system is used there is to be NO disturbance of the soil beneath. If roots are found they are to be covered over with damp hessian and a layer of either sharp sand, wood chip or top soil to prevent desiccation.

Structures: Demolition of existing structures and foundations situated either partially or completely within RPA of retained trees shall be undertaken with care and under the direct on-site arboricultural supervision as these areas are likely to contain roots. Where it is necessary for the foundations to be removed they are to be only be removed where critical to the proposed development and to the minimum depth required. The foundations will be broken up using a hand held pneumatic breaker, hand tools and a wheel barrow to break up and remove the surfacing. In some situations and at the discretion of the arborist it may be possible to use an excavator using a hydraulic breaker and suitably sized bootless grading bucket. If an excavator is to be used it must be situated outside of the RPA, on top of the hard surfacing working away from the RPA or from ground boarding. It is likely that there will be any collapse of the soil within the rooting environment excavations is to be stopped immediately and the trench is to be shored up to prevent loss of the rooting environment. Which ever system is used there is to be NO disturbance of the soil on the side of the foundations. If roots are found they are to be covered over with damp hessian and a layer of either sharp sand, wood chip or top soil to prevent desiccation.

Supervised Excavation

All excavations within and immediately adjacent to RPA are to be undertaken under direct on-site arboricultural supervision.

Any roots that are to be cut will be clearly severed by the project arboriculturalist using a suitable hand saw or secateurs. The edge of all excavation closest to the retained trees will be covered with damp hessian to prevent drying out, and where necessary be shrouded to prevent soil collapse or contamination by concrete. If appropriate soil beneath the depth of the excavation may be sheet piled, regular piled or have individual piles installed.

Manual excavation: Excavations within the RPA will be initially undertaken by hand under direct on-site arboricultural supervision to a minimum of 600mm deep (to be confirmed by the project arboriculturalist), whether this is for proposed foundations, hard surfacing or underground services. The soil is to be loosened with the use of a fork or pick and air-spade and then cleared with a shovel and or the aid of an air-spade and air-vec.

Mechanical excavation: Excavation within the RPA will consist of a mixture of mechanical and manual excavation. Where an excavator is used it will be fitted with a suitably sized bootless grading bucket, using a grading / scraping motion rather than digging. During each rotation the excavator will not be permitted to remove more than 10 - 20mm deep of soil in any one pass. If any roots are discovered, mechanical excavation will immediately be stopped and manual excavation will take over to expose the root. Upon the root being uncovered and either severed or protected the excavators can then continue. Any excavator or other machinery that is to be used will be situated outside of the RPA of all retained trees or on top of a suitable ground protection. Where an excavator or any other machinery is to be used within RPA or beneath copes the project arboriculturalist will clearly instruct the operator about what they want and expect to happen prior to any works may commence.

Utility apparatus

Underground utility apparatus Mechanical trenching for the installation of underground apparatus and storage where any roots present and can change the soil hydrology in a way that adversely affects the health of the tree. For this reason, particular care should be taken in the route and methods of installation of all underground apparatus. Wherever possible, apparatus should be routed outside of RPA. Where this is not possible, it is preferable to keep apparatus together in common ducts, all inspection chambers should be sited outside of the RPA. Where underground apparatus is to pass within the RPA, detailed plans showing the proposed route should be drawn up in conjunction with the project arboriculturalist. In such cases trenchless installation methods should be used with entry and retrieval pits being located outside of the RPA. If this option is not feasible and providing roots can be retained and protected excavations should be undertaken using hand held tools (air-spade, forks, shovels) or a combination of trenchless and manual excavation (broken trench). Any design and installation should be undertaken in accordance with the National Joint Utilities Guidelines (NJUG).

Above-ground utility apparatus Above-ground apparatus (including CCTV cameras and lighting) should be sited to avoid the need for destination tree pruning, as such the current and future crown size of the tree should be assessed. Tree branches can be pruned back with care to provide space, though it is not appropriate for repetitive and significant tree work to be done in the design solution unless this is a suitable management outcome for the tree. Any pruning should be undertaken in accordance with BS3998:2010

Tree Protection Area

KEEP OUT

Do not move this fence

TOWN & COUNTRY PLANNING ACT 1990

TREES ENCLOSED BY THIS FENCE ARE PROTECTED BY PLANNING CONDITIONS AND/OR ARE THE SUBJECT OF A TREE PRESERVATION ORDER.

CONTRAVENTION OF A TREE PRESERVATION ORDER MAY LEAD TO CRIMINAL PROSECUTION.

ANY ENCROACHMENT INTO THE PROTECTED AREA MUST BE WITH THE WRITTEN PERMISSION OF THE LOCAL PLANNING AUTHORITY

ARBTECH

ARBTECH CONSULTING LTD
121 43 Compayne Gardens, Chester, CH4 0DH
01244 661170
www.arbtech.co.uk

Supervised Demolition

Hard surfacing: Removal of and/or replacement of hard surfacing situated either partially or completely within the RPA of retained trees shall be undertaken with care and under the direct on-site arboricultural supervision as these areas are likely to contain roots. Where this is necessary the working course will be broken up using a hand held pneumatic breaker, hand tools and a wheel barrow to break up and remove the surfacing. If it is necessary to remove the sub base this is to be undertaken using hand tools such as a fork to loosen the material and removed using wheelbarrows and wheelbarrows. In some situations and at the discretion of the arborist it may be possible to use an excavator to dig a hydraulic sized bootless grading bucket, if an excavator is to be used it must be situated outside of the RPA, on top of the hard surfacing working away from the RPA or from ground boarding. Which ever system is used there is to be NO disturbance of the soil beneath. If roots are found they are to be covered over with damp hessian and a layer of either sharp sand, wood chip or top soil to prevent desiccation.

Structures: Demolition of existing structures and foundations situated either partially or completely within RPA of retained trees shall be undertaken with care and under the direct on-site arboricultural supervision as these areas are likely to contain roots. Where it is necessary for the foundations to be removed they are to be only be removed where critical to the proposed development and to the minimum depth required. The foundations will be broken up using a hand held pneumatic breaker, hand tools and a wheel barrow to break up and remove the surfacing. In some situations and at the discretion of the arborist it may be possible to use an excavator using a hydraulic breaker and suitably sized bootless grading bucket. If an excavator is to be used it must be situated outside of the RPA, on top of the hard surfacing working away from the RPA or from ground boarding. It is likely that there will be any collapse of the soil within the rooting environment excavations is to be stopped immediately and the trench is to be shored up to prevent loss of the rooting environment. Which ever system is used there is to be NO disturbance of the soil on the side of the foundations. If roots are found they are to be covered over with damp hessian and a layer of either sharp sand, wood chip or top soil to prevent desiccation.

Supervised Excavation

All excavations within and immediately adjacent to RPA are to be undertaken under direct on-site arboricultural supervision.

Any roots that are to be cut will be clearly severed by the project arboriculturalist using a suitable hand saw or secateurs. The edge of all excavation closest to the retained trees will be covered with damp hessian to prevent drying out, and where necessary be shrouded to prevent soil collapse or contamination by concrete. If appropriate soil beneath the depth of the excavation may be sheet piled, regular piled or have individual piles installed.

Manual excavation: Excavations within the RPA will be initially undertaken by hand under direct on-site arboricultural supervision to a minimum of 600mm deep (to be confirmed by the project arboriculturalist), whether this is for proposed foundations, hard surfacing or underground services. The soil is to be loosened with the use of a fork or pick and air-spade and then cleared with a shovel and or the aid of an air-spade and air-vec.

Mechanical excavation: Excavation within the RPA will consist of a mixture of mechanical and manual excavation. Where an excavator is used it will be fitted with a suitably sized bootless grading bucket, using a grading / scraping motion rather than digging. During each rotation the excavator will not be permitted to remove more than 10 - 20mm deep of soil in any one pass. If any roots are discovered, mechanical excavation will immediately be stopped and manual excavation will take over to expose the root. Upon the root being uncovered and either severed or protected the excavators can then continue. Any excavator or other machinery that is to be used will be situated outside of the RPA of all retained trees or on top of a suitable ground protection. Where an excavator or any other machinery is to be used within RPA or beneath copes the project arboriculturalist will clearly instruct the operator about what they want and expect to happen prior to any works may commence.

Utility apparatus

Underground utility apparatus Mechanical trenching for the installation of underground apparatus and storage where any roots present and can change the soil hydrology in a way that adversely affects the health of the tree. For this reason, particular care should be taken in the route and methods of installation of all underground apparatus. Wherever possible, apparatus should be routed outside of RPA. Where this is not possible, it is preferable to keep apparatus together in common ducts, all inspection chambers should be sited outside of the RPA. Where underground apparatus is to pass within the RPA, detailed plans showing the proposed route should be drawn up in conjunction with the project arboriculturalist. In such cases trenchless installation methods should be used with entry and retrieval pits being located outside of the RPA. If this option is not feasible and providing roots can be retained and protected excavations should be undertaken using hand held tools (air-spade, forks, shovels) or a combination of trenchless and manual excavation (broken trench). Any design and installation should be undertaken in accordance with the National Joint Utilities Guidelines (NJUG).

Above-ground utility apparatus Above-ground apparatus (including CCTV cameras and lighting) should be sited to avoid the need for destination tree pruning, as such the current and future crown size of the tree should be assessed. Tree branches can be pruned back with care to provide space, though it is not appropriate for repetitive and significant tree work to be done in the design solution unless this is a suitable management outcome for the tree. Any pruning should be undertaken in accordance with BS3998:2010

Arboricultural Supervision

The arboricultural consultant will be required to attend site to directly supervise all demolition and construction works that have to be undertaken within the root protection areas. This will include:

- Pre-commencement site meeting.
- Location of protective measures.
- Supervised demolition of existing hard surfacing and associated foundations within and adjacent to the RPA of tree numbers 2, 3 and 4.
- Supervised excavations for foundations for the garden room and decking within and adjacent to the RPA of tree numbers 2, 3 and 4.
- Any demolition and/or excavations within or adjacent to RPA, including foundations, hard surfacing or underground services (a non-exhaustive list).
- Arboricultural sign off and removal of protective measures.

Arboricultural Method Statement

Please refer to Arborist Consulting Ltd Tree Schedule and Arboricultural Method Statement, for full details on all surveyed trees and how all aspects of the development may be implemented without detriment to retained trees.

Arboricultural Supervision

The arboricultural consultant will be required to attend site to directly supervise all demolition and construction works that have to be undertaken within the root protection areas. This will include:

- Pre-commencement site meeting.
- Location of protective measures.
- Supervised demolition of existing hard surfacing and associated foundations within and adjacent to the RPA of tree numbers 2, 3 and 4.
- Supervised excavations for foundations for the garden room and decking within and adjacent to the RPA of tree numbers 2, 3 and 4.
- Any demolition and/or excavations within or adjacent to RPA, including foundations, hard surfacing or underground services (a non-exhaustive list).
- Arboricultural sign off and removal of protective measures.

Arboricultural Method Statement

Please refer to Arborist Consulting Ltd Tree Schedule and Arboricultural Method Statement, for full details on all surveyed trees and how all aspects of the development may be implemented without detriment to retained trees.

Arboricultural Supervision

The arboricultural consultant will be required to attend site to directly supervise all demolition and construction works that have to be undertaken within the root protection areas. This will include:

- Pre-commencement site meeting.
- Location of protective measures.
- Supervised demolition of existing hard surfacing and associated foundations within and adjacent to the RPA of tree numbers 2, 3 and 4.
- Supervised excavations for foundations for the garden room and decking within and adjacent to the RPA of tree numbers 2, 3 and 4.
- Any demolition and/or excavations within or adjacent to RPA, including foundations, hard surfacing or underground services (a non-exhaustive list).
- Arboricultural sign off and removal of protective measures.

Arboricultural Method Statement

Please refer to Arborist Consulting Ltd Tree Schedule and Arboricultural Method Statement, for full details on all surveyed trees and how all aspects of the development may be implemented without detriment to retained trees.

0m 1m 3m 5m



Arboricultural Impacts

Impacts	No. of trees
Group 1 (Trees to be removed) (Partial removal of groups)	0 (1)
Group 2 (Trees to be retained)	3
Group 3 (Trees to be retained)	0
Group 4 (Trees to be retained)	2
Group 5 (Trees to be retained)	0
Group 6 (Trees to be retained)	0
Group 7 (Trees to be retained)	0

Tree Work Schedule

No.	Species	Proposed structure	Inclusion
2	Lime	Garden room & decking	RPA
3	Lime	Garden room & decking	RPA
4	Pear	Decking	RPA

No. of individual trees to be removed

U	A	B	C
0	0	1	0

No. of groups / hedges to be removed

U	A	B	C
0	0	0	0

Arboricultural Method Statement

All tree work is to be undertaken in accordance with British Standard BS 3998:2010 Tree work - Recommendations. All arising work is to be undertaken in accordance with British Standard BS 3998:2010 Tree work - Recommendations. All arising work is to be undertaken in accordance with British Standard BS 3998:2010 Tree work - Recommendations. All arising work is to be undertaken in accordance with British Standard BS 3998:2010 Tree work - Recommendations.

ARBTECH

Unit 3, Well House Barns, Chester, CH4 0DH
https://arbtech.co.uk, 01244 661170

Project: Flat 2, 43 Compayne Gardens, London, NW6 3DD.

Client: Out of the Valley

Drawing: Tree Protection Plan

Based on: 121_43 CG Gardens Plans & Elevations

Drawing No: Arbtech TPP 01

Date: May 2021 **Scale:** 1:100 @ A2 **Drawn:** MGM

Key:

Tree No.:	1	Tree	Trunk
RPA:	Category 'B' trees	Category 'B' groups	Category 'C' trees
Category 'C' trees:	Category 'C' trees	Category 'C' groups	Category 'C' groups
Protective fencing:	Trunk protection	Ground boarding	Supervised excavation
Arboricultural Supervision:	Arboricultural Supervision	Arboricultural Supervision	Arboricultural Supervision

ARBTECH

Unit 3, Well House Barns, Chester, CH4 0DH
https://arbtech.co.uk, 01244 661170

Project: Flat 2, 43 Compayne Gardens, London, NW6 3DD.

Client: Out of the Valley

Drawing: Tree Protection Plan

Based on: 121_43 CG Gardens Plans & Elevations

Drawing No: Arbtech TPP 01

Date: May 2021 **Scale:** 1:100 @ A2 **Drawn:** MGM

Key:

Tree No.:	1	Tree	Trunk
RPA:	Category 'B' trees	Category 'B' groups	Category 'C' trees
Category 'C' trees:	Category 'C' trees	Category 'C' groups	Category 'C' groups
Protective fencing:	Trunk protection	Ground boarding	Supervised excavation
Arboricultural Supervision:	Arboricultural Supervision	Arboricultural Supervision	Arboricultural Supervision

ARBTECH

Unit 3, Well House Barns, Chester, CH4 0DH
https://arbtech.co.uk, 01244 661170

Project: Flat 2, 43 Compayne Gardens, London, NW6 3DD.

Client: Out of the Valley

Drawing: Tree Protection Plan

Based on: 121_43 CG Gardens Plans & Elevations

Drawing No: Arbtech TPP 01

Date: May 2021 **Scale:** 1:100 @ A2 **Drawn:** MGM

Key:

Tree No.:	1	Tree	Trunk
RPA:	Category 'B' trees	Category 'B' groups	Category 'C' trees
Category 'C' trees:	Category 'C' trees	Category 'C' groups	Category 'C' groups
Protective fencing:	Trunk protection	Ground boarding	Supervised excavation
Arboricultural Supervision:	Arboricultural Supervision	Arboricultural Supervision	Arboricultural Supervision

ARBTECH

Unit 3, Well House Barns, Chester, CH4 0DH
https://arbtech.co.uk, 01244 661170

Project: Flat 2, 43 Compayne Gardens, London, NW6 3DD.

Client: Out of the Valley

Drawing: Tree Protection Plan

Based on: 121_43 CG Gardens Plans & Elevations

Drawing No: Arbtech TPP 01

Date: May 2021 **Scale:** 1:100 @ A2 **Drawn:** MGM