

Application No:	Consultees Name:	Received:	Comment:	Response:
2021/1608/P	Highgate Conservation Area Advisory Committee	18/06/2021 20:03:55	OBJ	<p>Highgate Conservation Area Advisory Committee objects to this application because so little information is given about the energy/sustainability rating of the proposed extension.</p> <p>The applicants mention underfloor heating but do not mention insulation or other materials. No U-values are provided for the floor, walls, roof, or windows.</p> <p>The applicants should provide proof that the proposed building meets national and local standards for sustainability, climate change and so-on.</p>
