

<b>Application No:</b>	<b>Consultees Name:</b>	<b>Received:</b>	<b>Comment:</b>	<b>Response:</b>
2021/2015/P	Richard Simpson for Primrose Hill CAAC	27/06/2021 12:24:43	OBJ	ADVICE from Primrose Hill Conservation Area Advisory Committee 12A Manley Street, London NW1 8LT 16 June 2021

1 Berkley Road NW1 8XX 2021/2015/P

Objection.

We have no objection to the installation of solar panels to the main roof so long as they do not disrupt the visual line of the front parapet in views from across, but also along the street.

Unfortunately the section provided in the application does not show a convincing section of the roof structure and front parapet, or locate the proposed panels or indicate their installed height in relation to the roof (they appear suspended on a dashed line which is not identified). There is therefore no way to assess the impact of the proposal and whether it would preserve or enhance the character and appearance of the conservation area.

We look forward to seeing an appropriate drawing and reassessing the application.

Richard Simpson FSA  
Chair

---